

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7907110582 DOC. DATE: 78/09/19 NOTARIZED: NO
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.
 AUTH. NAME AUTHOR AFFILIATION
 WILSON, K.R. Duke Power Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 Region 2, Atlanta, Office of the Director

DOCKET #
05000269

SUBJECT: LER 78-018/03L-0 on 780818: quadrant power tilt in excess of error corrected limit of 2.29%. Cause is unknown but still under investigation.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 143
 TITLE: INCIDENT REPORTS

NOTES: M. CUNNINGHAM - ALL AMENDS TO FSAR & CHANGES TO TECH SPECS.

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	05 BC ORB #4	4	4			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	09 IRE	2	2	11 MPA	3	3
	14 TA/EDO	1	1	15 NOVAK/KNIEL	1	1
	16 EFB	1	1	17 AD FOR ENGR	1	1
	19 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	21 AD SYS/PROJ	1	1
	22 REAC SAFT BR	1	1	23 ENGR BR	1	1
	24 KREGER	1	1	25 PWR SYS BR	1	1
	26 AD/SITE ANAL	1	1	27 OPERA LIC BR	1	1
	28 ACCIDENT ANALYS	1	1	29 AUX SYS BR	1	1
	E JORDAN/IE	1	1	HANAUER, S.	1	1
	TMI DOC CENTER	1	1			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACKS	16	16			

Handwritten initials/signature

TOTAL NUMBER OF COPIES REQUIRED: LTR 48 ENCL 48