

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7908140723 DOC. DATE: 79/07/24 NOTARIZED: NO
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.
 AUTH. NAME VITO, D.J. AUTHOR AFFILIATION Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION

DOCKET # 05000269

SUBJECT: R0-269/79-23 on 790703 discovered steam generator tube leak in 1B Steam Generator, Investigation initiated immediately after shutdown.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: INCIDENT REPORTS

NOTES: M. CUNNINGHAM - ALL AMENDS TO FSAR & CHANGES TO TECH SPECS

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL		ID CODE/NAME	LTR
	05 BC ORB #4	4	1			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	14 TA/EDO	1	1	15 NOVAK/KNIEL	1	1
	16 EEB	1	1	17 AD FOR ENGR	1	1
	18 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	21 AD SYS/PROJ	1	1
	22 REAC SAFT BR	1	1	23 ENGR BR	1	1
	24 KREGER	1	1	25 PWR SYS BR	1	1
	26 AD/SITE ANAL	1	1	27 OPERA LIC BR	1	1
	28 ACIDENT ANALYS	1	1	29 AUX SYS BR	1	1
	E JORDAN/IE	1	1	HANAUER, S.	1	1
	I&C SYS BR	1	1	TMI-H STREET	1	1
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACRS	16	16			

CCP

AUG 16 1979

TOTAL NUMBER OF COPIES REQUIRED: LTR 49 ENCL 0

Handwritten: *Handwritten*

USNRC REG
ATLANTA, GA

19 JUL 24 AIR : 58

790270X

TO: Frank Cape
DEPUTY SECRETARY FOR NUCLEAR INSPECTION

FILE: R-786

DUKE POWER COMPANY
OCCUREN NUCLEAR STATION
NRC NOTIFICATION OF REPORTABLE OCCURRENCE

REPORT NUMBER 80-269/79-23

TIME/DATE OF INCIDENT 2330 7/23/79 TIME/DATE OF DISCOVERY 2330 7/23/79

UNIT(S) 1 UNIT STATUS AT TIME OF INCIDENT 2) R.F.P.

DESCRIPTION OF INCIDENT: Shutdown initiated due to discovery of a steam generator tube leak in the 1B' Steam Generator. (Measured - 0.88 gpm from Operating procedure 01/01/73 RCP system leakage, Tech. Spec. Limit - 0.20 gpm for Unit 1 5th Generator) The reactor was shutdown at 0301 on 7/23/79

HOW INCIDENT WAS DISCOVERED: From RCP system leakage calculation (Ops procedure) and from RIA increase

IMMEDIATE CORRECTIVE ACTION: Investigation began immediately after shutdown

REPORTABLE PURSUANT TO TECHNICAL SPECIFICATION to 6.2.1.6 (B)

DATE REPORT DUE TO NRC/OIR 8/6/79

TIME/DATE TELECOPIED OR OTHERWISE TRANSMITTED TO NRC/OIR 1030 7/24/79

PREPARED BY W.C. Hester PHONE (803) 882-2562

Aug 2 10 790376