

DUKE POWER COMPANY

P.O. BOX 33189

CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

July 28, 1986

Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
McGuire Nuclear Station
Docket Nos. 50-369 and 50-370
Catawba Nuclear Station
Docket Nos. 50-413 and 50-414


Subject: IE Bulletin No. 86-02
Static "O" Ring Differential Pressure Switches

Dear Dr. Grace:

As requested by IE Bulletin 86-02, a review has been conducted to determine if SOR Model 102 or 103 differential pressure switches were installed at Oconee, McGuire or Catawba. Results of this review indicate that the subject switches were not used in safety-related applications (as defined by 10 CFR 50.49b) at any of the three nuclear stations. A further review is in progress to determine if any of the subject switches have been installed in systems that are subject to Limiting Conditions for Operation in the Technical Specifications. Appropriate actions will be taken based on the results of the review.

I declare under penalty of perjury that the statements set forth therein are true and correct to the best of knowledge.

Very truly yours,



Hal B. Tucker

ROS/04/slb

B608010117 860728
PDR ADDCK 05000269
Q PDR

IE-11
1/0

Dr. J. Nelson Grace, Regional Administrator
July 28, 1986
Page Two

xc: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. K. Jabbour
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. J. C. Bryant
NRC Resident Inspector
Oconee Nuclear Station

Mr. Darl Hood
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D. C. 20555

Ms. Helen Pastis
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D. C. 20555

Mr. W. T. Orders
NRC Senior Resident Inspector
McGuire Nuclear Station

NRC Resident Inspector
Catawba Nuclear Station