

ENCLOSURE 1

NOTICE OF VIOLATION

Duke Power Company  
Oconee Unit 2

Docket No. 50-270  
License No. DPR-47

During the Nuclear Regulatory Commission (NRC) inspection conducted October 20 - November 20, 1987, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1987), the violation is listed below:

Technical Specification 6.4.1 states that the station shall be operated and maintained in accordance with approved procedures. Station Directive 3.2.1, Work Request Section 6.17, requires that correct component verification be performed and documented on all work requests each time a job is restarted after it is delayed.

Contrary to the above requirement, on October 29, 1987, Station Directive 3.2.1 was not followed in its entirety in that Instrument and Electrical technicians restarted Procedure IP/2/A/305/3B (RPS Channel "B" Calibration and Functional Test) after a two day delay without documenting correct component verification.

This is a Severity Level V Violation (Supplement I). This violation applies to Unit 2 only.

Pursuant to the provisions of 10 CFR 2.201, Duke Power Company is hereby required to submit a written statement or explanation to the Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector, Oconee, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include: (1) admission or denial of the violation, (2) the reason for the violation if admitted, (3) the corrective steps which have been taken and the results achieved, (4) the corrective steps which will be taken to avoid further violations, and (5) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked or why such other action as may be proper should not be taken.

FOR THE NUCLEAR REGULATORY COMMISSION

ORIGINAL SIGNED BY  
VIRGIL L. BROWNLEE

Virgil L. Brownlee, Chief  
Reactor Projects Branch 3  
Division of Reactor Projects

8712070138 871203  
PDR ADOCK 05000269  
Q PDR

Dated at Atlanta, Georgia  
this 3<sup>rd</sup> day of Dec. 1987