

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

June 8, 1988

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555


Subject: Oconee Nuclear Station
IE Inspection Report
50-269, -270, -287/88-09

Gentlemen:

Within the subject inspection report, Duke Power Company was advised of an emergency preparedness exercise weakness as a result of the annual exercise conducted April 14, 1988. To correct the weakness (incorrect classification of an emergency declaration), Duke has:

1. Revised the Emergency Classification procedure to clearly define the Alert and Site Area Emergency emergency action levels regarding Loss of Shutdown functions. In addition, the Emergency Plan (Volume A) has been revised to include the changes to the emergency action levels.
2. Training will be provided to all Operations personnel during annual requal which is scheduled to start on June 9, 1988. Training should be complete by October 1, 1988 for all licensed operators.

Very truly yours,


Hal B. Tucker

PJN/338/bhp

xc: Dr. J. Nelson Grace
Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, GA 30323

Mrs. Helen Pastis
Office of Nuclear Regulation
U.S. Regulatory Commission
Washington, DC 20555

Mr. P.H. Skinner
NRC Resident Inspector
Oconee Nuclear Station

IE35
1/0

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8806210024 DOC. DATE: 88/06/08 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H. B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Discusses actions taken to correct weakness in emergency preparedness noted Insp Repts 50-269/88-09, 50-270/88-09 & 50-287/88-09.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE:
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES: AEOD/Ornstein:1cy. 05000269
 AEOD/Ornstein:1cy. 05000270
 AEOD/Ornstein:1cy. 05000287

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 1	PASTIS, H	2 2
INTERNAL:	ACRS	2 2	AEOD	1 1
	DEDRO	1 1	NRR MORISSEAU, D	1 1
	NRR/DLPQ/FEB 11	1 1	NRR/DLPQ/QAB 10	1 1
	NRR/DOEA DIR 11	1 1	NRR/DREP/EPB 10	1 1
	NRR/DREP/RPB 10	2 2	NRR/DRIS DIR 9A	1 1
	NRR/PMAS/ILRB12	1 1	NUDOCS-ABSTRACT	1 1
	DE LIEBERMAN, J	1 1	OGC 15-B-18	1 1
	<u>REG FILE</u> 02	1 1	RES/DRPS DEPY	1 1
	RGN2 FILE 01	1 1		
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		
NOTES:		1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 26 ENCL 26

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

June 8, 1988

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555


Subject: Oconee Nuclear Station
IE Inspection Report
50-269, -270, -287/88-09

Gentlemen:

Within the subject inspection report, Duke Power Company was advised of an emergency preparedness exercise weakness as a result of the annual exercise conducted April 14, 1988. To correct the weakness (incorrect classification of an emergency declaration), Duke has:

1. Revised the Emergency Classification procedure to clearly define the Alert and Site Area Emergency emergency action levels regarding Loss of Shutdown functions. In addition, the Emergency Plan (Volume A) has been revised to include the changes to the emergency action levels.
2. Training will be provided to all Operations personnel during annual requal which is scheduled to start on June 9, 1988. Training should be complete by October 1, 1988 for all licensed operators.

Very truly yours,



Hal B. Tucker

PJN/338/bhp

xc: Dr. J. Nelson Grace
Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, GA 30323

Mrs. Helen Pastis
Office of Nuclear Regulation
U.S. Regulatory Commission
Washington, DC 20555

Mr. P.H. Skinner
NRC Resident Inspector
Oconee Nuclear Station

8806210024

AP.

IEO
11