

Central File

DUKE POWER COMPANY
POWER BUILDING
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

50-269
270
287

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

February 13, 1980

TELEPHONE: AREA 704
373-4083

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

REPRODUCTION
FEB 15 4:11:06

Re: RII:JPO
50-269
50-270
50-287
IE Bulletin 79-17


Dear Sir:

This visual examination of accessible portion of Oconee Unit 3 has been completed in accordance with the schedule supplied in my letter of November 28, 1979. No indication of leakage through cracks in stagnant borated water systems piping was observed.

Very truly yours,

William O Parker Jr.
William O. Parker, Jr.
by WAH

KRW:scs



AOI
2

8003100031