

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7812180196 DOC. DATE: 78/12/05 NOTARIZED: NO

DOCKET #
05 000270

FACIL: 50-270 OCONEE #2, DUKE POWER CO.

AUTH. NAME: WILSON, K.R.
AUTHOR AFFILIATION: DUKE POWER CO.
RECIP. NAME: _____
RECIPIENT AFFILIATION: _____

SUBJECT: LER#78-012/01T-0 on 781105: valve 2HP-127, RC Loop A1 HPI Stop check valve was in closed position during HPI check valve functional test. Caused by personnel error.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+2
TITLE: INCIDENT REPORTS

NOTES: M CUNNINGHAM - ALL AMENDMENTS TO FSAR & CHANGES TO TECH SPECS.

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	05 BC ORB#4	4	4			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	14 HANAUER	1	1	15 NOVAK/CHECK	1	1
	16 EEB	1	1	17 AD FOR ENGR	1	1
	18 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	21 AD SYS/PROJ	1	1
	22 REAC SAFT BR	1	1	23 ENGR BR	1	1
	24 COLLINS	0	0	24 KREGER	1	1
	25 PWR SYS BR	1	1	26 HOUSTON	0	0
	26 VOLLMER	1	1	E JORDAN/IE	1	1
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	27 ACRS	16	16			

DEC 19 1978

cep

A0/I-4

TOTAL NUMBER OF COPIES REQUIRED: LTR 43 ENCL 43