

JUNE 6 1983

DMB 016

Dockets Nos. 50-269, 50-270
and 50-287

LICENSEE: Duke Power Company (DPC)

FACILITY: Oconee Nuclear Station, Units Nos. 1, 2 and 3

SUBJECT: SUMMARY OF MEETING HELD ON MAY 12, 1983 WITH REPRESENTATIVES
OF DPC AND BABCOCK & WILCOX TO DISCUSS NEUTRON DOSIMETRY
AND UPPERSHELF MATERIAL PROPERTIES

The meeting was held to clarify the additional information requested by NRC letter dated March 22, 1983 in regard to the NRC review of the Oconee neutron dosimetry provided in BAW-1697 and BAW-1699. The attendees list and a copy of the meeting agenda utilized is enclosed.

Discussion

Bob Gill (DPC) announced at the beginning of the meeting his tentative schedule to submit the written responses requested by NRC in the March 22, 1983 letter by May 23, 1983. [Project Manager's Note: This submittal date will probably be delayed one week.] In addressing the four areas of concern to NRC, the presentation made by Whitmarsh and Lowe (B&W) presented the case that the analysis made to date took into sufficient account the plant specific similarities for neutron fluence and that due to their method of measurement the rotation of the capsule does not affect the fluence values obtained. Although B&W say they can support their uncertainty values used in the Oconee fluence analysis, NRC questioned the precision of the individual elements that comprise the overall cumulative uncertainty values. NRC inquired of B&W on the advisability of updating the predictions used in upper shelf life. Updating is being considered by B&W for future work. NRC still questions the predictive value of B&W's model in addressing weld metals.

Original signed by

John F. Suermann, Project Manager
Operating Reactors Branch #4, DL

Enclosures:
As Stated

cc w/enclosures:
See next page

8306200185 830606
PDR ADOCK 05000269
P PDR

OFFICE ▶	ORB #4: DL						
SURNAME ▶	JFSuermann;cf						
DATE ▶	6/3/83						

MEETING SUMMARY DISTRIBUTION

Licensee:

*Copies also sent to those people on service (cc) list for subject plant(s).

Docket File
NRC PDR
L PDR
ORB#4 Rdg
Project Manager-JSuermann
JStolz
BGrimes (Emerg. Preparedness only)

OELD
NSIC
ELJordan, IE
JMTaylor, IE
ACRS (10)

NRC Meeting Participants:

LLois
BElliot
PRandall

MEETING OF MAY 12, 1983
OCONEE NEUTRON DOSIMETRY

NRC

JSuermann

LLois

BElliot

PRandall

DPC

RGill

JPetty

B&W

CWhitmarsh

ALowe, Jr.

CHudson

HBehnke

CChagnon

Agenda

Duke Power/NRC/B&W

10:00 a.m. May 12, 1983 Room P110 Phillips Building
Bethesda, Maryland

Introduction

B.J. Elliot - NRC
R.L. Gill - DPCo

Objective of B&W Presentation

C.J. Hudson - B&W

Review of B&W Fluence Analysis Computational
Procedure

C.L. Whitmarsh - B&W

Identify Sources of Uncertainty

C.L. Whitmarsh

Status of Fluence Analysis at B&W

C.L. Whitmarsh

NRC Concerns for Oconee Fluence

C.L. Whitmarsh/A.L. Lowe

Plant Similarity

Capsule Rotation

Uncertainty Values

Use Limit

Future Action

C.L. Whitmarsh/A.L. Lowe

NRC Procedures

Utility/Vendor Effort

Summary

R.L. Gill - DPCo

DPCO/NRC/B&W MEETING OBJECTIVE

- o REVIEW FLUENCE ANALYSIS COMPLETED FOR OCONEE

- o ANSWER THE QUESTIONS ASKED OF DUKE POWER BY 3/22/83,
LETTER FROM J. F. STOLZ TO H. B. TUCKER,
DOCKET NOS. 50-269, 50-270 AND 50-287.

- o OBTAIN NRC REGULATORY POSITION AND PLANS FOR REACTOR
VESSEL FLUENCE DETERMINATION.

CALCULATIONAL MODEL INPUTS

GEOMETRY

MATERIALS

POWER DISTRIBUTION

TRANSPORT CODE PARAMETER

DOSIMETER ACTIVITY CALCULATION

DOSIMETER ACTIVITY MEASUREMENT

REACTOR VESSEL ARRANGEMENT




Figure 3-1. Reactor Vessel Cross Section Showing Location of Crystal River Unit 3, Capsule CR3-B








Figure 3-2. Surveillance Capsule Arrangement — With Compact Tension Specimens









Holder Tube

Water

Glad

Al Fillor

Specimens

Core

CALCULATIONAL MODEL INPUTS

GEOMETRY

MATERIALS

POWER DISTRIBUTION

TRANSPORT CODE PARAMETER

DOSIMETER ACTIVITY CALCULATION

DOSIMETER ACTIVITY MEASUREMENT

GEOMETRY INPUTS

CAPSULE LOCATION

Radiation ¹¹⁴~~ion~~ ~15%/cm

Azimuthal ~1%/deg (4 cm)

SIMULATION OF NON-CYLINDRICAL BOUNDARIES

Streaming

Attenuation

EFFECT OF TEMPERATURE

Operating condition

DIMENSIONAL TOLERANCES

Nominal dimensions

MATERIALS INPUTS

METAL COMPOSITION

Nominal values

CORE COMPOSITION

Mid-cycle values

COOLANT TEMPERATURE IN BYPASS REGION

Between inlet and core avg. temp.

6%/24°F

INLET COOLANT TEMPERATURE

.2%/°F at capsule

.4%/°F at vessel inner surface

Function of reactor power

POWER DISTRIBUTION INPUTS

SENSITIVITY NEAR CORE EDGE

Linear proportionality

Difficult to calculate

BOC TO EOC

~15% variation

Avg. static value

CYCLE TO CYCLE

~20% in early cycles

Dependent on fuel management

FISSION SPECTRUM

Fresh fuel primarily ^{235}U

Multiburned fuel 50-70% ^{239}Pu

TRANSPORT CODE PARAMETERS

P_3 Cross Sections

S_8 Quadrature

Mesh Spacing

Smaller is more accurate

Smaller is more costly

Microscopic Cross Sections

Fundamental point data

Broad group averaging

Energy groups

Macroscopic Cross Sections

Material density

DOSIMETER ACTIVITY CALCULATION

$$A = K \int \sigma(E) \phi(E) \int F (1 - e^{-\lambda t_1}) e^{-\lambda t_2}$$

NON SATURATION

Reactor power vs. time

Isotope half life

AXIAL FLUX SHAPE

RPD in nearby fuel assembly

SHORT LIVED ISOTOPES

Insensitive to flux early in irradiation

ENERGY RESPONSE

Only fission dosimeters responsive in
 $2.5 \times E > 1.0 \text{ MeV}$

>60% of fast flux in capsule in
 $2.5 \times E > 1.0 \text{ MeV}$

DOSIMETER REACTION CROSS SECTIONS

ENDF/BV Data

Broad group averaging

FISSION YIELDS

ENDF/BV Data

DOSIMETER ACTIVITY MEASUREMENT

COUNTING

Statistics

Efficiency

IMPURITY REACTIONS

Competing absorption

γ , f in fission dosimeters

MATERIAL COMPOSITION

Weight % of target isotope

SOURCES OF UNCERTAINTY TO VESSEL FLUENCE
EFFECT OF CAPSULE NORMALIZATION

ELIMINATED OR REDUCED SIGNIFICANTLY

Core boundary simulation
Temperature effect on dimensions
Coolant temperature in bypass region
Core and SS304 compositions
Power
Axial flux distribution

UNAFFECTED OR PARTIALLY REDUCED

Capsule location
Inlet coolant temperature
Power distribution
Fission spectrum
Microscopic cross sections (PCA) (P)
Macroscopic cross sections (PCA) (P)
Dimensional tolerances
Mesh spacing (PCA) (P)
Order of scattering (PCA) (P)
Quadrature (PCA) (P)

ADDED EFFECTS

Activity measurement (P)
Activity to fluence conversion (PCA) (P)
Flux perturbation (P)





TABLE 3.4

REEVALUATED EXPOSURE VALUES AND THEIR UNCERTAINTY FOR
LWR PRESSURE VESSEL SURVEILLANCE CAPSULES
(Revision of Reference 40 data)

Plant	Unit	Capsule	Fluency (at > 1 MeV) (n/cm ²)			New/Old	exp (s (1σ))	exp/old New	exp/s	Exposure ^a Time (s)
			Old	New (s (1σ))	New/Old					
Westinghouse										
Com. Tank		A	2.08 • 18	3.17 • 18 (12)	1.52	4.89-03 (12)	1.54-21	9.18-11	5.233 • 07	
Com. Tank		F	4.04 • 18	6.17 • 18 (24)	1.53	9.70-03 (27)	1.57-21	1.27-10	7.851 • 07	
Com. Tank		H	1.79 • 19	2.06 • 19 (25)	1.15	3.38-02 (28)	1.64-21	1.42-10	2.390 • 08	
Com. Tank		A	1.29 • 19	2.93 • 19 (22)	2.24	5.04-02 (27)	1.72-21	8.84-10	5.824 • 07	
Com. Tank		B	2.36 • 19	5.64 • 19 (26)	2.40	9.51-02 (29)	1.64-21	1.07-09	8.881 • 07	
Com. Tank		F	5.34 • 19	5.81 • 19 (14)	1.13	9.78-02 (29)	1.69-21	4.02-10	2.438 • 08	
Com. Tank	3	S	1.41 • 19	1.65 • 19 (25)	1.18	2.84-02 (27)	1.60-21	2.42-10	1.888 • 07	
Com. Tank	4	T	5.62 • 16	7.63 • 18 (19)	1.24	1.84-02 (12)	1.55-21	4.74-10	2.391 • 07	
Com. Tank	4	T	6.81 • 16	7.86 • 18 (13)	1.07	2.22-02 (13)	1.74-21	2.51-10	1.922 • 07	
Com. Tank	4	T	6.81 • 16	7.86 • 18 (13)	1.07	2.22-02 (13)	1.74-21	2.51-10	1.922 • 07	
Com. Tank	2	S	3.81 • 16	3.99 • 18 (24)	1.02	6.39-02 (27)	1.75-21	1.86-10	4.279 • 07	
Com. Tank	2	V	4.51 • 16	7.43 • 18 (22)	1.65	1.19-02 (25)	1.60-21	1.14-10	1.066 • 07	
Com. Tank	1	T	2.36 • 18	2.02 • 18 (9)	1.15	4.56-02 (12)	1.64-21	1.35-10	3.378 • 07	
Com. Tank	2	Z	3.07 • 18	3.05 • 18 (11)	1.01	4.81-02 (13)	1.54-21	1.30-10	3.667 • 07	
Com. Tank	1	V	2.99 • 18	2.74 • 18 (9)	1.10	4.17-02 (11)	1.52-21	1.17-10	3.570 • 07	
Com. Tank	1	V	5.21 • 18	6.09 • 18 (11)	1.17	1.09-02 (16)	1.72-21	2.04-10	4.244 • 07	
Com. Tank	2	V	5.00 • 18	6.00 • 18 (19)	1.20	1.19-02 (13)	1.75-21	2.71-10	4.398 • 07	
Com. Tank	1	H	7.80 • 18	1.17 • 19 (10)	1.34	2.18-02 (14)	1.86-21	2.62-10	8.328 • 07	
Com. Tank	1	V	4.80 • 18	5.30 • 18 (14)	1.22	1.03-02 (22)	1.71-21	2.22-10	4.612 • 07	
Com. Tank	1	V	5.59 • 18	6.44 • 18 (10)	1.14	1.16-02 (13)	1.80-21	2.86-10	4.067 • 07	
Com. Tank	1	S	—	8.51 • 18 (10)	—	1.46-02 (13)	1.74-21	1.27-10	1.163 • 08	
Com. Tank	1	R	2.22 • 19	2.17 • 19 (10)	0.98	4.41-02 (14)	2.03-21	2.70-10	1.627 • 08	
Com. Tank	2	T	9.65 • 18	9.47 • 18 (10)	1.00	1.59-02 (13)	1.64-21	1.44-10	1.087 • 08	
Com. Tank	2	V	4.74 • 18	7.33 • 18 (11)	1.54	1.23-02 (13)	1.54-21	2.56-10	4.805 • 07	
Com. Tank	2	R	2.81 • 19	2.54 • 19 (10)	1.04	4.51-02 (14)	1.84-21	2.85-10	1.840 • 08	
Com. Tank	1	T	1.00 • 18	2.78 • 18 (22)	1.54	4.41-02 (26)	1.64-21	1.16-10	3.991 • 07	
Com. Tank	2	T	2.00 • 18	3.34 • 18 (22)	1.65	5.45-02 (27)	1.64-21	1.23-10	4.473 • 07	
Com. Tank	3	T	2.50 • 18	3.30 • 18 (22)	1.12	5.34-02 (26)	1.63-21	1.28-10	4.211 • 07	
Com. Tank	1	T	1.00 • 18	3.00 • 18 (10)	1.70	4.97-02 (12)	1.62-21	1.31-10	3.789 • 07	
Com. Tank	2	W	8.82 • 18	1.82 • 19 (10)	1.14	1.68-02 (13)	1.65-21	1.49-10	1.123 • 08	
Com. Tank	1	W	2.80 • 18	2.82 • 18 (9)	1.41	4.34-02 (12)	1.61-21	1.13-10	4.037 • 07	
Com. Tank	1	T	2.50 • 18	2.91 • 18 (22)	1.14	4.77-02 (26)	1.64-21	1.39-10	3.426 • 07	
General Atomics										
Com. Tank		A	4.40 • 19	6.10 • 19 (23)	1.39	9.77-02 (28)	1.60-21	1.37-09	7.130 • 07	
Com. Tank		B	5.10 • 18	6.22 • 18 (15)	1.22	9.20-02 (18)	1.48-21	1.12-10	6.191 • 07	
Com. Tank	1	A	6.34 • 19	1.79 • 19 (19)	1.38	2.43-02 (23)	1.64-21	1.05-09	2.777 • 07	
Com. Tank	2	B	6.34 • 19	7.25 • 19 (13)	0.99	1.25-02 (18)	1.59-21	8.61-10	1.444 • 08	
Com. Tank		C	6.80 • 18	6.12 • 18 (13)	0.90	9.21-02 (15)	1.50-21	6.37-11	1.444 • 08	
Westinghouse										
Com. Tank	1	F	8.70 • 17	7.10 • 17 (21)	0.82	9.83-02 (20)	1.38-21	3.74-11	2.629 • 07	
Com. Tank	1	E	1.50 • 18	1.50 • 18 (10)	1.00	2.11-02 (10)	1.41-21	4.07-11	5.186 • 07	
Com. Tank	2	C	9.43 • 17	1.82 • 18 (10)	1.08	1.60-02 (11)	1.47-21	3.95-11	2.844 • 07	
Com. Tank	3	A	7.39 • 17	8.10 • 17 (10)	1.10	1.19-02 (11)	1.42-21	3.86-11	2.983 • 07	
Com. Tank	1	C	1.07 • 18	1.09 • 18 (9)	1.01	1.53-02 (9)	1.40-21	3.80-11	4.026 • 07	

*** 1.25

^aLowest constant under level exposure time.
= 3.17 • 10¹⁴ reads 3.17 • 10¹⁴ with a 12% (1σ) uncertainty.



PROGRAM TO IMPROVE FLUENCE
ANALYSIS - B&W OWNERS GROUP

TO DATE

SSC-1 Test

PCA Blind Test

ASTM E10.05

IN PROGRESS

Capsule Perturbation Test

DPA

PLANNED

PSF Blind Test

ENDF/BIV or BV Transport Cross Sections


Cavity Dosimetry

In-Reactor Benchmark Test


REACTOR PROPERTIES
PERTINENT TO VESSEL FLUENCE

1. CORE SHAPE
2. FUEL
3. INTERNALS CONFIGURATION
4. MATERIALS OF CONSTRUCTION
5. COOLANT DENSITY
6. POWER
7. POWER DISTRIBUTION

Core



Fast flux, $n/cm^2 \text{ sec } E > 1 \text{ MeV}$



ESTIMATED UNCERTAINTY
IN FLUENCE VALUES

1. MATERIAL SPECIMENS IN CAPSULES, $\pm 14\%$
 - SSC1 measurement comparison
 - HEDL reevaluation of capsule data

2. VESSEL DURING CAPSULE EXPOSURE, $\pm 20\%$
 - CAPSULE measurement
 - CAPSULE location
 - Radial extrapolation from capsule to vessel
 - Azimuthal extrapolation to maximum location.

3. VESSEL AT EOL (MAX. LOCATION), $\pm 22\%$
 - Vessel fluence from capsule measurement
 - Time extrapolation to EOL

4. WELDS OUTSIDE BELTLINE REGIONS, $\pm 33\%$
 - Maximum vessel location at EOL
 - Spatial extrapolation in azimuthal and axial directions.

Oconee Plants Controlling Weld Metals

Sources of Irradiated Data

<u>Plant</u>	<u>Weld I.D.</u>	<u>Res. Prog.</u>		<u>RVSP</u>		<u>Sim.W.W.</u>	
		<u>Cv</u>	<u>CF</u>	<u>Cv</u>	<u>CF</u>	<u>Cv</u>	<u>CF</u>
OC-1	SA1229(c) SA1430(l)					X	X
OC-2	WF25(c) WF154(c)	X	X	X	X	X	X
OC-3	WF67	X	X				

Projected Oconee Plant Fluences

<u>Plant</u>	<u>Weld I.D.</u>	<u>EOL Fluence</u>		<u>T/4 Fluence[®] to 50 ft-lbs</u>
		<u>I.S.</u>	<u>T/4</u>	
OC-1	SA1229	9.4E18	5.2E18	8.9E18
	SA1585	1.2E19	6.8E18	4.9E19
	SA1493	9.0E18	5.0E18	1.5E19
	SA1430	1.1E19	6.1E18	9.7E18
OC-2	WF154	9.1E18	5.1E18	7.4E18
	WF25	1.2E19	6.7E18	1.1E19
OC-3	WF67	1.6E19	8.7E18	>2.0E19

[®] - Per BAW-1511P

Irradiation Data Oconee Plant Weld Metals

		<i>Fluence</i>	<i>USM¹ FT-165</i>	<i>R.G.¹</i>	
<u>RVSP</u> —	WF25	1.1E18	81/24	30%	(30%)
	WF154	9.0E18	88/39	44%	(42%)
		2.4E19	88/46	52%	(48%)
		7.2E18	72/20	28%	(41%)
		2.4E19	72/23	32%	(48%)
<u>Res.Data</u> —	WF25	3.9E18	78/10	13%	(37%)
		8.5E18	78/20	26%	(42%)
	WF67	3.6E18	74/7	9%	(32%)
		7.6E18	74/20	27%	(37%)
	SA1585	4.2E18	80/3	4%	(29%)
		9.5E18	80/17	21%	(35%)

Predicted Oconee Plant Δ Use

(Per BAW-1511P)

<u>Plant</u>	<u>Weld I.D.</u>	<u>Fluence</u>	<u>Calendar Years</u>
OC-1	SA1229(c)	> 5E18	> 16
	SA1585(c)	> 5E18	> 16
	SA1493(I)	> 5E18	> 16
	SA1430(I)	> 5E18	> 16
OC-2	WF154(c)	> 5E18	> 16
	WF25(c)	> 5E18	> 16
OC-3	WF67(c)	> 5E18	> 16

Surveillance Capsule Data

Observed Δ Use Vs Predicted Δ Use

<u>Weld I.D.</u>	<u>Fluence</u>	<u>% Δ Use Drop</u>	
		<u>Predicted*</u>	<u>Observed</u>
WF193	4.0E18	22	25
WF193	6.6E18	23	25
WF209-1A	1.0E18	13	21
WF209-1A	3.4E18	17	28
WF209-1B	8.2E17	12	12
WF209-1B	3.1E18	17	26
WF182	2.3E18	22	14

*Per BAW-1511P

RESOLUTION OF ABC CONCERNS
FOR OCII-A AND OCIII-B CAPSULES

PLANT SIMILARITY

- Equivalent specimen damage per unit fluence.
- Vessel fluence is accounted for in calculation.

CAPSULE ROTATION

- No effect on specimen average fluence.
- No effect on dosimetry average activity.

FLUENCE UNCERTAINTY

Estimated values are applicable.

USE LIMIT

Predictions in BAW 1511P of > 16 years (>13 EFPY) are still valid.

Based on current fluence analysis, USE is > 50 ft.-lbs. through 32 EFPY.

NRC PLANS WITH REGARD TO

FLUENCE UNCERTAINTY

What effect will quantification of fluence uncertainty have on vessel service life?

Will reported uncertainty values be treated individually or collectively?

CAVITY DOSIMETRY

Is there any NRC interest in the use of dosimeters in the cavity of B&W reactors?

SPECTRAL EFFECTS

Will DPA be used to evaluate vessel service life?