

Dockets Nos. 50-269, 50-270
and 50-287

LICENSEE: Duke Power Company

FACILITY: Oconee Nuclear Station, Units 1, 2 and 3

SUBJECT: SUMMARY OF MEETING WITH DUKE POWER COMPANY ON COST/BENEFIT
EVALUATION OF THE REACTOR VESSEL COOLANT INVENTORY TRACKING
SYSTEM FOR THE OCONEE NUCLEAR STATION, UNITS 1, 2 AND 3

Duke Power Company (the licensee) requested to meet with the staff to present a new risk analysis relating to the cost/benefit evaluation of reactor vessel coolant inventory tracking system for the Oconee Nuclear Station. The staff met with the licensee on November 7, 1984 and the list of participants is included as Enclosure 1. Enclosure 2 lists the agenda which the licensee followed to make his presentation and Enclosure 3 is a copy of the viewgraphs presented during the meeting. On January 17, 1985, the NRC staff wrote the licensee a letter stating that "the generic requirement for reactor coolant inventory monitoring system was established after an extensive NRC review which included interaction with the industry during the decision process. Implementation of this requirement has been substantially completed on a majority of pressurized water reactors. A request for plant - specific deviation from this generic requirement must be supported by a comprehensive safety analysis and a probalistic risk assessment..."

Helen Nicolaras, Project Manager
Operating Reactors Branch #4
Division of Licensing

Enclosures:
As Stated

cc w/enclosures:
See next page

ORB#4:DL
HNicolaras;cr
7/2/85

8510040565 850724
PDR ADOCK 05000269
PDR

MEETING SUMMARY DISTRIBUTION

Licensee: Duke Power Company

*Copies also sent to those people on service (cc) list for subject plant(s).

Docket File
NRC PDR
L PDR
ORB#4 Rdg
Project Manager -HNicolaras
JStolz
BGrimes (Emerg. Preparedness only)
OELD
EJordan, IE
ACRS-10
PMorriette
NRC Meeting Participants:
HNicolaras
BBernero
LRubenstein
RJones
HLi
GLainas
JStolz
THuang
LPhillips
ATHadani
EChelliah
JShea



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

Dockets Nos. 50-269, 50-270
and 50-287

LICENSEE: Duke Power Company
FACILITY: Oconee Nuclear Station, Units 1, 2 and 3
SUBJECT: SUMMARY OF MEETING WITH DUKE POWER COMPANY ON COST/BENEFIT
EVALUATION OF THE REACTOR VESSEL COOLANT INVENTORY TRACKING
SYSTEM FOR THE OCONEE NUCLEAR STATION, UNITS 1, 2 AND 3

Duke Power Company (the licensee) requested to meet with the staff to present a new risk analysis relating to the cost/benefit evaluation of reactor vessel coolant inventory tracking system for the Oconee Nuclear Station. The staff met with the licensee on November 7, 1984 and the list of participants is included as Enclosure 1. Enclosure 2 lists the agenda which the licensee followed to make his presentation and Enclosure 3 is a copy of the viewgraphs presented during the meeting. On January 17, 1985, the NRC staff wrote the licensee a letter stating that "the generic requirement for reactor coolant inventory monitoring system was established after an extensive NRC review which included interaction with the industry during the decision process. Implementation of this requirement has been substantially completed on a majority of pressurized water reactors. A request for plant - specific deviation from this generic requirement must be supported by a comprehensive safety analysis and a probabilistic risk assessment..."

Helen Nicolaras
Helen Nicolaras, Project Manager
Operating Reactors Branch #4
Division of Licensing

Enclosures:
As Stated

cc w/enclosures:
See next page

MEETING WITH DUKE POWER COMPANY ON
REACTOR VESSEL INVENTORY TRACKING SYSTEM

NOVEMBER 7, 1984

<u>NAME</u>	<u>TITLE</u>	<u>AFFILIATION</u>
Helen Nicolaras	Project Manager	NRC/NRR/DL
Bud Gerling	Jr. Engr.	PRA/DUKE
Bob Bernero	Dir. DSI, NRR	NRC/NRR/DSI
L. S. Rubenstein	AD, Core/Plant Supt.	NRC/NRR/CPS
K. S. Canady	Manager, Nuclear Engr.	Duke Power Co.
Paul Guill	Assoc. Eng./Lic.	Duke Power Co.
G. B. Swindlehurst	Nuclear Engineer	Duke
R. C. Jones	Nuclear Engineer	NRC/NRR/DSI/RSB
R. K. Frahm	Section Leader	RRAB/DST/NRC
Hulbert C. Li	Reactor Engineer	NRC/DSI/ICSB
Jan Kozyra	Licensing Engineer	CP&L
Gus Lainas	AD/Operating Reactor	NRC/NRR/DL
John F. Stolz	B/C ORB#4/DL	NRC/NRR/DL
Tai Huang	Nuclear Engineer	NRC/NRR/DSI/CPB
Larry Phillips	Section Leader	NRC/NRR/DSI/CPB
Larry Reed	Sup. Pra	Duke Power
Ashok Thadani	Branch Chief	NRC/DST/RRAB
Erulappa Chelliah	Nuc. Sy. Eng.	NRC/DST/RRAB
Jim Shea	Project Manager	NRC/DL/ORB5

AGENDA

INTRODUCTION
PROGRESS REPORT ON CONFORMANCE TO THE ORDER
ON YCC INSTRUMENTATION IMPLEMENTATION
OBJECTIVE & APPROACH OF ANALYSIS

OVERVIEW OF ICC INSTRUMENTATION SYSTEM

CORE DAMAGE SEQUENCE EVALUATION

QUANTIFICATION OF SEQUENCES

ASSESSMENT OF AVERTED DOSE

RESULTS & CONCLUSIONS

PRESENTATION

PRA EVALUATION OF REACTOR COOLANT INVENTORY MONITORING SYSTEM

OCONEE NUCLEAR STATION

NOVEMBER 7, 1984

WASHINGTON, DC

AGENDA

INTRODUCTION	K. S. CANADY
OBJECTIVE & APPROACH OF ANALYSIS	L. A. REED
OVERVIEW OF ICC INSTRUMENTATION SYSTEM	L. A. REED
CORE DAMAGE SEQUENCE EVALUATION	R. J. GERLING
QUANTIFICATION OF SEQUENCES	L. A. REED
ASSESSMENT OF AVERTED DOSE	L. A. REED
RESULTS & CONCLUSIONS	L. A. REED

DEFINITION

ICC

- o SUBCOOLED
- o CORE EXIT TEMP
- o RC INVENTORY TRACKING

+ RC PUMP CURRENT

+ LEVEL

RCIMS

- LOOPS (A&B)
- VESSEL

OBJECTIVE

TO DETERMINE THE SAFETY BENEFIT,
USING PRA TECHNIQUES, OF
IMPLEMENTING RCIMS

APPROACH

- o UTILIZED OCONEE PRA STUDY
 - TO IDENTIFY ACCIDENT SEQUENCES WHERE THE RCIMS COULD CHANGE THE COURSE OF A CORE DAMAGE SEQUENCE
 - TO QUANTIFY POSSIBLE CHANGES IN THE FREQUENCIES OF AFFECTED SEQUENCES BECAUSE OF RCIMS
 - TO DETERMINE THE AVERTED DOSE TO THE PUBLIC BECAUSE OF RCIMS

- o APPLIED THE PROPOSED NRC COST/BENEFIT GUIDELINE TO ESTIMATE THE \$ BENEFIT DERIVED FROM RCIMS

OCONEE PRA

- o A PRA STUDY JOINTLY SPONSORED BY DUKE AND NSAC.
- o THE STUDY WAS COMPLETED IN 1983 AND PUBLISHED IN JUNE, 1984.
- o IN THE TERMINOLOGY OF NUREG/CR-2300, THE OCONEE PRA IS A LEVEL 3 WITH ANALYSES OF EXTERNAL EVENTS.

ICC INSTRUMENTATION

1. CONTROL BOARDS: PARAMETER BASED
2. SPDS: FUNCTION BASED
3. ICC: PARAMETER BASED

CONTROL BOARD
INSTRUMENTATION

- o INDICATION
 - SUBCOOLED MARGIN (RC LOOPS & CORE EXIT)
 - CORE EXIT THERMOCOUPLES
 - PRESSURIZER LEVEL/RC PRESSURE

ICC INST (CONT)

SPDS

- o FUNCTIONS
 - SUBCRITICALITY
 - ICC
 - HEAT SINK
 - RCS INTEGRITY
 - CONTAINMENT INTEGRITY
 - RCS INVENTORY

- o COLOR GRAPHIC DISPLAYS VIA PLANT COMPUTER

- o DISPLAY IS GENERATED FROM ON-LINE DATA THAT HAS BEEN PROCESSED VIA A LOGIC NETWORK


ICC INST (CONT)

ICC

- o INDICATION
 - SUBCOOLED MARGIN
 - CORE EXIT THERMOCOUPLES
 - INVENTORY TRACKING
 - RCIMS
 - RCP CURRENT
- o DEDICATED PLASMA DISPLAY (1 FOR EACH OF TWO TRAINS)
- o DIRECT INPUT TO READOUTS FROM SENSORS VIA MICRO PROCESSOR

CONTROL BOARD

SMM	CETS	L/P
-----	------	-----




SPDS

SUBCRITICAL
ICC
RC INTEGRITY
HEAT SINK
RC INVENTORY
CONTAINMENT INTEGRITY


ICC

SMM
CETS
RCIMS
RPM


CONTROL ROOM LAYOUT



1UB2



1UB1






PRZ RELIEF VALVE STATUS



ICC DISPLAYS



PRZ LEVEL RC PRESS




ICC KEYPADS



ICC INSTRUMENTATION

14



4

3

SEQUENCE SELECTION

- o EXAMINED THE MINIMAL CUT SETS THAT COMPRISE THE CORE-MELT SEQUENCES.
- o THESE MINIMAL CUT SETS ARE DUE TO VARIETY OF INITIATING EVENTS, COMPONENT FAILURES, HUMAN ERRORS.
- o CATEGORIZED MINIMAL CUT SETS INTO GROUPS ON THE BASIS POTENTIAL EFFECT BY RCIMS.

INITIATING - EVENT DESCRIPTION
(INTERNAL)

A	LARGE LOCA
+ R	SG TUBE RUPTURE
RPV RUPTURE	REACTOR-VESSEL RUPTURE
+ S	SMALL LOCA
+ T (ALL)	SUMMATION OF ALL TRANSIENT FREQUENCIES
T (NO LOFW)	SUMMATION OF TRANSIENT FREQUENCIES NOT INVOLVING LOSS OF FEEDWATER AS AN INITIATOR.
+ T2	LOSS OF MFW
T3	PARTIAL LOSS OF MFW (ASSUMED TO BE LOSS OF 1 TRAIN)
+ T4	LOSS OF CONDENSER VACUUM
+ T5FEEDF	FAILURE OF OFFSITE POWER DUE TO GRID OR FEEDER FAILURE
T5SUBF	FAILURE OF OFFSITE POWER DUE TO 230-KV SUBSTATION FAILURE (BOTH BUSES)
+ T6	LOSS OF IA
+ T8	SPURIOUS ES ACTUATION SIGNAL
T9	STEAMLINE BREAK
+T10	LARGE FEEDLINE BREAK
+T11	LOSS OF ICS POWER FROM BUS KI
T12	LOSS OF LPSW
T12	LOSS OF LPSW BY THE TRANSFER OF LPSW-108
T12	LOSS OF LPSW BY FAILURES OTHER THAN LPSW-108
+T13	SPURIOUS LOW PRESSURIZER PRESSURE SIGNAL
T14	LOSS OF 4-KV SWITCHGEAR 3TC
+ATWS	

NOTE:

+ APPEARS IN THE SEQUENCES SELECTED FOR QUANTIFICATION

INITIATING EVENTS (CONT)
(EXTERNAL)

EARTHQUAKES

EXTERNAL FLOODS

TORNADOES

+ FIRES

+ INTERNAL FLOODS

NOTE:

+ APPEARS IN THE SEQUENCES SELECTED FOR QUANTIFICATION

SEQUENCE SELECTION (CONT)

- GROUP 1 INITIATING EVENTS OR SYSTEM FAILURES ARE SUCH THAT RCIMS WILL HAVE NO EFFECT
EXAMPLE: RV RUPTURE, EXTERNAL FLOODING, LARGE LOCA WITH FAILURE OF SUMP RECIRCULATION
- GROUP 2 COMPRISED OF THOSE SEQUENCES WHERE RCIMS IS EXPECTED TO PROVIDE AN ADDITIONAL OPPORTUNITY FOR POSSIBLE RECOVERY
EXAMPLE: SEQUENCES WHERE OPERATORS FAILED TO INITIATE-HPI
- GROUP 3 COMPRISED OF THOSE SEQUENCES WHERE THE IMPACT OF RCIMS IS UNCLEAR AND REQUIRED ADDITIONAL INVESTIGATION
EXAMPLE: NATURAL CIRCULATION COOLDOWN, OVER THROTTLING OF HPI --- SMALL BREAK EVENTS, OVER THROTTLING OF LPI --- LARGE BREAK LOCA EVENTS, OVERCOOLING EVENTS.

SEQUENCES SELECTION (CONT)

- o THE SEQUENCES THAT WERE RETAINED WERE THOSE WHERE THE OPERATOR COULD AFFECT THE OUTCOME
 - THROTTLE HPI
 - INITIATE HPI


SEQUENCE SELECTION (CONT)

o NUMBER OF CUTSETS CONSIDERED
IN THE HUNDREDS

o NUMBER OF CUTSETS RETAINED

62

SBLOCA EVENT TREE




- S = SB LOCA INITIATOR
- K = REACTOR TRIP
- U = INITIATION OF HPI
- OT = THROTTLE OF HPI
- X = LONG TERM COOLING

EXAMPLE CUTSET

S* HPTH * RECOVERY

TRANSIENT EVENT TREE



- T = TRANSIENT INITIATOR
- K = REACTOR TRIP
- E = EMERGENCY FW
- U = INITIATION OF HPI
- X = LONG TERM COOLING

EXAMPLE CUTSET

T_2 * EFW * UTHPIH * RECOVERY

SEQUENCE SELECTION

RESULTING CUTSETS

CATEGORY 1 SMALL BREAK LOCA, HPI AVAILABLE, HPI OVERTHROTTLED

21 CUTSETS

CATEGORY 2 SEQUENCES WHERE LOSS OF ALL FEEDWATER OCCURRED,
FAILS TO INITIATE HPI.

41 CUTSETS

SEQUENCE QUANTIFICATION

- o OPERATOR/SEQUENCE INTERFACE
 - INSTRUMENTATION/CONTROLS
 - PROCEDURES
 - OPERATING SHIFT STRUCTURE
 - TRAINING & EXPERIENCE

- o ASSIGN PROBABILITIES
 - OVERTHROTTLED (OT)
 - FAIL TO RECOVER FROM AN OT CONDITION (x3W/LM)
 - FAIL TO INITIATE HPI SYSTEM (x3W/LM)

QUANTIFICATION (CONT)

o A TASK OF DETERMINING HUMAN RELIABILITY


SMM

CET

LM

L/P


- ESSENTIALLY DETERMINING THE WORTH OF AN ADDITIONAL READOUT
- DIANOSIS NOT IMPORTANT
- USED THE HR HANDBOOK I.E. TASK ORIENTED



SRO >

STA >

OPS/TECH
SUPPORT
CTRS



HPI FAILED

- o OT OR
- o NOT INITIATED

QUANTIFICATION (CONT)

CATEGORY I (THROTTLE)

[]*[OTI]*[R/WO]=

[]*[OTI]*[R/W]=

CATEGORY II (INITIATE)

[]*[R/WO]=

[]*[R/W]=

CONSEQUENCES ANALYSIS


DEFINITIONS

- o CORE DAMAGE CORE MELT
 - SUSTAINED CORE UNCOVERY

- o CORE MELT BINS (CM)
 - A CATEGORIZATION OF SIMILAR CONTAINMENT EFFECTS INTO GROUPINGS CALLED BINS. ACCIDENT SEQUENCES ARE REVIEWED AND PLACED IN THE APPROPRIATE BIN
 - FOR EXAMPLE: ALL SEQUENCES THAT RESULT IN A CORE MELT IN < 2 HOURS AND RC PRESS OF < 400 PSIG ARE GROUPED INTO BIN 1

- o PLANT DAMAGE STATES (PDS)
 - A CATEGORIZATION OF PLANT DAMAGE CONDITIONS INTO "STATES" THAT HAVE VERY SIMILAR CHARACTERISTICS IN TERMS OF A PARTICULAR RELEASE CATEGORY
 - FOR EXAMPLE: ALL CM BIN 1 SEQUENCES W/O REACTOR BLD. SPRAY BUT REACTOR BLD. COOLING UNIT IS AVAILABLE ARE GROUPED INTO THE PDS 1B


THE NEED FOR CATEGORIZING



CONSEQUENCE ANALYSES

- o PARTITION ΔF_s INTO CORE DAMAGE BINS THEN INTO PLANT DAMAGE BINS
- o CALCULATE THE (F) REDUCTION IN EACH OF THE SIX RELEASE CATEGORIES (RC)
- o DETERMINE MREM AVERTED FOR EACH RC
- o TOTALED MREM AVERTED FROM ALL RC'S

CONSEQUENCE (CONT)



RESULTS

- o REDUCTION IN CORE DAMAGE FREQUENCY ATTRIBUTABLE TO RCIMS IS 1.4 % OR 3.7×10^{-6} /YR

- o AVERTED POPULATION ROSE ATTRIBUTABLE TO RCIMS IS 0.11% OR 0.14 MREM/YR


CONCLUSIONS

- o NO SIGNIFICANT REDUCTION IN OVERALL CORE DAMAGE FREQUENCY CAN BE ATTRIBUTED TO RCIMS
- o AVERTED PUBLIC DOSE RESULTING FROM THE IMPLEMENTATION OF RCIMS IS NEGLIGIBLE
- o APPLICATION OF COST BENEFIT PERSPECTIVE SUGGESTS THAT THE COST OF THE SYSTEM IS OVERWHELMING COMPARED TO THE BENEFIT AND CANNOT BE JUSTIFIED ON THIS BASES

CONCLUSIONS (CONT)

o OTHER PERSPECTIVES

- NOT USEFUL WHEN RCPs ARE RUNNING OR RC VENTS ARE OPEN
- EQUIPMENT/CONTROL ROOM SPACE IS AT A PREMIUM
- THE RCIM SYSTEM IS PARASITIC IN THAT IT USES PLANT RESOURCES AND OPERATOR TIME WITHOUT PROVIDING AN EQUITABLE RETURN



STATUS

- o IMPLEMENTATION SCHEDULE PROVIDED BY 9/6/84 LETTER
- o CURRENTLY ON SCHEDULE
- o FINAL DESIGN DESCRIPTION - JULY, 1985
- o EOP TECHNICAL GUIDELINES
 - DUKE SUBMITTAL - MARCH, 1986
 - NRC APPROVAL - JULY, 1986
- o IMPLEMENTATION LETTER
 - UNIT 1 - NOVEMBER, 1986
 - UNIT 2 - MARCH, 1987
 - UNIT 3 - MARCH, 1986
- o INSTALLATION COMPLETED - JUNE, 1987

MEETING SUMMARY DISTRIBUTION

Licensee: Duke Power Company

*Copies also sent to those people on service (cc) list for subject plant(s).

Docket File

NRC PDR

L PDR

ORB#4 Rdg

Project Manager -HNicolaras

JStolz

BGrimes (Emerg. Preparedness only)

OELD

EJordan, IE

ACRS-10

PMorriette

NRC Meeting Participants:

HNicolaras

BBernero

LRubenstein

RJones

HLi

GLainas

JStolz

THuang

LPhillips

AThadani


EChelliah

JShea

CONCLUSIONS (CONT)

o OTHER PERSPECTIVES

- NOT USEFUL WHEN RCPs ARE RUNNING OR RC VENTS ARE OPEN
- EQUIPMENT/CONTROL ROOM SPACE IS AT A PREMIUM
- THE RCIM SYSTEM IS PARASITIC IN THAT IT USES PLANT RESOURCES AND OPERATOR TIME WITHOUT PROVIDING AN EQUITABLE RETURN



STATUS

- o IMPLEMENTATION SCHEDULE PROVIDED BY 9/6/84 LETTER
- o CURRENTLY ON SCHEDULE
- o FINAL DESIGN DESCRIPTION - JULY, 1985
- o EOP TECHNICAL GUIDELINES
 - DUKE SUBMITTAL - MARCH, 1986
 - NRC APPROVAL - JULY, 1986
- o IMPLEMENTATION LETTER
 - UNIT 1 - NOVEMBER, 1986
 - UNIT 2 - MARCH, 1987
 - UNIT 3 - MARCH, 1986
- o INSTALLATION COMPLETED - JUNE, 1987