



**KHNP**

**KOREA HYDRO & NUCLEAR POWER CO., LTD**

70-1312-gil, Yuseong-daero, Yuseong-gu, Daejeon, 305-343, KOREA

Tel: +82-42-870-5400 / Fax: +82-42-870-5449

<http://www.khnp.co.kr>

June 13, 2016  
Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attention: Mr. Jeff Ciocco  
Division of New Reactor Licensing

Docket No. 52-046  
MKD/NW-16-0438L

**Subject: Revised Response to RAI 267-8301 for the Question 03.07.03-1**

- References:**
- 1) NRC Request for Additional Information 267-8301, dated October 22, 2015
  - 2) KHNP Letter MKD/NW-16-0028L, Response to RAI 267-8301 for Questions 03.07.03-2, 03.07.03-4, and 03.07.03-5, dated January 12, 2016
  - 3) KHNP Letter MKD/NW-16-0072L, Response to RAI 267-8301 for Questions 03.07.03-1 and 03.07.03-3, dated January 27, 2016
  - 4) KHNP Letter MKD/NW-16-0493L, Revised Response to RAI 267-8301 for the Question 03.07.03-3, dated May 14, 2016
  - 5) KHNP Letter MKD/NW-16-0552L, Revised Response to RAI 267-8301 for the Question 03.07.03-2 and 03.07.03-5, dated May 26, 2016

KHNP is hereby submitting a revised response to RAI 267-8301, dated October 22, 2015. The RAI revised response addresses Question 03.07.03-1 in response to the bi-weekly seismic call with NRC, dated March 9, 2016. It revises the information to state that seismic Category I tanks installed in buildings are included in the seismic model of the building and provides the methods of the seismic analyses for other seismic Category I tanks.

The enclosure provides the revised response to RAI 267-8301 for the Question 03.07.03-1 (Non-Proprietary).

If additional information or clarification is required, please contact Daegeun Ahn, Director of KHNP Washington DC Center at [ahn.daegeun@khnp.co.kr](mailto:ahn.daegeun@khnp.co.kr) or 703-388-0592.

Sincerely,

Jae-yong Lee  
Project Manager  
Advanced Reactors Development Laboratory  
Korea Hydro and Nuclear Power Co., Ltd

Enclosure: Revised Response to RAI 267-8301 for the Question 03.07.03-1 (Non-Proprietary)

**Enclosure**

Revised Response to RAI 267-8301 for the Questions 03.07.03-1

(Non-Proprietary)

June 13, 2016