

Attachment E



Westinghouse Electric Company LLC
 Nuclear Fuel
 Columbia Fuel Site
 5801 Bluff Rd
 Hopkins, South Carolina 29061
 USA

Cynthia Logsdon

Direct tel: 803-647-1919
 Direct fax: 803-695-4158
 e-mail: wagoneda@westinghouse.com

Your ref:
 Our ref: LTR-EHS-14-15

Cc: Carl Snyder, Wayne Sepitko, Diana Joyner

Date: February 26, 2014

Subject: Assessment of Public Radiological Dose from Liquid and Gaseous Effluents for Calendar Year 2013

Effluents released from plant operations are monitored to determine the quantities of radio nuclides discharged into the environment. The cumulative effluent for the period starting 1-1-2013 and ending 12-31-2013 were summarized and input into dose models developed by the NRC/EPA to estimate the dose to the public via the following pathways:

- Air Effluents by Direct Inhalation – Estimated by running EPA's COMPLY Code at level 2 complexity. The organ dose was estimated by calculating the X/Q factor using the results of the COMPLY analysis for stack number 12, the measured release quantity, and the dose conversion factors from Federal Guidance Report No 11, "Limiting Values of Radionuclide Intake and Air concentration Factors for Inhalation, Submersion, and Ingestion"(FGR 11).
- Liquid Effluents by Ingestion of Potable Water – Estimated from formulas and recommended values in Regulatory Guide 1.109, Doses from Liquid Effluent Pathways (RG1.109). Dose conversion factors were taken from FGR 11.
- Liquid Effluents by Ingestion of Fish – Estimated from formulas and recommended values in RG 1.109. Dose conversion factors where taken from FGR 11.
- Liquid Effluents by Irradiation from Shoreline Deposition – Estimated from formulas and recommended values in RG 1.109. Dose conversion factors where taken from Federal Guidance report No 12, "External Exposure to Radionuclides in Air, Water, and Soil"

The radiological impacts were assessed by calculating the maximum total body dose and selected organ doses at the nearest site boundary.

- The inhalation dose is determined at the nearest site boundary at a distance of 595 meters.
- The ingestion dose from liquid and external dose from sediment deposition is determined at the point at which the liquid effluent leaves the diffuser in the Congaree River.

Page 2 of 3
Our ref: Westinghouse Electric
Company LLC
Nuclear Fuel
Columbia Fuel Site
5801 Bluff Rd
Hopkins, South Carolina 29061
USA

The release rates for gaseous effluent used in all of the calculations are taken from measured values obtained from daily air samples, one per stack for 47 stacks, measured for gross alpha. The release rates for liquid effluent, used in all of the calculations, are taken from monthly composite liquid effluent samples which are sent to an off-site lab for isotopic analysis. There is potential for technetium in our feed material and the liquid effluent is also tested for this isotope. Air samples were also tested for Tc-99 and no detectable quantities were found.

The total activities measured and /or estimated for calendar year 2013 were:

454.9 μCi of Uranium released as gaseous effluent
5.2 mCi of Uranium released in liquid effluent
9.3 mCi of Technetium released in liquid effluent

For airborne effluents released into the environment, the pathways considered for the individual dose calculations included direct inhalation and an estimate of the dose to the maximally exposed organ (lung and bone). For liquid effluent releases, the pathways included potable water, aquatic food (fish) and shoreline deposition. The models and various assumptions used in the liquid effluent environmental pathways are taken from Regulatory guide 1.109 and the details of both the gaseous and liquid dose calculations are documented in the attached spreadsheets listed below:

- | | |
|---------------|--|
| Attachment 1: | 2013 Gaseous Effluent Discharges |
| Attachment 2: | Lung/Bone Organ Dose from Gaseous Effluent |
| Attachment 3: | 2013 Liquid Effluent Discharges |
| Attachment 4: | Total Dose from Liquid Effluent Pathways - Potable Water |
| Attachment 5: | Dose to the Bone Surface from Liquid Effluent Pathways - Potable Water |
| Attachment 6: | Total Dose from Liquid Effluent Pathways - Aquatic Foods |
| Attachment 7: | Dose to the Bone Surface from Liquid Effluent Pathways - Aquatic Foods |
| Attachment 8: | Total Dose from Liquid Effluent Pathways – Shoreline Deposits |
| Attachment 9: | 2013 Isotopic Fractions |

Page 3 of 3
 Our ref: Westinghouse Electric
 Company LLC
 Nuclear Fuel
 Columbia Fuel Site
 5801 Bluff Rd
 Hopkins, South Carolina 29061
 USA

The results summarized in the table below indicate that the critical pathway is due to inhalation resulting in a maximum whole body dose of 0.160 mRem/yr and a lung dose of 1.64 mRem/yr. These doses are well below both the 25 mrem annual dose limit as well as the 10 mrem ALARA limit.

	Whole Body Dose (mrem/yr)	Organ Dose - Bone (mrem/yr)	Organ Dose - Lung (mrem/yr)
Air Effluents			
Direct inhalation*	0.16	6.22-03	1.64
Liquid Effluents			
Potable Water	1.26E-04	1.83E-03	-
Aquatic Food(Fish)	7.66E-06	1.06E-04	-
Shoreline Deposition	4.19E-09	-	-
<i>Total (mrem/yr)</i>	<i>0.16</i>	<i>8.16E-03</i>	<i>1.64</i>

* 80 % residence time

David Wagoner
 Radiation Safety Engineer
 EH&S Operations

Reviewed by Anna Pearson
 Manager, RSO
 EH&S Operations

Attachment 2

Lung/Bone Organ Dose due to Gaseous Effluents							
STACK IDENTIFICATION 12 S-1030-A	1st half (Jan-Jun)		2nd half (Jul-Dec)		Total uCi released 113.62	EPA Comply Run Results	
	uCi Uranium 103.64	uCi Uranium 9.98	uCi/yr 0.06100	mrem/yr 113.62		Dose (mrem/yr) Stack height (m) Release Rate (Ci/s)	6.10E-02 16 3.07E-12
use highest release for year to calculate X/Q used by COMPLY							
Dose from comply release quantity	0.06100		mrem/yr				
Inhalation from RG1.109	113.62		uCi/yr				
	1.14E-04		Ci/yr				
App E table E-5	8000.00		m3/yr				
Effective Dose conversion							
EPA FGR 11 p150-151							
U-234	3.58E-05	Sv/Bq		85%			
U-235	3.32E-05	Sv/Bq		3%			
U-238	3.20E-05	Sv/Bq		11%			
weighted dose conversion	3.49E-05	Sv/Bq					
conversion factor	3700.00	mrem/pCi= factor*	Sv/Bq				
weighted dose conversion	0.1293	mrem/pCi					
Dose (mrem/yr) = R(a)*3.17e4*Q*(X/Q)*effective Dose conversion				equations			
				see RG1.109-25			
Dose (mrem/yr)/(R(a)*3.17e4*Q*effective Dose conversion)=(X/Q)							
	1.64E-05	X/Q					
Estimate Lung Dose using X/Q and total released for 2013					Estimate Bone Dose using X/Q and total released for 2013		
App E table E-5							
Lung Organ Dose conversion							
EPA FGR 11 p150-151							
U-234	2.98E-04	Sv/Bq		85%	1.13E-06	Sv/Bq	
U-235	2.76E-04	Sv/Bq		3%	1.05E-06	Sv/Bq	
U-238	2.66E-04	Sv/Bq		11%	1.01E-06	Sv/Bq	
weighted dose conversion	2.93E-04	Sv/Bq			1.11E-06	Sv/Bq	
conversion factor	3700.00	mrem/pCi= factor*	Sv/Bq		3700.00	mrem/pCi= factor*	Sv/Bq
weighted dose conversion	1.0847	mrem/pCi			4.11E-03	mrem/pCi	
release quantity	454.89	uCi/yr			454.89	uCi/yr	
	4.55E-04	Ci/yr			4.55E-04	Ci/yr	
Lung *	1.64	mrem/yr	Bone *		6.22E-03	mrem/yr	
assume 80% residence							

Attachment 3

First Half Liquid Discharges

Radionuclide	Volume(ml)	uCi/ml	Error	LLD,uCi/ml	Quantity Released, uCi	Ci
		7.156E+10				
U234		4.407E-08	+/-	3.48E-09	6.00E-10	3154 3.15E-03
U235		1.555E-09	+/-	7.97E-10	6.00E-10	111 1.11E-04
U238		6.222E-09	+/-	1.33E-09	6.00E-10	445 4.45E-04
Tc-99		4.436E-08	+/-	1.14E-07	6.00E-10	3174 3.17E-03 Subtotal Tc99 3710 3.71E-03 Subtotal U

Second Half Liquid Discharges

Radionuclide	Volume(ml)	uCi/ml	Error	LLD,uCi/ml	Quantity Released, uCi	Ci
		7.447E+10				
U234		1.703E-08	+/-	2.25E-09	6.00E-10	1269 1.27E-03
U235		6.012E-10	+/-	5.25E-10	6.00E-10	45 4.48E-05
U238		2.405E-09	+/-	9.25E-10	6.00E-10	179 1.79E-04
Tc-99		8.154E-08	+/-	3.703E-09	6.00E-10	6073 6.07E-03 Subtotal Tc99 1492 1.49E-03 Subtotal U

Total Liquid Discharges

Radionuclide	Volume(ml)	uCi/ml	Quantity	
			Released, uCi	Ci
		1.460E+11		
U234		3.028E-08	4422	4.42E-03
U235		1.069E-09	156	1.56E-04
U238		4.275E-09	624	6.24E-04
Tc-99		6.332E-08	9247	9.25E-03
			Total U	5.20E+03
			Total Tc99	9.25E+03

Radionuclide % Activity

Radionuclide	% Activity	Ci
U234	0.8511	4.43E-03
U235	0.0329	1.71E-04
U236	0.0015	7.80E-06
U238	0.1146	5.96E-04
Tc-99	1	9.25E-03

Attachment 4

Total Dose from Liquid Effluent Pathways - Potable Water													
Whole Body-Ingestion													
730 liters	Usage by adult	U	10CFR20	7.3 x 10 ³ (ml) which is the annual water intake of "Reference Man."									
31293 mixing - dilution	Dilution at diffuser	M	Congaree Flow	9388 cubic feet/sec	see Nureg-1118 Environmental Assessment for renewam ...SNM-1107 May 1985								
0.3 cubic ft/sec	Average discharge	F	Effluent Flow	3.00E-01 cubic feet/sec									
2.83E-04 U-234	mRem/pCi	D	EPA Limiting Values of Radioanuclide Intake.....			effective	bone	effective	bone				
2.66E-04 U-235	mRem/pCi	D	FRG no 11 1988		U-234	7.66E-08	1.13E-06	2.83E-04	4.18E-03				
2.69E-04 U-236	mRem/pCi	D	Exposure-to-dose conversion factors for ingestion		U-235	7.19E-08	1.05E-06	2.66E-04	3.88E-03				
2.55E-04 U-238	mRem/pCi	D			U-236	7.26E-08	1.07E-06	2.69E-04	3.96E-03				
1.46E-06 Tc-99	mRem/pCi	D			U-238	6.88E-08	1.01E-06	2.55E-04	3.74E-03				
					Tc-99	3.95E-10	6.04E-11	1.46E-06	2.23E-07				
12 hrs	transit time	t-p	reg guide 1.109	table E-15									
3.23557E-10 U-234	decay const	λ	Nuclide	T(1/2) yr	T(1/2) hr	λ							
1.12404E-13 U-235	decay const	λ	URANIUM234	2.45E+05	2.14E+09	3.24E-10							
3.38075E-12 U-236	decay const	λ	URANIUM235	7.04E+08	6.17E+12	1.12E-13							
1.77058E-14 U-238	decay const	λ	URANIUM236	2.34E+07	2.05E+11	3.38E-12	for comparison only						
3.71407E-10 Tc-99	decay const	λ	URANIUM238	4.47E-09	3.91E+13	1.77E-14							
			TC-99	2.13E+05	1.87E+09	3.71E-10	Part 20 table 2 soluble forms						
0.9999999961 U-234	exp(-λt-p)						Dose Conversion						
1.0000000000 U-235	exp(-λt-p)						uCi/ml	milliters	uCi	pCi	mRem		
1.0000000000 U-236	exp(-λt-p)						U-234	3.00E-07	7.30E+05	2.19E-01	2.19E+05	50	2.28E-04
1.0000000000 U-238	exp(-λt-p)						U-235	3.00E-07	7.30E+05	2.19E-01	2.19E+05	50	2.28E-04
0.9999999955 Tc-99	exp(-λt-p)						U-236	3.00E-07	7.30E+05	2.19E-01	2.19E+05	50	2.28E-04
							U-238	3.00E-07	7.30E+05	2.19E-01	2.19E+05	50	2.28E-04
Annual Release rate							Tc-99	6.00E-05	7.30E+05	4.38E+01	4.38E+07	50	1.14E-06
5.2026E-03 total uranium(Ci)	Q	summation of liquid effluent alpha activity for 2012 (see Total Liq tab)	% of activity based on current nominal uranium isotopic (see U activity tab)				ICRP 69 Comparison						
4.4279E-03 U-234 release fraction	Ci	URANIUM234	85.11%	0.851			Sv/Bq	Rem/Bq	mRem/pCi				
1.7117E-04 U-235 release fraction	Ci	URANIUM235	3.29%	0.033									
7.8039E-06 U-236 release fraction	Ci	URANIUM236	0.15%	0.002									
5.9622E-04 U-238 release fraction	Ci	URANIUM238	11.46%	0.115			adult	5.00E-08	0.005	1.85E-04			
9.2469E-03 Tc-99 release fraction	Ci	TC-99					infant	3.70E-07	0.037	1.37E-03			
							bone-adult	7.90E-07	0.079	2.92E-03			
check U sum	0.00520												
1.25E-06 U-234	release fraction *dose factor*exp(-λt-p)												
4.55E-08 U-235	release fraction *dose factor*exp(-λt-p)												
2.10E-08 U-236	release fraction *dose factor*exp(-λt-p)												
1.52E-07 U-238	release fraction *dose factor*exp(-λt-p)												
1.35E-08 Tc-99	release fraction *dose factor*exp(-λt-p)												
1.47E-06 all nuclides	sum of nuclides												
85.53473 usage	1100*(usage*dilution)/flow												
1.26E-04 mRem/yr	see regulatory guide 1.109 page 1.109-2 and 1.109-3 for formula and definition of terms.												

Attachment 5

Dose to the Bone Surface from Liquid Effluent Pathways - Potable Water											
Bone Surface-Ingestion											
730 liters	Usage by adult	U	10CFR20	7.3×10^5 (ml)	which is the annual water intake of "Reference Man."						
31293 mixing - dilution	Dilution at difuser	M	Congaree Flow	9388 cubic feet/sec							
0.3 cubic ft/sec	Average discharge	F	Effluent Flow	3.00E-01 cubic feet/sec							
4.18E-03 U-234	mRem/pCi	D-bone	EPA Limiting Values of Radioanuclide Intake.....								
3.88E-03 U-235	mRem/pCi	D-bone	FRG no 11 1988			U-234	7.66E-08	1.13E-06	2.83E-04	4.18E-03	
3.96E-03 U-236	mRem/pCi	D-bone	Exposure-to-dose conversion factors for ingestion			U-235	7.19E-08	1.05E-06	2.66E-04	3.88E-03	
3.74E-03 U-238	mRem/pCi	D-bone				U-236	7.26E-08	1.07E-06	2.69E-04	3.96E-03	
2.23E-07 Tc-99	mRem/pCi	D-bone				U-238	6.88E-08	1.01E-06	2.55E-04	3.74E-03	
						Tc-99	3.95E-10	6.04E-11	1.46E-06	2.23E-07	
12 hrs	transit time	t-p	reg guide	table E-15							
3.23557E-10 U-234	decay const	λ	Nuclide	T(1/2) yr	T(1/2) hr	λ					
1.12404E-13 U-235	decay const	λ	URANIUM234	2.45E+05	2.14E+09	3.24E-10					
3.38075E-12 U-236	decay const	λ	URANIUM235	7.04E+08	6.17E+12	1.12E-13	Part 20 table 2		soluble forms		
1.77058E-14 U-238	decay const	λ	URANIUM236	2.34E+07	2.05E+11	3.38E-12	Dose Conversion				
3.71407E-10 Tc-99	decay const	λ	URANIUM238	4.47E+09	3.91E+13	1.77E-14					
			TC-99	2.13E+05	1.87E+09	3.71E-10	uCi/ml	milliters	uCi	pCi	
							U-234	3.00E-07	7.30E+05	2.19E-01	2.19E+05
0.9999999961 U-234	exp(- λt_p)						U-235	3.00E-07	7.30E+05	2.19E-01	2.19E+05
1.0000000000 U-235	exp(- λt_p)						U-236	3.00E-07	7.30E+05	2.19E-01	2.19E+05
1.0000000000 U-236	exp(- λt_p)						U-238	3.00E-07	7.30E+05	2.19E-01	2.19E+05
1.0000000000 U-238	exp(- λt_p)						Tc-99	6.00E-05	7.30E+05	4.38E+01	4.38E+07
0.9999999955 Tc-99	exp(- λt_p)										
							ICRP 69 Comparison				
Annual Release rate											
5.2026E-03 total uranium(Ci)	Q	summation of liquid effluent alpha activity for 2012(see Total Liq tab) % of activity based on current nominal uranium isotopic(see U activity tab)					Sv/Bq	Rem/Bq	mRem/pCi		
4.4279E-03 U-234 release fraction	Ci	URANIUM234	85.11%				adult	5.00E-08	0.005	1.85E-04	
1.7117E-04 U-235 release fraction	Ci	URANIUM235	3.29%				infant	3.70E-07	0.037	1.37E-03	
7.8039E-06 U-236 release fraction	Ci	URANIUM236	0.15%				bone-adult	7.90E-07	0.079	2.92E-03	
5.9622E-04 U-238 release fraction	Ci	URANIUM238	11.46%								
9.2469E-03 Tc-99 release fraction	Ci	TC-99									
check U sum	0.00520										
1.85E-05 U-234	release fraction *dose factor*exp(- λt_p)										
6.65E-07 U-235	release fraction *dose factor*exp(- λt_p)										
3.09E-08 U-236	release fraction *dose factor*exp(- λt_p)										
2.23E-06 U-238	release fraction *dose factor*exp(- λt_p)										
2.07E-09 Tc-99	release fraction *dose factor*exp(- λt_p)										
2.14E-05 all nuclides	sum of nuclides										
85.53473 usage	1100*(usage*dilution)/flow										
1.83E-03 mRem/yr	see regulatory guide 1.109 page 1.109-2 and 1.109-3 for formula and definition of terms.										

Attachment 6

Total Dose from Liquid Effluent Pathways - Aquatic Foods									
		Whole Body							
21	Kg	Usage by adult	U	see regulatory guide 1.109 page 1.109-40 table E-5, Recommended Values for U(ap)					
31293	mixing - dilution	Dilution at diffuser	M	Congaree Flow	9388 cubic feet/sec	see Nureg-1118 Environmental Assessment for renewam ...SNM-1107 May 1985			
0.3	cubic ft/sec	Average discharge	F	Effluent Flow	3.00E-01 cubic feet/sec				
2.83E-04	U-234	mRem/pCi	D	EPA Limiting Values of Radioanuclides Intake.....					
2.66E-04	U-235	mRem/pCi	D	FRG no 11 1988					
2.69E-04	U-236	mRem/pCi	D	Exposure-to-dose conversion factors for ingestion					
2.55E-04	U-238	mRem/pCi	D						
1.46E-06	Tc-99	mRem/pCi	D						
24	hrs	transit time	t-p	reg guide 1table E-15					
3.23557E-10	U-234	decay const	λ	Nuclide	T(1/2) yr	T(1/2) hr	λ		
1.12404E-13	U-235	decay const	λ	URANIUM234	2.45E+05	2.14E+09	3.24E-10		for comparison only
3.38075E-12	U-236	decay const	λ	URANIUM235	7.04E+08	6.17E+12	1.12E-13		
1.77058E-14	U-238	decay const	λ	URANIUM236	2.34E+07	2.05E+11	3.38E-12	Part 20 table 2	soluble forms
3.71407E-10	Tc-99	decay const	λ	URANIUM238	4.47E+09	3.91E+13	1.77E-14	Dose Conversion	
0.9999999923	U-234	exp(-λt-p)		TC-99	2.13E+05	1.87E+09	3.71E-10	uCi/ml	milliters
1.0000000000	U-235	exp(-λt-p)						uCi	pCi
0.99999999992	U-236	exp(-λt-p)						mRem	mRem/pCi
1.0000000000	U-238	exp(-λt-p)						50	2.28E-04
0.99999999109	Tc-99	exp(-λt-p)						50	2.28E-04
Annual Release rate								ICRP 69	Comparison
5.2026E-03	total uranium(Ci)	Q	summation of liquid effluent alpha activity for 2012 (see Total Liq tab)						
			% of activity based on current nominal uranium isotopic (see U activity tab)					Sv/Bq	Rem/Bq mRem/pCi
4.4279E-03	U-234 release fraction	Ci	URANIUM234 : 85.11%						
1.7117E-04	U-235 release fraction	Ci	URANIUM235 : 3.29%					adult	5.00E-08 0.005 1.85E-04
7.8039E-06	U-236 release fraction	Ci	URANIUM236 : 0.15%					infant	3.70E-07 0.037 1.37E-03
5.9622E-04	U-238 release fraction	Ci	URANIUM238 : 11.46%					bone-adult	7.90E-07 0.079 2.92E-03
9.2469E-03	Tc-99 release fraction	Ci	TC-99						
check U sum		0.00520							
								BNWL-2075	
2.51E-06	U-234	release fraction *bioaccumulation factor*dose factor*exp(-λ*t-p)			2)			UC-11	
9.11E-08	U-235	release fraction *bioaccumulation factor*dose factor*exp(-λ*t-p)			2)			Methodology for Calculation of Radiation Doses	
4.19E-09	U-236	release fraction *bioaccumulation factor*dose factor*exp(-λ*t-p)			2)			In the Environs from Nuclear Fuel	
3.04E-07	U-238	release fraction *bioaccumulation factor*dose factor*exp(-λ*t-p)			2)			Cycle Facilities	
2.03E-07	Tc-99	release fraction *bioaccumulation factor*dose factor*exp(-λ*t-p)			15				
3.11E-06	all nuclides	sum of nuclides							
2.46059	usage	1100*(usage*dilution)/flow							
7.66E-06	mRem/yr	see regulatory guide 1.109 page 1.109-2 and 1.109-3 for formula and definition of terms.							

Attachment 7

Dose to the Bone Surface from Liquid Effluent Pathways - Aquatic Foods																
Bone Surface																
21 Kg	Usage by adult	U	see regulatory guide 1.109 page 1.109-40 table E-5, Recommended Values for U(ap)													
31293 mixing - dilution	Dilution at diffuser	M	Congaree Flow	9388 cubic feet/sec		see Nureg-1118 Environmental Assessment for renewarm ...SNM-1107 May 1985										
0.3 cubic ft/sec	Average discharge	F	Effluent Flow	3.00E-01 cubic feet/sec												
4.18E-03 U-234	mRem/pCi	D	EPA Limiting Values of Radioanuclide Intake.....					effective	bone	effective	bone					
3.88E-03 U-235	mRem/pCi	D	FRG no 11 1988		U-234	7.66E-08 1.13E-06	2.83E-04	4.18E-03								
3.96E-03 U-236	mRem/pCi	D	Exposure-to-dose conversion factors for ingestion		U-235	7.19E-08 1.05E-06	2.66E-04	3.88E-03								
3.74E-03 U-238	mRem/pCi	D			U-236	7.26E-08 1.07E-06	2.69E-04	3.96E-03								
2.23E-07 Tc-99	mRem/pCi	D			U-238	6.88E-08 1.01E-06	2.55E-04	3.74E-03								
					Tc-99	3.95E-10 6.04E-11	1.46E-06	2.23E-07								
24 hrs	transit time	t-p	reg guide 1.109	table E-15												
3.23557E-10 U-234	decay const	λ	Nuclide		T(1/2) yr	T(1/2) hr	λ					for comparison only				
1.12404E-13 U-235	decay const	λ	URANIUM234		2.45E+05	2.14E+09	3.24E-10									
3.38075E-12 U-236	decay const	λ	URANIUM235		7.04E+08	6.17E+12	1.12E-13					Part 20 table 2	soluble forms			
1.77058E-14 U-238	decay const	λ	URANIUM236		2.34E+07	2.05E+11	3.38E-12					Dose Conversion				
3.71407E-10 Tc-99	decay const	λ	URANIUM238		4.47E+09	3.91E+13	1.77E-14					uCi/ml	milliters	uCi	pCi	mRem
					TC-99	2.13E+05	1.87E+09	3.71E-10								mRem/pCi
0.99999999223 U-234	exp(- λ t-p)							U-234	3.00E-07	7.30E+05	2.19E-01	2.19E+05	50	2.28E-04		
1.00000000000 U-235	exp(- λ t-p)							U-235	3.00E-07	7.30E+05	2.19E-01	2.19E+05	50	2.28E-04		
0.99999999992 U-236	exp(- λ t-p)							U-236	3.00E-07	7.30E+05	2.19E-01	2.19E+05	50	2.28E-04		
1.00000000000 U-238	exp(- λ t-p)							U-238	3.00E-07	7.30E+05	2.19E-01	2.19E+05	50	2.28E-04		
0.999999999109 Tc-99	exp(- λ t-p)							Tc-99	6.00E-05	7.30E+05	4.38E+01	4.38E+07	50	1.14E-06		
												ICRP 69	Comparison			
Annual Release rate:																
5.2026E-03 total uranium(C)	Q	summation of liquid effluent alpha activity for 2012 (see Total Liq tab)										Sv/Bq	Rrem/Bq	mRem/pCi		
% of activity based on current nominal uranium isotopic (see U activity tab)																
4.4279E-03 U-234 release fr/Ci	URANIUM234	85.11%										adult	5.00E-08	0.005	1.85E-04	
1.7117E-04 U-235 release fr/Ci	URANIUM235	3.29%										infant	3.70E-07	0.037	1.37E-03	
7.8039E-06 U-236 release fr/Ci	URANIUM236	0.15%										bone-adult	7.90E-07	0.079	2.92E-03	
5.9622E-04 U-238 release fr/Ci	URANIUM238	11.46%														
9.2469E-03 Tc-99 release fr/Ci	TC-99															
check U sum	0.00520							bioaccumulation factor	BNWL-2075							
3.70E-05 U-234	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)				2	UC-11										
1.33E-06 U-235	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)				2	Methodology for Calculation of Radiation Doses										
6.18E-08 U-236	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)				2	in the Environs from Nuclear Fuel										
4.46E-08 U-238	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)				2	Cycle Facilities										
3.10E-08 Tc-99	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)				15											
4.29E-05 all nuclides	sum of nuclides															
2.46059 usage	1100*(usage*dilution)/flow															
1.06E-04 mRem/yr	see regulatory guide 1.109 page 1.109-2 and 1.109-3 for formula and definition of terms.															

Attachment 8

Total Dose from Liquid Effluent Pathways - Shoreline Deposits									
		Whole Body							
12 hr	Usage by adult	U	see regulatory guide 1.109 page 1.109-40 table E-5, Recommended Values for U(ap)						
31293	mixing - dilution	Dilution at difuser	M	Congaree Flow	9388 cubic feet/sec	see Nureg-1118 Environmental Assessment for renewam ...SNM-1107 May 19			
0.3	cubic ft/sec	Average discharge	F	Effluent Flow	3.00E-01 cubic feet/sec				
9.86E-12	U-234	mRem*m^2/pCi*hr	D	U-234	7.40E-19 9.86E-12 EPA FRG 12	Dose Coeff for exposure to contaminated ground surface			
1.97E-09	U-235	mRem*m^2/pCi*hr	D	U-235	1.48E-16 1.97E-09				
8.66E-12	U-236	mRem*m^2/pCi*hr	D	U-236	6.50E-19 8.66E-12				
7.34E-12	U-238	mRem*m^2/pCi*hr	D	U-238	5.51E-19 7.34E-12				
1.04E-12	Tc-99	mRem*m^2/pCi*hr	D	Tc-99	7.80E-20 1.04E-12				
12 hrs	transit time	t-p	see regulatory guide 1.109 page 1.109-69 table E-15, Recommended Values ...			t-i			
131040	hrs	xposure time of sediment	t-b	page 1.109-68	Nuclide	T(1/2) yr	T(1/2) hr	λ	T(1/2) day
3.23557E-10	U-234	decay const	λ		URANIUM234	2.45E+05	2.14E+09	3.24E-10	8.90E+07
1.12404E-13	U-235	decay const	λ		URANIUM235	7.04E+08	6.17E+12	1.12E-13	2.56E+11
3.38075E-12	U-236	decay const	λ		URANIUM236	2.34E+07	2.05E+11	3.38E-12	8.52E+09
1.77058E-14	U-238	decay const	λ		URANIUM238	4.47E+09	3.91E+13	1.77E-14	1.63E+12
3.71407E-10	Tc-99	decay const	λ		TC-99	2.13E+05	1.87E+09	3.71E-10	7.75E+07
0.0000423980	U-234	$\exp(-\lambda t_p) * [1 - \exp(-\lambda t_b)]$							
0.0000000147	U-235	$\exp(-\lambda t_p) * [1 - \exp(-\lambda t_b)]$							
0.0000004430	U-236	$\exp(-\lambda t_p) * [1 - \exp(-\lambda t_b)]$							
0.0000000023	U-238	$\exp(-\lambda t_p) * [1 - \exp(-\lambda t_b)]$							
0.0000486679	Tc-99	$\exp(-\lambda t_p) * [1 - \exp(-\lambda t_b)]$							
Annual Release rate									
5.2026E-03	total uranium(Ci)	Q	summation of liquid effluent alpha activity for 2012(see Total Liq tab)						
			% of activity based on current nominal uranium isotopic(see U activity tab)						
4.4279E-03	U-234 release fraction	Ci	URANIUM234 85.11%						
1.7117E-04	U-235 release fraction	Ci	URANIUM235 3.29%						
7.8039E-06	U-236 release fraction	Ci	URANIUM236 0.15%						
5.9622E-04	U-238 release fraction	Ci	URANIUM238 11.46%						
9.2469E-03	Tc-99 release fraction	Ci	TC-99						
check U sum	0.00520								
1.65E-10	U-234	release fraction *dose factor* $\exp(-\lambda t_p) * [1 - \exp(-\lambda t_b)] * t_i$							
1.27E-09	U-235	release fraction *dose factor* $\exp(-\lambda t_p) * [1 - \exp(-\lambda t_b)] * t_i$							
2.55E-13	U-236	release fraction *dose factor* $\exp(-\lambda t_p) * [1 - \exp(-\lambda t_b)] * t_i$							
1.65E-11	U-238	release fraction *dose factor* $\exp(-\lambda t_p) * [1 - \exp(-\lambda t_b)] * t_i$							
3.63E-11	Tc-99	release fraction *dose factor* $\exp(-\lambda t_p) * [1 - \exp(-\lambda t_b)] * t_i$							
1.49E-09	all nuclides	sum of nuclides							
2.812101	usage	11000*(usage*dilution*shore width factor)/flow	see regulatory guide 1.109 page 1.109-40 table A-2,Shore width...						
4.19E-09	mRem/yr	see regulatory guide 1.109 page 1.109-2 and 1.109-3 for formula and definition of terms.							

Attachment 9

2013 Isotopic Fractions

Based on measured isotopes of pellets produced in 2013

Nuclide	Average wt%	Specific Activity Ci/g	Weighted Activity	% Activity
U-234	0.038	6.220E-03	2.388E-04	85.11
U-235	4.270	2.160E-06	9.223E-06	3.29
U-236	0.006	6.470E-05	4.076E-07	0.15
U-238	95.685	3.360E-07	3.215E-05	11.46
Total	100.000		2.806E-04	100.000

Attachment F



Westinghouse Electric Company
 Nuclear Fuel
 Columbia Fuel Site
 5801 Bluff Rd
 Hopkins, South Carolina 29061
 USA

To: Cynthia Logsdon

Direct tel: 803-647-1919
 Direct fax: 803-695-4158
 e-mail: wagoneda@westinghouse.com

Your ref:
 Our ref: LTR-EHS-15-14

Cc: John Howell, Carl Snyder, Nancy Parr,
 Anna Pearson, Sherrie Culler

February 23, 2015

Annual Assessment of Public Dose from Liquid and Gaseous Effluents

Effluents released from plant operations are monitored to determine the quantities of radionuclides discharged into the environment. The cumulative radioactivity released is summarized semi-annually and annually and input into dose models developed by the NRC and EPA to estimate the dose to the public.

The whole body and organ dose via the following pathways were determined in this assessment:

- Dose due to Gaseous Effluents by Direct Inhalation
 - The whole body dose was estimated using the EPA's COMPLY Code at level 2 complexity. The organ dose was estimated using the calculated X/Q factor for stack number 1247, the measured release quantity, and the dose conversion factors from Federal Guidance Report No 11, "Limiting Values of Radionuclide Intake and Air concentration Factors for Inhalation, Submersion, and Ingestion" (FGR 11).
- Dose due to Liquid Effluents by Ingestion of Potable Water
 - Estimated using equations and recommended values in Regulatory Guide 1.109, Doses from Liquid Effluent Pathways (RG1.109). Dose conversion factors were taken from FGR 11.
- Dose due to Liquid Effluents by Ingestion of Fish
 - Estimated using equations and recommended values in RG 1.109. Dose conversion factors were taken from FGR 11.
- Dose due to Liquid Effluents by Irradiation from Shoreline Deposition
 - Estimated using equations and recommended values in RG 1.109. Dose conversion factors were taken from Federal Guidance report No 12, "External Exposure to Radionuclides in Air, Water, and Soil"

The inhalation dose is determined at the nearest site boundary at a distance of 595 meters. The ingestion dose from liquid effluent and external dose from sediment deposition is determined at the point where the liquid effluent leaves the diffuser in the Congaree River.

The release rates for gaseous effluent are determined by gross alpha measurements performed on daily air samples, one per stack for 47 stacks (Attachment 1). The release rates for liquid effluent are determined by isotopic analysis of liquid effluent samples taken monthly (Attachment 3). Based on these results, the following quantities were released in calendar year 2014:

- 394.9 μCi of Uranium in gaseous effluent
- 3.8 mCi of Uranium in liquid effluent
- 10.1 mCi of Technetium in liquid effluent

Using these results and the methods previously mentioned the whole body dose, dose to the bone, and dose to the lung were determined for an individual present at the nearest site boundary. Table 1 provides a summary of the results for each pathway. The gaseous and liquid effluents released during 2014 resulted in a potential whole body dose of 0.16 mrem and a lung dose of 1.4 mrem to an individual present at the nearest site boundary. The dose to the bone is negligible. These doses are well below the 25 mrem annual dose limit and the 10 mrem annual ALARA limit for a member of the public.

Table 1. 2014 Annual Dose to the Public from Liquid and Gaseous Effluents

	Whole Body Dose (mrem/yr)	Organ Dose - Bone (mrem/yr)	Organ Dose - Lung (mrem/yr)
Gaseous Effluents			
Direct inhalation*	0.16	5.3E-03	1.4
Liquid Effluents			
Potable Water	9.2E-05	1.3E-03	-
Aquatic Food (Fish)	5.7E-06	7.7E-05	-
Shoreline Deposition	3.1E-09	-	-
<i>Total (mrem)</i>	<i>0.16</i>	<i>6.7E-03</i>	<i>1.4</i>


* Assumes 80 % residence time

There were no significant changes in source material, chemical form, or release points during 2014. The attachments below illustrate the method used to calculate each result listed in Table 1.

Westinghouse Non-Proprietary Class 3

Page 3 of 3
Westinghouse Electric Company
Nuclear Fuel
Columbia Fuel Site
5801 Bluff Rd
Hopkins, South Carolina 29061
USA

- Attachment 1: 2014 Gaseous Effluent Discharges
- Attachment 2: Lung/Bone Organ Dose due to Gaseous Effluent
- Attachment 3: 2014 Liquid Effluent Discharges
- Attachment 4: Whole Body Dose from Liquid Effluent Pathways - Potable Water
- Attachment 5: Dose to the Bone Surface from Liquid Effluent Pathways - Potable Water
- Attachment 6: Whole Body Dose from Liquid Effluent Pathways - Aquatic Foods
- Attachment 7: Dose to the Bone Surface from Liquid Effluent Pathways - Aquatic Foods
- Attachment 8: Whole Body Dose from Liquid Effluent Pathways – Shoreline Deposits
- Attachment 9: 2014 Isotopic Fractions
- Attachment 10: Comply Results



David Wagoner
Radiation Safety Engineer
EH&S Operations



Review by: Anna Pearson
Manager, RSO
EH&S Operations

Attachment 2

Lung/Bone Organ Dose due to Gaseous Effluents				
	1st half (Jan-Jun)	2nd half (Jul-Dec)	Total	EPA
STACK IDENTIFICATION	uCi Uranium	uCi Uranium	uCi released	Comply Run Results
Hot Oil Room Ex	28.48	14.77	43.25	Dose (mrem/yr)
use highest release for year to calculate X/Q used by COMPLY				2.30E-02
Dose from comply release quantity	0.02300 43.25	mrem/yr uCi/yr		12
Inhalation from RG1.109	4.33E-05	Ci/yr		U-234 1.17E-12
App E table E-5	8000.00	m3/yr		U-235 4.51E-14
Effective Dose conversion				U-238 1.57E-13
EPA FGR 11 p150-151				
U-234	3.58E-05	Sv/Bq	85%	
U-235	3.32E-05	Sv/Bq	3%	
U-238	3.20E-05	Sv/Bq	11%	
weighted dose conversion	3.52E-05	Sv/Bq		
conversion factor	3700.00	mrem/pCi= factor* Sv/Bq		
weighted dose conversion	0.1303	mrem/pCi		
			equations	
Dose (mrem/yr) = R(a)*3.17e4*Q*(X/Q)*effective Dose conversion			see RG1.109-25	
Dose (mrem/yr)/(R(a)*3.17e4*Q*effective Dose conversion)=(X/Q)				
	1.61E-05	X/Q		
Estimate Lung Dose using X/Q and total released for 2014			Estimate Bone Dose using X/Q and total released for 2014	
App E table E-5				
Lung Organ Dose conversion				
EPA FGR 11 p150-151				
U-234	2.98E-04	Sv/Bq	85%	1.13E-06
U-235	2.76E-04	Sv/Bq	3%	1.05E-06
U-238	2.66E-04	Sv/Bq	11%	1.01E-06
weighted dose conversion	2.93E-04	Sv/Bq		1.11E-06
conversion factor	3700.00	mrem/pCi= factor* Sv/Bq		3700.00 mrem/pCi= factor* Sv/Bq
weighted dose conversion	1.0847	mrem/pCi		4.11E-03 mrem/pCi
release quantity	394.86	uCi/yr		394.86 uCi/yr
	3.95E-04	Ci/yr		3.95E-04 Ci/yr
Lung *	1.40	mrem/yr	Bone *	5.30E-03 mrem/yr
*assume 80% residence				

2014

Attachment 3 - 2014 Liquid Effluent Discharges

Month	Liquid Effluent Discharges			Isotopic Uranium Measured Concentrations							Tc-99 Measured Concentrations		Sum U & Tc-99 uCi/ml E-06	Total uCi/month Released (based on monthly GEL discharge samples)				
	Average kgal/day	Actual kgal/month	Actual gal/month	U234 pCi/L	U234 uCi/ml E-06	U235 pCi/L	U235 uCi/ml E-06	U238 pCi/L	U238 uCi/ml E-06	SUM ISO U uCi/ml E-06	Tc-99 pCi/L	Tc-99 uCi/ml E-06		U234	U-235	U-238	Tc-99	
JAN	103,928	2806,060	2,806,060	23.9	0.024	0.890	0.001	3.29	0.003	0.028	69.2	0.069	0.097	JAN	291,446	10,853	40,120	843,852
FEB	113,506	2951,150	2,951,150	29.0	0.029	1.73	0.002	4.37	0.004	0.0351	145	0.145	0.180	FEB	348,852	20,811	52,568	1744,258
MAR	119,329	3699,200	3,699,200	21.1	0.021	0.865	0.001	2.44	0.002	0.024405	39.0	0.039	0.063	MAR	295,431	12,111	34,164	546,057
APR	84,031	2352,880	2,352,880	27.9	0.028	1.25	0.001	4.40	0.004	0.03355	34.0	0.034	0.068	APR	266,214	11,927	41,984	324,418
MAY	97,970	2253,310	2,253,310	27.6	0.028	0.539	0.001	3.34	0.003	0.031479	51.6	0.052	0.083	MAY	317,271	6,196	38,394	593,158
JUNE	100,426	3012,780	3,012,780	13.0	0.013	0.899	0.001	2.38	0.002	0.016279	109	0.109	0.125	JUNE	148,244	10,252	27,140	1242,968
JUL	102,678	2874,970	2,874,970	24.1	0.024	0.731	0.001	3.94	0.004	0.029	123.0	0.123	0.152	JUL	290,349	8,807	47,468	1481,863
AUG	110,894	3326,821	3,326,821	20.4	0.020	0.54	0.001	2.77	0.003	0.023709	27	0.027	0.051	AUG	265,440	7,013	36,043	348,715
SEP	102,726	2876,324	2,876,324	24.5	0.025	1.030	0.001	4.33	0.004	0.02986	0.0	0.000	0.030	SEP	285,781	12,014	50,507	0,000
OCT	87,940	2374,378	2,374,378	26.9	0.027	1.08	0.001	2.90	0.003	0.03088	0.0	0.000	0.031	OCT	277,566	11,144	29,923	0,000
NOV	87,694	2367,746	2,367,746	22.6	0.023	0.997	0.001	3.10	0.003	0.026697	146.0	0.146	0.173	NOV	225,044	9,928	30,869	1453,822
DEC	128,606	3215,145	3,215,145	13.6	0.014	0.823	0.001	1.87	0.002	0.016293	103	0.103	0.119	DEC	205,223	12,419	28,218	1554,266
Total (Jan-Dec)				34110,764	34,110,764									3216,859	133,475	457,398	10133,377	
Liters (L)				1.29E+08										3807.7			10133,377	
Milliliters (ml)				1.29E+11										uCi Uranium				
														13941,1				
														uCi Uranium & Tc-99				

Attachment 4

Whole Body Dose from Liquid Effluent Pathways - Potable Water											
Whole Body-Ingestion											
730 liters	Usage by adult/yr	U	10CFR20	7.3×10^5 (ml) which is the annual water intake of "Reference Man."							
31293 mixing - dilution	Dilution at diffuser	M	Congaree Flow	9388 cubic feet/sec	see Nureg-1118 Environmental Assessment for renewam ... SNM-1107 May 1985						
0.3 cubic ft/sec	Average discharge	F	Effluent Flow	3.00E-01 cubic feet/sec							
2.83E-04 U-234	mRem/pCi	D	EPA Limiting Values of Radioanuclide Intake.....								
2.66E-04 U-235	mRem/pCi	D	FRG no 11 1981	U-234	7.66E-08 1.13E-06	2.83E-04 4.16E-03					
2.69E-04 U-236	mRem/pCi	D	Exposure-to-dose conversion factors for ingestion	U-235	7.19E-08 1.05E-06	2.66E-04 3.88E-03					
2.55E-04 U-238	mRem/pCi	D		U-236	7.26E-08 1.07E-06	2.69E-04 3.96E-03					
1.46E-06 Tc-99	mRem/pCi	D		U-238	6.88E-08 1.01E-06	2.55E-04 3.74E-03					
				Tc-99	3.95E-10 6.04E-11	1.46E-06 2.23E-07					
12 hrs	transit time	t-p	reg guide 1.109 table E-15								
3.23557E-10 U-234	decay const	λ	Nuclide	T(1/2) yr	T(1/2) hr	λ					
1.12404E-13 U-235	decay const	λ	URANIUM234	2.45E+05	2.14E+09	3.24E-10					
3.38075E-12 U-236	decay const	λ	URANIUM235	7.04E+08	6.17E+12	1.12E-13					
1.77058E-14 U-238	decay const	λ	URANIUM236	2.34E+07	2.05E+11	3.38E-12	for comparison only				
3.71407E-10 Tc-99	decay const	λ	URANIUM238	4.47E+09	3.91E+13	1.77E-14					
			TC-99	2.13E+05	1.87E+09	3.71E-10	Part 20 table 2 soluble forms				
0.9999999961 U-234	exp(-λt-p)						Dose Conversion				
1.0000000000 U-235	exp(-λt-p)						uCi/ml milliters	uCi	pCi	mRem	mRem/pCi
1.0000000000 U-236	exp(-λt-p)						U-234	3.00E-07 7.30E+05	2.19E-01 2.19E+05	50	2.28E-04
1.0000000000 U-238	exp(-λt-p)						U-235	3.00E-07 7.30E+05	2.19E-01 2.19E+05	50	2.28E-04
0.9999999955 Tc-99	exp(-λt-p)						U-236	3.00E-07 7.30E+05	2.19E-01 2.19E+05	50	2.28E-04
							U-238	3.00E-07 7.30E+05	2.19E-01 2.19E+05	50	2.28E-04
Activity Released							Tc-99	6.00E-05 7.30E+05	4.38E+01 4.38E+07	50	1.14E-06
3.8077E-03 total uranium(Ci)	Q	summation of liquid effluent alpha activity	% of activity based on current nominal uranium isotopic (see U activity tab)				ICRP 69 Comparison				
3.2407E-03 U-234 release fraction	Ci	URANIUM234	85.11% 0.8511								
1.2527E-04 U-235 release fraction	Ci	URANIUM235	3.29% 0.0329								
5.7116E-06 U-236 release fraction	Ci	URANIUM236	0.15% 0.0015								
4.3636E-04 U-238 release fraction	Ci	URANIUM238	11.46% 0.1146				adult	5.00E-08 0.005	1.85E-04		
1.0133E-02 Tc-99 release fraction	Ci	TC-99					infant	3.70E-07 0.037	1.37E-03		
							bone-adult	7.90E-07 0.079	2.92E-03		
check U sum	0.00381										
9.18E-07 U-234	release fraction *dose factor*exp(-λt-p)										
3.33E-08 U-235	release fraction *dose factor*exp(-λt-p)										
1.53E-09 U-236	release fraction *dose factor*exp(-λt-p)										
1.11E-07 U-238	release fraction *dose factor*exp(-λt-p)										
1.48E-08 Tc-99	release fraction *dose factor*exp(-λt-p)										
1.08E-06 all nuclides	sum of nuclides										
85.53473 usage	1100*(usage*dilution)/flow										
9.23E-05 mRem	see regulatory guide 1.109 page 1.109-2 and 1.109-3 for formula and definition of terms.										

Attachment 5

Dose to the Bone Surface from Liquid Effluent Pathways - Potable Water												
Bone Surface-Ingestion												
730 liters	Usage by adult/yr	U	10CFR20	7.3×10^5 (ml)	which is the annual water intake of "Reference Man."							
31293 mixing - dilution	Dilution at diffuser	M	Congaree Flow	9388 cubic feet/sec								
0.3 cubic ft/sec	Average discharge	F	Effluent Flow	3.00E-01 cubic feet/sec								
4.18E-03 U-234	mRem/pCi	D-bone	EPA Limiting Values of Radioanuclide Intake.....									
3.88E-03 U-235	mRem/pCi	D-bone	FRG no 11 1988			U-234	7.66E-08	1.13E-06	2.83E-04	4.18E-03		
3.96E-03 U-236	mRem/pCi	D-bone	Exposure-to-dose conversion factors for ingestion			U-235	7.19E-08	1.05E-06	2.66E-04	3.88E-03		
3.74E-03 U-238	mRem/pCi	D-bone				U-236	7.26E-08	1.07E-06	2.69E-04	3.96E-03		
2.23E-07 Tc-99	mRem/pCi	D-bone				U-238	6.88E-08	1.01E-06	2.55E-04	3.74E-03		
12 hrs	transit time	t-p	reg guide	table E-15		Tc-99	3.95E-10	6.04E-11	1.46E-06	2.23E-07		
3.23557E-10 U-234	decay const	λ	Nuclide	T(1/2) yr	T(1/2) hr	λ						
1.12404E-13 U-235	decay const	λ	URANIUM234	2.45E+05	2.14E+09	3.24E-10						
3.38075E-12 U-236	decay const	λ	URANIUM235	7.04E+08	6.17E+12	1.12E-13						
1.77058E-14 U-238	decay const	λ	URANIUM236	2.34E+07	2.05E+11	3.38E-12						
3.71E-10 Tc-99	decay const	λ	URANIUM238	4.47E+09	3.91E+13	1.77E-14						
			TC-99	2.13E+05	1.87E+09	3.71E-10						
0.9999999961 U-234	exp(- λt_p)						U-234	3.00E-07	7.30E+05	2.19E-01	2.19E+05	50 2.28E-04
1.0000000000 U-235	exp(- λt_p)						U-235	3.00E-07	7.30E+05	2.19E-01	2.19E+05	50 2.28E-04
1.0000000000 U-236	exp(- λt_p)						U-236	3.00E-07	7.30E+05	2.19E-01	2.19E+05	50 2.28E-04
1.0000000000 U-238	exp(- λt_p)						U-238	3.00E-07	7.30E+05	2.19E-01	2.19E+05	50 2.28E-04
0.9999999955 Tc-99	exp(- λt_p)						Tc-99	6.00E-05	7.30E+05	4.38E+01	4.38E+07	50 1.14E-06
Activity Released												
3.8077E-03 total uranium(Ci)	Q	summation of liquid effluent alpha activity										
		% of activity based on current nominal uranium isotopic (see U activity tab)										
3.2407E-03 U-234 release fraction	Ci	URANIUM234	85.11%	0.8511			adult	5.00E-08	0.005	1.85E-04		
1.2527E-04 U-235 release fraction	Ci	URANIUM235	3.29%	0.0329			infant	3.70E-07	0.037	1.37E-03		
5.7116E-06 U-236 release fraction	Ci	URANIUM236	0.15%	0.0015			bone-adult	7.90E-07	0.079	2.92E-03		
4.3636E-04 U-238 release fraction	Ci	URANIUM238	11.46%	0.1146								
1.0133E-02 Tc-99 release fraction	Ci	TC-99										
check U sum	0.00381											
1.35E-05 U-234	release fraction *dose factor*exp(- λt_p)											
4.87E-07 U-235	release fraction *dose factor*exp(- λt_p)											
2.26E-08 U-236	release fraction *dose factor*exp(- λt_p)											
1.63E-06 U-238	release fraction *dose factor*exp(- λt_p)											
2.26E-09 Tc-99	release fraction *dose factor*exp(- λt_p)											
1.57E-05 all nuclides	sum of nuclides											
85.53473 usage	1100*(usage*dilution)/flow											
1.34E-03 mRem	see regulatory guide 1.109 page 1.109-2 and 1.109-3 for formula and definition of terms.											

Attachment 6

Whole Body Dose from Liquid Effluent Pathways - Aquatic Foods											
Whole Body											
21 Kg											
	Usage by adult/yr	U	see regulatory guide 1.109 page 1.109-40 table E-5, Recommended Values for U(ap)								
31293	mixing - dilution	Dilution at diffuser	M	Congaree Flow	9388	cubic feet/sec		see Nureg-1118 Environmental Assessment for renewam ... SNM-1107 May 1985			
0.3	cubic ft/sec	Average discharge	F	Effluent Flow	3.00E-01	cubic feet/sec					
2.83E-04	U-234	mRem/pCi	D	EPA Limiting Values of Radioanuclides Intake.....							
2.66E-04	U-235	mRem/pCi	D	FRG no 11 1988							
2.69E-04	U-236	mRem/pCi	D	Exposure-to-dose conversion factors for ingestion							
2.55E-04	U-238	mRem/pCi	D								
1.46E-06	Tc-99	mRem/pCi	D								
24	hrs	transit time	t-p	reg guide 1 table E-15							
3.23557E-10	U-234	decay const	λ	Nuclide	T(1/2) yr	T(1/2) hr	λ				
1.12404E-13	U-235	decay const	λ	URANIUM234	2.45E+05	2.14E+09	3.24E-10		for comparison only		
3.38075E-12	U-236	decay const	λ	URANIUM235	7.04E+08	6.17E+12	1.12E-13				
1.77058E-14	U-238	decay const	λ	URANIUM236	2.34E+07	2.05E+11	3.38E-12		Part 20 table 2 soluble forms		
3.71407E-10	Tc-99	decay const	λ	URANIUM238	4.47E+09	3.91E+13	1.77E-14		Dose Conversion		
				TC-99	2.13E+05	1.87E+09	3.71E-10			uCi/ml	milliters
0.9999999223	U-234	exp(- λ t-p)								uCi	pCi
1.0000000000	U-235	exp(- λ t-p)								mRem	mRem/pCi
0.9999999992	U-236	exp(- λ t-p)									
1.0000000000	U-238	exp(- λ t-p)									
0.999999999109	Tc-99	exp(- λ t-p)									
Activity Released									ICRP 69 Comparison		
3.8077E-03 total uranium(Ci)	Q	summation of liquid effluent alpha activity									
		% of activity based on current nominal uranium isotopic (see U activity tab)							Sv/Bq	Rem/Bq	mRem/pCi
3.2407E-03	U-234 release fraction	Ci	URANIUM234 .. 85.11%	0.8511							
1.2527E-04	U-235 release fraction	Ci	URANIUM235 .. 3.29%	0.0329					adult	5.00E-08	0.005
5.7116E-06	U-236 release fraction	Ci	URANIUM236 .. 0.15%	0.0015					infant	3.70E-07	0.037
4.3636E-04	U-238 release fraction	Ci	URANIUM238 .. 11.46%	0.1146					bone-adult	7.90E-07	0.079
1.0133E-02	Tc-99 release fraction	Ci	TC-99								
check U sum		0.00381									
1.84E-06	U-234	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)			2			BNWL-2075			
6.67E-08	U-235	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)			2			UC-11			
3.07E-09	U-236	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)			2			Methodology for Calculation of Radiation Doses			
2.22E-07	U-238	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)			2			in the Environs from Nuclear Fuel			
2.22E-07	Tc-99	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)			15			Cycle Facilities			
2.35E-06	all nuclides	sum of nuclides									
2.46059	usage	1100*(usage*dilution)/flow									
5.78E-06	mRem	see regulatory guide 1.109 page 1.109-2 and 1.109-3 for formula and definition of terms.									

Attachment 7

Dose to the Bone Surface from Liquid Effluent Pathways - Aquatic Foods											
Bone Surface											
21 Kg	Usage by adult/yr	U	see regulatory guide 1.109 page 1.109-40 table E-5, Recommended Values for U(ap)								
31293 mixing - dilution	Dilution at diffuser	M	Congaree Flow	9388 cubic feet/sec		see Nureg-1118 Environmental Assessment for renewam ...SNM-1107 May 1985					
0.3 cubic ft/sec	Average discharge	F	Effluent Flow	3.00E-01 cubic feet/sec							
4.18E-03 U-234	mRem/pCi	D	EPA Limiting Values of Radioanuclide Intake.....				effective	bone	effective	bone	
3.88E-03 U-235	mRem/pCi	D	FRG no 11 1988		U-234	7.66E-08	1.13E-06	2.83E-04	4.18E-03		
3.96E-03 U-236	mRem/pCi	D	Exposure-to-dose conversion factors for ingestion		U-235	7.19E-08	1.05E-06	2.66E-04	3.88E-03		
3.74E-03 U-238	mRem/pCi	D			U-236	7.26E-08	1.07E-06	2.69E-04	3.96E-03		
2.23E-07 Tc-99	mRem/pCi	D			U-238	6.88E-08	1.01E-06	2.55E-04	3.74E-03		
					Tc-99	3.95E-10	6.04E-11	1.46E-06	2.23E-07		
24 hrs	transit time	t-p	reg guide 1.109	table E-15							
3.23557E-10 U-234	decay const	λ	Nuclide		T(1/2) yr	T(1/2) hr	λ		for comparison only		
1.12404E-13 U-235	decay const	λ	URANIUM234		2.45E+05	2.14E+09	3.24E-10				
3.38075E-12 U-236	decay const	λ	URANIUM235		7.04E+08	6.17E+12	1.12E-13		Part 20 table 2	soluble forms	
1.77058E-14 U-238	decay const	λ	URANIUM236		2.34E+07	2.05E+11	3.38E-12		Dose Conversion		
3.71407E-10 Tc-99	decay const	λ	URANIUM238		4.47E+09	3.91E+13	1.77E-14				
			TC-99		2.13E+05	1.87E+09	3.71E-10		uCi/ml	milliters	uCi pCi mRem mRem/pCi
0.99999999223 U-234	exp(- λ t-p)							U-234	3.00E-07	7.30E+05	2.19E-01 2.19E+05
1.00000000000 U-235	exp(- λ t-p)							U-235	3.00E-07	7.30E+05	2.19E-01 2.19E+05
0.99999999992 U-236	exp(- λ t-p)							U-236	3.00E-07	7.30E+05	2.19E-01 2.19E+05
1.00000000000 U-238	exp(- λ t-p)							U-238	3.00E-07	7.30E+05	2.19E-01 2.19E+05
0.999999999109 Tc-99	exp(- λ t-p)							Tc-99	6.00E-05	7.30E+05	4.38E+01 4.38E+07
									ICRP 69 Comparison		
Activity Released											
3.8077E-03 total uranium(C) Q	summation of liquid effluent alpha activity								Sv/Bq	Rem/Bq	mRem/pCi
	% of activity based on current nominal uranium isotopic (see U activity tab)										
3.2407E-03 U-234 release fr/Ci	URANIUM234	85.11%	0.8511					adult	5.00E-08	0.005	1.85E-04
1.2527E-04 U-235 release fr/Ci	URANIUM235	3.29%	0.0329					infant	3.70E-07	0.037	1.37E-03
5.7116E-06 U-236 release fr/Ci	URANIUM236	0.15%	0.0015					bone-adult	7.90E-07	0.079	2.92E-03
4.3636E-04 U-238 release fr/Ci	URANIUM238	11.46%	0.1146								
1.0133E-02 Tc-99 release fr/Ci	TC-99										
check U sum	0.00381										
2.71E-05 U-234	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)						bioaccumulation factor	BNWL-2075			
9.73E-07 U-235	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)							UC-11			
4.52E-08 U-236	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)							Methodology for Calculation of Radiation Doses			
3.26E-06 U-238	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)							in the Environs from Nuclear Fuel			
3.40E-08 Tc-99	release fraction *bioaccumulation factor*dose factor*exp(- λ t-p)							Cycle Facilities			
3.14E-05 all nuclides	sum of nuclides										
2.46059 usage	1100*(usage/dilution)/flow										
7.73E-05 mRem	see regulatory guide 1.109 page 1.109-2 and 1.109-3 for formula and definition of terms.										

Attachment 9

2014 Isotopic Fractions

Based on the plant nominal enrichment for 2014

Nuclide	Average wt%	Specific Activity Ci/g	Weighted Activity	% Activity
U-234	0.038	6.220E-03	2.388E-04	85.11
U-235	4.273	2.160E-06	9.230E-06	3.29
U-236	0.006	6.470E-05	4.076E-07	0.15
U-238	95.682	3.360E-07	3.215E-05	11.46
Total	100.000		2.806E-04	100.000

Attachment 10

COMPLY: V1.6.

2/20/2015 3:47

40 CFR Part 61
National Emission Standards
for Hazardous Air Pollutants

REPORT ON COMPLIANCE WITH
THE CLEAN AIR ACT LIMITS FOR RADIONUCLIDE EMISSIONS
FROM THE COMPLY CODE - V1.6.

Prepared by:

Westinghouse Electric Company
Columbia Fuel Fabrication Facility
5801 Bluff Rd. Hopkins, SC 29061

David Wagoner
803.647.1919

Prepared for:

U.S. Environmental Protection Agency
Office of Radiation and Indoor Air
Washington, DC 20460

2014 Annual Dose to the Public due to Gaseous Effluent

SCREENING LEVEL 2

DATA ENTERED:

RELEASE RATES FOR STACK 1.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 4.770E-13
U-235	Y 1.840E-14
U-238	Y 6.420E-14

RELEASE RATES FOR STACK 2.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 5.180E-13
U-235	Y 2.000E-14
U-238	Y 6.980E-14

RELEASE RATES FOR STACK 3.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 2.000E-12
U-235	Y 7.750E-14
U-238	Y 2.700E-13

RELEASE RATES FOR STACK 4.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 3.630E-12
U-235	Y 1.400E-13
U-238	Y 4.890E-13

RELEASE RATES FOR STACK 5.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 6.190E-13
U-235	Y 2.390E-14
U-238	Y 8.330E-14

RELEASE RATES FOR STACK 6.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 1.530E-12
U-235	Y 5.910E-14
U-238	Y 2.060E-13

RELEASE RATES FOR STACK 7.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 8.650E-13
U-235	Y 3.340E-14
U-238	Y 1.160E-13

RELEASE RATES FOR STACK 8.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 1.020E-12
U-235	Y 3.930E-14
U-238	Y 1.370E-13

SITE DATA FOR STACK 1.

Release height 10 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 2.

Release height 11 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 3.

Release height 12 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 4.

Release height 13 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 5.

Release height 15 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 6.

Release height 16 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 7.

Release height 17 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 8.

Release height 18 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

Default mean wind speed used (2.0 m/sec).

NOTES:

Input parameters outside the "normal" range:

Building (width) is unusually WIDE.

Receptor is unusually FAR.

RESULTS:

Effective dose equivalent: 0.2 mrem/yr.

*** Comply at level 2.

This facility is in COMPLIANCE.

It may or may not be EXEMPT from reporting to the EPA.

You may contact your regional EPA office for more information.

***** END OF COMPLIANCE REPORT *****

COMPLY: V1.6.

2/20/2015 4:11

40 CFR Part 61
National Emission Standards
for Hazardous Air Pollutants

REPORT ON COMPLIANCE WITH
THE CLEAN AIR ACT LIMITS FOR RADIONUCLIDE EMISSIONS
FROM THE COMPLY CODE - V1.6.

Prepared by:

Westinghouse Electric Company
Columbia Fuel Fabrication Facility
5801 Bluff Rd. Hopkins, SC 29061

David Wagoner
803.647.1919

Prepared for:

U.S. Environmental Protection Agency
Office of Radiation and Indoor Air
Washington, DC 20460

Hot Oil Room Exhaust

SCREENING LEVEL 2

DATA ENTERED:

Nuclide	Release Rate (curies/SECOND)
U-234	Y 1.170E-12
U-235	Y 4.510E-14
U-238	Y 1.570E-13

Release height 12 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

Default mean wind speed used (2.0 m/sec).

NOTES:

Input parameters outside the "normal" range:

Building (width) is unusually WIDE.
Receptor is unusually FAR.

RESULTS:

Effective dose equivalent: 2.3E-02 mrem/yr.

*** Comply at level 2.

This facility is in COMPLIANCE.

It may or may not be EXEMPT from reporting to the EPA.

You may contact your regional EPA office for more information.

***** END OF COMPLIANCE REPORT *****

Attachment G



Westinghouse Electric Company
 Nuclear Fuel
 Columbia Fuel Site
 5801 Bluff Rd
 Hopkins, South Carolina 29061
 USA

To: Cynthia Logsdon	Direct tel: 803-647-1919
	Direct fax: 803-695-4158
	e-mail: wagoneda@westinghouse.com
	Your ref:
	Our ref: LTR-EHS-15-62
Cc: John Howell, Carl Snyder, Nancy Parr, Anna Pearson, Diana Joyner, Sherrie Culler	August 21, 2015

2015 Semi-Annual Assessment of Public Dose from Liquid and Gaseous Effluents

Effluents released from plant operations are monitored to determine the quantities of radionuclides discharged into the environment. The cumulative radioactivity released is summarized semi-annually and annually and input into dose models developed by the NRC and EPA to estimate the dose to the public.

The whole body and organ dose via the following pathways is determined in this assessment:

- Dose due to Gaseous Effluents by Direct Inhalation
 - The whole body dose was estimated using EPA's COMPLY Code at level 2 complexity. The organ dose was estimated by calculating the X/Q factor using the results of the COMPLY analysis for stack #1212 (S1030A), the measured release quantity, and the dose conversion factors from Federal Guidance Report No 11, "Limiting Values of Radionuclide Intake and Air concentration Factors for Inhalation, Submersion, and Ingestion" (FGR 11).
- Dose due to Liquid Effluents by Ingestion of Potable Water
 - Estimated using equations and recommended values in Regulatory Guide 1.109 (RG 1.109). Dose conversion factors are referenced from FGR 11.
- Dose due to Liquid Effluents by Ingestion of Fish
 - Estimated using equations and recommended values in RG 1.109. Dose conversion factors are referenced from FGR 11.
- Dose due to Liquid Effluents by Irradiation from Shoreline Deposition
 - Estimated using equations and recommended values in RG 1.109. Dose conversion factors are referenced from Federal Guidance report No 12, "External Exposure to Radionuclides in Air, Water, and Soil."

The inhalation dose is determined at the nearest site boundary at a distance of 595 meters. The ingestion dose from liquid effluent and external dose from sediment deposition is determined at the point at which the liquid effluent leaves the diffuser in the Congaree River.

The release rates for gaseous effluent are determined by gross alpha measurements performed on daily air samples, one per stack for 48 stacks (Attachment 1). The release rates for liquid effluent are determined by isotopic analysis of liquid effluent samples taken monthly (Attachment 3). Based on these results, the following quantities were released in the 1st half of calendar year 2015:

- 169.6 μCi of Uranium in gaseous effluent
- 1.63 mCi of Uranium in liquid effluent
- 3.70 mCi of Technetium in liquid effluent

Using these results and the methods previously mentioned the whole body dose, dose to the bone, and dose to the lung were determined for an individual present at the nearest site boundary. Table 1 provides a summary of the results for each pathway. The gaseous and liquid effluents released during the 1st half of 2015 resulted in a potential whole body dose of 0.08 mrem and a lung dose of 0.60 mrem to an individual present at the nearest site boundary. The dose to the bone is negligible. These doses are well below the 12.5 mrem (1/2 of the 25 mrem annual dose limit) and the 5 mrem ALARA limit (1/2 of 10 mrem annual ALARA limit) for a member of the public.

Table 1. 2015 Semi-Annual Dose to the Public from Liquid and Gaseous Effluents

	Whole Body Dose (mrem/6 months)	Organ Dose - Bone (mrem/6 months)	Organ Dose - Lung (mrem/6 months)
Gaseous Effluents			
Direct inhalation*	0.08	2.26E-03	0.60
Liquid Effluents			
Potable Water	1.98E-05	2.87E-04	-
Aquatic Food (Fish)	1.26E-06	1.65E-05	-
Shoreline Deposition	6.46E-10	-	-
<i>Total (mrem/6 months)</i>	<i>0.08</i>	<i>2.56E-03</i>	<i>0.60</i>


* Assumes 80 % residence time

There were no significant changes in source material or chemical form between 2014 and the 1st half of 2015. One release point, the Waterglass scrubber, was added to the air effluent monitoring program during the 1st half of 2015. Effluents from this release point are less than 1% of the total release quantity and are not expected to be a significant contributor. The attachments below illustrate the method used to calculate each result listed in Table 1. The annual dose calculation will be completed when the data is available for the entire calendar year.

- Attachment 1: 1st Half 2015 Gaseous Effluent Discharges
- Attachment 2: Lung/Bone Organ Dose due to Gaseous Effluent
- Attachment 3: 1st Half 2015 Liquid Effluent Discharges
- Attachment 4: Whole Body Dose from Liquid Effluent Pathways - Potable Water
- Attachment 5: Dose to the Bone Surface from Liquid Effluent Pathways - Potable Water
- Attachment 6: Whole Body Dose from Liquid Effluent Pathways - Aquatic Foods
- Attachment 7: Dose to the Bone Surface from Liquid Effluent Pathways - Aquatic Foods
- Attachment 8: Whole Body Dose from Liquid Effluent Pathways – Shoreline Deposits
- Attachment 9: 2015 Isotopic Fractions
- Attachment 10: Comply Results



David Wagoner
Radiation Safety Engineer
EH&S Operations



Review by: Anna Pearson
Manager, RSO
EH&S Operations

Attachment 2

Lung/Bone Organ Dose due to Gaseous Effluents			Total	EPA					
STACK IDENTIFICATION	1st half (Jan-Jun) uCi Uranium S1030A	2nd half (Jul-Dec) uCi Uranium N/A	uCi released 14.23	Comply Run Results Dose (mrem/yr) Stack height (m)	1.50E-02 16				
use highest release to calculate X/Q used by COMPLY				Release Rate (Ci/s)	7.75E-13	U-234	U-235	U-238	1.00E-13
Dose from comply release quantity	0.00750	mrem/6 mo							
Inhalation from RG1.109	14.23	uCi							
App E table E-5	1.42E-05	Ci							
Effective Dose conversion	4000.00	m3/6 mo							
EPA FGR 11 p150-151									
U-234	3.58E-05	Sv/Bq		85.64%					
U-235	3.32E-05	Sv/Bq		3.15%					
U-238	3.20E-05	Sv/Bq		11.07%					
weighted dose conversion	3.52E-05	Sv/Bq							
conversion factor	3700.00	mrem/pCi= factor* Sv/Bq							
weighted dose conversion	0.1304	mrem/pCi							
			equations						
Dose (mrem) = R(a)*3.17e4*Q*(X/Q)*effective Dose conversion			see RG1.109-25						
Dose (mrem)/(R(a)*3.17e4*Q*effective Dose conversion)=(X/Q)									
	3.19E-05	X/Q							
Estimate Lung Dose using X/Q and semi-annual releases for 2015			Estimate Bone Dose using X/Q and semi-annual releases for 2015						
App E table E-5									
Lung Organ Dose conversion									
EPA FGR 11 p150-151									
U-234	2.98E-04	Sv/Bq		85.64%	1.13E-06	Sv/Bq			
U-235	2.76E-04	Sv/Bq		3.15%	1.05E-06	Sv/Bq			
U-238	2.66E-04	Sv/Bq		11.07%	1.01E-06	Sv/Bq			
weighted dose conversion	2.93E-04	Sv/Bq			1.11E-06	Sv/Bq			
conversion factor	3700.00	mrem/pCi= factor* Sv/Bq			3700.00	mrem/pCi= factor* Sv/Bq			
weighted dose conversion	1.0854	mrem/pCi			4.12E-03	mrem/pCi			
release quantity	169.65	uCi/6 mo			169.65	uCi/6 mo			
	1.70E-04	Ci/6 mo			1.70E-04	Ci/6 mo			
Lung *	0.60	mrem/6 mo	Bone *	2.26E-03	mrem/6 mo				
assume 80% residence									

2015

Attachment 3 - 1st Half 2015 Liquid Effluent Discharges

	Liquid Effluent Discharges			Isotopic Uranium Measured Concentrations				Tc-99 Measured Concentrations	Sum U & Tc-99	Total uCi/month Released (based on monthly GEL discharge samples)				Measurement Uncertainty / Error				Uncertainty / Error					
Month	Average kgal/day	Actual kgal/month	Actual gal/month	U234 pCi/L	U235 pCi/L	U238 pCi/L	Total U pCi/L	Tc-99 pCi/L	Total U & Tc-99 pCi/L	U234	U-235	U-238	Tc-99	U234 pCi/L	U235 pCi/L	U238 pCi/L	Tc-99 pCi/L	U234 (uCi)	U-235 (uCi)	U-238 (uCi)	Tc-99 (uCi)		
JAN	104.160	3020.650	3,020,650	19.8	1.100	3.21	24,110	138	162,110	226.377	12.576	36,700	1577.776	1.57	0.417	0.644	118	17,950	4,768	7,363	1349,113		
FEB	86,000	2407.890	2,407,890	20.8	1.29	3.11	25,200	0.00	25,200	189.568	11.757	28,344	0.000	2.54	0.729	0.997	119	23,149	6,644	9,087	1084,550		
MAR	123,570	3707.010	3,707,010	21.9	1.22	3.56	26,680	0.00	26,680	307.280	17.118	49,950	0.000	2.23	0.606	0.909	119	31,289	8,503	12,754	1669,693		
APR	104,110	2811.010	2,811,010	25.5	1.01	3.53	30,040	67.9	97,940	271.312	10.746	37,558	722.434	2.62	0.610	0.984	120	27,876	6,490	10,469	1278,761		
MAY	97,570	2051.160	2,051,160	21.1	0.807	2.87	24,777	25.4	50,177	163.813	6.265	22,282	187.196	2.43	0.588	0.908	127	18,866	4,565	7,049	985,982		
JUNE	108,880	3266.300	3,266,300	16.4	0.663	2.06	19,123	96.9	116,023	202.752	8.197	25,468	1197.969	2.39	0.576	0.882	142	29,547	7,121	10,904	1755,538		
Total (Jan-June)				17264.020	17,264,020					1361.101	66.659	200.302	3695.376					149	38	58	8122		
Liters (L)				6.53E+07								1628.1	3695.376										
Milliliters (ml)				6.53E+10								uCi Uranium for 6-month period (all types)											
												5323.4											
												uCi Uranium & Tc-99 for 6-month period											

FIRST HALF LIQUID DISCHARGES

Radionuclide	LLD (uCi/ml)	Quantity Released (uCi)	Error	Average Concentration Released (uCi/ml)
U234	6.00E-10	1361.1	+/-	2.08E-08
U235	6.00E-10	66.7	+/-	1.02E-09
U238	6.00E-10	200.3	+/-	3.07E-09
Total U		1628.1		2.49E-08
Tc-99	6.00E-10	3695.4	+/-	5.66E-08
Total (Jan-June)		5323.4		1.06E-07

Attachment 5

Dose to the Bone Surface from Liquid Effluent Pathways - Potable Water									
Bone Surface-Ingestion									
365 liters	Usage by adult/6 mU	10CFR20	7.3×10^5 (ml) which is the annual water intake of "Reference Man."						
31293 mixing - dilution	Dilution at diffuser	M	Congaree Flow	9388 cubic feet/sec		see Nureg-1118 Environmental Assessment for renewam ...SNM-1107 May 1985			
0.3 cubic ft/sec	Average discharge	F	Effluent Flow	3.00E-01 cubic feet/sec			effective bone	effective bone	
4.18E-03 U-234	mRem/pCi	D-bone	EPA Limiting Values of Radioanuclide Intake.....		Sv/Bq	Sv/Bq	mRem/pCi	mRem/pCi	
3.88E-03 U-235	mRem/pCi	D-bone	FRG no 11 1988		U-234	7.66E-08	1.13E-06	2.83E-04	4.18E-03
3.96E-03 U-236	mRem/pCi	D-bone	Exposure-to-dose conversion factors for ingestion		U-235	7.19E-08	1.05E-06	2.66E-04	3.88E-03
3.74E-03 U-238	mRem/pCi	D-bone			U-236	7.26E-08	1.07E-06	2.69E-04	3.96E-03
2.23E-07 Tc-99	mRem/pCi	D-bone			U-238	6.88E-08	1.01E-06	2.55E-04	3.74E-03
12 hrs	transit time	t-p	reg guide 1 table E-15		Tc-99	3.95E-10	6.04E-11	1.46E-06	2.23E-07
3.23557E-10 U-234	decay const	λ	Nuclide	T(1/2) yr	T(1/2) hr	λ			
1.12404E-13 U-235	decay const	λ	URANIUM234	2.45E+05	2.14E+09	3.24E-10			
3.38075E-12 U-236	decay const	λ	URANIUM235	7.04E+08	6.17E+12	1.12E-13		Part 20 table 2	soluble forms
1.77058E-14 U-238	decay const	λ	URANIUM236	2.34E+07	2.05E+11	3.38E-12		Dose Conversion	
3.71407E-10 Tc-99	decay const	λ	URANIUM238	4.47E+09	3.91E+13	1.77E-14			
		TC-99		2.13E+05	1.87E+09	3.71E-10			
0.9999999961 U-234	exp(- λ t-p)						uCi/ml	milliters	uCi
1.0000000000 U-235	exp(- λ t-p)						pCi	mRem	mRem/pCi
1.0000000000 U-236	exp(- λ t-p)								
1.0000000000 U-238	exp(- λ t-p)								
0.9999999955 Tc-99	exp(- λ t-p)								
ICRP 69 Comparison									
Activity Released									
1.628E-03 total uranium(Ci)	Q	summation of liquid effluent alpha activity					Sv/Bq	Rem/Bq	mRem/pCi
		% of activity based on current nominal uranium isotopic (see U activity tab)							
1.3942E-03 U-234 release fraction	Ci	URANIUM234	85.64%				adult	5.00E-08	0.005
5.1282E-05 U-235 release fraction	Ci	URANIUM235	3.15%				infant	3.70E-07	0.037
2.2792E-06 U-236 release fraction	Ci	URANIUM236	0.14%				bone-adult	7.90E-07	0.079
1.8022E-04 U-238 release fraction	Ci	URANIUM238	11.07%						
5.323E-03 Tc-99 release fraction	Ci	TC-99							
check U sum		0.00163							
5.83E-06 U-234	release fraction *dose factor*exp(- λ *tp)								
1.99E-07 U-235	release fraction *dose factor*exp(- λ *tp)								
9.02E-09 U-236	release fraction *dose factor*exp(- λ *tp)								
6.73E-07 U-238	release fraction *dose factor*exp(- λ *tp)								
1.19E-09 Tc-99	release fraction *dose factor*exp(- λ *tp)								
6.71E-06 all nuclides	sum of nuclides								
42.76736 usage	1100*(usage*dilution)/flow								
2.87E-04 mRem	see regulatory guide 1.109 page 1.109-2 and 1.109-3 for formula and definition of terms.								

Attachment 9

2015 Isotopic Fractions

Based on the plant nominal enrichment for 2015

Nuclide	Average wt%	Specific Activity Ci/g	Weighted Activity	% Activity
U-234	0.04	6.220E-03	2.488E-04	85.64
U-235	4.24	2.160E-06	9.154E-06	3.15
U-236	0.01	6.470E-05	4.076E-07	0.14
U-238	95.72	3.360E-07	3.216E-05	11.07
Total	100.00		2.905E-04	100.00

Attachment 10 - COMPLY Results

COMPLY: v1.6.

8/21/2015 3:43

40 CFR Part 61
National Emission Standards
for Hazardous Air Pollutants

REPORT ON COMPLIANCE WITH
THE CLEAN AIR ACT LIMITS FOR RADIONUCLIDE EMISSIONS
FROM THE COMPLY CODE - V1.6.

Prepared by:

Westinghouse Electric Company
Columbia Fuel Fabrication Facility
5801 Bluff Rd. Hopkins, SC 29061

David Wagoner
803.647.1919

Prepared for:

U.S. Environmental Protection Agency
Office of Radiation and Indoor Air
Washington, DC 20460

2015 Semi-Annual Dose to the Public Due to Gaseous Effluent

SCREENING LEVEL 2

DATA ENTERED:

RELEASE RATES FOR STACK 1.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 3.900E-13
U-235	Y 1.430E-14
U-238	Y 5.040E-14

RELEASE RATES FOR STACK 2.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 3.450E-13
U-235	Y 1.270E-14
U-238	Y 4.460E-14

RELEASE RATES FOR STACK 3.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 1.430E-12
U-235	Y 5.260E-14
U-238	Y 1.850E-13

RELEASE RATES FOR STACK 4.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 3.390E-12
U-235	Y 1.250E-13
U-238	Y 4.380E-13

RELEASE RATES FOR STACK 5.

Nuclide	Release Rate (curies/SECOND)
U-234	Y 6.310E-13
U-235	Y 2.320E-14
U-238	Y 8.150E-14

RELEASE RATES FOR STACK 6.

Nuclide		Release Rate (curies/SECOND)
U-234	Y	1.260E-12
U-235	Y	4.630E-14
U-238	Y	1.630E-13

RELEASE RATES FOR STACK 7.

Nuclide		Release Rate (curies/SECOND)
U-234	Y	8.070E-13
U-235	Y	2.970E-14
U-238	Y	1.040E-13

RELEASE RATES FOR STACK 8.

Nuclide		Release Rate (curies/SECOND)
U-234	Y	9.900E-13
U-235	Y	3.640E-14
U-238	Y	1.280E-13

SITE DATA FOR STACK 1.

Release height 10 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 2.

Release height 11 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 3.

Release height 12 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 4.

Release height 13 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 5.

Release height 15 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 6.

Release height 16 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 7.

Release height 17 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

SITE DATA FOR STACK 8.

Release height 18 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

Default mean wind speed used (2.0 m/sec).

NOTES:

Input parameters outside the "normal" range:

Building (width) is unusually WIDE.
Receptor is unusually FAR.

RESULTS:

Effective dose equivalent: 0.2 mrem/yr.

*** Comply at level 2.

This facility is in COMPLIANCE.

It may or may not be EXEMPT from reporting to the EPA.

You may contact your regional EPA office for more information.

***** END OF COMPLIANCE REPORT *****

COMPLY: v1.6.

8/21/2015 3:59

40 CFR Part 61
National Emission Standards
for Hazardous Air Pollutants

REPORT ON COMPLIANCE WITH
THE CLEAN AIR ACT LIMITS FOR RADIONUCLIDE EMISSIONS
FROM THE COMPLY CODE - V1.6.

Prepared by:

Westinghouse Electric Company
Columbia Fuel Fabrication Facility
5801 Bluff Rd. Hopkins, SC 29061

David Wagoner
803.647.1919

Prepared for:

U.S. Environmental Protection Agency
Office of Radiation and Indoor Air
Washington, DC 20460

S1030A

SCREENING LEVEL 2

DATA ENTERED:

Nuclide	Release Rate (curies/SECOND)
U-234	Y 7.750E-13
U-235	Y 2.850E-14
U-238	Y 1.000E-13

Release height 16 meters.

Building height 9 meters.

The source and receptor are not on the same building.

Distance from the source to the receptor is 595 meters.

Building width 137 meters.

Default mean wind speed used (2.0 m/sec).

NOTES:

Input parameters outside the "normal" range:

Building (width) is unusually WIDE.
Receptor is unusually FAR.

RESULTS:

Effective dose equivalent: 1.5E-02 mrem/yr.

*** Comply at level 2.

This facility is in COMPLIANCE.

It may or may not be EXEMPT from reporting to the EPA.

You may contact your regional EPA office for more information.

***** END OF COMPLIANCE REPORT *****

Attachment H

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W3A	Mar-04	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
W3A	Jun-05	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W3A	Jun-06	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W3A	Jun-07	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W3A	Mar-08	NA	NA	NA	NA	NA	NA	0.11	2.10	1.53	NA	NA	NA
	Jun-08	NA	NA	NA	NA	NA	NA	0.15	2.98	2.39	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	0.14	2.46	0.00	NA	NA	NA
	Dec-08	<1.0	<1.0	<1.0	<2.0	<0.50	<1.00	0.03	0.30	2.48	<5.0	NA	NA
W3A	Mar-09	NA	NA	NA	NA	<0.50	4.92	0.22	0.90	0.02	NA	NA	NA
	Jun-09	NA	NA	NA	NA	<0.50	<1.00	0.11	0.76	0.00	NA	NA	NA
	Sep-09	NA	NA	NA	NA	<0.50	<1.00	0.13	2.76	6.17	NA	NA	NA
	Dec-09	NA	NA	NA	NA	<0.50	<1.00	NA	0.65	0.00	NA	NA	NA
W3A	Mar-10	NA	NA	NA	NA	<0.50	<1.00	49.00	1.27	<0.001	NA	NA	NA
	Jun-10	<1.00	<1.00	<1.00	<2.00	<0.50	<1.00	0.12	2.66	10.70	NA	NA	NA
	Sep-10	NA	NA	NA	NA	<0.50	<1.00	0.08	2.94	1.20	NA	NA	NA
	Dec-10	NA	NA	NA	NA	<0.50	<1.00	<0.02	2.02	3.16	NA	NA	NA
W3A	Apr-11	NA	NA	NA	NA	<0.50	<1.00	<0.02	0.28	0.00	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	<1.00	<0.02	0.86	2.07	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	<0.02	2.33	1.32	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	<0.02	1.81	0.17	NA	NA	NA
W3A	Mar-12	NA	NA	NA	NA	<0.50	0.05	0.04	2.86	1.00	NA	NA	NA
	Jun-12	NA	NA	NA	NA	<0.50	<1.00	<0.02	1.33	1.52	NA	NA	NA
	Sep-12	NA	NA	NA	NA	<0.50	<1.00	N/A	1.35	0.00	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	<1.00	<0.02	0.00	0.73	NA	NA	NA
W3A	Mar-13	NA	NA	NA	NA	<0.50	<1.00	<0.02	0.46	4.85	NA	NA	NA
	Jun-13	NA	NA	NA	NA	<0.50	<1.00	<0.02	2.65	1.25	NA	NA	NA
	Oct-13	NA	NA	NA	NA	<0.50	<1.00	<0.02	<0.77	<0.31	NA	NA	NA
W7	Feb/Mar 04	<1.0	<1.0	<1.0	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	18.60	33.30	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	17.20	45.00	NA	NA	NA	NA	NA	NA
	Dec-04	1.30	<1.0	<1.0	<2.0	19.60	0.97	38.80	9.00	97.00	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W7	Jun-05	NA	NA	NA	NA	16.00	45.80	41.50	5.00	175.00	NA	NA	NA
	Dec-05	NA	NA	NA	NA	17.70	39.80	240.00	8.00	240.00	NA	NA	NA
W7	Jun-06	<1.0	<1.0	<1.0	<2.0	15.20	54.30	42.70	5.00	127.00	NA	NA	NA
	Dec-06	NA	NA	NA	NA	16.00	52.30	48.80	1.00	215.00	NA	NA	NA
W7	Jun-07	1.30	<1.0	<1.0	<2.0	13.00	54.20	53.30	2.00	141.00	NA	NA	NA
	Dec-07	NA	NA	NA	NA	17.00	45.10	46.90	2.00	195.00	NA	NA	NA
W7	Mar-08	NA	NA	NA	NA	NA	NA	42.60	14.80	234.00	NA	NA	NA
	Jun-08	1.20	<1.0	<1.0	<2.0	11.30	46.30	43.60	1.00	143.00	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	38.70	1.27	139.00	NA	NA	NA
	Dec-08	<1.0	<1.0	<1.0	<2.0	12.20	34.00	35.60	1.10	171.00	5.0	4.1	166.9
W7	Mar-09	NA	NA	NA	NA	12.85	51.50	40.10	26.10	122.00	NA	NA	NA
	Jun-09	NA	NA	NA	NA	29.40	46.00	35.70	0.35	214.00	NA	NA	NA
	Sep-09	NA	NA	NA	NA	12.45	63.10	40.50	9.95	211.00	NA	NA	NA
	Dec-09	NA	NA	NA	NA	14.75	48.00	43.00	7.29	169.00	NA	NA	NA
W7	Mar-10	NA	NA	NA	NA	12.30	64.00	NA	NA	NA	NA	NA	NA
	Jun-10	NA	NA	NA	NA	11.90	52.00	63.00	4.21	153.00	NA	NA	NA
	Sep-10	NA	NA	NA	NA	9.50	58.00	90.00	1.30	215.00	NA	NA	NA
	Dec-10	NA	NA	NA	NA	10.20	49.00	130.00	5.72	212.00	NA	NA	NA
W7	Apr-11	NA	NA	NA	NA	7.60	52.00	<20.00	3.24	136.00	NA	NA	NA
	Jun-11	NA	NA	NA	NA	7.60	53.00	150.00	5.63	146.00	NA	NA	NA
	Sep-11	NA	NA	NA	NA	7.60	45.00	140.00	7.78	112.00	NA	NA	NA
	Dec-11	NA	NA	NA	NA	8.55	59.40	130.00	9.03	185.00	NA	NA	NA
W7	Mar-12	NA	NA	NA	NA	8.40	54.80	140.00	10.30	199.00	NA	NA	NA
	Jun-12	NA	NA	NA	NA	9.05	51.60	120.00	5.80	92.70	NA	NA	NA
	Sep-12	NA	NA	NA	NA	8.35	40.40	74.00	4.82	102.00	NA	NA	NA
	Dec-12	NA	NA	NA	NA	8.60	53.50	91.00	6.43	181.00	NA	NA	NA
W7	Mar-13	NA	NA	NA	NA	8.95	45.90	120.00	5.35	135.00	NA	NA	NA
	Jun-13	NA	NA	NA	NA	6.75	51.00	140.00	2.24	102.00	NA	NA	NA
	Oct-13	NA	NA	NA	NA	8.15	55.90	160.00	5.12	164.00	NA	NA	NA
W10	Feb/Mar-04	<1.0	<1.0	<1.0	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	5.16	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	4.10	6.26	NA	NA	NA	NA	NA	NA
	Dec-04	<1.0	<1.0	<1.0	<2.0	5.64	6.85	25.00	6.00	25.00	NA	NA	NA
W10	Jun-05	NA	NA	NA	NA	1.70	4.70	22.90	7.00	28.00	NA	NA	NA
	Dec-05	NA	NA	NA	NA	7.00	6.90	29.80	4.00	58.00	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W10	Jun-06	NA	NA	NA	NA	7.40	3.70	26.80	6.00	63.00	NA	NA	NA
	Dec-06	NA	NA	NA	NA	5.10	2.50	31.40	0.00	77.00	NA	NA	NA
W10	Jun-07	NA	NA	NA	NA	5.10	7.60	43.40	3.00	72.00	NA	NA	NA
	Dec-07	NA	NA	NA	NA	4.80	14.00	11.80	4.00	70.00	NA	NA	NA
W10	Mar-08	NA	NA	NA	NA	NA	NA	16.00	5.71	65.70	NA	NA	NA
	Jun-08	NA	NA	NA	NA	0.50	1.10	17.20	3.00	41.00	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	11.20	0.65	28.30	NA	NA	NA
	Dec-08	<1.0	<1.0	<1.0	<2.0	2.90	2.00	10.50	0.52	47.60	<5.0	NA	NA
W10	Mar-09	NA	NA	NA	NA	3.50	1.40	15.30	3.83	34.30	NA	NA	NA
	Jun-09	NA	NA	NA	NA	3.14	2.00	13.50	0.68	38.80	NA	NA	NA
	Sep-09	NA	NA	NA	NA	3.36	3.40	18.60	2.46	46.10	NA	NA	NA
	Dec-09	NA	NA	NA	NA	3.93	3.00	19.00	2.48	43.30	NA	NA	NA
W10	Mar-10	NA	NA	NA	NA	3.10	7.00	NA	NA	NA	NA	NA	NA
	Jun-10	<1.0	<1.0	<1.0	<2.0	3.07	3.00	34.00	3.55	70.20	NA	NA	NA
	Sep-10	<1.0	<1.0	<1.0	<2.0	3.40	7.00	47.00	4.35	78.80	NA	NA	NA
	Dec-10	NA	NA	NA	NA	4.86	11.00	24.00	0.34	55.20	NA	NA	NA
W10	Apr-11	NA	NA	NA	NA	6.75	4.00	<20.00	1.48	86.80	NA	NA	NA
	Jun-11	NA	NA	NA	NA	3.22	3.00	44.00	5.49	81.70	NA	NA	NA
	Sep-11	NA	NA	NA	NA	4.60	12.00	41.00	5.08	77.80	NA	NA	NA
	Dec-11	NA	NA	NA	NA	4.19	15.20	27.00	6.22	99.30	NA	NA	NA
W10	Mar-12	NA	NA	NA	NA	4.15	10.40	35.00	6.12	117.00	NA	NA	NA
	Jun-12	NA	NA	NA	NA	4.23	2.21	39.00	2.72	58.60	NA	NA	NA
	Sep-12	NA	NA	NA	NA	2.57	3.41	28.00	3.10	53.50	NA	NA	NA
	Dec-12	NA	NA	NA	NA	3.78	15.70	18.00	1.41	56.70	NA	NA	NA
W10	Mar-13	NA	NA	NA	NA	4.59	<1.00	83.00	4.04	79.80	NA	NA	NA
	Jun-13	NA	NA	NA	NA	2.30	5.42	76.00	5.13	53.90	NA	NA	NA
	Oct-13	NA	NA	NA	NA	2.20	6.19	39.00	<4.51	59.20	NA	NA	NA
W13	Mar-04	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	0.44	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	0.48	<1.00	8.10	2.00	13.00	NA	NA	NA
W13	Jun-05	NA	NA	NA	NA	<0.50	<1.00	6.90	0.00	1.00	NA	NA	NA
	Dec-05	NA	NA	NA	NA	<0.50	<1.00	16.60	3.00	3.00	NA	NA	NA
W13	Jun-06	NA	NA	NA	NA	<0.50	<1.00	7.20	2.00	3.00	NA	NA	NA
	Dec-06	NA	NA	NA	NA	<0.50	<1.00	8.00	2.00	0.00	NA	NA	NA
W13	Jun-07	NA	NA	NA	NA	<0.50	<1.00	12.30	4.00	4.00	NA	NA	NA
	Dec-07	NA	NA	NA	NA	<0.50	<1.00	15.10	6.00	7.00	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W13	Mar-08	NA	NA	NA	NA	NA	NA	5.15	2.58	6.61	NA	NA	NA
	Jun-08	NA	NA	NA	NA	<0.50	<1.00	8.29	3.00	3.00	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	<1.0	<1.0	<1.0	<2.0	<0.50	<1.00	8.30	NA	NA	<5.0	NA	NA
W13	Mar-09	NA	NA	NA	NA	<0.50	<1.00	3.62	4.04	5.24	NA	NA	NA
	Jun-09	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NA	NA	NA	NA	<0.50	<1.00	1.60	1.61	4.98	NA	NA	NA
W13	Mar-10	NA	NA	NA	NA	<0.50	<1.00	NA	NA	NA	NA	NA	NA
	Jun-10	NA	NA	NA	NA	<0.50	<1.00	7.20	0.68	<0.001	NA	NA	NA
	Sep-10	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NA	NA	NA	NA	12.15	43.00	40.00	0.78	81.40	NA	NA	NA
W13	Apr-11	NA	NA	NA	NA	10.75	54.00	<20.00	2.60	85.60	NA	NA	NA
	Jun-11	NA	NA	NA	NA	10.35	56.00	35.00	9.92	121.00	NA	NA	NA
	Sep-11	NA	NA	NA	NA	10.00	47.00	40.00	16.90	90.60	NA	NA	NA
	Dec-11	NA	NA	NA	NA	10.40	56.70	51.00	17.90	132.00	NA	NA	NA
W13	Mar-12	NA	NA	NA	NA	9.60	53.70	44.00	7.30	138.00	NA	NA	NA
	Jun-12	NA	NA	NA	NA	10.90	59.00	43.00	7.66	68.20	NA	NA	NA
	Sep-12	NA	NA	NA	NA	9.85	46.30	38.00	2.94	110.00	NA	NA	NA
	Dec-12	NA	NA	NA	NA	11.10	51.00	36.00	9.65	142.00	NA	NA	NA
W13	Mar-13	NA	NA	NA	NA	10.40	41.60	40.00	5.78	99.30	NA	NA	NA
	Jun-13	NA	NA	NA	NA	10.90	50.20	39.00	3.01	130.00	NA	NA	NA
	Oct-13	NA	NA	NA	NA	10.20	48.10	31.00	<1.94	140.00	NA	NA	NA
W14	Mar-04	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	<0.40	1.21	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	<0.40	1.22	NA	NA	NA	NA	NA	NA
W14	Jun-05	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W14	Jun-06	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W14	Jun-07	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W14	Mar-08	NA	NA	NA	NA	NA	NA	2.24	3.01	6.41	NA	NA	NA
	Jun-08	NA	NA	NA	NA	NA	NA	0.17	4.22	17.30	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	0.49	6.53	8.88	NA	NA	NA
	Dec-08	42.00	7.40	2.00	<2.0	<0.50	<1.00	2.90	1.50	9.00	8.0	6.6	2.4

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W14	Mar-09	NA	NA	NA	NA	<0.50	7.79	0.41	4.39	11.70	NA	NA	NA
	Jun-09	NA	NA	NA	NA	<0.50	2.15	0.12	1.43	17.50	NA	NA	NA
	Sep-09	NA	NA	NA	NA	<0.50	2.60	0.14	3.29	9.50	NA	NA	NA
	Dec-09	NA	NA	NA	NA	<0.50	<1.00	NA	3.64	10.30	NA	NA	NA
W14	Mar-10	NA	NA	NA	NA	<0.50	2.60	<0.02	2.92	11.40	NA	NA	NA
	Jun-10	NA	NA	NA	NA	<0.50	2.00	<0.02	3.85	14.00	NA	NA	NA
	Sep-10	NA	NA	NA	NA	<0.50	2.41	0.30	14.40	23.10	NA	NA	NA
	Dec-10	NA	NA	NA	NA	<0.50	2.00	0.13	2.99	11.30	NA	NA	NA
W14	Apr-11	NA	NA	NA	NA	<0.50	2.00	0.79	1.69	10.40	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	3.00	0.10	6.41	10.10	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	3.00	0.20	3.23	8.74	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	1.40	2.01	9.88	NA	NA	NA
W14	Mar-12	NA	NA	NA	NA	<0.50	<1.00	3.90	0.22	5.01	NA	NA	NA
	Jun-12	NA	NA	NA	NA	<0.50	1.76	2.60	0.91	6.62	NA	NA	NA
	Sep-12	NA	NA	NA	NA	<0.50	1.28	3.10	0.00	4.12	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	2.77	0.84	6.91	15.90	NA	NA	NA
W14	Mar-13	NA	NA	NA	NA	<0.50	<1.00	4.70	1.32	2.82	NA	NA	NA
	Jun-13	NA	NA	NA	NA	<0.50	<1.00	4.30	0.82	3.98	NA	NA	NA
	Oct-13	NA	NA	NA	NA	<0.50	1.43	2.30	<0.97	28.60	NA	NA	NA
W15	Feb/Mar-04	49.00	4.10	2.00	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	<0.40	9.53	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	5.00	15.60	NA	NA	NA	NA	NA	NA
	Dec-04	44.00	3.80	2.20	<2.0	7.20	17.20	15.90	1.00	62.00	NA	NA	NA
W15	Jun-05	NA	NA	NA	NA	4.60	<1.00	16.50	1.00	5.00	NA	NA	NA
	Dec-05	NA	NA	NA	NA	6.20	15.10	18.40	6.00	158.00	NA	NA	NA
W15	Jun-06	NA	NA	NA	NA	5.40	17.70	19.70	6.00	101.00	NA	NA	NA
	Dec-06	NA	NA	NA	NA	3.90	10.10	23.60	12.00	231.00	NA	NA	NA
W15	Jun-07	NA	NA	NA	NA	5.90	7.60	16.00	1.00	132.00	NA	NA	NA
	Dec-07	NA	NA	NA	NA	6.70	13.40	15.20	7.00	131.00	NA	NA	NA
W15	Mar-08	NA	NA	NA	NA	NA	NA	20.70	10.30	268.00	NA	NA	NA
	Jun-08	28.00	2.70	1.90	<2.0	6.60	13.60	16.90	0.35	153.00	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	14.40	1.33	144.00	NA	NA	NA
	Dec-08	35.00	3.50	2.50	<2.0	6.60	10.70	20.00	2.10	210.00	6.4	5.2	204.8

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W16	Mar-10	NA	NA	NA	NA	11.30	22.50	0.15	1.04	13.20	NA	NA	NA
	Jun-10	NA	NA	NA	NA	9.95	18.00	2.30	1.76	25.90	NA	NA	NA
	Sep-10	NA	NA	NA	NA	9.20	21.60	3.30	31.20	59.80	NA	NA	NA
	Dec-10	NA	NA	NA	NA	10.50	17.00	2.40	3.19	15.00	NA	NA	NA
W16	Apr-11	NA	NA	NA	NA	1.00	20.20	3.20	0.03	14.80	NA	NA	NA
	Jun-11	NA	NA	NA	NA	9.00	17.00	3.40	1.26	17.90	NA	NA	NA
	Sep-11	NA	NA	NA	NA	8.00	23.00	2.80	0.64	19.10	NA	NA	NA
	Dec-11	NA	NA	NA	NA	10.60	20.00	3.40	0.75	18.00	NA	NA	NA
W16	Mar-12	NA	NA	NA	NA	7.40	17.90	3.70	1.98	18.80	NA	NA	NA
	Jun-12	NA	NA	NA	NA	10.10	21.60	5.10	0.70	18.10	NA	NA	NA
	Sep-12	NA	NA	NA	NA	9.65	16.10	4.10	0.97	14.40	NA	NA	NA
	Dec-12	NA	NA	NA	NA	10.10	20.40	2.60	0.11	16.60	NA	NA	NA
W16	Mar-13	NA	NA	NA	NA	11.50	19.80	2.90	3.59	25.70	NA	NA	NA
	Jun-13	NA	NA	NA	NA	7.90	15.20	3.40	3.81	19.20	NA	NA	NA
	Oct-13	NA	NA	NA	NA	9.65	15.30	1.90	<0.32	16.10	NA	NA	NA
W17	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W17	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W17	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W17	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W17	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W17	Mar-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W17	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W17	Apr-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-11	NA	NA	NA	NA	2.40	7.00	11.00	6.81	224.00	NA	NA	NA
	Dec-11	NA	NA	NA	NA	2.48	7.40	5.20	3.29	273.00	NA	NA	NA
W17	Mar-12	NA	NA	NA	NA	2.64	7.32	11.00	7.43	263.00	NA	NA	NA
	Jun-12	NA	NA	NA	NA	2.30	8.02	21.00	1.54	257.00	NA	NA	NA
	Sep-12	NA	NA	NA	NA	2.53	6.88	11.00	6.35	202.00	NA	NA	NA
	Dec-12	NA	NA	NA	NA	2.28	6.99	12.00	0.53	356.00	NA	NA	NA
W17	Mar-13	NA	NA	NA	NA	2.64	7.95	11.00	5.90	314.00	NA	NA	NA
	Jun-13	NA	NA	NA	NA	2.45	7.37	12.00	2.63	264.00	NA	NA	NA
	Oct-13	NA	NA	NA	NA	1.96	6.07	12.00	12.80	372.00	NA	NA	NA
W18	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W18	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	4.30	<1.0	1.00	<2.0	15.90	<1.00	55.90	155.00	119.00	NA	NA	NA
W18	Jun-06	2.10	<1.0	<1.0	<2.0	25.70	<1.00	132.00	9.00	296.00	NA	NA	NA
	Dec-06	NA	NA	NA	NA	11.60	3.10	2.40	66.00	18.00	NA	NA	NA
W18	Jun-07	2.50	<1.0	<1.0	<2.0	1.70	3.10	3.90	112.00	19.00	NA	NA	NA
	Dec-07	NA	NA	NA	NA	10.80	39.40	69.80	31.00	38.00	NA	NA	NA
W18	Mar-08	NA	NA	NA	NA	NA	NA	12.50	3.46	11.80	NA	NA	NA
	Jun-08	NA	NA	NA	NA	12.00	82.60	141.00	8.44	72.20	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	86.40	12.40	47.40	NA	NA	NA
	Dec-08	1.10	<1.0	<1.0	<2.0	12.40	63.60	94.20	5.00	71.00	7.6	6.2	64.8
W18	Mar-09	NA	NA	NA	NA	13.15	88.50	151.00	9.50	103.00	NA	NA	NA
	Jun-09	NA	NA	NA	NA	3.82	3.00	142.00	9.25	94.70	NA	NA	NA
	Sep-09	NA	NA	NA	NA	11.45	106.00	85.60	17.80	55.70	NA	NA	NA
	Dec-09	NA	NA	NA	NA	14.95	71.00	15.00	17.40	45.10	NA	NA	NA
W18	Mar-10	NA	NA	NA	NA	10.60	130.00	NA	NA	NA	NA	NA	NA
	Jun-10	NA	NA	NA	NA	6.00	90.00	3.80	10.40	101.00	NA	NA	NA
	Sep-10	NA	NA	NA	NA	13.00	110.00	200.00	24.60	115.00	NA	NA	NA
	Dec-10	NA	NA	NA	NA	12.00	92.00	240.00	4.52	118.00	NA	NA	NA
W18	Apr-11	NA	NA	NA	NA	11.90	91.00	<20.00	8.85	176.00	NA	NA	NA
	Jun-11	NA	NA	NA	NA	11.15	106.00	290.00	10.90	214.00	NA	NA	NA
	Sep-11	NA	NA	NA	NA	10.00	82.00	250.00	10.40	142.00	NA	NA	NA
	Dec-11	NA	NA	NA	NA	11.40	110.00	0.22	16.60	151.00	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W18	Mar-12	NA	NA	NA	NA	10.60	114.00	360.00	13.80	242.00	NA	NA	NA
	Jun-12	NA	NA	NA	NA	8.70	83.90	270.00	11.30	103.00	NA	NA	NA
	Sep-12	NA	NA	NA	NA	8.55	88.10	310.00	16.40	110.00	NA	NA	NA
	Dec-12	NA	NA	NA	NA	7.15	95.70	350.00	18.00	162.00	NA	NA	NA
W18	Mar-13	NA	NA	NA	NA	9.30	78.60	280.00	37.20	192.00	NA	NA	NA
	Jun-13	NA	NA	NA	NA	7.75	82.30	490.00	18.60	184.00	NA	NA	NA
	Oct-13	NA	NA	NA	NA	7.60	103.00	510.00	12.60	235.00	NA	NA	NA
W19	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
W19	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W19	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W19	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W19	Mar-08	NA	NA	NA	NA	NA	NA	6.10	1.52	3.65	NA	NA	NA
	Jun-08	NA	NA	NA	NA	NA	NA	6.50	1.57	1.51	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	5.95	2.39	7.77	NA	NA	NA
	Dec-08	NA	NA	NA	NA	<0.50	<1.00	6.20	0.90	1.60	NA	NA	NA
W19	Mar-09	NA	NA	NA	NA	<0.50	5.33	6.16	0.81	2.08	NA	NA	NA
	Jun-09	NA	NA	NA	NA	<0.50	<1.00	6.17	0.44	1.06	NA	NA	NA
	Sep-09	NA	NA	NA	NA	<0.50	<1.00	5.93	1.30	3.91	NA	NA	NA
	Dec-09	NA	NA	NA	NA	<0.50	<1.00	NA	1.10	0.00	NA	NA	NA
W19	Mar-10	NA	NA	NA	NA	5.40	13.00	6.10	0.00	0.00	NA	NA	NA
	Jun-10	NA	NA	NA	NA	N/A	<1.00	6.20	1.60	3.12	NA	NA	NA
	Sep-10	NA	NA	NA	NA	<0.50	<1.00	5.70	1.66	1.93	NA	NA	NA
	Dec-10	NA	NA	NA	NA	<0.50	<1.00	6.50	0.00	0.00	NA	NA	NA
W19	Apr-11	NA	NA	NA	NA	<0.50	<1.00	6.50	0.00	1.05	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	<1.00	4.60	1.19	1.55	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	4.90	0.79	1.09	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	4.90	0.95	0.00	NA	NA	NA
W19	Mar-12	NA	NA	NA	NA	<0.50	0.03	6.90	0.35	1.01	NA	NA	NA
	Jun-12	NA	NA	NA	NA	<0.50	<1.00	6.10	0.27	2.57	NA	NA	NA
	Sep-12	NA	NA	NA	NA	<0.50	<1.00	5.40	0.61	1.30	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	<1.00	5.10	1.55	2.54	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W19	Mar-13	NA	NA	NA	NA	<0.50	<1.00	5.10	5.69	4.87	NA	NA	NA
	Jun-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Oct-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W20	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
W20	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W20	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W20	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W20	Mar-08	NA	NA	NA	NA	NA	NA	0.91	1.08	1.43	NA	NA	NA
	Jun-08	NA	NA	NA	NA	NA	NA	0.11	2.58	2.96	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	0.16	0.92	0.00	NA	NA	NA
	Dec-08	NA	NA	NA	NA	<0.50	<1.00	0.40	0.00	3.40	NA	NA	NA
W20	Mar-09	NA	NA	NA	NA	<0.50	4.98	0.62	2.02	0.80	NA	NA	NA
	Jun-09	NA	NA	NA	NA	<0.50	<1.00	0.41	1.69	0.16	NA	NA	NA
	Sep-09	NA	NA	NA	NA	<0.50	<1.00	0.09	0.00	7.88	NA	NA	NA
	Dec-09	NA	NA	NA	NA	<0.50	<1.00	NA	0.73	0.00	NA	NA	NA
W20	Mar-10	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
	Jun-10	NA	NA	NA	NA	N/A	<1.00	0.48	3.16	1.02	NA	NA	NA
	Sep-10	NA	NA	NA	NA	<0.50	<1.00	0.49	3.69	0.00	NA	NA	NA
	Dec-10	NA	NA	NA	NA	<0.50	<1.00	0.03	1.48	0.20	NA	NA	NA
W20	Apr-11	NA	NA	NA	NA	<0.50	<1.00	0.25	0.09	2.35	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	<1.00	0.19	0.81	0.00	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	0.73	2.76	0.00	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	<0.02	0.55	1.93	NA	NA	NA
W20	Mar-12	NA	NA	NA	NA	0.48	0.08	0.23	0.38	0.78	NA	NA	NA
	Jun-12	NA	NA	NA	NA	<0.50	<1.00	0.83	2.38	3.03	NA	NA	NA
	Sep-12	NA	NA	NA	NA	<0.50	<1.00	0.09	1.62	0.00	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	<1.00	0.03	1.85	2.46	NA	NA	NA
W20	Mar-13	NA	NA	NA	NA	<0.50	<1.00	0.14	2.03	0.00	NA	NA	NA
	Jun-13	NA	NA	NA	NA	<0.50	<1.00	0.52	0.15	0.59	NA	NA	NA
	Oct-13	NA	NA	NA	NA	<0.50	<1.00	<0.02	<0.44	<2.27	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W22	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	<0.40	6.94	37.00	6.00	144.00	NA	NA	NA
W22	Jun-05	NA	NA	NA	NA	<0.50	<1.00	2.50	0.00	7.00	NA	NA	NA
	Dec-05	NA	NA	NA	NA	<0.50	<1.00	2.50	0.00	7.00	NA	NA	NA
W22	Jun-06	NA	NA	NA	NA	33.70	<1.00	35.00	0.00	2.00	NA	NA	NA
	Dec-06	NA	NA	NA	NA	3.10	52.30	56.80	3.00	38.00	NA	NA	NA
W22	Jun-07	NA	NA	NA	NA	5.00	10.20	22.80	2.00	8.00	NA	NA	NA
	Dec-07	NA	NA	NA	NA	5.00	10.20	22.80	NA	NA	NA	NA	NA
W22	Mar-08	NA	NA	NA	NA	NA	NA	10.80	2.43	10.40	NA	NA	NA
	Jun-08	NA	NA	NA	NA	20.50	87.70	71.40	2.08	25.60	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	<1.0	<1.0	<1.0	<2.0	5.60	5.70	21.60	2.60	13.70	<5.0	NA	NA
W22	Mar-09	NA	NA	NA	NA	6.30	22.90	43.90	4.00	26.20	NA	NA	NA
	Jun-09	NA	NA	NA	NA	1.22	<1.00	6.74	0.50	6.54	NA	NA	NA
	Sep-09	NA	NA	NA	NA	16.55	21.80	75.10	2.64	31.30	NA	NA	NA
	Dec-09	NA	NA	NA	NA	1.84	3.00	7.80	0.75	7.59	NA	NA	NA
W22	Mar-10	NA	NA	NA	NA	5.40	13.00	NA	NA	NA	NA	NA	NA
	Jun-10	NA	NA	NA	NA	6.80	14.00	5.70	6.78	33.80	NA	NA	NA
	Sep-10	NA	NA	NA	NA	15.00	94.00	72.00	13.50	67.50	NA	NA	NA
	Dec-10	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W22	Apr-11	NA	NA	NA	NA	11.35	34.00	<20.00	5.92	21.60	NA	NA	NA
	Jun-11	NA	NA	NA	NA	15.05	84.00	150.00	14.70	95.10	NA	NA	NA
	Sep-11	NA	NA	NA	NA	7.00	49.00	100.00	12.30	86.70	NA	NA	NA
	Dec-11	NA	NA	NA	NA	23.10	105.00	0.12	32.60	224.00	NA	NA	NA
W22	Mar-12	NA	NA	NA	NA	16.00	78.00	190.00	14.30	126.00	NA	NA	NA
	Jun-12	NA	NA	NA	NA	6.35	19.90	28.00	7.82	5.13	NA	NA	NA
	Sep-12	NA	NA	NA	NA	11.90	27.40	110.00	8.67	51.20	NA	NA	NA
	Dec-12	NA	NA	NA	NA	16.40	94.20	290.00	28.20	143.00	NA	NA	NA
W22	Mar-13	NA	NA	NA	NA	11.40	43.90	220.00	4.92	70.90	NA	NA	NA
	Jun-13	NA	NA	NA	NA	5.50	7.24	26.00	9.88	26.10	NA	NA	NA
	Oct-13	NA	NA	NA	NA	15.80	65.00	260.00	8.13	91.20	NA	NA	NA
W23	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W23	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W23	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W23	Mar-08	NA	NA	NA	NA	NA	NA	7.62	5.09	1.26	NA	NA	NA
	Jun-08	NA	NA	NA	NA	NA	NA	3.24	10.60	5.79	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	1.99	3.54	3.25	NA	NA	NA
	Dec-08	<1.0	<1.0	<1.0	<2.0	<0.50	<1.00	2.30	1.30	0.40	<5.0	NA	NA
W23	Mar-09	NA	NA	NA	NA	<0.50	4.75	2.72	1.90	1.51	NA	NA	NA
	Jun-09	NA	NA	NA	NA	<0.50	<1.00	2.40	0.25	3.37	NA	NA	NA
	Sep-09	NA	NA	NA	NA	<0.50	<1.00	1.83	5.82	6.79	NA	NA	NA
	Dec-09	NA	NA	NA	NA	<0.50	<1.00	NA	0.59	2.68	NA	NA	NA
W23	Mar-10	NA	NA	NA	NA	<0.50	<1.00	1.80	1.14	<0.001	NA	NA	NA
	Jun-10	NA	NA	NA	NA	<0.50	<1.00	1.90	25.10	18.90	NA	NA	NA
	Sep-10	NA	NA	NA	NA	<0.50	<1.00	1.10	46.70	27.90	NA	NA	NA
	Dec-10	NA	NA	NA	NA	<0.50	<1.00	1.30	2.11	1.66	NA	NA	NA
W23	Apr-11	NA	NA	NA	NA	<0.50	<1.00	92.00	2.02	2.92	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	<1.00	0.27	18.80	20.50	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	0.30	0.23	3.87	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	<0.02	3.40	1.03	NA	NA	NA
W23	Mar-12	NA	NA	NA	NA	<0.50	<1.00	0.34	2.69	2.60	NA	NA	NA
	Jun-12	NA	NA	NA	NA	<0.50	<1.00	1.20	2.25	2.76	NA	NA	NA
	Sep-12	NA	NA	NA	NA	<0.50	<1.00	1.20	1.10	2.49	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	<1.00	0.77	0.94	3.19	NA	NA	NA
W23	Mar-13	NA	NA	NA	NA	<0.50	<1.00	1.20	1.77	2.07	NA	NA	NA
	Jun-13	NA	NA	NA	NA	<0.50	<1.00	1.30	1.27	6.40	NA	NA	NA
	Oct-13	NA	NA	NA	NA	<0.50	<1.00	1.40	6.92	5.78	NA	NA	NA
W24	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	<0.40	<1.00	2.80	0.00	9.00	NA	NA	NA
W24	Jun-05	NA	NA	NA	NA	<0.50	<1.00	2.20	0.00	9.00	NA	NA	NA
	Dec-05	NA	NA	NA	NA	<0.50	<1.00	2.10	0.00	3.00	NA	NA	NA
	Jun-06	NA	NA	NA	NA	<0.50	<1.00	1.20	1.00	1.00	NA	NA	NA
	Dec-06	NA	NA	NA	NA	<0.50	<1.00	1.60	0.00	5.00	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W24	Jun-07	NA	NA	NA	NA	<0.50	<1.00	1.00	1.00	7.00	NA	NA	NA
	Dec-07	NA	NA	NA	NA	<0.50	<1.00	5.90	3.00	4.00	NA	NA	NA
W24	Mar-08	NA	NA	NA	NA	NA	NA	3.28	0.29	1.53	NA	NA	NA
	Jun-08	NA	NA	NA	NA	<0.50	<1.00	2.69	0.55	3.58	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	1.28	0.04	0.90	NA	NA	NA
	Dec-08	NA	NA	NA	NA	<0.50	<1.00	1.30	1.50	1.10	NA	NA	NA
W24	Mar-09	NA	NA	NA	NA	<0.50	4.60	0.80	0.00	2.24	NA	NA	NA
	Jun-09	NA	NA	NA	NA	<0.50	<1.00	0.27	0.03	1.67	NA	NA	NA
	Sep-09	NA	NA	NA	NA	<0.50	<1.00	0.37	1.25	9.14	NA	NA	NA
	Dec-09	NA	NA	NA	NA	<0.50	<1.00	0.31	1.25	0.71	NA	NA	NA
W24	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	NA	NA	NA	NA	<0.50	<1.00	<0.02	0.11	1.13	NA	NA	NA
	Sep-10	NA	NA	NA	NA	<0.50	<1.00	0.13	8.57	4.88	NA	NA	NA
	Dec-10	NA	NA	NA	NA	<0.50	<1.00	0.13	1.22	3.80	NA	NA	NA
W24	Apr-11	NA	NA	NA	NA	<0.50	<1.00	0.15	0.73	0.78	NA	NA	NA
	Jun-11	NA	NA	NA	NA	16.80	<1.00	0.12	0.70	4.37	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	0.11	9.47	5.81	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	0.06	2.74	2.23	NA	NA	NA
W24	Mar-12	NA	NA	NA	NA	<0.50	<1.00	0.22	3.48	2.26	NA	NA	NA
	Jun-12	NA	NA	NA	NA	<0.50	<1.00	0.49	1.05	1.61	NA	NA	NA
	Sep-12	NA	NA	NA	NA	<0.50	<1.00	0.21	0.60	0.00	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	<1.00	0.22	2.22	1.25	NA	NA	NA
W24	Mar-13	NA	NA	NA	NA	<0.50	<1.00	0.23	5.11	5.84	NA	NA	NA
	Jun-13	NA	NA	NA	NA	<0.50	<1.00	0.30	0.41	8.05	NA	NA	NA
	Oct-13	NA	NA	NA	NA	<0.50	<1.00	0.04	4.88	<2.34	NA	NA	NA
W26	Feb/Mar-04	7.30	<1.0	<1.0	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	3.30	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	3.60	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	24.00	4.80	28.00	<2.0	3.52	<1.00	5.80	1.00	11.00	NA	NA	NA
W26	Jun-05	23.00	7.20	38.00	<2.0	3.50	<1.00	6.00	2.00	10.00	NA	NA	NA
	Dec-05	24.00	9.80	65.00	<2.0	3.00	<1.00	1.00	1.00	15.00	NA	NA	NA
W26	Jun-06	2.20	1.30	13.00	<2.0	2.30	<1.00	4.50	1.00	12.00	NA	NA	NA
	Dec-06	<1.0	<1.0	1.00	<2.0	1.80	<1.00	12.30	1.00	22.00	NA	NA	NA
W26	Jun-07	<1.0	<1.0	1.20	<2.0	<0.50	<1.00	16.00	1.00	14.00	NA	NA	NA
	Dec-07	<1.0	NA	NA	NA	<0.50	7.00	12.70	1.00	23.00	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W26	Mar-08	NA	NA	NA	NA	NA	NA	11.50	1.41	19.40	NA	NA	NA
	Jun-08	<1.0	<1.0	<1.0	<2.0	<0.50	<1.00	9.76	1.83	13.00	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	6.87	0.27	14.70	NA	NA	NA
	Dec-08	<1.0	<1.0	<1.0	<2.0	<0.50	<1.00	9.80	0.29	14.40	5.2	4.3	10.1
W26	Mar-09	NA	NA	NA	NA	2.40	4.94	6.88	3.33	13.20	NA	NA	NA
	Jun-09	NA	NA	NA	NA	2.47	<1.00	6.31	1.64	11.10	NA	NA	NA
	Aug/Sep-09	<1.0	<1.0	<1.0	<2.0	2.31	<1.00	5.93	0.04	8.23	NA	NA	NA
	Dec-09	<1.0	<1.0	<1.0	<2.0	2.30	<1.00	NA	<0.001	10.10	NA	NA	NA
W26	Mar-10	NA	NA	NA	NA	1.50	<1.00	0.94	1.56	12.10	NA	NA	NA
	Jun-10	<1.0	<1.0	<1.0	<2.0	2.50	<1.00	15.00	6.29	27.00	NA	NA	NA
	Sep-10	<1.0	<1.0	<1.0	<2.0	2.60	<1.00	14.00	3.15	25.30	NA	NA	NA
	Dec-10	<1.0	<1.0	<1.0	<2.0	2.10	<1.00	13.00	0.00	16.30	NA	NA	NA
W26	Apr-11	<1.0	<1.0	<1.0	<2.0	2.90	<1.00	14.00	0.10	7.25	NA	NA	NA
	Jun-11	<1.0	<1.0	<1.0	<2.0	2.10	<1.00	11.00	1.78	17.70	NA	NA	NA
	Sep-11	<1.0	<1.0	<1.0	<2.0	2.18	<1.00	10.00	0.39	11.80	NA	NA	NA
	Dec-11	<1.0	<1.0	<1.0	<2.0	2.50	<1.00	9.60	2.15	9.98	NA	NA	NA
W26	Mar-12	<1.0	<1.0	<1.0	<1.0	2.14	<1.00	8.50	2.84	15.60	NA	NA	NA
	Jun-12	<1.0	<1.0	<1.0	<1.0	2.56	<1.00	8.90	3.21	11.40	NA	NA	NA
	Sep-12	<1.0	<1.0	<1.0	<1.0	2.70	<1.00	5.90	0.98	8.36	NA	NA	NA
	Dec-12	<1.0	<1.0	<1.0	<1.0	2.34	<1.00	6.50	2.24	22.10	NA	NA	NA
W26	Mar-13	<1.0	<1.0	<1.0	<1.0	2.57	<1.00	5.70	1.49	14.10	NA	NA	NA
	Jun-13	<1.0	<1.0	<1.0	<1.0	2.52	<1.00	6.50	0.57	9.21	NA	NA	NA
	Oct-13	<1.0	<1.0	1.70	<1.0	1.91	<1.00	4.80	<1.86	13.50	NA	NA	NA
W27	Feb/Mar-04	<1.0	<1.0	<1.0	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	2.37	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	2.10	5.33	NA	NA	NA	NA	NA	NA
	Dec-04	<1.0	<1.0	<1.0	<2.0	2.96	4.98	NA	NA	NA	NA	NA	NA
W27	Jun-05	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W27	Jun-06	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W27	Jun-07	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W27	Mar-08	NA	NA	NA	NA	NA	NA	<0.02	0.79	4.07	NA	NA	NA
	Jun-08	NA	NA	NA	NA	NA	NA	0.22	0.56	7.07	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	0.18	0.13	3.74	NA	NA	NA
	Dec-08	<1.0	<1.0	<1.0	<2.0	5.25	<1.00	0.28	1.80	8.10	<5.0	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W27	Mar-09	NA	NA	NA	NA	5.70	9.44	0.09	1.14	3.38	NA	NA	NA
	Jun-09	NA	NA	NA	NA	5.70	7.26	0.13	1.39	6.58	NA	NA	NA
	Sep-09	NA	NA	NA	NA	6.25	9.60	0.24	1.64	6.96	NA	NA	NA
	Dec-09	NA	NA	NA	NA	6.25	7.00	NA	0.58	4.26	NA	NA	NA
W27	Mar-10	NA	NA	NA	NA	6.35	8.60	<0.02	<0.001	3.40	NA	NA	NA
	Jun-10	NA	NA	NA	NA	N/A	7.00	<0.02	2.50	7.14	NA	NA	NA
	Sep-10	NA	NA	NA	NA	6.20	9.72	<0.02	6.04	8.93	NA	NA	NA
	Dec-10	NA	NA	NA	NA	6.45	7.00	<0.02	2.23	5.03	NA	NA	NA
W27	Apr-11	NA	NA	NA	NA	8.00	9.00	<0.02	1.28	8.56	NA	NA	NA
	Jun-11	NA	NA	NA	NA	5.85	10.00	<0.02	3.58	5.72	NA	NA	NA
	Sep-11	NA	NA	NA	NA	6.40	9.00	<0.02	0.96	5.88	NA	NA	NA
	Dec-11	NA	NA	NA	NA	7.50	9.00	<0.02	3.07	0.38	NA	NA	NA
W27	Mar-12	NA	NA	NA	NA	7.35	9.11	0.04	3.10	6.61	NA	NA	NA
	Jun-12	NA	NA	NA	NA	6.50	9.80	<0.02	4.96	6.13	NA	NA	NA
	Sep-12	NA	NA	NA	NA	6.65	8.09	0.04	1.07	1.60	NA	NA	NA
	Dec-12	NA	NA	NA	NA	7.05	10.30	0.31	1.49	5.50	NA	NA	NA
W27	Mar-13	NA	NA	NA	NA	6.75	9.72	<0.02	3.08	12.20	NA	NA	NA
	Jun-13	NA	NA	NA	NA	6.35	7.18	<0.02	3.81	10.60	NA	NA	NA
	Oct-13	NA	NA	NA	NA	7.25	8.99	0.04	<0.35	12.50	NA	NA	NA
W28	Mar-04	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	7.28	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	7.60	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	10.56	<1.00	NA	NA	NA	NA	NA	NA
W28	Jun-05	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W28	Jun-06	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W28	Jun-07	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W28	Mar-08	NA	NA	NA	NA	NA	NA	16.10	10.80	9.92	NA	NA	NA
	Jun-08	NA	NA	NA	NA	NA	NA	6.82	1.22	0.00	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	7.03	3.29	10.80	NA	NA	NA
	Dec-08	<1.0	<1.0	<1.0	<2.0	7.20	<1.00	9.10	4.20	8.99	7.7	6.3	2.7
W28	Mar-09	NA	NA	NA	NA	12.50	<1.00	4.93	3.65	6.21	NA	NA	NA
	Jun-09	NA	NA	NA	NA	6.35	<1.00	9.82	6.15	8.87	NA	NA	NA
	Sep-09	NA	NA	NA	NA	14.05	2.50	2.69	9.69	10.00	NA	NA	NA
	Dec-09	NA	NA	NA	NA	9.45	<1.00	NA	2.36	7.13	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W28	Mar-10	NA	NA	NA	NA	12.20	<1.00	NA	NA	NA	NA	NA	NA
	Jun-10	NA	NA	NA	NA	N/A	<1.00	5.90	8.26	9.33	NA	NA	NA
	Sep-10	NA	NA	NA	NA	23.00	5.00	1.80	18.80	15.80	NA	NA	NA
	Dec-10	NA	NA	NA	NA	16.40	2.00	9.60	4.56	11.80	NA	NA	NA
W28	Apr-11	NA	NA	NA	NA	4.00	<1.00	<20.00	6.89	13.80	NA	NA	NA
	Jun-11	NA	NA	NA	NA	26.05	5.00	3.80	7.71	10.70	NA	NA	NA
	Sep-11	NA	NA	NA	NA	12.00	<1.00	13.00	14.60	18.70	NA	NA	NA
	Dec-11	NA	NA	NA	NA	6.15	<1.00	5.90	25.00	119.00	NA	NA	NA
W28	Mar-12	NA	NA	NA	NA	6.30	0.81	9.80	21.30	105.00	NA	NA	NA
	Jun-12	NA	NA	NA	NA	5.55	<1.00	13.00	27.40	66.40	NA	NA	NA
	Sep-12	NA	NA	NA	NA	6.85	20.60	8.50	16.40	31.10	NA	NA	NA
	Dec-12	NA	NA	NA	NA	7.00	<1.00	3.60	19.00	47.40	NA	NA	NA
W28	Mar-13	NA	NA	NA	NA	5.85	<1.00	4.70	14.70	26.70	NA	NA	NA
	Jun-13	NA	NA	NA	NA	4.02	<1.00	5.00	11.40	22.60	NA	NA	NA
	Oct-13	NA	NA	NA	NA	7.75	<1.00	3.50	18.70	33.50	NA	NA	NA
W29	Mar-04	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	6.96	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	7.10	4.80	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	9.60	9.35	27.70	2.00	7.00	NA	NA	NA
W29	Jun-05	NA	NA	NA	NA	7.00	6.80	18.50	4.00	9.00	NA	NA	NA
	Dec-05	NA	NA	NA	NA	9.40	9.10	37.50	4.00	19.00	NA	NA	NA
W29	Jun-06	NA	NA	NA	NA	7.00	12.20	28.70	2.00	12.00	NA	NA	NA
	Dec-06	NA	NA	NA	NA	7.90	6.80	37.40	2.00	12.00	NA	NA	NA
W29	Jun-07	NA	NA	NA	NA	6.00	7.50	35.20	1.00	15.00	NA	NA	NA
	Dec-07	NA	NA	NA	NA	7.00	6.40	23.50	1.00	15.00	NA	NA	NA
W29	Mar-08	NA	NA	NA	NA	NA	NA	31.70	2.42	21.20	NA	NA	NA
	Jun-08	NA	NA	NA	NA	4.30	6.90	32.40	2.52	19.40	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	26.00	3.65	15.60	NA	NA	NA
	Dec-08	1.80	<1.0	<1.0	<2.0	6.50	6.40	20.90	0.24	17.40	<5.0	NA	NA
W29	Mar-09	NA	NA	NA	NA	6.45	9.26	25.00	2.49	9.07	NA	NA	NA
	Jun-09	NA	NA	NA	NA	6.70	3.00	28.60	1.37	12.30	NA	NA	NA
	Sep-09	NA	NA	NA	NA	6.80	11.70	21.20	2.64	17.20	NA	NA	NA
	Dec-09	NA	NA	NA	NA	6.40	7.00	26.00	4.64	1.33	NA	NA	NA
W29	Mar-10	NA	NA	NA	NA	5.10	11.00	NA	NA	NA	NA	NA	NA
	Jun-10	NA	NA	NA	NA	6.80	7.00	13.00	2.73	10.30	NA	NA	NA
	Sep-10	NA	NA	NA	NA	7.10	8.00	20.00	7.30	9.51	NA	NA	NA
	Dec-10	NA	NA	NA	NA	6.25	7.00	13.00	1.29	6.00	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*		MCL=50*	MCL=50*
W29	Apr-11	NA	NA	NA	NA	5.45	9.00	<20.00	1.35	8.33	NA	NA	NA
	Jun-11	NA	NA	NA	NA	4.40	7.00	18.00	3.41	5.38	NA	NA	NA
	Sep-11	NA	NA	NA	NA	4.50	3.00	28.00	3.82	9.78	NA	NA	NA
	Dec-11	NA	NA	NA	NA	4.94	8.50	17.00	7.10	8.30	NA	NA	NA
W29	Mar-12	NA	NA	NA	NA	3.95	18.70	690.00	10.10	97.60	NA	NA	NA
	Jun-12	NA	NA	NA	NA	3.87	36.30	790.00	6.07	101.00	NA	NA	NA
	Sep-12	NA	NA	NA	NA	4.03	5.02	840.00	4.81	78.20	NA	NA	NA
	Dec-12	NA	NA	NA	NA	4.10	38.20	450.00	7.22	50.90	NA	NA	NA
W29	Mar-13	NA	NA	NA	NA	4.06	25.20	980.00	12.70	94.40	NA	NA	NA
	Jun-13	NA	NA	NA	NA	3.89	20.70	440.00	6.42	67.60	NA	NA	NA
	Oct-13	NA	NA	NA	NA	4.44	19.70	170.00	6.94	32.10	NA	NA	NA
W30	Mar-04	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	23.96	31.90	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	20.80	35.90	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	19.24	32.60	380.00	21.00	64.00	NA	NA	NA
W30	Jun-05	NA	NA	NA	NA	10.00	30.60	521.00	45.00	61.00	NA	NA	NA
	Dec-05	NA	NA	NA	NA	15.60	<1.00	476.00	35.00	64.00	NA	NA	NA
W30	Jun-06	NA	NA	NA	NA	12.30	35.90	296.00	28.00	132.00	NA	NA	NA
	Dec-06	NA	NA	NA	NA	17.30	6.30	3.30	3.00	98.00	NA	NA	NA
W30	Jun-07	NA	NA	NA	NA	17.70	5.80	359.00	8.00	66.00	NA	NA	NA
	Dec-07	NA	NA	NA	NA	23.40	4.10	197.00	11.00	29.00	NA	NA	NA
W30	Mar-08	NA	NA	NA	NA	NA	NA	189.00	13.50	45.00	NA	NA	NA
	Jun-08	NA	NA	NA	NA	10.00	3.50	419.00	51.20	121.00	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	187.00	15.60	61.50	NA	NA	NA
	Dec-08	3.30	<1.0	<1.0	<2.0	27.60	2.30	133.00	10.00	70.00	8.0	6.6	63.4
W30	Mar-09	NA	NA	NA	NA	20.10	1.74	95.80	12.20	24.30	NA	NA	NA
	Jun-09	NA	NA	NA	NA	29.50	9.00	194.00	10.30	36.50	NA	NA	NA
	Sep-09	NA	NA	NA	NA	28.65	7.40	87.60	19.30	44.60	NA	NA	NA
	Dec-09	NA	NA	NA	NA	27.50	3.00	120.00	13.10	51.70	NA	NA	NA
W30	Mar-10	NA	NA	NA	NA	37.30	4.00	NA	NA	NA	NA	NA	NA
	Jun-10	NA	NA	NA	NA	30.10	6.00	83.00	12.90	34.90	NA	NA	NA
	Sep-10	NA	NA	NA	NA	16.10	4.00	180.00	26.00	66.60	NA	NA	NA
	Dec-10	NA	NA	NA	NA	12.50	4.00	150.00	9.52	39.20	NA	NA	NA
W30	Apr-11	NA	NA	NA	NA	11.85	5.00	<20.00	9.32	37.30	NA	NA	NA
	Jun-11	NA	NA	NA	NA	11.00	2.00	110.00	10.50	46.90	NA	NA	NA
	Sep-11	NA	NA	NA	NA	5.00	53.00	230.00	18.90	45.80	NA	NA	NA
	Dec-11	NA	NA	NA	NA	12.15	3.50	2,900.00	26.10	80.20	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W30	Mar-12	NA	NA	NA	NA	13.90	12.40	1,800.00	11.10	117.00	NA	NA	NA
	Jun-12	NA	NA	NA	NA	12.50	8.11	620.00	20.80	77.80	NA	NA	NA
	Sep-12	NA	NA	NA	NA	13.10	60.60	540.00	17.40	56.60	NA	NA	NA
	Dec-12	NA	NA	NA	NA	14.30	10.10	1,000.00	45.10	135.00	NA	NA	NA
W30	Mar-13	NA	NA	NA	NA	13.20	4.09	660.00	18.80	102.00	NA	NA	NA
	Jun-13	NA	NA	NA	NA	12.70	2.78	300.00	13.30	45.70	NA	NA	NA
	Oct-13	NA	NA	NA	NA	16.60	<1.00	140.00	18.80	53.70	NA	NA	NA
W32	Mar-04	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	<0.40	1.57	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	<0.40	<1.00	37.70	75.00	546.00	NA	NA	NA
W32	Jun-05	NA	NA	NA	NA	<0.50	<1.00	46.00	70.00	1,020.00	NA	NA	NA
	Dec-05	NA	NA	NA	NA	<0.50	1.40	49.60	8.00	1,810.00	NA	NA	NA
W32	Jun-06	NA	NA	NA	NA	13.00	52.90	44.10	7.00	171.00	NA	NA	NA
	Dec-06	NA	NA	NA	NA	11.70	40.40	50.20	8.00	265.00	NA	NA	NA
W32	Jun-07	NA	NA	NA	NA	9.40	59.10	61.80	3.00	190.00	NA	NA	NA
	Dec-07	NA	NA	NA	NA	9.90	35.10	59.50	3.00	237.00	NA	NA	NA
W32	Mar-08	NA	NA	NA	NA	NA	NA	71.70	6.00	260.00	NA	NA	NA
	Jun-08	NA	NA	NA	NA	6.00	50.60	84.60	0.87	301.00	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	72.90	1.57	240.00	NA	NA	NA
	Dec-08	<1.0	<1.0	<1.0	<2.0	5.60	45.50	70.50	1.80	265.00	7.5	6.2	258.9
W32	Mar-09	NA	NA	NA	NA	7.10	46.10	71.10	7.72	236.00	NA	NA	NA
	Jun-09	NA	NA	NA	NA	8.15	46.00	63.70	2.30	260.00	NA	NA	NA
	Sep-09	<1.0	<1.0	<1.0	<2.0	7.70	65.20	63.00	5.41	235.00	NA	NA	NA
	Dec-09	NA	NA	NA	NA	8.25	42.00	57.00	3.51	285.00	NA	NA	NA
W32	Mar-10	NA	NA	NA	NA	6.90	54.00	NA	NA	NA	NA	NA	NA
	Jun-10	NA	NA	NA	NA	8.85	48.00	54.00	12.00	266.00	NA	NA	NA
	Sep-10	NA	NA	NA	NA	9.30	46.00	57.00	3.47	270.00	NA	NA	NA
	Dec-10	NA	NA	NA	NA	8.70	40.00	55.00	1.11	165.00	NA	NA	NA
W32	Apr-11	NA	NA	NA	NA	7.85	48.00	<20.00	0.74	196.00	NA	NA	NA
	Jun-11	NA	NA	NA	NA	7.00	68.00	82.00	0.68	211.00	NA	NA	NA
	Sep-11	NA	NA	NA	NA	10.00	1.00	110.00	10.40	183.00	NA	NA	NA
	Dec-11	NA	NA	NA	NA	5.15	65.40	130.00	11.70	315.00	NA	NA	NA
W32	Mar-12	NA	NA	NA	NA	4.36	63.60	160.00	4.88	258.00	NA	NA	NA
	Jun-12	NA	NA	NA	NA	4.86	72.40	190.00	5.40	208.00	NA	NA	NA
	Sep-12	NA	NA	NA	NA	4.13	<1.00	170.00	3.48	136.00	NA	NA	NA
	Dec-12	NA	NA	NA	NA	3.63	64.70	150.00	0.00	283.00	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W32	Mar-13	NA	NA	NA	NA	3.79	47.10	84.00	8.43	264.00	NA	NA	NA
	Jun-13	NA	NA	NA	NA	3.28	54.10	170.00	2.08	213.00	NA	NA	NA
	Oct-13	NA	NA	NA	NA	3.53	69.60	180.00	14.70	265.00	NA	NA	NA
W33	Feb/Mar-04	470.00	94.00	5.10	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	280.00	50.00	2.80	<2.0	<0.40	<1.00	NA	NA	NA	NA	NA	NA
W33	Jun-05	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	360.00	61.00	1.60	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
W33	Jun-06	530.00	87.00	2.10	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W33	Jun-07	450.00	61.00	<2.0	<4.0	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W33	Mar-08	NA	NA	NA	NA	NA	NA	71.70	3.12	20.70	NA	NA	NA
	Jun-08	300.00	43.00	1.20	<2.0	NA	NA	18.20	0.45	10.80	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	9.56	0.00	4.01	NA	NA	NA
	Dec-08	240.00	36.00	<1.0	<2.0	<0.50	<1.00	9.50	0.80	8.88	<5.0	NA	NA
W33	Mar-09	NA	NA	NA	NA	<0.50	4.87	10.90	0.31	4.28	NA	NA	NA
	Jun-09	NA	NA	NA	NA	<0.50	<1.00	18.10	0.17	9.19	NA	NA	NA
	Sep-09	NA	NA	NA	NA	<0.50	<1.00	19.80	0.07	8.89	NA	NA	NA
	Dec-09	NA	NA	NA	NA	<0.50	<1.00	NA	0.10	4.11	NA	NA	NA
W33	Mar-10	NA	NA	NA	NA	<0.50	<1.00	16.00	<0.001	5.01	NA	NA	NA
	Jun-10	NA	NA	NA	NA	N/A	<1.00	17.00	7.24	26.70	NA	NA	NA
	Sep-10	NA	NA	NA	NA	<0.50	<1.00	15.00	14.60	15.40	NA	NA	NA
	Dec-10	NA	NA	NA	NA	<0.50	<1.00	15.00	2.62	4.95	NA	NA	NA
W33	Apr-11	NA	NA	NA	NA	<0.50	<1.00	0.10	1.19	5.07	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	<1.00	10.00	0.00	10.00	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	10.00	0.33	2.19	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	9.20	0.87	6.78	NA	NA	NA
W33	Mar-12	NA	NA	NA	NA	<0.50	<1.00	8.70	1.01	2.12	NA	NA	NA
	Jun-12	NA	NA	NA	NA	<0.50	<1.00	16.00	3.40	7.39	NA	NA	NA
	Sep-12	NA	NA	NA	NA	<0.50	<1.00	9.50	0.08	3.19	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	<1.00	7.40	4.03	6.06	NA	NA	NA
W33	Mar-13	NA	NA	NA	NA	<0.50	<1.00	7.90	1.96	4.28	NA	NA	NA
	Jun-13	NA	NA	NA	NA	<0.50	<1.00	7.80	0.83	6.39	NA	NA	NA
	Oct-13	NA	NA	NA	NA	<0.50	<1.00	8.10	<3.17	9.44	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W35	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W35	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W35	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W35	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W35	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W35	Mar-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W35	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W35	Apr-11	NA	NA	NA	NA	<0.50	<1.00	0.41	NA	NA	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	<1.00	0.30	2.22	8.30	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	0.57	1.73	2.88	NA	NA	NA
	Dec-11	NA	NA	NA	NA	0.02	<1.00	0.55	1.65	3.97	NA	NA	NA
W35	Mar-12	NA	NA	NA	NA	<0.50	<1.00	0.60	1.13	2.64	NA	NA	NA
	Jun-12	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-12	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-12	NA	NA	NA	NA	<0.50	1.20	0.12	4.30	7.95	NA	NA	NA
W35	Mar-13	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-13	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Oct-13	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W36	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W36	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W36	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W36	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W36	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	<1.0	<1.0	<1.0	<2.0	<0.50	<1.00	0.20	0.00	0.00	<5.0	NA	NA
W36	Mar-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W36	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W36	Apr-11	NA	NA	NA	NA	<0.50	<1.00	0.13	NA	NA	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	<1.00	0.17	1.14	4.94	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	0.21	0.87	1.00	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	<0.02	1.20	2.39	NA	NA	NA
W36	Mar-12	NA	NA	NA	NA	<0.50	<1.00	0.55	0.57	0.94	NA	NA	NA
	Jun-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W36	Mar-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Oct-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W37	Feb-Mar-04	<1.0	<1.0	<1.0	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
	Jun-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	<1.0	<1.0	<1.0	<2.0	<0.40	<1.00	NA	NA	NA	NA	NA	NA
W37	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W37	Jun-06	<1.0	<1.0	<1.0	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W37	Jun-07	<1.0	<1.0	<1.0	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W37	Mar-08	NA	NA	NA	NA	NA	NA	5.13	3.43	3.21	NA	NA	NA
	Jun-08	<1.0	<1.0	<1.0	<2.0	NA	NA	3.27	0.11	2.91	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	3.33	0.78	4.85	NA	NA	NA
	Dec-08	<1.0	<1.0	<1.0	<2.0	<0.50	<1.00	3.60	0.60	1.60	<5.0	NA	NA
W37	Mar-09	NA	NA	NA	NA	<0.50	<1.00	3.58	0.14	1.24	NA	NA	NA
	Jun-09	NA	NA	NA	NA	<1.00	<1.00	3.63	2.31	1.86	NA	NA	NA
	Sep-09	NA	NA	NA	NA	<0.50	<1.00	3.77	0.75	7.59	NA	NA	NA
	Dec-09	NA	NA	NA	NA	1.70	<1.00	NA	0.27	4.50	NA	NA	NA
W37	Mar-10	NA	NA	NA	NA	<0.50	<1.00	NA	NA	NA	NA	NA	NA
	Jun-10	NA	NA	NA	NA	NA	<1.00	4.10	1.34	15.90	NA	NA	NA
	Sep-10	NA	NA	NA	NA	<0.50	<1.00	5.40	7.58	13.90	NA	NA	NA
	Dec-10	NA	NA	NA	NA	<0.50	<1.00	4.00	1.47	2.43	NA	NA	NA
W37	Apr-11	NA	NA	NA	NA	<0.50	2.00	<20.00	0.97	2.18	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	<1.00	3.80	1.55	3.82	NA	NA	NA
	Sep-11	NA	NA	NA	NA	6.00	<1.00	3.50	1.36	2.44	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	2.80	0.00	4.28	NA	NA	NA
W37	Mar-12	NA	NA	NA	NA	<0.50	0.17	5.70	0.00	5.64	NA	NA	NA
	Jun-12	NA	NA	NA	NA	<0.50	<1.00	5.50	0.13	3.99	NA	NA	NA
	Sep-12	NA	NA	NA	NA	<0.50	<1.00	3.70	0.00	2.58	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	<1.00	4.10	6.32	28.50	NA	NA	NA
W37	Mar-13	NA	NA	NA	NA	<0.50	<1.00	4.20	1.17	1.88	NA	NA	NA
	Jun-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Oct-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W38	Feb/Mar-04	12.00	140.00	<1.0	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	0.92	<1.00	NA	NA	NA	NA	NA	NA
	Sep-04	NA	NA	NA	NA	1.30	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	9.00	100.00	<1.0	<2.0	1.78	<1.00	NA	NA	NA	NA	NA	NA
W38	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	2.50	45.00	<1.0	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
W38	Jun-06	2.10	47.00	<1.0	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W38	Jun-07	2.60	48.00	<1.0	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W38	Mar-08	NA	NA	NA	NA	NA	NA	3.26	0.40	0.00	NA	NA	NA
	Jun-08	2.30	47.00	<1.0	<2.0	NA	NA	6.45	0.62	1.71	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	5.49	1.67	5.46	NA	NA	NA
	Dec-08	2.00	38.00	<1.0	<2.0	1.80	<1.00	6.60	0.50	6.20	<5.0	NA	NA
W38	Mar-09	NA	NA	NA	NA	1.30	<1.00	9.37	1.99	3.99	NA	NA	NA
	Jun-09	NA	NA	NA	NA	1.79	<1.00	9.34	<0.001	3.01	NA	NA	NA
	Sep-09	NA	NA	NA	NA	1.98	<1.00	9.70	0.44	2.50	NA	NA	NA
	Dec-09	NA	NA	NA	NA	<0.50	<1.00	NA	0.57	1.92	NA	NA	NA
W38	Mar-10	NA	NA	NA	NA	0.50	<1.00	NA	NA	NA	NA	NA	NA
	Jun-10	NA	NA	NA	NA	N/A	<1.00	14.00	3.14	3.63	NA	NA	NA
	Sep-10	NA	NA	NA	NA	0.80	<1.00	15.00	5.99	3.23	NA	NA	NA
	Dec-10	NA	NA	NA	NA	0.83	<1.00	15.00	0.83	4.35	NA	NA	NA
W38	Apr-11	NA	NA	NA	NA	1.09	2.00	<20.00	0.00	3.40	NA	NA	NA
	Jun-11	NA	NA	NA	NA	1.08	<1.00	16.00	1.62	6.11	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	9.10	2.30	1.44	NA	NA	NA
	Dec-11	NA	NA	NA	NA	1.12	<1.00	13.00	2.76	2.17	NA	NA	NA
W38	Mar-12	NA	NA	NA	NA	1.11	0.17	17.00	3.50	3.53	NA	NA	NA
	Jun-12	NA	NA	NA	NA	1.47	<1.00	17.00	3.71	7.57	NA	NA	NA
	Sep-12	NA	NA	NA	NA	1.60	<1.00	12.00	2.46	7.22	NA	NA	NA
	Dec-12	NA	NA	NA	NA	1.43	<1.00	14.00	<2.46	4.38	NA	NA	NA
W38	Mar-13	NA	NA	NA	NA	1.60	<1.00	14.00	4.10	5.24	NA	NA	NA
	Jun-13	NA	NA	NA	NA	8.95	<1.00	12.00	7.72	<2.77	NA	NA	NA
	Oct-13	NA	NA	NA	NA	0.70	<1.00	13.00	<0.98	2.93	NA	NA	NA
W39	Feb/Mar-04	210.00	10.00	4.60	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	110.00	7.10	1.20	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
W39	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	140.00	7.20	<1.0	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
W39	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W39	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W39	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	110.00	4.40	1.70	<2.0	<0.50	<1.00	58.30	1.50	11.70	<5.0	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W39	Mar-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W39	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W39	Apr-11	NA	NA	NA	NA	<0.50	<1.00	150.00	NA	NA	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	<1.00	99.00	7.09	17.00	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	92.00	11.90	29.20	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	52.00	3.02	17.80	NA	NA	NA
W39	Mar-12	NA	NA	NA	NA	<0.50	<1.00	80.00	4.34	20.10	NA	NA	NA
	Jun-12	NA	NA	NA	NA	<0.50	<1.00	59.00	2.74	14.30	NA	NA	NA
	Sep-12	NA	NA	NA	NA	<0.50	<1.00	110.00	4.58	13.70	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	<1.00	150.00	9.83	35.40	NA	NA	NA
W39	Mar-13	NA	NA	NA	NA	<0.50	<1.00	87.00	2.20	23.70	NA	NA	NA
	Jun-13	NA	NA	NA	NA	<0.50	<1.00	54.00	1.70	16.00	NA	NA	NA
	Oct-13	NA	NA	NA	NA	<0.50	<1.00	56.00	5.31	19.30	NA	NA	NA
W40	Feb/Mar-04	<1.0	<1.0	<1.0	>2.0	NA	NA	NA	NA	NA	NA	NA	NA
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	2.20	<1.0	<1.0	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
W40	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W40	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W40	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W40	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	<1.0	<1.0	<1.0	<2.0	<0.50	<1.00	6.80	0.00	1.50	<5.0	NA	NA
W40	Mar-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W40	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W40	Apr-11	NA	NA	NA	NA	<0.50	<1.00	6.10	NA	NA	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	<1.00	6.40	2.58	5.71	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	9.70	4.69	3.98	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	5.70	5.72	9.54	NA	NA	NA
W40	Mar-12	NA	NA	NA	NA	<0.50	<1.00	9.30	3.95	10.70	NA	NA	NA
	Jun-12	NA	NA	NA	NA	<0.50	<1.00	8.20	1.27	6.52	NA	NA	NA
	Sep-12	NA	NA	NA	NA	<0.50	<1.00	6.40	3.10	3.95	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	<1.00	5.50	6.25	9.37	NA	NA	NA
W40	Mar-13	NA	NA	NA	NA	<0.50	<1.00	5.90	4.02	5.62	NA	NA	NA
	Jun-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Oct-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W41	Mar-04	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	320.00	54.00	3.70	<2.0	<0.40	<1.00	36.40	2.00	8.00	NA	NA	NA
W41	Jun-05	360.00	55.00	3.20	<2.0	<0.40	<1.00	35.10	3.00	23.00	NA	NA	NA
	Dec-05	280.00	72.00	3.30	<2.0	<0.40	<1.00	41.70	3.00	22.00	NA	NA	NA
W41	Jun-06	300.00	62.00	3.00	<2.0	<0.40	<1.00	30.10	3.00	22.00	NA	NA	NA
	Dec-06	280.00	61.00	3.40	<2.0	<0.40	<1.00	37.10	2.00	8.00	NA	NA	NA
W41	Jun-07	350.00	64.00	2.90	<2.0	<0.50	<1.00	41.80	3.00	12.00	NA	NA	NA
	Dec-07	240.00	49.00	2.10	NA	<0.50	<1.00	40.10	2.00	11.00	NA	NA	NA
W41	Mar-08	NA	NA	NA	NA	NA	NA	37.50	2.06	9.57	NA	NA	NA
	Jun-08	240.00	46.00	2.10	<2.0	<0.50	<1.00	41.10	1.88	10.90	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	38.90	1.81	10.30	NA	NA	NA
	Dec-08	200.00	42.00	1.80	<2.0	<0.50	<1.00	40.30	5.50	13.40	5.3	4.3	9.1
W41	Mar-09	NA	NA	NA	NA	<0.50	4.69	42.60	1.62	10.50	NA	NA	NA
	Jun-09	NA	NA	NA	NA	<0.50	<1.00	50.00	2.16	15.60	NA	NA	NA
	Aug/Sep-09	140.00	29.00	<1.0	<2.0	<0.50	<1.00	51.80	2.53	14.10	NA	NA	NA
	Dec-09	230.00	47.00	2.00	<2.0	<0.50	<1.00	NA	1.80	16.50	NA	NA	NA
W41	Mar-10	NA	NA	NA	NA	<0.50	<1.00	31.00	1.90	9.30	NA	NA	NA
	Jun-10	51.00	9.50	<1.0	<2.0	<0.50	<1.00	63.00	6.19	13.90	NA	NA	NA
	Sep-10	120.00	22.00	<1.0	<2.0	<0.50	<1.00	67.00	6.24	23.20	NA	NA	NA
	Dec-10	140.00	29.00	1.20	<2.0	<0.50	<1.00	61.00	3.58	19.00	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W41	Apr-11	170.00	35.00	1.30	<2.0	<0.50	<1.00	53.00	5.03	14.30	NA	NA	NA
	Jun-11	180.00	39.00	<2.0	<2.0	<0.50	<1.00	56.00	2.50	17.60	NA	NA	NA
	Sep-11	200.00	44.00	1.70	<2.0	<0.50	<1.00	59.00	3.95	16.70	NA	NA	NA
	Dec-11	210.00	46.00	1.70	<2.0	<0.50	<1.00	52.00	4.60	18.40	NA	NA	NA
W41	Mar-12	220.00	50.00	1.80	<2.0	<0.50	<1.00	56.00	4.46	16.90	NA	NA	NA
	Jun-12	250.00	48.00	1.60	<1.0	<0.50	<1.00	52.00	1.50	15.00	NA	NA	NA
	Sep-12	270.00	52.00	1.60	<1.0	<0.50	<1.00	41.00	2.54	8.36	NA	NA	NA
	Dec-12	210.00	41.00	<20.0	<1.0	<0.50	<1.00	41.00	3.82	21.40	NA	NA	NA
W41	Mar-13	210.00	41.00	<5.0	<1.0	<0.50	<1.00	37.00	4.51	11.70	NA	NA	NA
	Jun-13	180.00	43.00	1.20	<1.0	<0.50	<1.00	40.00	2.87	10.60	NA	NA	NA
	Oct-13	160.00	22.00	1.20	<1.0	<0.50	<1.00	43.00	<2.40	19.30	NA	NA	NA
W42	Feb/Mar-04	<1.0	<1.0	<1.0	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	<1.0	<1.0	<1.0	<1.0	NA	NA	NA	NA	NA	NA	NA	NA
W42	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W42	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W42	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W42	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	<1.0	<1.0	<1.0	<2.0	1.90	5.00	17.40	1.90	27.80	6.4	5.2	22.6
W42	Mar-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W42	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W42	Apr-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W42	Mar-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W42	Mar-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Oct-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W43	Feb/Mar-04	<1.0	<1.0	<1.0	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	<1.0	<1.0	<1.0	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
W43	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W43	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W43	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W43	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	<1.0	<1.0	<1.0	<2.0	<0.50	<1.00	10.80	2.50	4.40	<5.0	NA	NA
W43	Mar-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W43	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W43	Apr-11	NA	NA	NA	NA	<0.50	<1.00	8.50	NA	NA	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	<1.00	11.00	4.07	9.07	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	6.20	2.42	6.58	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	12.00	1.09	4.28	NA	NA	NA
W43	Mar-12	NA	NA	NA	NA	<0.50	<1.00	19.00	2.08	9.90	NA	NA	NA
	Jun-12	NA	NA	NA	NA	<0.50	<1.00	13.00	5.97	6.68	NA	NA	NA
	Sep-12	NA	NA	NA	NA	<0.50	<1.00	5.90	5.00	5.74	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	<1.00	10.00	3.33	6.32	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W43	Mar-13	NA	NA	NA	NA	<0.50	<1.00	9.40	4.74	6.44	NA	NA	NA
	Jun-13	NA	NA	NA	NA	<0.50	<1.00	6.90	0.66	5.47	NA	NA	NA
	Oct-13	NA	NA	NA	NA	<0.50	<1.00	3.40	7.35	11.20	NA	NA	NA
W44	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	<1.0	<1.0	<1.0	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
W44	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W44	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W44	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W44	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	3.00	<1.0	<1.0	<2.0	<0.50	<1.00	9.30	0.90	7.90	<5.0	NA	NA
	Mar-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W44	Jun-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W44	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Apr-11	NA	NA	NA	NA	<0.50	<1.00	4.00	NA	NA	NA	NA	NA
W44	Jun-11	NA	NA	NA	NA	<0.50	<1.00	3.60	2.41	7.98	NA	NA	NA
	Sep-11	NA	NA	NA	NA	<0.50	<1.00	5.00	0.65	6.92	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	7.40	0.27	3.37	NA	NA	NA
	Mar-12	NA	NA	NA	NA	<0.50	0.03	9.60	1.28	7.99	NA	NA	NA
W44	Jun-12	NA	NA	NA	NA	<0.50	<1.00	10.00	2.75	7.82	NA	NA	NA
	Sep-12	NA	NA	NA	NA	<0.50	<1.00	7.90	3.68	2.30	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	<1.00	9.00	5.42	4.45	NA	NA	NA
	Mar-13	NA	NA	NA	NA	<0.50	<1.00	8.80	1.28	8.40	NA	NA	NA
W44	Jun-13	NA	NA	NA	NA	<0.50	<1.00	8.20	1.40	5.35	NA	NA	NA
	Oct-13	NA	NA	NA	NA	<0.50	<1.00	2.80	<2.88	4.21	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W45	Feb/Mar-04	1.70	<1.0	1.00	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	<1.0	<1.0	1.60	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
W45	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W45	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W45	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W45	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W45	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W45	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W45	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	<1.0	<1.0	<1.0	<2.0	1.10	<1.00	0.20	0.30	3.90	<5.0	NA	NA
W45	Mar-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W45	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W45	Apr-11	NA	NA	NA	NA	0.80	<1.00	<0.02	NA	NA	NA	NA	NA
	Jun-11	NA	NA	NA	NA	1.17	<1.00	0.03	7.08	5.43	NA	NA	NA
	Sep-11	NA	NA	NA	NA	1.40	<1.00	<0.02	9.88	5.28	NA	NA	NA
	Dec-11	NA	NA	NA	NA	1.38	<1.00	<0.02	21.60	8.51	NA	NA	NA
W45	Mar-12	NA	NA	NA	NA	1.39	<1.00	<0.02	22.00	13.20	NA	NA	NA
	Jun-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-12	NA	NA	NA	NA	1.36	<1.00	<0.02	15.90	12.70	NA	NA	NA
W45	Mar-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Oct-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W46	Feb/Mar-04	1.00	<1.0	<1.0	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	1.40	<1.0	<1.0	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
W46	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W46	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W46	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W46	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W46	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	1.90	<1.0	<1.0	<2.0	<0.50	<1.00	9.50	1.60	22.40	<5.0	NA	NA
W46	Mar-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W46	Sep-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W46	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W46	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W46	Apr-11	NA	NA	NA	NA	<0.50	<1.00	7.60	NA	NA	NA	NA	NA
	Jun-11	NA	NA	NA	NA	<0.50	<1.00	7.60	2.52	23.50	NA	NA	NA
W46	Sep-11	NA	NA	NA	NA	<0.50	<1.00	8.10	3.58	33.90	NA	NA	NA
	Dec-11	NA	NA	NA	NA	<0.50	<1.00	9.80	1.00	23.20	NA	NA	NA
W46	Mar-12	NA	NA	NA	NA	0.12	0.03	9.20	2.41	22.00	NA	NA	NA
	Jun-12	NA	NA	NA	NA	<0.50	<1.00	8.80	0.86	28.50	NA	NA	NA
W46	Sep-12	NA	NA	NA	NA	<0.50	<1.00	7.30	1.62	16.20	NA	NA	NA
	Dec-12	NA	NA	NA	NA	<0.50	<1.00	7.40	0.55	39.50	NA	NA	NA
W46	Mar-13	NA	NA	NA	NA	<0.50	<1.00	7.40	1.64	37.80	NA	NA	NA
	Jun-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W46	Oct-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W47	Feb/Mar-04	1.70	<1.0	<1.0	<2.0	NA	NA	NA	NA	NA	NA	NA	NA
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W47	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	<1.0	<1.0	<1.0	<2.0	NA	NA	NA	NA	NA	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W47	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W47	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W47	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W47	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	3.60	<1.0	<1.0	<2.0	6.80	16.10	22.90	0.30	10.10	8.0	6.6	3.5
W47	Mar-09	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-09	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NA	NA	NA	NA	NS	NS	NS	NS	NS	NS	NS	NS
W47	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W47	Apr-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W47	Mar-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-12	NA	NA	NA	NA	6.00	20.70	26.00	1.85	59.00	NA	NA	NA
	Sep-12	NA	NA	NA	NA	5.35	15.00	27.00	1.25	74.10	NA	NA	NA
	Dec-12	NA	NA	NA	NA	5.60	23.00	27.00	8.53	129.00	NA	NA	NA
W47	Mar-13	NA	NA	NA	NA	5.50	17.90	26.00	3.97	116.00	NA	NA	NA
	Jun-13	NA	NA	NA	NA	5.55	13.90	27.00	3.84	96.40	NA	NA	NA
	Oct-13	NA	NA	NA	NA	5.85	18.90	37.00	9.98	102.00	NA	NA	NA
W48	Feb/Mar-04	320.00	2.90	12.00	<2.0	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	290.00	2.80	12.00	<2.0	<0.40	<1.00	7.80	1.00	4.00	NA	NA	NA
W48	Jun-05	360.00	4.00	<1.0	<2.0	<0.50	<1.00	7.80	0.00	11.00	NA	NA	NA
	Dec-05	370.00	10.00	22.00	<2.0	<0.40	<1.00	8.70	0.00	11.00	NA	NA	NA
W48	Jun-06	380.00	7.50	18.00	<2.0	<0.40	<1.00	8.10	1.00	7.00	NA	NA	NA
	Dec-06	340.00	5.40	16.00	<2.0	<0.40	<1.00	8.90	4.00	9.00	NA	NA	NA

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*		MCL=50*	
W48	Jun-07	390.00	2.80	7.80	<4.0	<0.50	<1.00	6.50	1.00	6.00	NA	NA	NA
	Dec-07	340.00	2.80	9.20	<4.0	<0.50	<1.00	9.70	2.00	6.00	NA	NA	NA
W48	Mar-08	NA	NA	NA	NA	NA	NA	9.87	2.58	14.80	NA	NA	NA
	Jun-08	170.00	1.20	3.70	<2.0	<0.50	<1.00	9.62	1.09	8.43	NA	NA	NA
	Sep-08	NA	NA	NA	NA	NA	NA	9.27	1.46	14.00	NA	NA	NA
	Dec-08	270.00	1.80	6.70	<2.0	<0.50	<1.00	9.20	0.90	13.40	<5.0	NA	NA
W48	Mar-09	NA	NA	NA	NA	<0.50	4.82	8.41	0.39	7.23	NA	NA	NA
	Jun-09	NA	NA	NA	NA	<0.50	<1.00	7.93	0.72	1.75	NA	NA	NA
	Aug/Sep-09	250.00	3.30	9.60	<4.0	<0.50	<1.00	4.71	0.49	4.98	NA	NA	NA
	Dec-09	320.00	5.00	11.00	<2.0	<0.50	<1.00	NA	<0.001	6.34	NA	NA	NA
W48	Mar-10	NA	NA	NA	NA	<0.50	<1.00	9.10	0.84	3.71	NA	NA	NA
	Jun-10	330.00	2.10	5.90	<2.0	<0.50	<1.00	8.20	<0.001	8.48	NA	NA	NA
	Sep-10	370.00	2.20	6.60	<2.0	<0.50	<1.00	7.40	1.23	9.06	NA	NA	NA
	Dec-10	340.00	1.90	5.10	<2.0	<0.50	<1.00	8.30	0.65	11.80	NA	NA	NA
W48	Apr-11	310.00	1.80	5.10	<2.0	2.80	<1.00	10.00	1.65	8.03	NA	NA	NA
	Jun-11	230.00	<4.0	4.70	<8.0	<0.50	<1.00	8.90	0.94	7.93	NA	NA	NA
	Sep-11	260.00	1.70	5.20	<2.0	<0.50	<1.00	7.80	1.94	4.81	NA	NA	NA
	Dec-11	140.00	<1.0	2.40	<2.0	<0.50	<1.00	6.30	2.03	7.02	NA	NA	NA
W48	Mar-12	140.00	<1.0	2.10	<2.0	<0.50	<1.00	8.60	1.36	8.46	NA	NA	NA
	Jun-12	150.00	<1.0	2.40	<1.0	<0.50	<1.00	10.00	0.02	0.00	NA	NA	NA
	Sep-12	130.00	<1.0	1.70	<1.0	<0.50	<1.00	6.50	0.70	7.72	NA	NA	NA
	Dec-12	180.00	1.40	3.50	<1.0	<0.50	<1.00	6.20	3.60	8.70	NA	NA	NA
W48	Mar-13	180.00	1.30	3.20	<5.0	<0.50	<1.00	6.40	0.00	10.10	NA	NA	NA
	Jun-13	140.00	1.40	3.50	<1.0	<0.50	<1.00	6.20	2.30	7.33	NA	NA	NA
	Oct-13	160.00	2.80	5.00	<1.0	<0.50	<1.00	5.20	6.70	16.60	NA	NA	NA
W49	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W49	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W49	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W49	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W49	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	<1.0	<1.0	<1.0	<2.0	<0.50	<1.00	<0.02	0.06	0.00	<5.0	NA	NA
W49	Mar-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W49	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W49	Apr-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-11	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W49	Mar-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W49	Mar-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Oct-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W50	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W50	Jun-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-05	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W50	Jun-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-06	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W50	Jun-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-07	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
W50	Mar-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-08	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-08	<1.0	<1.0	<1.0	<2.0	<0.50	<1.00	<0.02	NA	NA	<5.0	NA	NA
W50	Mar-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-09	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W50	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Dec-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
W50	Apr-11	NS	NS	NS	NS	<0.50	<1.00	0.06	NA	NA	NA	NA	NA
	Jun-11	NS	NS	NS	NS	<0.50	<1.00	0.03	1.73	0.00	NA	NA	NA
	Sep-11	NS	NS	NS	NS	<0.50	<1.00	0.03	2.14	3.56	NA	NA	NA
	Dec-11	NS	NS	NS	NS	<0.50	<1.00	<0.02	3.46	0.00	NA	NA	NA
W50	Mar-12	NS	NS	NS	NS	<0.50	<1.00	<0.02	1.35	0.49	NA	NA	NA
	Jun-12	NS	NS	NS	NS	NA	NA	NA	NA	NA	NA	NA	NA
	Sep-12	NS	NS	NS	NS	NA	NA	NA	NA	NA	NA	NA	NA
	Dec-12	NS	NS	NS	NS	NA	NA	NA	NA	NA	NA	NA	NA
W50	Mar-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Oct-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
WRW-2	Mar-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-04	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Sep-04	NA	NA	NA	NA	<0.40	<1.00	NA	NA	NA	NA	NA	NA
	Dec-04	NA	NA	NA	NA	0.42	<1.00	54.90	7.00	15.00	NA	NA	NA
WRW-2	Jun-05	97.00	8.70	1.80	<2.00	<0.50	<1.00	153.00	11.00	99.00	NA	NA	NA
	Dec-05	83.00	7.20	1.70	<2.00	<0.50	<1.00	510.00	28.00	184.00	NA	NA	NA
WRW-2	Jun-06	190.00	9.60	2.40	<2.00	0.60	5.60	244.00	7.00	38.00	NA	NA	NA
	Dec-06	230.00	12.00	2.80	<2.00	1.50	4.20	139.00	9.00	48.00	NA	NA	NA
WRW-2	Jun-07	290.00	13.00	3.10	<2.00	1.00	6.50	127.00	6.00	52.00	NA	NA	NA
	Dec-07	160.00	9.70	2.70	<2.00	1.30	1.10	121.00	10.00	37.00	NA	NA	NA
WRW-2	Mar-08	NA	NA	NA	<2.00	NA	NA	77.70	3.55	23.00	NA	NA	NA
	Jun-08	120.00	6.00	2.20	<2.00	1.40	<1.00	148.00	3.78	30.70	NA	NA	NA
	Sep-08	NA	NA	NA	<2.00	N/A	N/A	117.00	4.18	31.90	NA	NA	NA
	Dec-08	NA	NA	NA	<2.00	1.20	<1.00	114.00	3.75	37.00	5.2	4.3	32.7

Table 4-3
 Summary of Analytical Results in Groundwater (2004-2013)
 Westinghouse Columbia Fuel Fabrication Facility
 Hopkins, South Carolina
 AECOM Project No. 60302740

Well	Sample Date	Tetrachloro-ethene ug/L	Trichloro-ethene Ug/L	cis-1,2-dichloro-ethene Ug/L	Vinyl Chloride Ug/L	Fluoride mg/L	NH3(N) mg/L	NO3 mg/L	Gross Alpha pCi/L	Gross Beta pCi/L	Potassium mg/L	Potassium 40 mg/L	Adjusted Gross Beta pCi/L
		MCL=5	MCL=5	MCL=70	MCL=2	MCL=4		MCL=10	MCL=15	MCL=50*			MCL=50*
WRW-2	Mar-09	NA	NA	NA	<2.00	1.30	5.77	109.00	2.69	25.80	NA	NA	NA
	Jun-09	NA	NA	NA	<2.00	1.68	<1.00	160.00	3.03	28.60	NA	NA	NA
	Aug/Sep-09	44.00	2.90	<1.00	<2.00	1.27	3.40	192.00	9.86	48.60	NA	NA	NA
	Dec-09	30.00	3.80	<1.00	<2.00	0.77	<1.00	N/A	5.50	45.60	NA	NA	NA
WRW-2	Mar-10	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
	Jun-10	8.40	1.80	<1.00	<2.00	0.60	<1.00	78.00	1.01	26.20	NA	NA	NA
	Sep-10	12.00	1.90	<1.00	<2.00	0.60	<1.00	66.00	20.40	26.70	NA	NA	NA
	Dec-10	37.00	4.00	<1.00	<2.00	1.00	1.00	56.00	1.93	17.40	NA	NA	NA
WRW-2	Mar/Apr-11	180.00	9.00	<1.00	<2.00	<0.50	1.00	38.00	6.92	14.30	NA	NA	NA
	Jun-11	290.00	10.00	<4.00	<8.00	<0.50	1.00	33.00	6.13	14.80	NA	NA	NA
	Sep-11	NA	NA	NA	<2.00	<0.50	1.00	16.00	6.47	8.94	NA	NA	NA
	Dec-11	240.00	9.30	1.50	<2.00	<0.50	1.00	31.00	4.17	8.18	NA	NA	NA
WRW-2	Mar-12	230.00	11.00	1.40	<1.00	<0.50	1.00	30.00	5.03	10.50	NA	NA	NA
	Jun-12	190.00	8.00	1.70	<1.00	<0.50	1.00	27.00	0.54	4.78	NA	NA	NA
	Sep-12	160.00	7.00	1.60	<1.00	<0.50	<1.00	25.00	4.53	4.88	NA	NA	NA
	Dec-12	190.00	10.00	1.30	<1.00	<0.50	<1.00	34.00	3.47	14.20	NA	NA	NA
WRW-2	Mar-13	170.00	7.70	1.10	<1.00	<0.50	<1.00	28.00	1.91	7.72	NA	NA	NA
	Jun-13	130.00	5.80	<1.00	<1.00	<0.50	<1.00	30.00	0.69	7.81	NA	NA	NA
	Oct-13	130.00	12.00	<1.00	<1.00	<0.50	<1.00	28.00	<3.05	12.50	NA	NA	NA

Notes:

mg/L: Milligrams per liter

pCi/L: Picocuries per liter

MCL: Maximum contaminant level

Bold: The analyte was detected by the laboratory

Bold and Shaded: The analyte concentration exceeded the EPA MCL

NA: Not available

NS: Not sampled