

Revised Draft of Section 2.1 from DG-1285

1 2.1 Evaluation of Defense-in-Depth Attributes and Safety Margins

2 One aspect of the engineering evaluation is to show that the proposed change does not
3 compromise the fundamental safety principles on which the plant design was based. Design-basis
4 accidents (DBAs) play a central role in the design of nuclear power plants. DBAs are a combination of
5 postulated challenges and failure events against which plants are designed to ensure adequate and safe
6 plant response. During the design process, plant response and associated safety margins are evaluated
7 using assumptions of physical properties and operating characteristics that are intended to be
8 conservative. National standards and other considerations such as defense-in-depth attributes and the
9 single-failure criterion constitute additional engineering considerations that also influence plant design
10 and operation. The licensee's proposed LB change may affect margins and defenses incorporated into the
11 current plant design and operation; therefore, the licensee should reevaluate these items to support a
12 requested LB change. As part of this evaluation, the impact of the proposed LB change on the functional
13 capability, reliability, and availability of affected equipment should be determined. The plant's LB
14 identified in the FSAR is the reference point for judging whether a proposed change adversely affects
15 safety margins or defense-in-depth. Sections 2.1.1 and 2.1.2 below provide guidance on assessing
16 whether implementation of the proposed change maintains adequate safety margins and consistency with
17 the defense-in-depth philosophy.

18 2.1.1 *Defense-in-Depth*

19 The engineering evaluation should evaluate whether the impact of the proposed LB change is
20 consistent with the defense-in-depth philosophy. In this regard, the intent of this key principle of risk-
21 informed decision-making is to ensure that any impact of the proposed LB change on defense-in-depth is
22 fully understood and addressed and that the philosophy of defense-in-depth is maintained; not to prevent
23 changes in the way defense-in-depth is achieved. The licensee must fully understand how the change will
24 impact the design, operation and maintenance of the plant, both from risk and traditional engineering
25 perspectives.

26 This section provides some background on the defense-in-depth philosophy. Next is discussion
27 of seven key factors that may be used to evaluate the impact of a proposed change on defense-in-depth.
28 One or more examples are provided to help illustrate what is meant by each factor. Finally, this section
29 provides guidance on a process for evaluating the seven key factors, including an integrated example.

30 2.1.1.1 Background

31 Defense-in-depth is an element of the NRC's safety philosophy that employs successive
32 compensatory measures to prevent accidents or mitigate damage if a malfunction, accident, or naturally
33 caused event occurs at a nuclear facility¹. The defense-in-depth philosophy has traditionally been applied
34 in reactor design and operation to provide multiple means to accomplish safety functions and prevent the
35 release of radioactive material. It has been and continues to be an effective way to account for
36 uncertainties in equipment and human performance and, in particular, to account for the potential for
37 unknown and unforeseen failure mechanisms or phenomena, which (because they are unknown or
38 unforeseen) may not be reflected in either the PRA or traditional engineering analyses.

¹ Staff Requirements Memorandum (SRM) - SECY-98-0144, "White Paper on Risk-Informed and Performance-Based Regulation," March 1, 1999, (Agencywide Document Access and Management System (ADAMS) accession number ML003753601).

Revised Draft of Section 2.1 from DG-1285

39 For the purposes of this RG, it is useful to consider the following layers of defense (successive
40 measures) when evaluating the impact of the proposed licensing basis change on defense-in-depth:

- 41 • Robust plant design to survive hazards and minimize challenges that could result in an event
42 occurring;
- 43 • Prevention of a severe accident (core damage) should an event occur;
- 44 • Containment of the source term should a severe accident occur; and,
- 45 • Protection of the public from any releases of radioactive material (through, e.g., siting in low
46 population areas and the ability to shelter or evacuate people if necessary).

47 2.1.1.2 Key Factors for Evaluating the Impact of LB Changes on Defense-in-depth

48 Any one or more of the layers of defense discussed above may be adversely impacted by a
49 proposed change to a plant's licensing basis. The NRC has identified seven factors that should be used to
50 assess the impact of the change on defense-in-depth. These are discussed in detail below. Guidance on
51 how to apply these factors is discussed in more detail in section 2.1.1.3.

52 The NRC finds it acceptable for a licensee to use the following seven key factors to evaluate
53 whether a proposed change to the LB maintains the philosophy of defense-in-depth.

54 1. Preserve a reasonable balance among the layers of defense.

55 a. Guidance

56 *A propose change should not* significantly reduce the effectiveness of a layer of defense that
57 exists in the plant design before the proposed change.

58 *The evaluation of the proposed change should* consider insights based on traditional engineering
59 approaches; insights from risk assessments may be used to support engineering insights, but not
60 be the only justification for meeting this factor.

62 b. Discussion

63 A reasonable balance of the layers of defense, minimizing challenges to the plant, preventing any
64 events from progressing to core damage, containing the radioactive source term, and emergency
65 preparedness, helps to ensure an apportionment of the plant's capabilities between limiting
66 disturbances to the plant and mitigating their consequences. The term *reasonable balance* is not
67 meant to imply an equal apportionment of capabilities. A reasonable balance is preserved if the
68 proposed plant change does not significantly reduce the effectiveness of a layer that exists in the
69 plant design before the proposed change. The NRC recognizes that there may be aspects of a
70 plant's design that may cause one of the layers to be adversely affected. For these situations, the
71 balance among the other three layers becomes especially important when evaluating the impact of
72 a proposed change to the LB and its impact on defense-in-depth.

73 If a comprehensive risk analysis is done, it can provide insights into whether the balance among
74 the layers of defense remains appropriate to ensure protection of public health and safety. Such a
75 risk analysis would not only include the likelihood of challenges to the plant (i.e., initiating event
76 frequencies) from various hazards, but would include estimates of core damage frequency,

Revised Draft of Section 2.1 from DG-1285

77 containment response and, in some cases, dose estimates to the public. It would include
78 implementation of the emergency plan and estimate the effectiveness of actions such as sheltering
79 in place or evacuation.

80 Note that the risk acceptance guidelines in this RG are based on the surrogates for the
81 Commission's quantitative health objectives, CDF and LERF. These risk metrics, developed as
82 part of the risk assessment, can help inform the licensee's assessment of the relative balance
83 between the second and third layers of defense.

84 However, to address the unknown and unforeseen failure mechanisms or phenomena, the
85 licensee's evaluation of this factor of defense-in-depth should also address insights based on
86 traditional engineering approaches. Results of the risk assessment may be used to support the
87 conclusion but should not be the only justification for meeting this factor. The licensee should
88 consider the impact of the proposed change on each of the layers of defense:

- 89 – Robust plant design to survive hazards and minimize challenges that could result in an event
90 occurring - the change should not significantly increase the likelihood of initiating events or
91 create new significant initiating events;
- 92 – Prevention of a severe accident (core damage) should an event occur - the change should
93 maintain the availability and reliability of SSCs that provide the safety functions that prevent
94 plant challenges from progressing to core damage;
- 95 – Containment of the source term should a severe accident occur - the change should maintain
96 the containment and SSCs that support that barrier, such as containment fan coolers and
97 sprays; and,
- 98 – Protection of the public from any releases of radioactive material - the change should not
99 reduce the effectiveness of the EP program, including the ability to detect and measure
100 releases of radioactivity, to notify offsite agencies and the public, to shelter or evacuate the
101 public as necessary

102 c. Examples

103 A licensee relies on the pressure in containment generated as a result of an accident to provide
104 adequate NPSH for safety-related pumps needed to mitigate that accident. This is referred to as
105 containment accident pressure (CAP). A pre-existing leak in the containment, a failure of the
106 containment to isolate, or a post-accident leak in containment, all of sufficient magnitude, could
107 result in failure of the emergency core cooling system (ECCS) and containment spray pumps.
108 Thus, a failure of containment could result in core damage. In this example, a licensee wishes to
109 either take credit for CAP for the first time or increase the amount of CAP credit over what is
110 currently in the licensing basis for the plant (either magnitude of pressure needed or duration).
111 The increase in the amount of CAP credit may be consistent with this defense-in-depth factor if
112 the licensee can demonstrate that the increase in the likelihood of containment leakage or
113 isolation failure is low enough. In this example, the increase is sufficiently low such that the
114 associated layer of defense has not been significantly degraded so as to have placed additional
115 reliance on the other layers of defense.

- 116 2. Preserve adequate capability of design features without an over-reliance on programmatic
117 activities as compensatory measures.

Revised Draft of Section 2.1 from DG-1285

118 a. Guidance

119 *A proposed change should not significantly reduce the reliability and availability of design*
120 *features to perform their safety functions.*

121
122 *The evaluation of the proposed change should demonstrate that the change does not result in the*
123 *overreliance of programmatic activities to compensate for a proposed reduction in the capability*
124 *of engineered safety features.*

125 b. Discussion

126 Nuclear power plant licensees implement a number of programs, including, for example,
127 programs for quality assurance, testing and inspection, maintenance, control of transient
128 combustible material, foreign material exclusion, containment cleanliness, training, and so forth.
129 In some cases, activities taken as part of these programs are used to ensure safety functions; for
130 example, reactor vessel inspections that provide assurance that reactor vessel failure is unlikely.

131 A proposed change that does not affect how safety functions are performed or reduce the
132 reliability or availability of the SSCs that perform those functions would meet this defense-in-
133 depth factor. However, a licensee could contemplate a change where a reduction in the capability
134 of those SSCs is compensated in some manner by reliance on plant programs. In such a case, the
135 licensee should assess whether the proposed change would increase the need for programmatic
136 activities to compensate for the lack of engineered features. If the change requires new or
137 additional reliance on such programs, the licensee should justify that reliance on these measures
138 is not excessive. Use of compensatory measures may be considered overreliance when a program
139 is substituted for an engineered means of performing a safety function, or failure of the
140 programmatic activity could prevent an engineered safety feature from performing its intended
141 function.

142 The NRC also recognizes that compensatory measures are sometimes associated with temporary
143 conditions. A licensee may request a risk-informed change to the plant's licensing basis to permit
144 occasional entry into conditions requiring measures that rely on plant programs to compensate for
145 reduced capability of engineered systems, or for one-time to allow completion of corrective
146 action to restore engineered systems to match the design and licensing basis. For such situations,
147 the licensee should demonstrate that the plant condition requiring such compensatory measures
148 would occur at a sufficiently low frequency or that the time frame to effect corrective action is
149 commensurate with the significance of the non-conforming condition.

150 c. Examples

151 The proposed plant change involves the removal of fire doors with an associated compensatory
152 measure of placing a fire watch. The compensatory measure may be consistent with this defense-
153 in-depth factor if the compensatory measure were implemented, for example, on a temporary
154 basis (e.g., until the next fuel reload or other appropriate interval).

155 3. Maintain sufficient availability and reliability of SSC commensurate with their importance to
156 safety.

Revised Draft of Section 2.1 from DG-1285

157 a. Guidance

158 *A proposed change should not* defeat the redundancy, independence, or diversity of design
159 features.

160
161 *The evaluation of the proposed change should demonstrate that the change does not* result in a
162 substantial reduction in the availability or reliability of the associated SSCs, e.g., introduction of a
163 new single failure.

164 b. Discussion

165 The importance of system redundancy, independence and diversity is to ensure that the system
166 function can be achieved. A proposed risk-informed change should consider both safety-related
167 and nonsafety-related SSCs that are important to core damage or large early release. Redundancy
168 provides for duplicate equipment that enables the failure or unavailability of at least one set of
169 equipment to be tolerated without loss of function. Independence among equipment implies that
170 the redundant equipment are separate such that they do not rely on the same supports to function.
171 It can sometimes be achieved by the use of physical separation or physical protection. Diversity
172 is accomplished by having equipment that perform the same function rely on different attributes,
173 such as different principles of operation, different physical variables, different conditions of
174 operation, or production by different manufacturers.

175 A substantial reduction in the ability to accomplish a safety function would likely undermine the
176 effectiveness of a layer of defense-in-depth and, therefore, would not be consistent with the
177 defense-in-depth philosophy. A safety function may be compromised if one of the plant features
178 that provides for either system redundancy, independence, or diversity is defeated. This adverse
179 impact could occur by the introduction of a new dependency that could potentially defeat the
180 redundancy, independence or diversity of the affected equipment. That is, system redundancy,
181 independence and diversity can be assumed to be sufficient if, given the proposed licensing
182 change, the affected system safety function can be accomplished assuming a single failure.

183 The licensee should demonstrate that the proposed licensing change would not affect system
184 redundancy, independence, or diversity of the affected equipment; that is, the affected system
185 safety function can still be accomplished assuming a single failure.

186 c. Examples

187 The proposed plant change involves extending the Technical Specification completion time for
188 one train of a risk-significant system. Even though one train of the system is out of service, the
189 proposed change may be consistent with this factor of defense-in-depth if it can be demonstrated,
190 for example, that there is another train available to achieve the system function, the plant is not
191 placed in an unanalyzed condition, and the proposed length of the completion time can be
192 justified (e.g., ...).

193 4. Preserve adequate defense against potential common-cause failures (CCF).

194 a. Guidance

195 *A proposed change should not* reduce defenses against CCFs that could defeat the redundancy,
196 independence, and/or diversity of DID layers, fission product barriers, and engineered safety
197 features.

Revised Draft of Section 2.1 from DG-1285

198
199 *The evaluation of the proposed change should demonstrate that the change does not* result in a
200 reduction of existing CCF defenses or introduce new CCF dependencies.

201 b. Discussion

202 An important aspect of ensuring defense-in-depth is to guard against CCF. Failure of several
203 devices or components to function may occur as a result of a single specific event or cause. Such
204 failures may simultaneously affect several different items important to risk. The event or cause
205 may be a design deficiency, a manufacturing deficiency, an operating or maintenance error, a
206 natural phenomenon, a human-induced event, or an unintended cascading effect from any other
207 operation or failure within the plant.

208 The licensee should evaluate the proposed change to determine whether it increases the potential
209 for events or causes that would be a CCF. The licensee should also evaluate the proposed change
210 to determine whether new CCF mechanisms could be introduced.

211 c. Examples

212 The proposed change relates to the use of a new corrosion-resistant material for one component
213 of the plant's seawater pumps. There may be uncertainty regarding how this new material will
214 perform with respect to the other materials in the pump, creating the potential for new failure
215 mechanisms (e.g., galvanic corrosion). Even though changing the related component for all of
216 service water pumps within a short time may create a CCF mechanism, this change may be
217 consistent with this defense-in-depth factor if the licensee demonstrates that the potential for CCF
218 has not been increased. This demonstration can be achieved by, for example, providing staggered
219 implementation or materials testing prior to modification.

220 5. Maintain multiple fission product barriers.

221 a. Guidance

222 *A proposed change should not* significantly reduce the effectiveness of the multiple fission
223 product barriers.

224
225 *The evaluation of the proposed change should demonstrate that the change does not:*

- 226
227 — Create a significant increase in the likelihood or consequence of an event that simultaneously
228 challenges multiple barriers and is within the plant's existing licensing basis.
229
230 — Introduce the possibility of a new event that would simultaneously impact multiple barriers.

231
232 b. Discussion

233 This factor refers to the physical fission product barriers e.g., the fuel cladding, reactor coolant
234 system pressure boundary, and containment. This includes the physical barriers themselves and
235 any equipment relied upon to protect the barriers (e.g., containment spray). In general, these
236 barriers are designed to perform independently so that a complete failure of one barrier does not
237 disable the next subsequent barrier. For example, one barrier, the containment, is designed to
238 withstand a double-ended guillotine break of the largest pipe in the reactor coolant system,
239 another barrier.

Revised Draft of Section 2.1 from DG-1285

240 A plant's licensing basis may contain events that, by their very nature, challenge multiple barriers
 241 simultaneously. Examples include interfacing-system LOCA and SGTR. Therefore, complete
 242 independence of barriers, while a goal, may not be achievable for all possible scenarios.

243 To demonstrate that this factor is met, the licensee should demonstrate that the change does not
 244 create a significant increase in the likelihood or consequence of an event that simultaneously
 245 challenges multiple barriers and is within the plant's existing licensing basis.

246 Furthermore, the licensee should demonstrate that the change does not introduce the possibility of
 247 a new event that would simultaneously impact multiple barriers. If this cannot be shown, the
 248 licensee should:

- 249 — Perform a deterministic analysis to show that the simultaneous challenge to multiple barriers
 250 caused by the new event can be mitigated. This may be done by assuming that the new event
 251 has occurred and performing an analysis (using conservative assumptions) demonstrating that
 252 affected barriers would perform their safety function or;
- 253 — Use the results of the plant's PRA to demonstrate that the likelihood of the new event is
 254 sufficiently low such that independence of barriers would not be significantly affected by the
 255 proposed change.

256 c. Examples

257 The proposed change relates to changing to a new fuel design that involves a new fuel matrix
 258 material and ceramic cladding. In this example, it is assumed that limited testing has indicated
 259 that this new fuel design is superior to current designs, however, there is still uncertainty due to
 260 the range of conditions that might be encountered in an actual plant. If the confidence in the
 261 safety aspects of the new design is relatively high and the other fission product barriers are not
 262 being changed, then the proposed change may be consistent with this defense-in-depth factor.
 263 However, if additional testing is warranted to provide acceptable confidence in the safety aspects
 264 of the new design, or if other barriers (e.g., the containment) have reduced efficacy, then the
 265 proposed change may not be consistent with this defense-in-depth factor.

266 6. Preserve sufficient defense against human errors.

267 a. Guidance

268 *A proposed change should not* significantly increase the potential for or create new human errors
 269 that may adversely affect one or more layers of defense.

270 *The evaluation of the proposed change should demonstrate that the change does not*

- 271 — create new human failure events that have a significant adverse impact on risk;
- 272 — significantly increase the burden on the operators responding to events; or,
- 273 — significantly increase the human error probability of existing operator actions.

274 b. Discussion

275 Human errors include the failure of operators to perform the actions necessary to operate the plant
 276 or respond to off-normal conditions and accidents, errors committed during test and maintenance,
 277 and operators performing an incorrect action. Human errors can result in the degradation or

Revised Draft of Section 2.1 from DG-1285

278 failure of a system to perform its function, thereby significantly reducing the effectiveness of one
279 of the defense-in-depth layers or one of the fission product barriers.

280 The plant design and operation includes defenses to prevent the occurrence of such errors and
281 events. These defenses generally involve the use of procedures, training, and human engineering;
282 however, other factors, e.g., communication protocols, may also be important.

283 In determining whether these defenses are preserved, the licensee should assess whether the
284 proposed change would create new operator actions that significantly impact the change in risk,
285 place a greater mental/physical demand on operators in responding to events, or increase the
286 probability of existing operator errors. The licensee should consider whether the change creates
287 new situations that are likely to cause errors, not only for operators, but for maintenance
288 personnel and other plant staff.

289 c. Examples

290 The proposed plant change results in a new complex operator action. Defenses against human
291 error may be preserved if it can be demonstrated, for example, that operators have adequate
292 indications, available time, and training to provide a high confidence that the action would be
293 successfully performed when needed.

294 7. Continue to meet the intent of the plant's design criteria. **[NRC staff is considering deleting
295 this evaluation factor and expanding the narrative of the first paragraph of Section 2.1.1 of
296 this document to more fully explain the concept of this factor.]**

297 a. Guidance

298 *A proposed change should not affect meeting the intent of the plant's design criteria referenced in*
299 *the licensing basis.*

300
301 *The evaluation of the proposed change should demonstrate that the change does not affect*
302 *meeting the intent of the plant's design criteria referenced in the licensing basis.*

303
304 b. Discussion

305 The plant's design criteria establish the necessary design, fabrication, construction, testing, and
306 performance requirements for SSCs important to safety; that is, SSCs that provide reasonable
307 assurance that the facility can be operated without undue risk to the health and safety of the
308 public. The plant's design criteria define minimum requirements that achieve aspects of the
309 defense-in-depth philosophy; as a consequence, a compromise to those design criteria can directly
310 result in a significant reduction in the effectiveness of one or more of the defense-in-depth layers.
311 When evaluating the effect of the proposed change, the licensee should demonstrate that the
312 intent of the plant's design criteria continue to be met.

313 The General Design Criteria of Appendix A to 10 CFR 50 form the basis for the design criteria
314 for newer plants. In some cases, exemptions to specific GDC may have been granted. Older
315 plants may have been licensed to other criteria, such as the AEC draft design criteria. A given
316 plant's design criteria are summarized in its UFSAR. This factor of defense-in-depth should
317 consider the current licensing basis of the plant.

318 c. Examples

319 [Under development]

DRAFT