

Michael J. Yox  
Regulatory Affairs Director  
Vogtle 3 & 4  
Nuclear Development

Southern Nuclear  
Operating Company, Inc.  
7825 River Road  
Waynesboro, GA 30830  
Tel: 706.848.6459



Docket No.: 52-025

**JUN 28 2016**

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555-0001

ND-16-0932  
10 CFR 52.99(c)(1)

Southern Nuclear Operating Company  
Vogtle Electric Generating Plant Unit 3  
ITAAC Closure Notification on  
Completion of ITAAC 2.1.01.07.i [Index Number 8]


Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), the purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 3 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item 2.1.01.07.i [Index Number 8] for verifying that the calculated effective neutron multiplication factor for the new and spent fuel storage racks meets the requirements of 10 CFR 50.68 limits under normal conditions. The closure process for this ITAAC is based on the guidance described in NEI 08-01, "Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52," which was endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) requests NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact David Woods at 706-848-6903.

Respectfully submitted,



Michael J. Yox  
Regulatory Affairs Director Vogtle 3&4

Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 3  
Completion of ITAAC 2.1.01.07.i [Index Number 8]

**To:**

**Southern Nuclear Operating Company/Georgia Power Company**

Mr. S. E. Kuczynski (w/o enclosures)

Mr. D. A. Bost (w/o enclosures)

Mr. M. D. Meier

Mr. M. D. Rauckhorst (w/o enclosures)

Mr. D. H. Jones (w/o enclosures)

Ms. K. D. Fili

Mr. D. L. McKinney

Mr. B. H. Whitley

Mr. D. L. Fulton

Mr. C. E. Morrow

Mr. M. J. Yox

Mr. D. Woods

Ms. A. L. Pugh

Ms. K. Stacy

Mr. J. J. Olson

Mr. W. A. Sparkman

Mr. J. P. Redd

Mr. D. R. Culver

Document Services RTYPE: VND.LI.L06

File AR.01.02.06

cc:

**Nuclear Regulatory Commission**

Ms. C. Haney (w/o enclosures)

Mr. M. Delligatti (w/o enclosures)

Mr. L. Burkhardt (w/o enclosures)

Mr. C. Patel

Mr. B. M. Bovol

Ms. R. Reyes

Ms. M. A. Sutton

Mr. M. E. Ernstes

Mr. G. Khouri

Mr. M. G. Kowal

Mr. J. D. Fuller

Mr. T. Chandler

Ms. S. Temple

Ms. P. Braxton

Mr. T. Brimfield

**Oglethorpe Power Corporation**

Mr. M. W. Price

Ms. K. T. Haynes

Ms. A. Whaley

**Municipal Electric Authority of Georgia**

Mr. J. E. Fuller  
Mr. S. M. Jackson

**Dalton Utilities**

Mr. D. Cope

**WECTEC**

Ms. K. Stoner (w/o enclosures)  
Mr. C. A. Castell

**Westinghouse Electric Company, LLC**

Mr. R. Easterling (w/o enclosures)  
Mr. J. W. Crenshaw (w/o enclosures)  
Mr. L. Woodcock (w/o enclosures)  
Mr. M. P. Rubin  
Mr. P. A. Russ  
Mr. G. F. Couture  
Mr. M. Y. Shaqqo  
Ms. S. DiTommaso

**Other**

Mr. J. E. Hesler, *Bechtel Power Corporation*  
Ms. L. Matis, *Tetra Tech NUS, Inc.*  
Dr. W. R. Jacobs, Jr., *Ph.D., GDS Associates, Inc.*  
Mr. S. Roetger, *Georgia Public Service Commission*  
Ms. S. W. Kernizan, *Georgia Public Service Commission*  
Mr. K. C. Greene, *Troutman Sanders*  
Mr. S. Blanton, *Balch Bingham*

**Southern Nuclear Operating Company  
ND-16-0932  
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 3  
Completion of ITAAC 2.1.01.07.i [Index Number 8]**

### **ITAAC Statement**

#### **Design Commitment:**

7. The new and spent fuel storage racks maintain the effective neutron multiplication factor required by 10 CFR 50.68 limits during normal operation, design basis seismic events, and design basis dropped spent fuel assembly accidents over the spent fuel storage racks.

#### **Inspections, Tests, Analyses:**

- i) Analyses will be performed to calculate the effective neutron multiplication factor in the new and spent fuel storage racks during normal conditions.

#### **Acceptance Criteria:**

- i) The calculated effective neutron multiplication factor for the new and spent fuel storage racks meets the requirements of 10 CFR 50.68<sup>(1)</sup> limits under normal conditions.

#### **Note:**

1. The requirements of 10 CFR 50.68 are summarized as follows:
  - For new fuel storage racks:
    - The effective neutron multiplication factor (K-effective) must not exceed 0.95 when flooded with unborated water and
    - K-effective must not exceed 0.98 with optimum moderator conditions.
  - For spent fuel storage racks:
    - If methodology does not take credit for soluble boron:
      - K-effective must not exceed 0.95 when flooded with unborated water.
    - Or if methodology takes credit for soluble boron:
      - K-effective must not exceed 0.95 when flooded with borated water and
      - K-effective must remain below 1.0 when flooded with unborated water.

### **ITAAC Determination Basis**

Multiple Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) are used to verify the new and spent fuel storage racks maintain the effective neutron multiplication factor required by 10 CFR 50.68 limits during normal operation, design basis seismic events, and design basis dropped spent fuel assembly accidents over the spent fuel storage racks. This ITAAC requires that analyses be performed to ensure the calculated effective neutron multiplication factor for the new and spent fuel storage racks meets the requirements of 10 CFR 50.68 limits under normal conditions.

The requirements of 10 CFR 50.68 are summarized as follows:

- For new fuel storage racks:
  - The effective neutron multiplication factor (K-effective) must not exceed 0.95 when flooded with unborated water and
  - K-effective must not exceed 0.98 with optimum moderator conditions.

- For spent fuel storage racks:
  - If methodology does not take credit for soluble boron:
    - K-effective must not exceed 0.95 when flooded with unborated water.
  - Or if methodology takes credit for soluble boron:
    - K-effective must not exceed 0.95 when flooded with borated water and
    - K-effective must remain below 1.0 when flooded with unborated water.

The criticality analyses for the AP1000 new fuel storage rack and spent fuel storage racks have been conducted to comply with the requirements of 10 CFR 50.68. The analyses employ the KENO version V.a model for the new fuel storage rack (Reference 1), and Monte Carlo N-Particle Transport Code (MCNP) version 4A, for the spent fuel storage racks (Reference 2). Each analysis evaluated a three dimensional model of the fuel storage racks filled with a maximum 5.0 weight-percent U-235 Westinghouse AP1000 17x17 fuel assemblies. The new fuel storage rack is modeled inside a concrete vault optimally moderated and fully flooded with unborated water. The spent fuel storage racks are modeled inside a pool fully flooded with borated and unborated water.

The results as documented in the criticality analysis for the new fuel storage rack (Reference 1) and the criticality analysis for the spent fuel storage racks (Reference 2) demonstrate the maximum K-effective value for the new storage racks is 0.9205, and the spent fuel storage racks is 0.9207 (with borated water) and 0.9950 (with unborated water) which meet the ITAAC acceptance criteria.

### **ITAAC Finding Review**

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all ITAAC findings pertaining to the subject ITAAC and associated corrective actions. This review found that there are no relevant ITAAC findings associated with this ITAAC. The ITAAC completion review document number is included in the Vogtle Unit 3 ITAAC Completion Package for ITAAC 2.1.01.07.i (Reference 3) and available for NRC inspection.

### **ITAAC Completion Statement**

Based on the above information, SNC hereby notifies the NRC that ITAAC 2.1.01.07.i was performed for VEGP Unit 3 and that the prescribed acceptance criteria are met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

**References (available for NRC inspection)**

1. APP-GW-GLR-030, Rev. 0, New Fuel Storage Rack Criticality Analysis
2. APP-GW-GLR-029, Rev. 4, AP1000 Spent Fuel Storage Racks Criticality Analysis
3. SVP\_SV0\_003951, Attachment 1, Submittal of Inspections, Test, Analyses and Acceptance Criteria (ITAAC) Completion Package for Unit 3 ITAAC 2.1.01.07.i (COL Index Number 8) (FHS Fuel Storage Rack K-effective)