

Appendix 3H Auxiliary and Shield Building Critical Sections

3H.1 Introduction

[This appendix summarizes the structural design and analysis of structures identified as "Critical Sections" in the auxiliary and shield buildings. The design summaries include the following information:

- Description of buildings
- Governing codes and regulations
- Structural loads and load combinations
- Global analyses
- Structural design of critical structural elements

*Subsections 3H.2 through 3H.5 include a general description of the auxiliary building and shield building, a summary of the design criteria and the global analyses. The 3H.5 figures referenced in the descriptions show the structural designs for critical sections which are identified in subsection 3H.5 and shown in Figure 3H.5-1 (3 sheets). The exact locations of the critical sections related to the shield building cylinder are shown in Figure 3H.5-16. Representative design details are provided for these structures in subsection 3H.5.]**

3H.2 Description of Auxiliary and Shield Buildings

3H.2.1 Description of Auxiliary Building

[The auxiliary building is a reinforced concrete structure. The auxiliary building is one of the three buildings that make up the nuclear island and shares a common basemat with the containment building and the shield building. The auxiliary building general layout is shown in Figure 3H.2-1. It is a C-shaped section of the nuclear island that wraps around approximately half of the circumference of the shield building. The building dimensions are shown on key structural dimension drawings, Figure 3.7.2-12.

The auxiliary building is divided into six areas, which are identified in Figure 3H.2-1. It is a 5-story building; three stories are located above grade and two are located below grade. Areas 1 and 2 (Figure 3H.2-1) have five floors, including two floors below grade level. The lowest floor at elevation 66'-6" is used exclusively for housing battery racks. The next higher floor, at elevation 82'-6", also has battery racks and some electrical equipment. The floor at the grade level, elevation 100'-0", has electrical penetration areas, a remote shutdown workstation room, motor control centers, and some Division A and Division C equipment. The main control room is situated on the floor at elevation 117'-6", which also has rooms for the main steam and feedwater lines. The floor at elevation 135'-3" carries air filtration and air handling units, chiller pumps, and other mechanical and electrical equipment. The roof for areas 1 and 2 is at elevation 153'-0".

Areas 3 and 4 of the auxiliary building are the areas east of the containment shield building. Valve and piping areas, and some mechanical equipment, are located in the basement floor at elevation 66'-6". The floor at elevation 82'-6" has a piping penetration area, a radiation chemistry laboratory, makeup pumps, and other mechanical equipment. The floor at grade level elevation 100'-0" has an electrical penetration room, a staging area for the equipment hatch, and the access opening to the annex building. The electrical penetration area, trip switchgears, and other electrical equipment occupy most of the floor at elevation 117'-6". The floor at elevation 135'-3" is used for the

*NRC Staff approval is required prior to implementing a change in this information.

storage of main control room air cylinders and provides access to the annex building. The roof for these areas is at elevation 160'-6".

Areas 5 and 6 include facilities for storage and handling of new and spent fuel. The spent fuel pool, fuel transfer canal, and cask loading and cask washdown pits have concrete walls and floors. They are lined on the inside surface with stainless steel plate for leak prevention. *Interior structural walls and major floors are constructed using concrete filled steel plate modules, steel form modules, or reinforced concrete.* The new fuel storage area is a separate reinforced concrete pit providing temporary dry storage for the new fuel assemblies. A 150-ton cask handling crane travels in the east-west direction. The location and travel of this crane prevents the crane from carrying loads over the spent fuel pool to preclude them from falling into the spent fuel pool. Mechanical equipment is also located in this area for spent fuel cooling, residual heat removal, and liquid waste processing. This equipment is generally nonsafety-related.]*

3H.2.2 Description of Shield Building

The shield building is the structure and annulus area that surrounds the containment building. It shares a common basemat with the containment building and the auxiliary building. The shield building uses concrete-filled steel plate construction (SC) as well as reinforced concrete (RC) structure. The figures in [Section 1.2](#) show the layout of the shield building and its interface with the other buildings of the nuclear island.

[Figure 3.8.4-5](#) shows the following significant features and the principal systems and components of the shield building:

- Shield building cylindrical structure
- Shield building roof structure
- RC/SC connections
- Air inlets and tension ring
- Knuckle region (connection to exterior wall of PCS tank)
- Compression ring (connection to interior wall of PCS tank)
- Passive containment cooling system (PCS) water storage tank (PCCWST)

The overall configuration of the shield building is established from functional requirements related to radiation shielding, missile barrier, passive containment cooling, tornado, and seismic event protection. These functional requirements led to establishing the design based on two primary design codes used for nuclear plant structures: 1) ACI 349 for reinforced concrete design, and 2) ANSI/AISC N690 for structural steel design.

The shield building SC walls are anchored to the RC basemat and shield building RC wall by mechanical connections. These RC-to-SC connections are also used in the other regions of the shield building, including:

- Auxiliary building RC roof connection to the shield building SC wall
- Auxiliary building RC wall connection to shield building SC wall
- Tension ring connection to the shield building RC roof

The connections provide for the direct transfer of forces from the RC reinforcing steel to the SC liner plates.

The cylindrical shield wall has an outside radius of 72.5 feet and a thickness of 36 inches. The cylindrical wall section that is a few feet below the auxiliary building roof line is a reinforced concrete (RC) structure. The section that is not protected by the auxiliary building is a steel concrete (SC) composite structure (see [Figure 3H.5-16](#)). The overall thickness of 36 inches is the same as the RC

*NRC Staff approval is required prior to implementing a change in this information.

wall below. The concrete for the SC portion is standard concrete with compressive strength of 6000 psi. The SC portion is constructed with steel surface plates, which act as concrete reinforcement. The 0.75-inch tie bars are welded to the steel faceplates to develop composite behavior of the steel faceplates and concrete. The shear studs are welded to the inside surface of the steel plate. The tie bar spacing is reduced in the higher stress regions. A typical SC wall panel is shown in [Figure 3H.5-13](#).

The tension ring is located at the interface of the shield building steel concrete composite air inlet structures and the shield building reinforced concrete roof. The top of the tension ring interfaces with the RC roof slab. The tension ring supports the roof girders that are located under the RC roof slab. The bottom of the tension ring is attached to the air inlets structure. The bottom of the air inlets structure is attached to the top of the cylindrical SC wall of the shield building. The connection of the tension ring to the roof is of RC design and is described above.

The primary function of the tension ring is to resist the thrust from the shield building roof. The air inlets structure is located directly below the tension ring and includes the air openings that provide for natural circulation of cooling air. Though its steel plates are connected to the concrete infill by studs and tie bars, the tension ring is conservatively designed as a hollow steel box girder. The concrete infill is credited only for out-of-plane shear transfer and for stability of the steel plates. The tension ring is designed to have high stiffness and to remain elastic under required load combinations.

The air inlets structure is a 4.5-foot-thick SC structure with through-wall openings for air flow. The air inlet openings consist of circular pipes at a downward inclination of 38 degrees from the vertical. Steel plates on each face, aligned with the inner and outer flanges of the tension ring, serve as primary reinforcement. The concrete infill is connected to the steel plates with tie bars and studs. The top of the air inlets structure is welded to the underside of the tension ring. The bottom of the air inlets structure is welded to the SC wall.

The shield building conical roof steel structure consists of 32 radial beams. Between each pair of radial beams there are circumferential beams. A steel plate is welded to the top flanges of each beam and forms a surface on which the concrete is placed. The steel structure forms a conical shell that spans the area from the compression ring to the tension ring.

The outside diameter of the PCS tank (passive containment cooling water storage tank) intersects with the shield building roof at the knuckle region. Outside of the PCS tank, the concrete roof slab thickness is 3 feet and at the bottom of the PCS tank, the concrete thickness is 2 feet. The wall from the PCS tank applies a load to the roof slab, and also provides stiffness and increases the strength of the roof in that region.

The inside diameter of the PCS tank intersects with the roof slab at the compression ring. The compression ring provides the compression support for the conical roof dome. It consists of a composite structure having a curved steel beam section, which supports the concrete roof directly above it. The inside wall of the PCS tank is located above the concrete roof. Studs are placed on the top flange of the steel girder to allow the steel and concrete sections to act as a composite unit. The curved girder is designed to provide support for the steel structure during construction and during the initial placement of the concrete roof before the concrete has hardened sufficiently.

The PCS tank sits on top of the shield building roof. It is supported by and acts integrally with the conical roof. The inside surface has a liner that functions to provide leak protection, but is not required to provide structural strength to the structure. Leak chase channels are provided over the liner welds. The top elevation of the water inside the tank for the PCS has sufficient freeboard to preclude impact on the roof during the SSE.

3H.3 Design Criteria

[The auxiliary and shield building structures are reinforced concrete structures, structural modules, and horizontal concrete slabs supported by composite structural steel framing.]

- *Seismic forces are obtained from the response spectrum analysis of the three-dimensional finite element analysis models as described in [subsection 3H.4](#). The shear wall and floor slab design also considers out-of-plane bending and shear forces due to loading, such as live load, dead load, seismic, lateral earth pressure, hydrostatic, hydrodynamic, and wind pressure.*
- *The shield building roof and the passive containment cooling water storage tank are analyzed using three-dimensional finite element models with the ANSYS computer code]* as described in [subsection 3.8.4.4.1](#). [Loads and load combinations include construction, dead, live, thermal, wind, and seismic. The response spectrum analysis of the nuclear island is supplemented by equivalent static acceleration analysis of a more detailed model of a quadrant of the shield building roof. The results from the more detailed analysis are used in the evaluation of the tension ring, air inlets, and radial beams. The seismic response of the water in the tank is analyzed in a separate analysis with seismic input defined by the floor response spectrum.*
- *The structural steel framing is used primarily to support the concrete slabs and roofs. Metal decking, supported by the steel framing, is used as form work for the concrete slabs and roofs.*
- *The finned floors for the main control room and the instrumentation and control room ceilings are designed as reinforced concrete slabs in accordance with American Concrete Institute standard ACI 349. The steel panels are designed and constructed in accordance with American Institute of Steel Construction Standard AISC N690. For positive bending, the steel plate is in tension and the steel plate with fin stiffeners serves as the bottom reinforcement. For negative bending, compression is resisted by the stiffened plate and tension by top reinforcement in the concrete.]**

3H.3.1 Governing Codes and Standards

[The primary codes and standards used in the design of the auxiliary and shield buildings are listed below:]

- *ACI 349-01, "Code Requirements for Nuclear Safety Related Concrete Structures" (refer to [Subsection 3.8.4.5](#) for supplementary requirements and [Subsection 3.8.4.4.1](#) for alternative requirements).*
- *ANSI/AISC N690-1994, "Specification for the Design, Fabrication and Erection of Safety-Related Steel Structures for Nuclear Facilities" (refer to [subsection 3.8.4.5](#) for supplemental requirements). American Welding Society (AWS), Structural Welding Code - Steel, AWS D1.1-2000 provides an acceptable alternative for AISC N690 weld requirements as described in [Subsections 3.8.3.2 and 3.8.4.2](#).]**

3H.3.2 Seismic Input

The SSE design response spectra are given in [Figures 3.7.1-1 and 3.7.1-2](#). *[They are based on the Regulatory Guide 1.60 response spectra anchored to 0.30g, but are amplified at 25 Hertz to reflect larger high-frequency seismic energy content observed for eastern United States sites.]** The nuclear island seismic analyses are summarized in [Subsection 3.7.2](#).

*NRC Staff approval is required prior to implementing a change in this information.

3H.3.3 Loads

*[The auxiliary and shield buildings are seismic Category I structures. The loads listed in the following subsections are used for the design of the building structures. All the listed loads are not necessarily applicable to all structures and their elements. Loads for which each structural element is designed are based on the conditions to which that particular structural element is potentially subjected.]**

Dead Load (D):

[The weight of all permanent construction and installations, including fixed equipment, is included as the dead load during its normal operating condition.

*The weight of minor equipment (not specifically included in the dead load), piping, cables and cable trays, ducts, and their supports was included as equivalent dead load (EDL). A minimum of 50 pounds per square foot (psf) was used as EDL. For floors with a significant number of small pieces of equipment, the total weight of miscellaneous small pieces of equipment, divided by the floor area of the room plus an additional 50 psf was used as the equivalent dead load.]**

Earth Pressure (H):

*[The static earth pressure acting on the structures during normal operation is considered in the design of exterior walls. The dynamic soil pressure, induced during a safe shutdown earthquake (SSE), is included as a seismic load.]**

Live Loads (L):

[The load imposed by the use and occupancy of the building is included as the live load. Live loads include floor area loads, laydown loads, fuel transfer casks, equipment handling loads, trucks, railroad vehicles, and similar items. The floor area live load is not applied on areas occupied by equipment whose weight is specifically included in the dead load. Live load is applicable on areas under equipment where access is provided, for instance, the floor under an elevated tank supported on legs.

Floor loading diagrams are prepared for areas for component laydown. The diagrams show the location of major pieces of equipment and their foot-print loads or equivalent uniformly distributed loads.

The following live load items are considered in design:

A. Building floor loads

The following minimum values for live loads are used.

- Structural platforms and gratings 100 psf*
- Ground floors 250 psf*
- All other elevated floors 200 psf*
(This load is reduced if the equivalent dead load for the floor is more than 50 psf. The sum of the live load and the equivalent dead load is 250 psf.)

B. Roof loads

*NRC Staff approval is required prior to implementing a change in this information.

The roof is designed for a uniform snow load of 63 psf calculated in accordance with ASCE 7-98. This corresponds to ground snow load of 75 psf, exposure factor of 1.0, thermal factor of 1.0, and an importance factor of 1.2.

C. Concentrated loads for the design of local members

- Concentrated load on beams and girders (in load combinations that do not include seismic load) 5,000 pounds so applied as to maximize moment or shear. This load is not carried to columns or walls. It is not applied in areas where no heavy equipment will be located or transported, such as the access control areas.
- Concentrated load on slabs (considered with dead load only) 5,000 pounds so applied as to maximize moment or shear. This load is not carried to columns or walls. It is not applied in access control areas.

In design reconciliation analysis, if actual loads are established to be lower than the above loads, the actual loads are used for reconciliation.

D. Temporary exterior wall surcharge

When applicable, a minimum surcharge outside and adjacent to subsurface wall of 250 psf is applied.

E. Construction loads

The additional construction loads produced by cranes, trucks, and the like, with their pickup loads, are considered. For steel beams supporting concrete floors, the weight of the wet concrete plus 100 psf uniform load and 5,000 pounds concentrated load, distributed near points of maximum shear and moment, is applied. A one-third increase in allowable stress is permitted.

Metal decking and precast concrete panels, used as formwork for concrete floors are designed for the wet weight of the concrete plus a construction live load of 20 psf uniform or 150 pounds concentrated. The deflection during normal operation is limited to span in inches divided by 180, or 0.75 inch, whichever is less.

F. Crane loads

The impact allowance for traveling crane supports and runway horizontal forces is in accordance with AISC N690.

G. Elevator loads

The impact allowance used for the elevator supports is 100 percent, applied to design capacity and weight of car plus appurtenances, unless otherwise specified by the equipment supplier.

H. Equipment laydown and major maintenance

Floors are designed for planned refueling and maintenance activities as defined on equipment laydown drawings.]*

Wind Load

[The wind loads are as follows:

*NRC Staff approval is required prior to implementing a change in this information.

- *Design wind (W)*

For the design of the exterior walls, wind loads are applied in accordance with ASCE 7-98 with a basic wind speed of 145 mph. The importance factor is 1.15, and the exposure category is C. Wind loads are not combined with seismic loads.

- *Tornado load (W_t)*

*The exterior walls of the auxiliary and shield buildings are designed for tornado. A maximum wind speed of 300 mph (maximum rotational speed: 240 mph, maximum translational speed: 60 mph) is used to design the structures.]**

Seismic Loads (E_s)

*[The SSE (E_s) is used for evaluation of the structures of the auxiliary and shield buildings. E_s is defined as the loads generated by the SSE specified for the plant, including the associated hydrodynamic loads and dynamic incremental soil pressure.]**

Operating Thermal Loads (T_o)

[Normal thermal loads for the exterior walls and roofs are addressed in the design. These correspond to positive and negative linear temperature gradients with the inside surface at an average 70°F and the outside air temperature at -40°F and +115°F, respectively. These loads are considered for the seismic Category I structures in combination with the SSE also. All exterior walls of the nuclear island above grade not protected by adjacent buildings are designed for these thermal loads. The thermal gradient is also applied to the portion of the shield building between the upper annulus and the auxiliary building.

Normal thermal loads for the passive containment cooling system (PCS) tank design are calculated based on the outside air temperature extremes specified for the safety-related design. The PCS tank is assumed to be at 40°F when the outside air temperature is -40°F. The water in the PCS tank is assumed to be at 70°F when the outside air temperature is postulated to be at 115°F.

*Normal thermal loads due to a thermal gradient in the structures below the grade level (exterior walls and basemat) are small and are not considered in the design.]**

Effects of Pipe Rupture (Y)

[The evaluations consider the following loads:

- *Accident design pressure load, P_a , within or across a compartment and/or building generated by the postulated pipe rupture, including the dynamic effects due to the pressure time history.*

Main steam isolation valve (MSIV) and steam generator blowdown valve compartments are designed for a pressurization load of 6 pounds per square inch (psi).

- *Accident thermal loads, T_a , due to thermal conditions generated by the postulated pipe break and including T_o .*

Temperature gradients are based on an exterior air temperature of -40°F.

*The structural integrity of the west wall of the main control room is also evaluated for the jet impingement (Y_j)]**

*NRC Staff approval is required prior to implementing a change in this information.

3H.3.4 Load Combinations and Acceptance Criteria

[Concrete structures are designed in accordance with ACI 349 for the load combinations and load factors given in [Table 3.8.4-2](#). Steel structures are designed in accordance with AISC N690 for the load combinations and stress limit coefficients given in [Table 3.8.4-1](#). The following supplemental requirements are applied for the use of AISC N690:

- In Section Q1.0.2, the definition of secondary stress applies to stresses developed by temperature loading only.
- In Section Q1.3, where the structural effects of differential settlement are present, they are included with the dead load, *D*.
- In Table Q1.5.7.1, the stress limit coefficients for compression are as follows:
 - 1.3 instead of 1.5 in load combinations 2, 5, and 6
 - 1.4 instead of 1.6 in load combinations 7, 8, and 9
 - 1.6 instead of 1.7 in load combination 11
- In Section Q1.5.8, for constrained members (rotation and/or displacement constraint such that a thermal load causes significant stresses) supporting safety-related structures, systems, or components, the stresses under load combinations 9, 10, and 11 are limited to those allowed in Table Q1.5.7.1 as modified above.]*

3H.4 Seismic Analyses

[A global seismic analysis of the AP1000 nuclear island structure is performed to obtain building seismic response for the seismic design of nuclear safety-related structures. The seismic loads for the design of the shear walls and the slabs in the auxiliary building are based on a response spectrum analysis of the auxiliary building and the shield building 3D finite element models.]* This analysis is described in [Subsection 3.7.2](#). [For determining the out-of-plane seismic loads on flexible slabs and wall segments, spectral accelerations are obtained from time history analyses or from the relevant response spectra, using the 7 percent damping curve. Hand calculations are performed to estimate the out-of-plane seismic forces and the corresponding bending moment in each shear wall and floor slab element to supplement the loads obtained from the global seismic analysis.]*

3H.4.1 Live Load for Seismic Design

[Floor live loads, based on requirements during plant construction and maintenance activities, are specified varying from 50 to 250 pounds per square foot.

For the local design of members, such as the floors and beams, seismic loads include the response due to masses equal to 25 percent of the specified floor live loads or 75 percent of the roof snow load, whichever is applicable. These seismic loads are combined with 100 percent of the specified live loads, or 75 percent of the roof snow load, whichever is applicable. These live and snow loads are included as mass in calculating the vertical seismic forces on the floors and roof. The mass of equipment and distributed systems is included in both the dead and seismic loads.]*

3H.5 Structural Design of Critical Sections

[This subsection summarizes the structural design of representative seismic Category I structural elements in the auxiliary building and shield building. [Critical sections are listed below and the](#)

*NRC Staff approval is required prior to implementing a change in this information.

corresponding location numbers are shown on [Figure 3H.5-1](#) for twelve of the critical sections. Items 13 and 14 in the list below are located in the shield building cylinder and are discussed in APP-GW-GLR-602 (Reference 1). The basis for their selection to this list is also provided for each critical section.

- (1) South wall of auxiliary building (column line 1), elevation 66'-6" to elevation 180'-0". (This exterior wall illustrates typical loads such as soil pressure, surcharge, temperature gradients, seismic, and tornado.) – see [subsection 3H.5.1.1](#) and [Figures 3H.5-2](#) and [3H.5-3](#)
- (2) Interior wall of auxiliary building (column line 7.3), elevation 66'-6" to elevation 160'-6" (This is one of the most highly stressed shear walls.) – see [subsection 3H.5.1.2](#) and [Figure 3H.5-4](#)
- (3) West wall of main control room in auxiliary building (column line L), elevation 117'-6" to elevation 153'-0". (This illustrates design of a wall for subcompartment pressurization.) – see [subsection 3H.5.1.3](#) and [Figure 3H.5-12](#)
- (4) North wall of MSIV east compartment (column line 11 between column lines L and M), elevation 117'-6" to elevation 153'-0". (The main steam line is anchored to this wall segment.) – see [subsection 3H.5.1.4](#) and [Figure 3H.5-5](#)
- (5) Roof slab at elevation 180'-0" adjacent to shield building cylinder. (This is the connection between the two buildings at the highest elevation.) – see [subsection 3H.5.2.1](#) and [Figure 3H.5-7](#)
- (6) Floor slab on metal decking at elevation 135'-3". (This is a typical slab on metal decking and structural steel framing.) – see [subsection 3H.5.2.2](#) and [Figure 3H.5-6](#)
- (7) 2'-0" slab in auxiliary building (operations work area (tagging room) ceiling) at elevation 135'-3". (This illustrates the design of a typical 2'-0" thick concrete slab.) – see [subsection 3H.5.3.1](#) and [Figure 3H.5-8](#). (Note: The 'Tagging Room' has been renamed as "Operations Work Area." However, to avoid changing the associated design and analysis documents, this room is referred to as the 'Tagging Room'.)
- (8) Finned floor in the main control room at elevation 135'-3". (This illustrates the design of the finned floors.) – see [subsection 3H.5.4](#) and [Figure 3H.5-9](#)
- (9) Shield building roof/exterior wall of PCS water storage tank. (This is a unique area of the roof and water tank.) – see [subsection 3H.5.6.3](#)
- (10) Shield building roof/interior wall of PCS water storage tank. (This is a unique area of the roof and water tank.) – see [subsection 3H.5.6.2](#)
- (11) Shield building roof, tension ring, and air inlet. (This is the junction between the shield building roof and the cylindrical wall of the shield building.) – see [subsections 3H.5.6](#) and [3H.5.6.1](#)
- (12) Divider wall between the spent fuel pool and the fuel transfer canal. (This wall is subjected to thermal and seismic sloshing loads.) – see [subsection 3H.5.5.1](#) and [Figure 3H.5-10](#)
- (13) Shield building SC cylinder is the exposed portions of the shield building that are not protected by the Auxiliary Building and is a steel concrete composite structure – see [subsection 3H.5.7.1](#), [Figure 3H.5-16](#), and [Figures 5 and 6 of APP-GW-GLR-602 \(Reference 1\)](#)

*NRC Staff approval is required prior to implementing a change in this information.

- (14) *Shield building SC to RC connection is the region of the shield building that anchors the SC cylindrical wall modules to the RC basemat and wall of the shield building – see subsection 3H.5.7.2, Figure 3H.5-16, and Figures 1, 2, and 3 of APP-GW-GLR-602 (Reference 1)*

*The design implemented in fabrication and construction drawings and instructions will have the design shown, an equal design, or a better design for the key structural elements.]**

3H.5.1 Shear Walls

Structural Description

[Shear walls in the auxiliary building vary in size, configuration, aspect ratio, and amount of reinforcement. The stress levels in shear walls depend on these parameters and the seismic acceleration level. The range of these parameters and the stress levels in various regions of the most severely stressed shear wall are described in the following paragraphs.

The height of the major structural shear walls in the auxiliary building ranges between 30 to 120 feet. The length ranges between 40 and 260 feet. The aspect ratio of these walls (full height/full length) is generally less than 1.0 and often less than 0.25. The walls are typically 2 to 5 feet thick, and are monolithically cast with the concrete floor slabs, which are 9 inches to 2 feet thick. Exterior shear walls are several stories high and do not have many large openings. Interior shear walls, however, are discontinuous in both vertical and horizontal directions. The in-plane behavior of these shear walls, including the large openings, is adequately represented in the analytical models for the global seismic response. Where the refinement of these finite element models is insufficient for design of the reinforcement, for example in walls with a large number of openings, detailed finite element models are used.

*The shear walls are used as the primary system for resisting the lateral loads, such as earthquakes. The auxiliary building shear walls are also evaluated for flexure and shear due to the out-of-plane loads.]**

Design Approach

[The auxiliary building shear walls are designed to withstand the loads specified in subsection 3H.3.3. Beside dead, live, and other normal operating condition loads, the following loads are considered in the shear wall design:

- *Seismic loads*
 - *The SSE loads for the wall are obtained from the seismic analyses of auxiliary/shield buildings that are described in subsection 3H.4.*
 - *Calculations are performed by considering shear wall segments bounded by the floors below and above the segment and the adjacent walls perpendicular to, on both sides of, the segment under consideration. Appropriate boundary conditions are assumed for the four edges of the segment. Natural frequencies of wall segments are determined using finite element models or text book formulas for the frequency of plate structures. Corresponding spectral acceleration is determined from the applicable response spectrum.*
 - *Exterior walls, below grade level, are also evaluated for dynamic earth pressure exerted during an SSE for two cases:*
 - *Dynamic earth pressure calculated in accordance with ASCE 4-98*

*NRC Staff approval is required prior to implementing a change in this information.

- *Passive earth pressure*
- *Accident pressure load*
 - *Shear walls of the main steam isolation valves (MSIV) rooms are designed for 6 pounds per square inch (psi) differential pressure acting in conjunction with the seismic loads. Member forces due to accident pressure and SSE are combined by absolute sum.*
 - *The main control room wall of the east MSIV compartment is evaluated for the pressure and the jet load due to a postulated main steamline break.*
- *Tornado load*

For exterior walls above grade level, tornado loads are considered.

The design temperatures for thermal gradient are included in [Table 3H.5-1](#).

*The shear walls are designed for the load combinations, as applicable, contained in [Table 3.8.4-2](#). The wall sections are designed in accordance with the requirements of ACI 349-01.]**

3H.5.1.1 Exterior Wall at Column Line 1

[The wall at column line 1 is the exterior wall at the south end of the nuclear island. The reinforced concrete wall extends from the top of the basemat at elevation 66'-6" to the roof at elevation 180'-0". It is 3'-0" thick below the grade and 2'-3" thick above the grade.

*The wall is designed for the applicable loads including dead load, live load, hydrostatic load, static and dynamic lateral soil pressure loads, seismic loads, and thermal loads. For various segments of this wall, [Table 3H.5-2](#) provides the listing and magnitude of the various design loads and [Table 3H.5-3](#) presents the details of the wall reinforcement. The sections where the required reinforcement is calculated are shown in [Figure 3H.5-2](#) (Sheet 1). Typical wall reinforcement is shown on [Figure 3H.5-3](#).]**

3H.5.1.2 Wall at Column Line 7.3

[The wall at column line 7.3 is a shear wall that connects the shield building and the nuclear island exterior wall at column line I. It extends from the top of the basemat at elevation 66'-6" to the top of the roof. The wall is 3 feet thick below the grade at elevation 100'-0" and 2 feet thick above the grade. Out-of-plane lateral support is provided to the wall by the floor slabs on either side of it and the roof at the top.

The auxiliary building design loads are described in [Section 3H.3.3](#), and the wall is designed for the applicable loads.

*For various segments of this wall, the corresponding governing load combination and associated design loads are shown in [Table 3H.5-4](#). [Table 3H.5-5](#) presents the details of the wall reinforcement. The sections where the required reinforcement is calculated are shown in [Figure 3H.5-2](#) (Sheet 2). Typical wall reinforcement is shown on [Figure 3H.5-4](#).]**

3H.5.1.3 Wall at Column Line L

[The wall at column line L is a shear wall on the west side of the Main Control Room. It extends from the top of the basemat at elevation 66'-6" to the top of the roof. The wall is 2 feet thick. Out-of-plane lateral support is provided to the wall by the floor slabs on either side of it and the roof at the top. The

*NRC Staff approval is required prior to implementing a change in this information.

segment of the wall that is a part of the main control room boundary is from elevation 117'-6" to elevation 135'-3".

The auxiliary building design loads are described in [subsection 3H.3.3](#), and the wall is designed for the applicable loads. In addition to the dead, live and seismic loads, the wall is designed to withstand a 6 pounds per square inch pressure load due to a pipe break in the MSIV room even though it is a break exclusion area. This wall segment is also designed to withstand a jet load due to the pipe break.

The governing load combination and associated design loads are those due to the postulated pipe rupture and are shown in [Table 3H.5-6](#), [Table 3H.5-7](#) and [Figure 3H.5-12](#) present the details of the wall reinforcement. The sections where the required reinforcement is calculated are shown in [Figure 3H.5-2](#) (Sheet 3).]*

3H.5.1.4 Wall at Column Line 11

[The north wall of the MSIV east compartment, at column line 11 between elevation 117'-6" and elevation 153'-0", has been identified as a critical section.

The segment of the wall between elevation 117'-6" and elevation 135'-3" is 4 feet thick, and several pipes such as the main steam line, main feed water line, and the start-up feed water line are anchored to this wall at the interface with the turbine building.

The wall segment from elevation 135'-3" to elevation 153'-0" does not provide support to any high energy lines, and is 2 feet thick. This portion does not have to withstand reactions from high energy line breaks.

The wall is designed to withstand loads such as the dead load, live load, seismic load and the thermal load. The MSIV room is a break exclusion area, but the design also considered the loads associated with one square foot pipe rupture in the MSIV room, such as compartment pressurization, jet load, and the reactions at the pipe anchors. The loads on the pipe anchor include pipe rupture loads for breaks in the turbine building.

The wall structure is analyzed using three dimensional finite element analyses supplemented by hand calculations. Analyses are performed for individual loads, and design loads are determined for applicable load combinations from [Table 3.8.4-2](#).

Typical wall reinforcement is shown in [Figure 3H.5-5](#).]*

3H.5.2 Composite Structures (Floors and Roof)

[The floors consist of a concrete slab on metal deck, which rests on structural steel floor beams. Several floors in the auxiliary building are designed as one-way reinforced concrete slabs supported continuously on steel beams. Typically, the beams span between two reinforced concrete walls. The beams are designed as composite with formed metal deck spanning perpendicular to the members. Unshored construction is used. For the floors, beams are predominately spaced at about 5- to 6-foot intervals and spans are between 15 feet and 25 feet. Based on local geometry considerations the intervals and spans are outside these ranges in a limited number of locations. The spacing between the beams or between beams and walls is as small as 3 feet and as large as 8 feet. The span of the beams is as small as 2 feet, 6 inches and as large as 38 feet, 6 inches. The designs of the beams satisfy the requirements in AISC N690 for composite structures.]*

*NRC Staff approval is required prior to implementing a change in this information.

Structural Description

[A typical layout of these floors is shown in [Figure 3H.5-6](#). The metal deck rests on the top flange of the structural steel floor beam, with the longitudinal axes of the metal deck ribs and floor beams placed perpendicular to each other. [Figure 3H.5-6](#) shows the key structural elements in composite floors. The reinforcement size and spacing are based on loads and spans for this type of floor and are determined at each location based on the requirements in ACI 349 and ACI 318-11, Section 12.6. The development of the floor reinforcement in the walls can be either headed reinforcement or standard hooks. The beam size and spacing and beam support designs are based on loads and spans for this type of floor as noted on the figure. The beam support designs include beam seats or shear plates connected to the web of the beam. The detail design of the support for the beam, including the portion embedded in the concrete wall, is based on the load and structural system configuration as noted on the figure. The designs of these floors are in conformance with AISC N690 and ACI 349. The depth of the ribs for 9-inch concrete floor slabs, 9.5-inch concrete floor slabs, and 15-inch deep concrete roof slabs are 3 inches, 2.5 inches, and 4.5 inches respectively. The concrete slab is tied to the structural steel floor beam by shear connectors, which are welded to the top flange of the floor beam. The concrete slab and the floor beams form a composite floor system. For the design loads after hardening of concrete, the transformed section is used to check the stresses.

The construction sequence is as follows:

- The structural steel floor (floor beam, metal deck, and shear connectors) is fabricated in the shop, brought to the floor location, and placed in position. In some cases, the beams and deck are preassembled and placed as a module.
- The metal deck is used as the formwork, and concrete is poured on the metal deck. Until concrete hardens, the load is carried by the metal deck and the steel floor beam.
- During concreting, no shoring is provided.]*

Design Approach

[The floor design considers the dead, live, construction, extreme environmental, and other applicable loads identified in [Section 3H.3.3](#). The design floor loading includes the equipment attached to the floor. The end condition for the steel beams is simply supported, or continuous. The seismic load is obtained using the applicable floor acceleration response spectrum (7 percent damping for the SSE loads).

The load combinations applicable to the design of these floors are shown in [Tables 3.8.4-1](#) and [3.8.4-2](#). The design of the floor system is performed in two parts:

- Design of structural steel beams
 - The structural steel floor beams are evaluated to withstand the weight of wet concrete during the placement of concrete. The composite section is designed for the design loads during normal and extreme environment conditions. Shear connectors are also designed.
- Design of concrete slab
 - The concrete slab and the steel reinforcement of the composite section are evaluated for normal and extreme environmental conditions. The slab concrete and the reinforcement is designed to meet the requirements of American Concrete Institute standard ACI 349-01 "Code Requirements for Nuclear Safety Related Concrete Structures."

*NRC Staff approval is required prior to implementing a change in this information.

- *The slab design considers the in-plane and out-of-plane seismic forces. The global in-plane and out-of-plane forces are obtained from the response spectrum analysis of the 3D finite element model of the auxiliary and shield buildings. The out-of plane seismic forces due to floor self-excitation are determined by hand calculations using the applicable vertical seismic response spectrum and slab frequency.]**

3H.5.2.1 Roof at Elevation 180'-0", Area 6 (Critical Section is between Col. Lines N & K-2 and 3 & 4)

[The layout of this segment of the roof is shown in Figure 3H.5-7 as Region "B." The concrete slab is 15 inches thick, plus 4.5-inch deep metal deck ribs. It is composite with 5 feet deep plate girders, spaced 14'-2" center to center, by using shear connectors. The girder flanges are 20" x 2" and the web is 56" x 7/16". The girders span approximately 64 feet in the north-south direction and are designed as simply supported. The concrete slab between the girders behaves as a one-way slab and is designed to span between the girders.

The roof girders are designed for dead and live loads, including construction loads (with wet concrete) with simple support end conditions. A one-third increase in allowable stress is permitted for the construction load combination.

The girders are also evaluated as part of the composite beam after drying of concrete. The composite roof structure is designed to withstand dead and live load / snow load, as well as the wind, tornado and seismic loads.

*A typical connection of the roof slab to the shield building is shown in Figure 3H.5-7. The figure shows the arrangement of reinforcement at the connection in the fuel building portion of the auxiliary building roof, the shield building cylindrical wall, and the walls of the auxiliary building just below the roof. The design summary is shown in Table 3H.5-10. The details of the connections between the auxiliary building roof and the shield building wall in other locations vary because of loads on the connection and the orientation of the wall to the roof reinforcement arrangement. These connection design details satisfy the requirements identified in Subsection 3.8.4.5.5.6.]**

3H.5.2.2 Floor at Elevation 135'-3", Area 1 (Between Column Lines M and P)

[The design of a typical composite floor is shown in Figure 3H.5-6. The design summary for the floor between column lines M and P at elevation 135'-3" is shown in Table 3H.5-11. The concrete slab is 9 inches thick, plus 3-inch deep metal deck ribs. The floor beam size is shown on the figure.

- *The floor beams are designed for construction load (with wet concrete) with simple support end conditions. The design loads include the dead load and a construction live load of 100 pounds per square foot (psf) distributed load plus 5000 pounds concentrated load near the point of maximum shear and moment. A one-third increase in allowable stress is permitted.*
- *The floor beams are also designed as part of the composite beam after drying of the concrete. Because of continuity of rebars into the wall and the connection of the bottom flange to the support embedment, the end support condition is considered as fixed.]**

3H.5.3 Reinforced Concrete Slabs

[Reinforced concrete floors in auxiliary building are 24 inch or 36 inch thick. These floors are constructed with reinforced concrete placed on the top of 8 to 12 inch thick precast concrete panels. The precast concrete panels are installed at the bottom to serve as the formwork and withstand the load of wet concrete slab. The spans of the floors are predominately 13 feet to 20 feet, and the

*NRC Staff approval is required prior to implementing a change in this information.

precast panels are predominately 7 to 14 feet wide. Based on local geometry considerations, the widths and spans are outside these ranges in a limited number of locations. The spans of the floor are as small as 5 feet and as large as 21 feet. The width of the precast panels is as small as 4 feet and as large as 19 feet. The number of side-by-side precast panels ranges from one to eight.

Examples of such floors are the Operations Work Area (Tagging Room) ceiling slab at elevation 135 ft 3 inches in Area 2, and the Area 5/6 elevation 100'-0" slab between column lines 1 & 2.

Figure 3H.5-8 shows the key structural elements in reinforced concrete floor slabs. The precast panels and the cast-in-place concrete are designed to act together as a composite reinforced slab so that the floor dynamic response is consistent with the auxiliary building finite element analysis. However, the precast panels are neglected in determining floor strength and load carrying capacity. The reinforcement size and spacing are determined for each location, based on specific loads and spans, and satisfy the requirements in ACI 349 and ACI 318-11, Section 12.6. The floor thickness and precast panel thickness for this type of floor are based on specific loads and spans as noted on the figure. The type and thickness of adjacent walls and floors vary as noted on the figure. The main reinforcement is provided in the cast-in-place concrete. Reinforcement is placed in both the top and bottom layers of the cast-in-place concrete in both directions. For the design of the reinforcement in the cast-in-place floors, post-construction loads are conservatively assumed to be resisted only by the cast-in-place concrete and the reinforcement placed within it. The reinforcement in the cast-in-place portion is fully developed into supporting adjacent walls such that the connection is assumed to be a fixed connection. The development of the floor reinforcement in the walls is achieved using either headed reinforcement or standard hooks.

The precast panel reinforcement is designed to resist the weight of the panel and the wet weight of the cast-in-place concrete during construction. Reinforcement is placed within the precast panel portion in both top and bottom layers in both directions. The precast panel reinforcement is contained within the panel. The reinforcement is discontinuous with a design gap between adjacent precast panels and between precast panels and walls. The precast panels are connected to the concrete placed above them by shear reinforcement which satisfies the requirements of ACI 349 Chapter 17. The precast panels and the cast-in-place concrete are made to act together as a composite reinforced concrete slab by roughening the top surface of the precast panel and providing shear ties between the two elements. The detail designs of the supports for the precast panels are based on the loading and design requirements. The design of these floors is in conformance with AISC N690 and ACI 349.

The finite element analysis model used for the auxiliary building seismic response assumes a homogenous thickness of concrete for the floor system, and includes floor-to-wall connections that are fixed over the full thickness of the reinforced concrete floor. The detailed design of the floor system includes a gap between the precast panel and the wall and between adjacent precast panels. Although the gap between the precast panels and the wall reduces the thickness of the floor in direct contact with the wall, the design of the floor system satisfies the requirements of ACI 349, including fully developing the floor reinforcement in the wall. The design of the floor system and the connection with the wall provide a fixed connection that transfers forces and moments from the floor to the wall.

Detailed analysis of the floor system connection design details, including the gap between the precast panel and wall is performed for the floor constructed with precast panels and is consistent with the nuclear island seismic model. The effects of stiffness, reinforcement anchorage, and concrete cracking are considered in the detailed analyses. The detailed analyses demonstrate that these floors have vertical response above 33 Hz and are rigid, which is consistent with the nuclear island seismic model.]*

*NRC Staff approval is required prior to implementing a change in this information.

3H.5.3.1 Operations Work Area (Tagging Room) Ceiling

The tagging room (room number 12401) location is shown on [Figure 1.2-8](#). [[Figure 3H.5-8](#) shows the typical cross section and reinforcement. [The design summary for this location is shown in Table 3H.5-12](#). Design dimensions of the Operations Work Area (Tagging Room) Ceiling are as follows:

Room Size:	16'-0" x 11'-10"
Boundary Conditions:	Fixed at Walls J and K
Clear Span:	16'-0"
Slab Thickness:	Total = 24 inches
	Precast Panel = 8 inches
	Cast-in-Place = 16 inches

*The two precast concrete panels, each 5'-11" wide and spanning over 16'-0" clear span, are installed to serve as the formwork.]**

3H.5.4 Concrete Finned Floors

[The ceilings of the main control room and the instrumentation and control rooms in the auxiliary building are designed as finned-floor modules. A typical floor design is shown in [Figure 3H.5-9](#). A finned floor consists of a 24-inch-thick concrete slab poured over a stiffened steel plate ceiling. The fins, welded to stiffen the steel plate, are half inch by 9 inch rectangular sections perpendicular to the plate. Shear studs are welded on the other side of the steel plate, and the steel and concrete act as a composite section. The fins are exposed to the environment of the room and enhance the heat-absorbing capacity of the ceiling. Several shop-fabricated steel panels, cut to room width and placed side by side perpendicular to the room length, are used to construct the stiffened plate ceiling in a modularized fashion. The stiffened plate with fins is designed to withstand construction loads prior to concrete hardening.

The main control room ceiling fin floor is designed for the dead, live, and the seismic loads. The design summary is shown in [Table 3.H.5-13](#).

*The finned floor structure is evaluated for the load combinations listed in [Tables 3.8.4-1](#) and [3.8.4-2](#).]**

Design Methodology

[The finned floors are designed as reinforced concrete slabs in accordance with ACI Standard 349. For positive bending, the steel plate is in tension. The steel plate with fin stiffeners serves the function of bottom rebars. For negative bending, the potential for buckling due to compression in this element is checked by using the criteria of American National Standards Institute/American Institute of Steel Construction standards ANSI/AISC N690-94. Twisting, and therefore lateral buckling of the stiffener, is restrained by the concrete.

The finned floors resist vertical and in-plane forces for both normal and extreme loading conditions. For positive bending, the concrete above the neutral axis carries compressive stresses and the stiffened steel plate resists tension. Negative bending compression is resisted by the stiffened plate and tension by top rebars in the concrete. The neutral axis for negative bending is located in the stiffened plate section, and the concrete in tension is assumed inactive. Horizontal in-plane forces are resisted by the stiffened plate and longitudinal rebars.

*NRC Staff approval is required prior to implementing a change in this information.

Minimum top reinforcement is provided in the slab in each direction for shrinkage and temperature crack control. In addition, top reinforcement located parallel to the stiffeners is used as tension reinforcement in negative bending. The stiffened plate provides crack control capability for the bottom of the slab in the transverse direction.

Composite section properties, based on an all steel-transformed section, as detailed in Section Q1.11 of ANSI/AISC N690-94, are used to design the following:

- Weld strength between stiffener and the steel plate
- Spacing of the shear studs for the composite action

The stiffened plate alone is designed to resist all construction loads prior to the concrete hardening. The plate is designed against the criteria for bending and shear, specified in ANSI/AISC N690-94, Sections Q1.5.1.4 and Q1.5.1.2. In addition, the weld between the stiffener and the steel plate is designed to satisfy the code requirements.]*

3H.5.5 Structural Modules

[Structural modules are used for some of the structural elements on the south side of the auxiliary building. These structural modules are structural elements built up with welded steel structural shapes and plates. The modules consist of steel faceplates connected by steel trusses as shown in [Figure 3.8.3-2](#). The primary purpose of the trusses is to stiffen and hold together the faceplates during handling, erection, and concrete placement. The thickness of the steel faceplates is 0.5 inch except in a few local areas. The nominal spacing of the trusses is 30 inches. Shear studs are welded to the inside faces of the steel faceplates. Faceplates are welded to adjacent faceplates with full penetration welds so that the weld is at least as strong as the plate. The structural wall modules are anchored to the concrete base by reinforcing steel dowels or other types of connections embedded in the reinforced concrete below. After erection, concrete is placed between the faceplates.

These modules include the spent fuel pool, fuel transfer canal, and cask loading and cask washdown pits. The structural modules are similar to the structural modules for the containment internal structures (see description in [subsection 3.8.3](#) and [Figures 3.8.3-8](#), [3.8.3-14](#), [3.8.3-15](#) and [3.8.3-17](#)). [Figure 3.8.4-4](#) shows the location of the structural modules in the auxiliary building. The structural modules extend from elevation 66'-6" to elevation 135'-3".

The loads and load combinations applicable to the structural modules in the auxiliary building are the same as for the containment internal structures]* ([Subsection 3.8.3.5.3](#)) [except that there are no ADS nor pressure loads due to pipe breaks.

The design methodology of these modules in the auxiliary building is similar to the design of the structural modules in the containment internal structures]* described in [Subsection 3.8.3.5.3](#).

3H.5.5.1 West Wall of Spent Fuel Pool

[[Figure 3H.5-10](#) shows an elevation of the west wall of the spent fuel pool (column line L-2), and element numbers in the finite element model. The wall is a 4 feet thick concrete filled structural wall module.

A finite element analysis is performed for seismic, thermal, and hydrostatic loads with the following assumptions:

- The seismic in-plane and out-of-plane forces are obtained from the response spectrum analysis of the 3D finite element model of the auxiliary and shield buildings.

*NRC Staff approval is required prior to implementing a change in this information.

- The thermal loads are applied as linearly varying temperatures between the inner and outer faces of the walls and floors.
- The hydrostatic loads are applied to the spent fuel pool walls and floors, which is considered full with water. This provides the loads for the design of the divider wall.
- The seismic sloshing is modeled in the spent fuel pool.

The concrete filled structural wall modules are designed as reinforced concrete structures in accordance with the requirements of ACI-349. The face plates are treated as reinforcing steel.

Methods of analysis are based on accepted principles of structural mechanics and are consistent with the geometry and boundary conditions of the structures. Both computer codes and hand calculations are used.

Table 3H.5-8 shows the required plate thickness for certain critical locations. The steel plates are half inch thick.]*

3H.5.6 Shield Building Roof and Connections

[The shield building roof is a reinforced concrete shell (supporting the passive containment cooling system tank and air diffuser), which is supported on a structural steel module. The structural configuration is shown on sheets 7, 8, and 9 of **Figure 3.7.2-12**. Air intakes are located at the top of the cylindrical portion of the shield building. The conical roof supports the passive containment cooling system tank. The conical roof is constructed as a structural steel module and lifted into place during construction. Steel beams provide permanent structural support for steel liner and concrete. The concrete is cast in place. Connection between concrete and steel liner are made using shear studs.

The design of the shield building is shown in **Figure 3H.5-11** (Sheets 1-6). These figures show the typical details of the “Tension Ring,” the “Air Inlet Structure,” and the “Exterior Wall of the Passive Containment Cooling System Tank.” **Figure 3H.5-16**, Sheets 1 and 2, also shows the typical dimensions of the surface plates and the SC to RC connections on the shield building cylindrical segment.]* The column line and auxiliary building roof information in **Figure 3H.5-16** is shown for reference and is not Tier 2* information.

[A detailed ANSYS model was used to represent these components of the enhanced design. Analyses were performed to determine the response of the structures for the dead weight, hydrostatic load due to PCS water, snow load, wind load, tornado load, seismic load (including seismic-induced pressure on PCS wall), and thermal loads. The design was evaluated to comply with the requirements of ANSI/AISC N690-94 and of ACI 349-01.

The design summaries of the components are included in **Table 3H.5-9**.

The steel frame for the shield building roof and the concrete placed directly thereon is designed to AISC N690.

- In the radial direction, the steel beams, the steel surface plate, and the concrete are evaluated as a composite section using the axial and bending member forces in the steel and concrete section from the finite element analyses. The steel stresses and the end connection are calculated assuming the steel alone resists all loads applied before the concrete has reached 75 percent of its required strength and the effective composite section resists all loads applied after that time.

*NRC Staff approval is required prior to implementing a change in this information.

- *The concrete is evaluated using all member forces in the concrete and surface steel plate from the finite element analyses (in-plane and out-of-plane forces and moments). The circumferential channels are provided for construction only and are not modeled in the finite element analysis or credited for resisting permanent loads. The concrete section is evaluated by the strength method of ACI-349. The steel plate is not considered as reinforcement in the circumferential direction.*

*Additional information is provided in [Table 3H.5-15](#).]**

3H.5.6.1 Air Inlets and Tension Ring

[The configuration and plate size of the air inlets enhance their structural performance. The air inlets structure (as shown on [Figure 3H.5-14](#)) is located at the top of the cylindrical wall portion of the shield building, beginning at approximately elevation 251' and rising to approximately elevation 266'. The air inlets serve as the intake for air as part of the PCS.

Above the air inlets, at approximately elevation 266', is the connection designated as the tension ring that connects and supports the conical roof. The tension ring also contains 32 radial beam seat connections where the W36 x 393 radial beams for the conical roof are connected.

The air inlets region is 4.5-feet thick with steel plates on each face as the primary reinforcement, which are connected using tie bars. Near the bottom of the air inlet structure, the thickness transitions to 3 feet thick to connect with the shield building cylinder. The air inlet openings are formed using pipe at a downward inclination of 38 degrees from the vertical. The pipe spacing is approximately 2.81 degrees circumferentially with shear studs welded to the outside surface of the pipes. The tie bars are located with three bars between adjacent air inlets at each elevation at maximum design spacing of 8.5 inches vertically. At approximately the same elevations as the tie bars, two 3/4-inch by 6-inch (minimum) shear studs are located between the tie bars except at elevations where there is interference with the air inlet pipes. Tie bars and studs may be omitted in local areas due to design features and other obstructions.

*The tension ring is designed as a structural steel box structure with concrete infill and shear studs. Also the connection of the RC conical roof to the tension ring is designed to be a mechanical connection. The air inlets and tension ring design methodology is supported by linear analysis and benchmarked nonlinear analysis. The tension ring is designed to ANSI/AISC N690 and is a concrete-filled box girder, with two continuous 1.5-inch-thick steel plates top and bottom, which connect the inner liner plate to the outer liner plate, as shown in [Figure 3H.5-15](#).]**

3H.5.6.2 Compression Ring and Interior Wall of Passive Containment Cooling Water Storage Tank

[The other areas of the shield building are designed to existing industry code requirements, and include the conical roof, the passive containment cooling water storage tank, the compression ring, the knuckle region, and their related attachments. These areas are designed as RC structures in accordance with ACI 349. The steel frame for the roof is designed for the applicable building code ANSI/AISC N690. The concrete roof is designed to ACI 349 requirements without credit for the steel plate on the bottom of the concrete. The configuration and reinforcement of the compression ring and the connection to the interior wall of the passive containment cooling water storage tank is shown in [Figure 3H.5-11](#).

*Additional information is provided in [Table 3H.5-15](#).]**

*NRC Staff approval is required prior to implementing a change in this information.

3H.5.6.3 Knuckle Region and Exterior Wall of Passive Containment Cooling System Tank

[The exterior wall of the passive containment cooling system tank is two feet thick. The wall starts at the tank floor elevation of 293' 9". There is a stainless steel liner on the inside surface of the tank. The wall liner consists of a plate with stiffeners and welded studs on the concrete side of the plate. Leak chase channels are provided over the liner welds. The reinforcement in the concrete wall is designed without taking credit for the strength provided by the liner. The governing loads for design of the exterior wall are the hydrostatic pressure of the water, the in-plane and out-of-plane seismic response, and the temperature gradient across the wall. The reinforcement is shown in [Figure 3H.5-11](#). The reinforcement required and the reinforcement provided is summarized in [Table 3H.5-9](#).

Additional information is provided in [Table 3H.5-15](#).]*

3H.5.7 Shield Building Cylinder (SC)

3H.5.7.1 Shield Building Cylindrical Wall

[The shield building surrounds the containment vessel and shares a common basemat with the containment vessel and the auxiliary building. The cylindrical shield wall has an outside radius of 72.5 feet and a thickness of 36 inches. The cylindrical wall section that is below the auxiliary building roof line is a reinforced concrete structure. The section that is not protected by the auxiliary building is a steel concrete composite structure, where two 0.75-inch plates act compositely with 34.5 inches of concrete via tie bars and shear studs. The steel plate modules are connected to the reinforced concrete basemat and walls by mechanical connectors as described below.

A typical configuration of the SC wall is shown in [Figure 3H.5-13](#). The overall thickness of 36 inches is the same as the RC wall below. The concrete for the SC portion is standard concrete with a compressive strength of 6000 psi. The SC portion is constructed with steel surface plates, which act as concrete reinforcement. The nominal thickness of the steel faceplates is 0.75 inches. *The faceplates are thicker (up to 1.0-inch nominal thickness), as necessary, to address loads from connections and attachments in the areas of these local loads.* In each module, tie bars are welded to the steel faceplates to develop composite behavior of the steel faceplates and concrete. The shear studs are welded to the inside surface of the steel plate to provide composite action. The tie bars are at closer spacing in the higher stress regions. The reinforcement detailing incorporates ACI 349 requirements.

The panels of the SC wall are welded together with a complete joint penetration weld.

The wall is designed for the applicable loads described in [subsection 3H.3.3](#). A finite element analysis is performed to determine the design forces.

[Table 3H.5-14](#) shows the design summary for the enhanced shield SC cylindrical wall. The three sheets represent locations in the shield building cylinder that have some of the largest demands due to mechanical loads. The element on the west side at grade near the RC/SC connection has large tension forces due to overturning of the cylinder under seismic demand. This area is one of the most stressed elements in tension. The element near the fuel handling building roof at elevation 180' is an element with high out-of-plane shear due to the interaction between the fuel handling building and the cylinder during an earthquake. This element is located close to the fuel building roof. The element above wall 7.3 at elevation 175' has the largest demand for out-of-plane shear in the general part of the cylindrical wall away from the SC/RC connection and the interface with the auxiliary building roof.

*NRC Staff approval is required prior to implementing a change in this information.

*Additional discussion and information are provided in Section 4 and Figures 5 and 6 of APP-GW-GLR-602 (Reference 1).]**

3H.5.7.2 Reinforced Concrete (RC)/Steel Concrete Composite (SC) Horizontal and Vertical Connections

[The steel plate modules are anchored to the RC basemat and walls of the shield building by mechanical rebar connections. The connectors provide for the direct transfer of forces from the RC reinforcing steel to the SC liner plates.

At the horizontal connection at the interface with the RC structure that occurs on the bottom of the lowest SC wall module, vertical reinforcing bars in the RC basemat wall are connected to the module with a mechanical connection. A similar vertical connection occurs on the vertical edges of SC wall modules that interface with the RC portion of the shield building wall. In the vertical connection, hoop reinforcing bars in the RC wall are connected to a mechanical connection and forces are transferred directly from the hoop bars to the SC liner plate. The mechanical connections are designed to the stress limits of ANSI/AISC N690 for loads in the reinforcing bars equivalent to 125 percent of the specified yield strength of the reinforcing bar and are proven components used in existing structures. This design basis exceeds the maximum demand that occurs on the west side of the shield building at grade and is summarized in Sheet 3 of Table 3H.5-14. This connection improves the overall ductility of the RC/SC connection.

*Additional discussion and information are provided in Section 4 and Figures 1, 2, 3, and 4 of APP-GW-GLR-602 (Reference 1).]**

3H.5.8 References

1. *[APP-GW-GLR-602, Revision 5 (Proprietary) and APP-GW-GLR-603, Revision 5 (Non-Proprietary), "AP1000 Shield Building Design Details for Select Wall and RC/SC Connections," Westinghouse Electric Company LLC.]**

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-1
Nuclear Island: Design Temperatures for Thermal Gradient**

Structure (See detail in Subsection 3H.3.3.)	Load	Temperature (°F)		Remark
		[(Outside)	(Inside)	
PCS Tank Walls	Normal Thermal, T _o	-40 +115	+40 +70]*	–
Roofs and Exterior Walls Above Grade Air Temperatures	Normal Thermal, T _o	-40 +115	+70 +70	–
	Accident Thermal, T _a	-40 -40	+132 +212]*	MSIV room Fuel handling area
Roofs and Exterior Walls Above Grade Concrete Temperatures	Normal Thermal, T _o	-21.6 -22.8 -25.4 +3.2 +109.1 +108.0 +107.5 +98.6	+47 +48.4 +51.5 +46.6 +79.2 +80.7 +81.3 +81.3	24" thickness 27" thickness 36" thickness 15" insulated roof 24" thickness 27" thickness 36" thickness 15" insulated roof
		Accident Thermal, T _a	-40 -40 +63	+132 +212 +212]*
Interior Walls/Slabs Concrete Temperatures	Normal Thermal, T _o	[(Side 1) N/R	(Side 2) N/R	–
	Accident Thermal, T _a	+70 +70	+132 +212]*	MSIV room Fuel handling area
Exterior Walls Below Grade	Normal Thermal, T _o	N/R	N/R	–
	Accident Thermal, T _a	N/R	N/R	–
Basemat	Normal Thermal, T _o	N/R	N/R	–
	Accident Thermal, T _a	N/R	N/R	–
Shield Building (Between Upper Annulus and Auxiliary Building)	Normal Thermal, T _o	[(Outside) -40 +115	(Inside) +70 +70	–
	Accident Thermal, T _a	-40 N/R	+132 N/R]*	MSIV room wall Rest of wall

Notes:

1. N/R means loads due to a thermal gradient are not required to be considered.
2. Based on ACI 349-01 (Appendix A), the base temperature for the construction is assumed to be 70°F.

*NRC Staff approval is required prior to implementing a change in this information.

Table 3H.5-2
Exterior Wall at Column Line 1 Forces and Moments in Critical Locations
 (Units: kips, ft)

Load Combination	M_X	M_Y	M_{XY}	T_X	T_Y	T_{XY}
Elevation 180'-0" to 135'-3"						
$[D + L + H + Ta$		177.8	3.1		115.5	8.8
$1.05 D + 1.3 L + 1.3 H + 1.2 To]^*$	106.4		5.6	117.0		23.9
Elevation 135'-3" to 100'-0"						
$[D + L + H + Ta$		50.8	0.3		89.8	104.8
$D + L + H + Ta$	82.9		7.6	172.9		24.8
$D + L + H + Ta]^*$	60.0		3.6	165.7		106.0
Elevation 100'-0" to 82'-6"						
$[1.05 D + 1.3 L + 1.3 H + 1.2 To$		48.1	8.4		106.1	17.3
$D + L + Es]^*$	1.8		5.4	15.6		58.6
Elevation 82'-6" to 66'-6"						
$[D + L - Es$		93.8	26.5		170.7	31.5
$0.9 D + Es$		32.7	27.2		182.1	42.4
$0.9 D + Es]^*$	15.5		27.2	18.6		42.4

Note:

X is along the horizontal direction, and Y is in the vertical direction.

*NRC Staff approval is required prior to implementing a change in this information.

Table 3H.5-3
Exterior Wall on Column Line 1 Details of Wall Reinforcement (in ²/ft)
 (See Figure 3H.5-2 for Locations of Wall Sections.)

Wall Segment (See detail in Subsection 3H.5.1.1.)	Location	Required ⁽²⁾			[Provided (Minimum)]*		
		Vertical	Horizontal	Shear ⁽³⁾	Vertical	Horizontal	Shear ⁽³⁾
Wall Section 1, 6							
Elevation 180'-0" to 135'-3"				NR			None
	Outside Face	3.48	2.65		[3.91	3.12	
	Inside Face	1.94	1.52		3.12	3.12]*	
Wall Section 2, 3, 7							
Elevation 135'-3" to 100'-0"				NR			None
	Outside Face	1.88	3.04		[3.12	3.12	
	Inside Face	1.77	2.23		3.12	3.12]*	
Wall Section 4, 8							
Elevation 100'-0" to 82'-6"				0.003			[0.44]*
	Outside Face	1.42	0.70		[3.12	1.56	
	Inside Face	1.01	0.70		3.12	1.27]*	
Wall Section 5, 9							
Elevation 82'-6" to 66'-6"				0.27			[0.88]*
	Outside Face	2.29	0.87		[4.39	1.27	
	Inside Face	1.87	0.87		3.12	1.27]*	

Notes:

1. NR = not required.
2. Thermal loads have been considered in the design of critical sections. The required reinforcement values shown do not include the load case where seismic and normal thermal loads are numerically combined as the normal thermal loads were assessed to be insignificant. When the seismic and normal thermal loads are numerically combined, the value of required reinforcement may increase; however, in all cases the required reinforcement is less than the provided reinforcement and thus the design of the critical section reinforcement is acceptable.
3. Refer to Subsection 3.8.4.4.1 for the requirements for shear reinforcement.

*NRC Staff approval is required prior to implementing a change in this information.

Table 3H.5-4
Interior Wall at Column Line 7.3 Forces and Moments in Critical Locations
 (Units: kips, ft)

Load Combination	M _X	M _Y	M _{XY}	T _X	T _Y	T _{XY}
From Roof to Elevation 155'-6"						
[1.05 D + 1.3 L + 1.2 T _o		135.3	10.9		117.3	210.2
1.05 D + 1.3 L + 1.2 T _o]*	75.5		4.1	229.8		94.3
Elevation 155'-6" to 135'-3"						
[0.9 D – Es		14.1	1.3		160.8	228.7
D + L – Es]*	28.0		1.0	29.8		231.7
Elevation 135'-3" to 117'-6"						
[0.9 D – Es		3.3	1.3		142.2	140.9
D + L – Es]*	10.0		1.0	41.7		175.0
Elevation 117'-6" to 100'-0"						
[0.9 D – Es		4.7	2.8		143.9	184.9
D + L + Es]*	6.4		1.5	172.8		107.9
Elevation 100'-0" to 82'-6"						
[0.9 D – Es		15.4	2.6		90.4	169.8
D + L – Es]*	8.7		2.6	46.6		175.6
Elevation 82'-6" to 66'-6"						
[0.9 D – Es		23.5	1.3		80.9	49.3
D + L – Es]*	0.8		1.3	1.7		74.1

Note:

X is along the horizontal direction, and Y is in the vertical direction.

*NRC Staff approval is required prior to implementing a change in this information.

Table 3H.5-5
Interior Wall on Column Line 7.3 Details of Wall Reinforcement
 (See Figure 3H.5-2 for Locations of Wall Sections.)

Wall Segment (See detail in Subsection 3H.5.1.2.)	Location	Wall Section	Reinforcement on Each Face (in ² /ft)	
			Required ⁽¹⁾	[<i>Provided (Min.)</i>]*
From Roof to Elevation 155'-6"	Horizontal	1	3.96	[4.12
	Vertical	7	3.60	3.72
Elevation 155'-6" to 135'-3"	Horizontal	2	2.80	3.12
	Vertical	8	3.59	3.72
Elevation 135'-3" to 117'-6"	Horizontal	3	2.03	2.54
	Vertical	9	2.63	3.12
Elevation 117'-6" to 100'-0"	Horizontal	4	2.29	2.54
	Vertical	10	2.98	3.12
Elevation 100'-0" to 82'-6"	Horizontal	5	1.69	2.54
	Vertical	11	2.08	3.12
Elevation 82'-6" to 66'-6"	Horizontal	6	0.85	1.27
	Vertical	12	0.98	1.56
Shear Reinforcement⁽²⁾ (in²/ft²)				
From Roof to Elevation 155'-6"	Standard hook or T headed bar	7	0.38	0.44]*

Notes:

- Thermal loads have been considered in the design of critical sections. The required reinforcement values shown do not include the load case where seismic and normal thermal loads are numerically combined as the normal thermal loads were assessed to be insignificant. When the seismic and normal thermal loads are numerically combined, the value of required reinforcement may increase; however, in all cases the required reinforcement is less than the provided reinforcement and thus the design of the critical section reinforcement is acceptable.
- Refer to Subsection 3.8.4.4.1 for the requirements for shear reinforcement.

*NRC Staff approval is required prior to implementing a change in this information.

Table 3H.5-6
Interior Wall at Column Line L Forces and Moments in Critical Locations
 (Units: kips, ft)

Load Combination	M_X	M_Y	M_{XY}	T_X	T_Y	T_{XY}
Elevation 154'-2" to 135'-3"						
$[0.9 D + Es + Pa + Yj]$		6.0	3.5		115.4	170.2
$0.9 D + Es + Pa + Yj]^*$	14.3		3.5	46.0		170.2
Elevation 135'-3" to 117'-6"						
$[0.9 D + Es + Pa + Yj]$		145.3	12.2		26.0	38.2
$0.9 D + Es + Pa + Yj]^*$	24.5		7.1	15.5		114.9

Note:

X is along the horizontal direction, and Y is in the vertical direction.

*NRC Staff approval is required prior to implementing a change in this information.

Table 3H.5-7
Interior Wall on Column Line L Details of Wall Reinforcement
 (See Figure 3H.5-2, Sheet 3, for Locations of Wall Sections.)

Wall Segment (See detail in Subsection 3H.5.1.3.)	Location	Wall Section	Reinforcement on Each Face (in ² /ft ²)	
			Required ⁽¹⁾	[Provided (Min.)]*
Elevation 154'-2" to 135'-3"	Horizontal	1	2.08	[2.27
	Vertical	3	2.59	3.12
Elevation 135'-3" to 117'-6"	Horizontal	2	1.36	4.39
	Vertical	4	2.02	5.66]*
Shear Reinforcement⁽²⁾ (in²/ft²)				
Elevation 154'-2" to 135'-3"	Standard hook or T headed bar	5	0.01	[0.11
Elevation 135'-3" to 117'-6"	Standard hook or T headed bar	6	0.33	1.76]*

Notes:

1. Thermal loads have been considered in the design of critical sections. The required reinforcement values shown do not include the load case where seismic and normal thermal loads are numerically combined as the normal thermal loads were assessed to be insignificant. When the seismic and normal thermal loads are numerically combined, the value of required reinforcement may increase; however, in all cases the required reinforcement is less than the provided reinforcement and thus the design of the critical section reinforcement is acceptable.
2. Refer to Subsection 3.8.4.4.1 for the requirements for shear reinforcement.

*NRC Staff approval is required prior to implementing a change in this information.

Table 3H.5-8 (Sheet 1 of 7)
Design Summary of Spent Fuel Pool Wall Design Loads, Load Combinations, and Comparisons to Acceptance Criteria – Element No. 20477

Load/Combination	S _{xx} kip/ft	S _{yy} kip/ft	S _{xy} kip/ft	M _{xx} k-ft/ft	M _{yy} k-ft/ft	N _x kip/ft	N _y kip/ft	Comments
Dead (D)	-16.15	-22.92	-28.34	-1.34	-1.06	-0.32	-0.32	
Live (L)	1.46	0.32	-1.57	-0.06	-0.21	0.04	0.03	
Hydro (F)	37.52	12.36	-4.32	-100.50	-14.49	62.14	-9.95	
Seismic (Es)	46.21	56.51	183.20	81.72	28.70	103.00	14.79	
Thermal (To)	-561.80	-267.70	-51.15	-426.90	-145.50	90.32	-23.66	
Thermal (Ta)	-955.80	-444.60	-139.70	-1401.0	-450.00	227.50	-83.16	
LC(1a)	32.40	-14.25	-48.39	-142.68	-22.12	86.61	-14.33	[1.4D+1.7L+1.4F
LC(3a)	84.05	51.21	147.24	-60.38	7.15	189.71	0.56	D+L+F+Es
LC(3b)	84.05	51.21	-219.16	-223.82	-50.25	-16.29	-29.02	D+L+F+E's
LC(3e)	-267.08	-116.11	115.28	-327.19	-83.79	246.16	-14.22	D+L+F+Es+To
LC(3f)	-267.08	-116.11	-251.12	-490.63	-141.19	40.16	-43.80	D+L+F+E's+To
LC(3m)	84.20	53.18	151.64	-60.18	7.46	189.71	0.57	0.9D+F+Es
LC(3n)	84.20	53.18	-214.76	-223.62	-49.94	-16.29	-29.01	0.9D+F+E's
LC(3o)	-266.92	-114.13	119.68	-326.99	-83.47	246.16	-14.22	0.9D+F+Es+To
LC(3p)	-266.92	-114.13	-246.72	-490.43	-140.87	40.16	-43.80	0.9D+F+E's+To
LC(5a)	-574.55	-288.12	-121.54	-977.52	-297.00	204.04	-62.22	D+L+F+Ta
LC(5b)	-825.30	-421.18	-153.29	-53.19	-5.28	63.89	-15.73	D+L+F+Ta
LC(7a)	-397.01	-211.45	-74.69	-427.19	-125.72	132.70	-28.49	1.05D+1.3L+1.05F+1.2To]*

Notes:

x – direction is horizontal; y – direction is vertical.

See Figure 3H.5-10 for element location.

Plate thickness required for load combinations excluding thermal:

0.42 inches (Maximum)

[Plate thickness provided:

0.50 -0.01 +0.10 inches]*

Maximum principal stress for load combination 5 including thermal:

46.33 ksi

[Yield stress:

65.0 ksi (Minimum)]*

Maximum stress intensity range for load combination 5 including thermal:

46.3 ksi

Allowable stress intensity:

130.0 ksi (Minimum)

*NRC Staff approval is required prior to implementing a change in this information.

Table 3H.5-8 (Sheet 2 of 7)
Design Summary of Spent Fuel Pool Wall Design Loads, Load Combinations, and Comparisons to Acceptance Criteria – Element No. 10529

Load/Combination	S _{xx} kip/ft	S _{yy} kip/ft	S _{xy} kip/ft	M _{xx} k-ft/ft	M _{yy} k-ft/ft	N _x kip/ft	N _y kip/ft	Comments
Dead (D)	-24.40	-96.30	-20.71	-1.16	-2.27	-0.28	-0.34	
Live (L)	-0.44	-2.48	-0.55	-0.01	-0.24	0.01	0.08	
Hydro (F)	9.86	-5.49	6.22	8.37	-73.49	16.94	16.02	
Seismic (Es)	110.80	335.20	95.73	19.03	93.81	22.15	29.34	
Thermal (To)	-215.70	-479.30	-150.10	-99.69	-357.90	16.39	19.34	
Thermal (Ta)	-389.40	-883.60	-273.20	-364.10	-982.20	40.42	17.26	
LC(1a)	-21.10	-146.72	-21.23	10.09	-106.48	23.34	22.09	[1.4D+1.7L+1.4F
LC(3a)	99.77	228.74	83.17	29.58	-11.59	45.60	51.51	D+L+F+Es
LC(3b)	99.77	228.74	-108.29	-8.48	-199.21	1.30	-7.17	D+L+F+E's
LC(3e)	-35.05	-70.83	-10.64	-32.72	-235.28	55.84	63.60	D+L+F+Es+To
LC(3f)	-35.05	-70.83	-202.10	-70.78	-422.90	11.54	4.92	D+L+F+E's+To
LC(3m)	102.64	240.85	85.80	29.71	-11.12	45.61	51.47	0.9D+F+Es
LC(3n)	102.64	240.85	-105.66	-8.35	-198.74	1.31	-7.21	0.9D+F+E's
LC(3o)	-32.17	-58.72	-8.02	-32.60	-234.81	55.86	63.55	0.9D+F+Es+To
LC(3p)	-32.17	-58.72	-199.48	-70.66	-422.43	11.56	4.87	0.9D+F+E's+To
LC(5a)	-258.35	-656.52	-185.79	-220.36	-689.88	41.93	26.55	D+L+F+Ta
LC(5b)	-362.67	-963.64	-260.17	7.94	-144.07	12.21	12.80	D+L+F+Ta
LC(7a)	-177.61	-469.58	-128.51	-67.20	-348.29	29.80	31.07	1.05D+1.3L+1.05F+1.2To]*

Notes:

x – direction is horizontal; y – direction is vertical.

See Figure 3H.5-10 for element location.

Plate thickness required for load combinations excluding thermal:

0.47 inches (maximum)

[Plate thickness provided:

0.50 -0.01 +0.10 inches]*

Maximum principal stress for load combination 5 including thermal:

40.3 ksi

[Yield stress:

65.0 ksi (Minimum)*

Maximum stress intensity range for load combination 5 including thermal:

50.8 ksi

Allowable stress intensity:

130.0 ksi (Minimum)

*NRC Staff approval is required prior to implementing a change in this information.

Table 3H.5-8 (Sheet 3 of 7)
Design Summary of Spent Fuel Pool Wall Design Loads, Load Combinations, and Comparisons to Acceptance Criteria – Element No. 10544

Load/Combination	S _{xx} kip/ft	S _{yy} kip/ft	S _{xy} kip/ft	M _{xx} k-ft/ft	M _{yy} k-ft/ft	N _x kip/ft	N _y kip/ft	Comments
Dead (D)	-20.03	-75.69	-42.72	3.53	-2.18	-0.01	-1.93	
Live (L)	-0.64	-1.98	-1.22	0.36	-0.06	0.02	-0.07	
Hydro (F)	-4.13	-2.97	-4.10	39.78	3.54	0.99	-4.80	
Seismic (Es)	67.42	185.70	113.20	48.28	7.62	5.78	5.32	
Thermal (To)	-121.60	-387.30	-239.80	75.83	-107.40	39.64	49.91	
Thermal (Ta)	-215.20	-670.10	-416.60	184.20	-269.30	115.50	136.20	
LC(1a)	-34.91	-113.49	-67.62	61.25	1.81	1.40	-9.54	[1.4D+1.7L+1.4F
LC(3a)	40.97	103.87	63.52	107.86	10.34	7.18	-3.41	D+L+F+Es
LC(3b)	40.97	103.87	-162.88	11.30	-4.90	-4.39	-14.04	D+L+F+E's
LC(3e)	-35.03	-138.19	-86.36	155.26	-56.79	31.95	27.79	D+L+F+Es+To
LC(3f)	-35.03	-138.19	-312.76	58.70	-72.02	20.39	17.15	D+L+F+E's+To
LC(3m)	43.61	113.42	69.01	107.15	10.61	7.16	-3.14	0.9D+F+Es
LC(3n)	43.61	113.42	-157.39	10.59	-4.62	-4.41	-13.78	0.9D+F+E's
LC(3o)	-32.39	-128.64	-80.87	154.54	-56.51	31.93	28.05	0.9D+F+Es+To
LC(3p)	-32.39	-128.64	-307.27	57.98	-71.75	20.37	17.41	0.9D+F+E's+To
LC(5a)	-159.30	-499.45	-308.41	158.79	-167.01	73.19	78.32	D+L+F+Ta
LC(5b)	-267.05	-805.64	-503.54	51.38	-38.58	1.37	-9.65	D+L+F+Ta
LC(7a)	-117.40	-375.64	-230.60	102.82	-79.20	30.78	30.27	1.05D+1.3L+1.05F+1.2To]*

Notes:

x – direction is horizontal; y – direction is vertical.

See Figure 3H.5-10 for element location.

Plate thickness required for load combinations excluding thermal:

[Plate thickness provided:

Maximum principal stress for load combination 5 including thermal:

[Yield stress:

Maximum stress intensity range for load combination 5 including thermal:

Allowable stress intensity:

0.31 inches (Maximum)

0.50 -0.01 +0.10 inches)*

46.95 ksi

65.0 ksi (Minimum)]*

84.9 ksi

130.0 ksi (Minimum)

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-8 (Sheet 4 of 7)
Design Summary of Spent Fuel Pool Wall Design Loads, Load Combinations, and Comparisons to Acceptance Criteria – Element No. 10524**

Load/Combination	S _{xx} kip/ft	S _{yy} kip/ft	S _{xy} kip/ft	M _{xx} k-ft/ft	M _{yy} k-ft/ft	N _x kip/ft	N _y kip/ft	Comments
Dead (D)	-35.61	-104.80	0.68	-4.70	7.72	-0.55	-2.22	
Live (L)	-0.45	-2.21	-0.72	-0.25	-0.49	0.00	0.10	
Hydro (F)	11.85	-1.35	4.92	28.52	16.50	3.71	3.79	
Seismic (Es)	76.80	225.60	79.29	53.31	177.00	6.83	55.70	
Thermal (To)	-369.10	-433.40	179.90	-215.40	-109.40	-7.32	-59.63	
Thermal (Ta)	-696.60	-730.00	329.40	-555.10	-487.60	-13.58	-95.78	
LC(1a)	-34.04	-152.37	6.62	32.92	33.09	4.43	2.37	[1.4D+1.7L+1.4F
LC(3a)	57.33	116.69	86.14	88.29	207.34	11.48	58.89	D+L+F+Es
LC(3b)	57.33	116.69	-72.44	-18.33	-146.66	-2.18	-52.51	D+L+F+E's
LC(3e)	-173.36	-154.18	198.57	-46.34	138.96	6.90	21.62	D+L+F+Es+To
LC(3f)	-173.36	-154.18	39.99	-152.96	-215.04	-6.76	-89.78	D+L+F+E's+To
LC(3m)	61.34	129.38	86.78	89.00	207.05	11.53	59.02	0.9D+F+Es
LC(3n)	61.34	129.38	-71.80	-17.62	-146.95	-2.13	-52.38	0.9D+F+E's
LC(3o)	-169.35	-141.49	199.22	-45.62	138.68	6.96	21.75	0.9D+F+Es+To
LC(3p)	-169.35	-141.49	40.64	-152.24	-215.32	-6.71	-89.65	0.9D+F+E's+To
LC(5a)	-459.59	-564.62	210.75	-323.37	-281.01	-5.32	-58.19	D+L+F+Ta
LC(5b)	-741.71	-755.24	398.88	19.86	124.99	-105.77	-114.64	D+L+F+Ta
LC(7a)	-302.36	-439.4	139.9	136.9	57.2	-2.2	-42.9	1.05D+1.3L+1.05F+1.2To]*

Notes:

x – direction is horizontal; y – direction is vertical.

See Figure 3H.5-10 for element location.

Plate thickness required for load combinations excluding thermal:

0.32 inches (Maximum)

[Plate thickness provided:

0.50 -0.01 +0.10 inches]*

Maximum principal stress for load combination 5 including thermal:

42.1 ksi

[Yield stress:

65.0 ksi (Minimum)]*

Maximum stress intensity range for load combination 5 including thermal:

72.5 ksi

Allowable stress intensity:

130.0 ksi (Minimum)

*NRC Staff approval is required prior to implementing a change in this information.

Table 3H.5-8 (Sheet 5 of 7)
Design Summary of Spent Fuel Pool Wall Design Loads, Load Combinations, and Comparisons to Acceptance Criteria – Element No. 20462

Load/Combination	S _{xx} kip/ft	S _{yy} kip/ft	S _{xy} kip/ft	M _{xx} k-ft/ft	M _{yy} k-ft/ft	N _x kip/ft	N _y kip/ft	Comments
Dead (D)	-7.31	-29.13	-1.51	-1.45	-3.75	-0.06	0.35	
Live (L)	-0.11	-0.55	0.21	-0.14	-0.60	0.00	0.05	
Hydro (F)	5.04	-0.04	-1.61	-16.58	64.59	-1.48	-20.87	
Seismic (Es)	25.64	33.82	32.90	10.45	114.90	2.48	12.55	
Thermal (To)	-286.10	-78.70	66.37	-208.70	-130.00	0.86	-1.51	
Thermal (Ta)	-616.80	-121.80	116.60	-650.20	-502.40	6.16	3.93	
LC(1a)	-3.36	-41.77	-4.01	-25.47	84.16	-2.15	-28.64	[1.4D+1.7L+1.4F
LC(3a)	25.28	4.09	29.35	-14.35	200.98	0.35	-16.27	D+L+F+Es
LC(3b)	25.28	4.09	-36.45	-35.25	-28.82	-4.61	-41.37	D+L+F+E's
LC(3e)	-153.54	-45.10	70.83	-144.78	119.73	0.89	-17.21	D+L+F+Es+To
LC(3f)	-153.54	-45.10	5.03	-165.68	-110.07	-4.07	-42.31	D+L+F+E's+To
LC(3m)	26.11	7.55	29.29	-14.06	201.95	0.35	-16.35	0.9D+F+Es
LC(3n)	26.11	7.55	-36.51	-34.96	-27.85	-4.61	-41.45	0.9D+F+E's
LC(3o)	-152.70	-41.63	70.77	-144.50	120.70	0.89	-17.29	0.9D+F+Es+To
LC(3p)	-152.70	-41.63	4.97	-165.40	-109.10	-4.07	-42.39	0.9D+F+E's+To
LC(5a)	-387.88	-105.84	69.97	-424.54	-253.76	2.31	-18.01	D+L+F+Ta
LC(5b)	-646.13	-113.41	80.41	35.38	175.18	-4.36	-31.38	D+L+F+Ta
LC(7a)	-217.10	-90.37	46.78	-175.63	-34.40	-0.96	-22.61	1.05D+1.3L+1.05F+1.2To]*

Notes:

x – direction is horizontal; y – direction is vertical.

See Figure 3H.5-10 for element location.

Plate thickness required for load combinations excluding thermal:

0.20 inches (Maximum)

[Plate thickness provided:

0.50 -0.01 +0.10 inches]*

Maximum principal stress for load combination 5 including thermal:

20.6 ksi

[Yield stress:

65.0 ksi (Minimum)]*

Maximum stress intensity range for load combination 5 including thermal:

20.6 ksi

Allowable stress intensity:

130.0 ksi (Minimum)

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-8 (Sheet 6 of 7)
Design Summary of Spent Fuel Pool Wall Design Loads, Load Combinations, and Comparisons to Acceptance Criteria – Element No. 21402**

Load/Combination	S _{xx} kip/ft	S _{yy} kip/ft	S _{xy} kip/ft	M _{xx} k-ft/ft	M _{yy} k-ft/ft	N _x kip/ft	N _y kip/ft	Comments
Dead (D)	-1.82	-17.93	4.00	0.92	0.93	-0.32	0.22	
Live (L)	-0.21	-0.98	0.41	0.19	-0.04	-0.02	-0.03	
Hydro (F)	7.14	0.29	-2.18	104.60	15.51	-16.65	3.08	
Seismic (Es)	36.81	21.41	17.68	139.90	28.75	12.42	12.08	
Thermal (To)	-228.50	-181.90	85.52	-291.30	-212.00	11.34	6.92	
Thermal (Ta)	-379.10	-378.40	159.80	-783.80	-661.10	41.72	28.29	
LC(1a)	7.08	-26.36	3.24	148.06	22.95	-23.80	4.56	[1.4D+1.7L+1.4F
LC(3a)	44.77	2.90	19.03	287.45	51.36	-11.24	16.58	D+L+F+Es
LC(3b)	44.77	2.90	-16.33	7.65	-6.14	-36.08	-7.58	D+L+F+E's
LC(3e)	-98.05	-110.78	72.48	105.39	-81.14	-4.15	20.90	D+L+F+Es+To
LC(3f)	-98.05	-110.78	37.12	-174.41	-138.64	-28.99	-3.26	D+L+F+E's+To
LC(3m)	45.16	5.68	18.23	287.17	51.31	-11.18	16.59	0.9D+F+Es
LC(3n)	45.16	5.68	-17.13	7.37	-6.19	-36.02	-7.57	0.9D+F+E's
LC(3o)	-97.65	-108.01	71.68	105.11	-81.19	-4.09	20.91	0.9D+F+Es+To
LC(3p)	-97.65	-108.01	36.32	-174.69	-138.69	-28.93	-3.25	0.9D+F+E's+To
LC(5a)	-231.84	-255.12	102.10	-384.16	-396.79	9.08	20.95	D+L+F+Ta
LC(5b)	-268.90	-468.00	168.35	-17.41	14.23	-18.83	13.88	D+L+F+Ta
LC(7a)	-166.1	-156.2	66.6	-107.4	-141.8	-9.3	8.6	1.05D+1.3L+1.05F+1.2To]*

Notes:

x – direction is horizontal; y – direction is vertical.

See Figure 3H.5-10 for element location.

Plate thickness required for load combinations excluding thermal:

0.28 inches (Maximum)

[Plate thickness provided:

0.50 -0.01 +0.10 inches]*

Maximum principal stress for load combination 5 including thermal:

25.1 ksi

[Yield stress:

65.0 ksi (Minimum)]*

Maximum stress intensity range for load combination 5 including thermal:

31.3 ksi

Allowable stress intensity:

130.0 ksi (Minimum)

*NRC Staff approval is required prior to implementing a change in this information.

Table 3H.5-8 (Sheet 7 of 7)
Design Summary of Spent Fuel Pool Wall Design Loads, Load Combinations, and Comparisons to Acceptance Criteria – Element No. 21414

Load/Combination	S _{xx} kip/ft	S _{yy} kip/ft	S _{xy} kip/ft	M _{xx} k-ft/ft	M _{yy} k-ft/ft	N _x kip/ft	N _y kip/ft	Comments
Dead (D)	0.69	-10.62	-2.57	-0.52	-0.22	-0.03	0.12	
Live (L)	0.18	0.12	-0.45	0.00	-0.11	-0.01	0.02	
Hydro (F)	4.25	0.56	-2.73	-27.01	-31.06	-1.46	1.82	
Seismic (Es)	26.90	13.88	36.68	26.35	21.70	2.17	4.34	
Thermal (To)	-79.35	-40.69	49.04	-129.00	-119.30	10.01	6.90	
Thermal (Ta)	-129.60	-66.37	57.50	-374.60	-374.70	26.38	24.34	
LC(1a)	7.24	-13.89	-8.19	-38.54	-43.97	-2.09	2.75	[1.4D+1.7L+1.4F
LC(3a)	33.73	4.16	29.84	-11.98	-22.11	0.10	7.03	D+L+F+Es
LC(3b)	33.73	4.16	-43.52	-64.68	-65.51	-4.24	-1.66	D+L+F+E's
LC(3e)	-15.86	-21.27	60.49	-92.61	-96.67	6.36	11.34	D+L+F+Es+To
LC(3f)	-15.86	-21.27	-12.87	-145.31	-140.07	2.01	2.66	D+L+F+E's+To
LC(3m)	33.48	5.10	30.55	-11.93	-21.98	0.11	7.00	0.9D+F+Es
LC(3n)	33.48	5.10	-42.81	-64.63	-65.38	-4.23	-1.69	0.9D+F+E's
LC(3o)	-16.12	-20.33	61.20	-92.56	-96.54	6.37	11.31	0.9D+F+Es+To
LC(3p)	-16.12	-20.33	-12.16	-145.26	-139.94	2.02	2.62	0.9D+F+E's+To
LC(5a)	-75.87	-51.43	30.19	-261.65	-265.57	15.00	17.17	D+L+F+Ta
LC(5b)	-114.31	-96.07	55.47	-35.06	-36.08	2.55	-1.61	D+L+F+Ta
LC(7a)	-54.08	-40.93	30.63	-125.65	-122.46	5.94	7.24	1.05D+1.3L+1.05F+1.2To]*

Notes:

x – direction is horizontal; y – direction is vertical.

See Figure 3H.5-10 for element location.

Plate thickness required for load combinations excluding thermal:

0.14 inches (Maximum)

[Plate thickness provided:

0.50 -0.01 +0.10 inches]*

Maximum principal stress for load combination 5 including thermal:

22.1 ksi

[Yield stress:

65.0 ksi (Minimum)]*

Maximum stress intensity range for load combination 5 including thermal:

22.1 ksi

Allowable stress intensity:



130.0 ksi (Minimum)

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-9 (Sheet 1 of 3)
Shield Building Roof Reinforcement Summary
(Tension Ring)**

Tension Ring – Axial Force and Bending Verification								
Location		Seismic Maximum Stresses		Maximum Stresses ksi	F _y ksi	Maximum Steel Area Required ⁽²⁾ (in ² /ft)	[Steel Area Provided]*	[Design Limit ⁽¹⁾ for Ratio Max Required/ Provided]*
Section	Angles	Seismic L/C	f _a ksi					
2 lower	5.625°	9	14.31	14.31	50	7.74	[Liner 1 1/2" = 18 (in ² /ft) (Min)]*	[0.43 + 2%]*
	84.375°	17	12.52					
1 lower	0°	9	12.97					
	90°	17	11.39					

Tension Ring – Shear Force and Torsion Verification								
Location		Seismic Maximum Stresses		Maximum Stresses ksi	F _y ksi	Maximum Steel Area Required ⁽²⁾ (in ² /ft)	[Steel Area Provided]*	[Design Limit for Ratio Max Required/ Provided]*
Section	Angles	Seismic L/C	f _v ksi					
2 lower	5.625°	17	4.83	5.52	50	5.04	[Liner 1 1/2" = 18 (in ² /ft) (Min.)]*	[0.28 + 2%]*
	84.375°	9	5.52					
1 lower	0°	18	3.20					
	90°	11	4.00					



Notes:

- [Two percent of the value may be added to the design limit as an allowance for minor variances in analysis results.]*
- Thermal loads have been considered in the design of critical sections. The required reinforcement values shown do not include the load case where seismic and normal thermal loads are numerically combined as the normal thermal loads were assessed to be insignificant. When the seismic and normal thermal loads are numerically combined, the value of required reinforcement may increase; however, in all cases the required reinforcement is less than the provided reinforcement and thus the design of the critical section reinforcement is acceptable.

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-9 (Sheet 2a of 3)
Shield Building Roof Reinforcement Summary
(Air Inlet)**

AIS Reinforcement Summary – Horizontal Sections						
Locations (Figure 3H.5-11)		Steel Area (Vertical Direction – Z Local Dir.)				
		Required - Seismic Load Combinations (in ² /ft)		Maximum Required ⁽²⁾ (in ² /ft)	[Provided]*	[Design Limit ⁽¹⁾ for Ratio Max Required/ Provided]*
Sections	Angles	Seismic L/C	Values			
5+6	0°-5.625°	16	1.65	2.10	[Liner 1" = 12 (in ² /ft) (Min.)]*	[0.175 + 2%]*
	84.375°-90°	8	1.41			
8	0°-5.625°	16	2.10			
	84.375°-90°	8	1.69			
9	0°-5.625°	16	2.10			
	84.375°-90°	8	1.68			
11	0°-5.625°	16	1.61	1.61	[Liner 3/4" = 9 (in ² /ft) (Min.)]*	[0.18 + 2%]*
	84.375°-90°	24	1.21			



Notes:

1. [Two percent of the value may be added to the design limit as an allowance for minor variances in analysis results.]*
2. Thermal loads have been considered in the design of critical sections. The required reinforcement values shown do not include the load case where seismic and normal thermal loads are numerically combined as the normal thermal loads were assessed to be insignificant. When the seismic and normal thermal loads are numerically combined, the value of required reinforcement may increase; however, in all cases the required reinforcement is less than the provided reinforcement and thus the design of the critical section reinforcement is acceptable.

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-9 (Sheet 2b of 3)
Shield Building Roof Reinforcement Summary
(Air Inlet)**

AIS Reinforcement Summary – Vertical Sections						
Locations (Figure 3H.5-11)		Steel Area (Hoop Direction – Y Local Dir.)				
Sections	Angles	Required - Seismic Load Combinations (in ² /ft)		Maximum Required ⁽²⁾ (in ² /ft)	[Provided]*	[Design Limit ⁽¹⁾ for Ratio Max Required/ Provided]*
		Seismic L/C	Values			
3 Upper	0°	9	9.56	10.04	[Liner 1" = 12 (in ² /ft) (Min.)]*	[0.84 + 2%]*
	90°	17	8.32			
3 Lower	0°	9	8.14			
	90°	18	7.03			
4 Upper	5.625°	9	10.04			
	84.375°	17	8.69			
4 Lower	5.625°	9	7.98			
	84.375°	19	6.82			



Notes:

1. [Two percent of the value may be added to the design limit as an allowance for minor variances in analysis results.]*
2. Thermal loads have been considered in the design of critical sections. The required reinforcement values shown do not include the load case where seismic and normal thermal loads are numerically combined as the normal thermal loads were assessed to be insignificant. When the seismic and normal thermal loads are numerically combined, the value of required reinforcement may increase; however, in all cases the required reinforcement is less than the provided reinforcement and thus the design of the critical section reinforcement is acceptable.

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-9 Sheet 2c of 3)
(Shield Building Roof Reinforcement Summary
(Air Inlet)**

Out of Plane Shear Reinforcement Summary – AIS							
Locations (Figure 3H.5-11)		Required – Seismic Load Combinations (in ² /ft)			Maximum Required ⁽²⁾ (in ² /ft)	[Steel Area Provided]*	[Design Limit ⁽¹⁾ for Ratio Max Required/ Provided]*
Angles	Sections	Seismic L/C	Values	Sum			
0° - 5.625°	Max of Vertical Sections 3 upper - 4 upper	1	0.10	0.10	0.34	[3 #6 TIE BAR @2.8125° (41.36") (8 1/2" in vertical direction) = 0.54 (in ² / ft) (Min.)]*	[0.63 + 2%]*
	Horizontal Section 5+6		0.00				
84.375° - 90°	Max of Vertical sections 3 upper - 4 upper	1	0.10	0.10			
	Horizontal Section 5+6		0.00				
0° - 5.625°	Max of Vertical Sections 3 upper – 4 upper	9	0.10	0.34			
	Horizontal Section 8		0.24				
84.375° - 90°	Max of Vertical Sections 3 upper – 4 upper	1	0.10	0.30			
	Horizontal Section 8		0.20				
0° - 5.625°	Max of Vertical Sections 3 lower - 4 lower	0	0.093	0.22			
	Horizontal Section 9		0.127				
84.375° - 90°	Max of Vertical Sections 3 lower - 4 lower	0	0.183	0.18			
	Horizontal Section 9		0.000				
0° - 5.625°	Max of Vertical Sections 3 lower - 4 lower	1	0.167	0.17			
	Horizontal Section 11		0.000				
84.375° - 90°	Max of Vertical Sections 3 lower - 4 lower	0	0.02	0.02			
	Horizontal Section 11		0.00				

Notes:

- [Two percent of the value may be added to the design limit as an allowance for minor variances in analysis results.]*
- Thermal loads have been considered in the design of critical sections. The required reinforcement values shown do not include the load case where seismic and normal thermal loads are numerically combined as the normal thermal loads were assessed to be insignificant. When the seismic and normal thermal loads are numerically combined, the value of required reinforcement may increase; however, in all cases the required reinforcement is less than the provided reinforcement and thus the design of the critical section reinforcement is acceptable.

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-9 (Sheet 3 of 3)
Shield Building Roof Reinforcement Summary
(Exterior Wall Of Passive Containment Cooling System Tank)**

Wall Segment	Location (Figure 3H.5-11 Sheet 5 of 6)	Reinforcement on Each Face, in ² /ft			Ratio Required/ Provided
		Maximum Required	Provided (Minimum)		
Bottom	Vertical	1.37	1#11@1.2°	[1.72	0.80
	Hoop	0.67	1#9@6"	2	0.33
	Shear	0.07	1#6@1.2°x12"	0.48	0.15
Mid-height	Vertical	0.64	1#11@1.2°	1.72	0.37
	Hoop	1.85	1#9@6"	2	0.92
Top	Vertical	0.52	1#11@1.2°	1.72	0.30
	Hoop	0.79	1#9@6"	2]*	0.39

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-10
Design Summary Of Roof At Elevation 180'-0", Area 6
(Near Shield Building Interface)**

Governing Load Combination (Roof Girder)	
Combination Number	3 – Extreme Environmental Condition Downward Seismic Acceleration
Bending Moment	= 7125 kips-ft
Corresponding Stress	= 24.1 ksi
Allowable Stress	= 38.0 ksi
Shear Force	= 447 kips
Corresponding Stress	= 17.0 ksi
Allowable Stress	= 20.1 ksi
Governing Load Combination (Concrete Slab)	
Parallel to Girders	
Combination Numbers	3 – Extreme Environmental Condition
Reinforcement (Each Face)	
Required ⁽¹⁾	= 1.74 in ² /ft
[<i>Provided</i>]	= 2.54 in ² /ft (<i>Minimum</i>)]*
Perpendicular to Girders	
Combination Numbers	3 – Extreme Environmental Condition
Reinforcement (Each Face)	
Required ⁽¹⁾	= 1.68 in ² /ft
[<i>Provided</i>]	= 3.12 in ² /ft (<i>Minimum</i>)]*

Note:

1. Thermal loads have been considered in the design of critical sections. The required reinforcement values shown do not include the load case where seismic and normal thermal loads are numerically combined as the normal thermal loads were assessed to be insignificant. When the seismic and normal thermal loads are numerically combined, the value of required reinforcement may increase; however, in all cases the required reinforcement is less than the provided reinforcement and thus the design of the critical section reinforcement is acceptable.

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-11
Design Summary Of Floor At Elevation 135'-3" Area 1 (Between Column Lines M And P)**

Governing Load Combination (Steel Beam)	
Load Combination	3 – Extreme Environmental Condition Downward Seismic
Bending Moment	=(-) 63.9 kips-ft
Corresponding Stress	= 17.0 ksi
Allowable Stress	=33.26 ksi
Shear Force	= 30.7 kips
Corresponding Stress	= 8.7 ksi
Allowable Stress	= 20.1 ksi
Governing Load Combination (Concrete Slab)	
Parallel to the Beams	
Load Combination	3 – Extreme Environmental Condition Downward Seismic
Bending Moment	=(-) 16.0 kips-ft/ft
In-plane Shear	=20.0 kips (per foot width of the slab)
Reinforcement (Each Face)	
Required ⁽¹⁾	= 0.41 in ² /ft
[<i>Provided</i>]	= 0.44 in ² /ft (Min.)*
Perpendicular to the Beams	
Combination Number	Normal Condition
Bending Moment	=(+) 6.66 kips-ft (per foot width of the slab)
Reinforcement (Each Face)	
Required ⁽¹⁾	= 0.28 in ² /ft
[<i>Provided</i>]	= 0.60 in ² /ft (Min.)*

Note:

1. Thermal loads have been considered in the design of critical sections. The required reinforcement values shown do not include the load case where seismic and normal thermal loads are numerically combined as the normal thermal loads were assessed to be insignificant. When the seismic and normal thermal loads are numerically combined, the value of required reinforcement may increase; however, in all cases the required reinforcement is less than the provided reinforcement and thus the design of the critical section reinforcement is acceptable.

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-12
Design Summary Of Floor At Elevation 135'-3"
(Operations Work Area (Previously Known As 'Tagging Room') Ceiling))**

Design of Precast Concrete Panels	
Governing Load Combination	Construction
Design Bending Moment (Midspan)	= 14.53 kip-ft/ft
Bottom Reinforcement (E/W Direction)	
Required ⁽¹⁾	= 0.58 in ² /ft
[<i>Provided</i>]	= 0.79 in ² /ft (Min.)*
Top Reinforcement (E/W Direction)	
Required ⁽¹⁾	= (Minimum required by Code)
[<i>Provided</i>]	= 0.20 in ² /ft (Min.)*
Top and Bottom Reinforcement (N/S Direction)	
Required ⁽¹⁾	= (Minimum required by Code)
[<i>Provided</i>]	= 0.20 in ² /ft (Min.)*
Design of 24-inch-Thick Slab	
Governing Load Combination	Extreme Environmental Condition (SSE)
Design Bending Moment (E/W Direction) Midspan	= 14.40 kips ft/ft
Design In-plane Shear	= 31.9 kips ft
Design In-plane Tension	= 21.9 kips ft
Bottom Reinforcement (E/W Direction)	
Required ⁽¹⁾	= 0.53 in ² /ft
[<i>Provided</i>]	= 0.79 in ² /ft (Min.)*
Design Bending Moment (E/W Direction) at Support	= 28.81 kips-ft/ft
Design In-plane Shear	= 31.9 kips/ft
Design In-plane Tension	= 21.9 kips/ft
Top Reinforcement (E/W Direction)	
Required ⁽¹⁾	= 0.93 in ² /ft
[<i>Provided</i>]	= 1.00 in ² /ft (Min.)*
Design Bending Moment (N/S Direction)	= 8.47 kips ft/ft
Design In-plane Shear	= 31.9 kips/ft
Design In-plane Tension	= 27.2 kip/ ft
Top and Bottom Reinforcement (N/S Direction)	
Required ⁽¹⁾	= 0.59 in ² /ft
[<i>Provided</i>]	= 0.79 in ² /ft (Min.)*

Note:

1. Thermal loads have been considered in the design of critical sections. The required reinforcement values shown do not include the load case where seismic and normal thermal loads are numerically combined as the normal thermal loads were assessed to be insignificant. When the seismic and normal thermal loads are numerically combined, the value of required reinforcement may increase; however, in all cases the required reinforcement is less than the provided reinforcement and thus the design of the critical section reinforcement is acceptable.

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-13
Design Summary Of Floor At Elevation 135'-3" Area 1 (Main Control Room Ceiling)**

The design of the bottom plate with fins is governed by the construction load.
For the composite floor, the design forces used for the evaluation of a typical 9-inch-wide strip of the slab are as follows: Maximum bending moment=+35.0 (-24.4) kips-ft Maximum shear force=22.3 kips
The design evaluation results are summarized below: ⁽¹⁾ <ul style="list-style-type: none"> • [The actual area of the tension steel is 9.0 in² (Min.),]* which provides a design strength of 518.5 kips-ft bending moment capacity. • [The design shear strength is 23.22 kips. • The shear studs are spaced a maximum of 9 inches c/c, in both directions.]* The calculated required spacing is 9.06 inches.

Note:

1. Thermal loads have been considered in the design of critical sections. The required reinforcement values shown do not include the load case where seismic and normal thermal loads are numerically combined as the normal thermal loads were assessed to be insignificant. When the seismic and normal thermal loads are numerically combined, the value of required reinforcement may increase; however, in all cases the required reinforcement is less than the provided reinforcement and thus the design of the critical section reinforcement is acceptable.

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-14 (Sheet 1 of 3)
Design Summary of Enhanced Shield Building Cylindrical Wall Load Combinations, and Comparison to Acceptance Criteria Elevation 180 Feet Near Fuel Handling Building Roof**

Load/Combination	TX	TY	TXY	MX	MY	MXY	NX	NY	Comments
	kip/ft	kip/ft	kip/ft	k-ft/ft	k-ft/ft	k-ft/ft	kip/ft	kip/ft	
Dead	-7	-118	15	-25	-18	4	-6	-5	
Live	1	-1	1	0	0	0	0	0	
Seismic	157	390	163	301	211	35	71	33	
1	-8	-168	22	-35	-24	5	-8	-7	1.4 D + 1.7 L
2	152	270	179	276	194	38	66	28	D + L + Es
3	152	270	-148	-326	-228	-31	-77	-38	D + L + E's
4	-163	-509	-148	-326	-228	-31	-77	-38	D + L - Es
5	-163	-509	179	276	194	38	66	28	D + L - E's
6	152	283	177	278	195	38	66	28	0.9 D + Es
7	152	283	-150	-324	-227	-31	-77	-38	0.9 D + E's
35 ⁽²⁾	205	399	233	449	303	69	105	31	0.9 D + E's + αTo(W1)
37 ⁽²⁾	221	387	238	460	311	68	108	31	0.9 D + E's + αTo(W2)
x-direction is horizontal; y-direction is vertical. Element number: 12164 [Plate thickness required for load combinations excluding thermal: 0.50 inches + 2% ⁽¹⁾]* [Plate thickness required for load combinations including thermal: 0.65 inches + 2% ⁽¹⁾]* [Plate thickness provided: 0.75 inches]* ⁽³⁾ [Shear reinforcement required for load combinations excluding thermal: 0.72 in ² /ft ² + 2% ⁽¹⁾]* [Shear reinforcement required for load combinations including thermal: 1.00 in ² /ft ² + 2% ⁽¹⁾]* Shear reinforcement provided: See [APP-GW-GLR-602, Section 4.]*									

Notes:

- [The Tier 2* designation for "Plate thickness required" requires NRC approval if this value is exceeded as a result of design changes or detail design adjustments identified during preparation of fabrication or construction drawings or instructions.]*
- Load cases 35 and 37 are the two governing load combinations for element 12164 that include thermal and seismic loads combined numerically. W1 designates the winter conditions with the spent fuel pool at the normal operating temperature limit. W2 designates the winter conditions with the spent fuel pool and fuel transfer canal at the normal operating temperature limit. Es is SRSS (member forces are positive) of the SSE loads. E's is Es with all member forces except axial forces (TX, TY) reversed to negative.
- The 0.75-inch plate thickness is the nominal plate size for the shield building away from connections, attachments, and other local loads. The plate may be thicker (up to 1.0-inch nominal thickness) in the area around these local loads.

*NRC Staff approval is required prior to implementing a change in this information.

Table 3H.5-14 (Sheet 2 of 3)
Design Summary of Enhanced Shield Building Load Combinations, and Comparison to Acceptance Criteria Elevation 175 Feet Near Intersection With Wall 7.3

Load/Combination	TX	TY	TXY	MX	MY	MXY	NX	NY	Comments
	kip/ft	kip/ft	kip/ft	k-ft/ft	k-ft/ft	k-ft/ft	kip/ft	kip/ft	
Dead	-7	-106	12	-6	5	1	0	2	
Live	0	-1	0	0	0	0	0	0	
Seismic	34	327	178	38	25	13	2	8	
1	-9	-150	17	-9	7	1	0	3	1.4 D + 1.7 L
2	28	220	190	32	30	14	2	10	D + L + Es
3	28	220	-166	-45	-21	-12	-3	-6	D + L + E's
4	-40	-434	-166	-45	-21	-12	-3	-6	D + L - Es
5	-40	-434	190	32	30	14	2	10	D + L - E's
6	28	232	189	33	30	14	2	10	0.9 D + Es
7	28	232	-167	-44	-21	-12	-3	-7	0.9 D + E's
19 ⁽²⁾	75	251	168	-39	-107	-20	-2	-5	D + L + E's + α To(W1)
37 ⁽²⁾	75	251	168	-39	-107	-20	-2	-5	0.9 D + E's + α To(W2)
x-direction is horizontal; y-direction is vertical. Element number: 11514 [Plate thickness required for load combinations excluding thermal: 0.45 inches + 2% ⁽¹⁾]* [Plate thickness required for load combinations including thermal: 0.50 inches + 2% ⁽¹⁾]* [Plate thickness provided: 0.75 inches]* ⁽³⁾ [Shear reinforcement required for load combinations excluding thermal: 0.09 in ² /ft ² + 2% ⁽¹⁾]* [Shear reinforcement required for load combinations including thermal: 0.12 in ² /ft ² + 2% ⁽¹⁾]* Shear reinforcement provided: See [APP-GW-GLR-602, Section 4.]*									

Notes:

- [The Tier 2* designation for "Plate thickness required" requires NRC approval if this value is exceeded as a result of design changes or detail design adjustments identified during preparation of fabrication or construction drawings or instructions.]*
- Load cases 19 and 37 are the two governing load combinations for element 11514 that include thermal and seismic loads combined numerically. W1 designates the winter conditions with the spent fuel pool at the normal operating temperature limit. W2 designates the winter conditions with the spent fuel pool and fuel transfer canal at the normal operating temperature limit. Es is SRSS (member forces are positive) of the SSE loads. E's is Es with all member forces except axial forces (TX, TY) reversed to negative.
- The 0.75-inch plate thickness is the nominal plate size for the shield building away from connections, attachments, and other local loads. The plate may be thicker (up to 1.0-inch nominal thickness) in the area around these local loads.

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-14 (Sheet 3 of 3)
Design Summary of Enhanced Shield Building Load Combinations, and Comparison to
Acceptance Criteria Elevation Grade on West Side**

Load/Combination	TX	TY	TXY	MX	MY	MXY	NX	NY	Comments
	kip/ft	kip/ft	kip/ft	k-ft/ft	k-ft/ft	k-ft/ft	kip/ft	kip/ft	
Dead	-4	-129	0	2	16	0	0	-2	
Live	0	1	0	0	0	0	0	0	
Seismic	80	489	234	2	20	18	4	8	
1	-5	-179	0	3	23	0	0	-2	1.4 D + 1.7 L
2	77	362	234	5	36	19	4	7	D + L + Es
3	77	362	-234	0	-4	-18	-4	-10	D + L + E's
4	-84	-617	-234	0	-4	-18	-4	-10	D + L - Es
5	-84	-617	234	5	36	19	4	7	D + L - E's
6	77	374	234	5	34	19	4	7	0.9 D + Es
7	77	374	-235	0	-5	-18	-4	-10	0.9 D + E's
23 ⁽²⁾	202	377	-240	113	151	-18	-4	-32	D + L + E's + αTo(W1)
41 ⁽²⁾	203	393	-240	112	149	-17	-4	-32	0.9 D + E's + αTo(W2)
x-direction is horizontal; y-direction is vertical. Element number: 23752 [Plate thickness required for load combinations excluding thermal: 0.65 inches + 2% ⁽¹⁾ * [Plate thickness required for load combinations including thermal: 0.66 inches + 2% ⁽¹⁾ * [Plate thickness provided: 0.75 inches]* ⁽³⁾ [Shear reinforcement required for load combinations excluding thermal: 0.08 in ² /ft ² + 2% ⁽¹⁾ * [Shear reinforcement required for load combinations including thermal: 0.26 in ² /ft ² + 2% ⁽¹⁾ * Shear reinforcement provided: See [APP-GW-GLR-602, Section 4.]*									

Notes:

- [The Tier 2* designation for "Plate thickness required" requires NRC approval if this value is exceeded as a result of design changes or detail design adjustments identified during preparation of fabrication or construction drawings or instructions.]*
- Load cases 23 and 41 are the two governing load combinations for element 23752 that include thermal and seismic loads combined numerically. W1 designates the winter conditions with the spent fuel pool at the normal operating temperature limit. W2 designates the winter conditions with the spent fuel pool and fuel transfer canal at the normal operating temperature limit. Es is SRSS (member forces are positive) of the SSE loads. E's is Es with all member forces except axial forces (TX, TY) reversed to negative.
- The 0.75-inch plate thickness is the nominal plate size for the shield building away from connections, attachments, and other local loads. The plate may be thicker (up to 1.0-inch nominal thickness) in the area around these local loads.

*NRC Staff approval is required prior to implementing a change in this information.

**Table 3H.5-15
Shield Building Roof Reinforcement Ratio of Code Required Versus Provided**

Critical Sections	Stress Component	Required in ² /ft	Provided (Minimum) in ² /ft	Reinforcement Ratio
[Conical Roof Steel Beams]* ⁽¹⁾	Axial + Bending	-	[Radial Beams W36 X 393]*	1.33
	Shear	-		8.33
[Conical Roof Near Tension Ring]*	Radial	1.80	[1.96]*	1.09
	Hoop	4.31	[4.68]*	1.09
[Knuckle Region]*	Vertical	1.37	[1.72]*	1.25
	Radial	1.52	[2.23]*	1.47
	Hoop	1.37	[3.12]*	2.28
[Compression Ring]*	Vertical	1.04	[1.48]*	1.42
	Radial	3.09	[4.42]*	1.43
	Hoop	2.14	[3.12]*	1.45

Note:

- Steel beams are not considered as reinforcement for the reinforced concrete roof. Ratio for conical roof steel beams is based on demand and allowable stresses in psi.

*NRC Staff approval is required prior to implementing a change in this information.




Figure 3H.2-1
[General Layout of Auxiliary Building]*

*NRC Staff approval is required prior to implementing a change in this information.




Figure 3H.5-1 (Sheet 1 of 3)
[Nuclear Island Critical Sections
Plan at El. 135'-3"]*

*NRC Staff approval is required prior to implementing a change in this information.




Figure 3H.5-1 (Sheet 2 of 3)
[Nuclear Island Critical Sections
Plan at El. 180'-0"]*

*NRC Staff approval is required prior to implementing a change in this information.

Security-Related Information, Withheld Under 10 CFR 2.390d

Figure 3H.5-1 (Sheet 3 of 3)
[*Nuclear Island Critical Sections*
Section A-A*]

*NRC Staff approval is required prior to implementing a change in this information.




Figure 3H.5-2 (Sheet 1 of 3)
[Wall on Column Line 1]*

*NRC Staff approval is required prior to implementing a change in this information.




Figure 3H.5-2 (Sheet 2 of 3)
[Wall on Column Line 7.3]*

*NRC Staff approval is required prior to implementing a change in this information.





Figure 3H.5-2 (Sheet 3 of 3)
[Wall on Column Line L]*


*NRC Staff approval is required prior to implementing a change in this information.



NOTE 1:
 REFER TO SUBSECTION 3.8.4.4.1 FOR THE REQUIREMENTS FOR
 SHEAR REINFORCEMENT AND TABLE 3H.5-3 FOR SHEAR
 REINFORCEMENT PROVIDED.

Figure 3H.5-3
[Typical Reinforcement in Wall on Column Line 1]*


*NRC Staff approval is required prior to implementing a change in this information.



NOTE 1:
REFER TO SUBSECTION 3.8.4.1 FOR THE REQUIREMENTS FOR SHEAR REINFORCEMENT AND TABLE 3H.5-5 FOR SHEAR REINFORCEMENT PROVIDED.

Figure 3H.5-4
[Typical Reinforcement in Wall 7.3]*

*NRC Staff approval is required prior to implementing a change in this information.



**Figure 3H.5-5 (Sheet 1 of 3)
[Concrete Reinforcement in Wall 11]***

*NRC Staff approval is required prior to implementing a change in this information.




Figure 3H.5-5 (Sheet 2 of 3)
[Concrete Reinforcement Layers in Wall 11 (Looking East)]*

*NRC Staff approval is required prior to implementing a change in this information.






Figure 3H.5-5 (Sheet 3 of 3)
[Wall 11 at Main Steamline Anchor
Section A-A]*

*NRC Staff approval is required prior to implementing a change in this information.



PLAN VIEW
NOTES 1, 3, 6



SECTION A-A
NOTES 1, 2, 3, 4, 5, 6, & 7

NOTES:

1. DETAIL SHOWN IS SPECIFIC TO THE COMPOSITE FLOOR AT EL. 135'-3" AT INTERSECTION WITH WALL M. REFER TO SUBSECTION 3H.5.2 AND OTHER NOTES FOR ADDITIONAL INFORMATION ABOUT DESIGN DETAILS FOR OTHER FLOOR SECTIONS.
2. REFER TO SUBSECTION 3.8.4.1 FOR THE REQUIREMENTS FOR DEVELOPMENT OF HEADED REINFORCEMENT.
3. FLOOR BEAM SIZE AND SPACING ARE DESIGNED BASED ON FLOOR LOAD AND GEOMETRY TO SATISFY AISC N690 REQUIREMENTS. THE BEAM SIZES USED ARE PREDOMINATELY W14x26 AND W14x48. THE RANGE OF BEAM SIZES USED IN OTHER LOCATIONS IS FROM W10 TO W44. THE SPACING BETWEEN THE BEAMS IS PREDOMINATELY IN A RANGE OF 5 TO 6 FEET.
4. THE REINFORCEMENT SHOWN IS FOR LOCATIONS AWAY FROM OPENINGS, PENETRATIONS, EMBEDMENTS, AND OTHER OBSTRUCTIONS.
5. REINFORCEMENT SIZE AND SPACING ARE BASED ON THE REQUIREMENTS IN ACI 349 AND ACI 318-11, SECTION 12.6.
6. THE ADJACENT WALL MAY BE DESIGNED AS A STRUCTURAL WALL MODULE.
7. THE DETAIL DESIGN, LOCATION, AND EMBEDMENT OF THE BEAM SUPPORTS ARE DESIGNED TO THE REQUIREMENTS OF AISC N690 AND ACI 349 AS APPLICABLE. SUPPORT CONFIGURATION, INCLUDING THE USE OF PLATES, STRUCTURAL SHAPES, AND STIFFENERS, IS BASED ON LOADING AND LOCAL GEOMETRY CONSIDERATIONS. THE DESIGN OF EMBEDMENT ANCHORAGE INCLUDING TYPE, SIZE, AND SPACING SATISFIES THE REQUIREMENTS OF APPENDIX B AS WELL AS OTHER APPLICABLE SECTIONS OF ACI 349.

Figure 3H.5-6
[Auxiliary Building
Typical Composite Floor]*

*NRC Staff approval is required prior to implementing a change in this information.




Figure 3H-7
[Typical Reinforcement and Connection to Shield Building]*

*NRC Staff approval is required prior to implementing a change in this information.





Figure 3H.5-8
[Auxiliary Building Operations Work Area
(Tagging Room) Ceiling]*

*NRC Staff approval is required prior to implementing a change in this information.



**Figure 3H.5-9 (Sheet 1 of 3)
[Auxiliary Building Finned Floor]***

*NRC Staff approval is required prior to implementing a change in this information.




Figure 3H.5-9 (Sheet 2 of 3)
[Auxiliary Building Finned Floor]*

*NRC Staff approval is required prior to implementing a change in this information.




Figure 3H.5-9 (Sheet 3 of 3)
[Auxiliary Building Finned Floor]*

*NRC Staff approval is required prior to implementing a change in this information.




Figure 3H.5-10
[Spent Fuel Pool Wall Divider Wall Element Locations]*

*NRC Staff approval is required prior to implementing a change in this information.

Security-Related Information, Withheld Under 10 CFR 2.390d

Figure 3H.5-11 (Sheet 1 of 6)
[Design of Shield Building: Roof and Air Inlets]*

*NRC Staff approval is required prior to implementing a change in this information.

Security-Related Information, Withheld Under 10 CFR 2.390d

Figure 3H.5-11 (Sheet 2 of 6)
[Design of Shield Building: Concrete Detail at Tension Ring]*

*NRC Staff approval is required prior to implementing a change in this information.

Security-Related Information, Withheld Under 10 CFR 2.390d

Figure 3H.5-11 (Sheet 3 of 6)
[Design of Shield Building: Roof/Air Inlet Interface]*

*NRC Staff approval is required prior to implementing a change in this information.

Security-Related Information, Withheld Under 10 CFR 2.390d

Figure 3H.5-11 (Sheet 4 of 6)
[Design of Shield Building at Air Inlets]*

*NRC Staff approval is required prior to implementing a change in this information.

Security-Related Information, Withheld Under 10 CFR 2.390d

Figure 3H.5-11 (Sheet 5 of 6)
***[Design of Shield Building:
Tank/Roof Interface Reinforcement]****

*NRC Staff approval is required prior to implementing a change in this information.

Compression Ring Configuration





Figure 3H.5-11 (Sheet 6 of 6)
Design of Shield Building:
Tank/Compression Ring Roof Interface Reinforcement



NOTE 1:
REFER TO SUBSECTION 3.8.4.4.1 FOR THE REQUIREMENTS FOR
SHEAR REINFORCEMENT AND TABLE 3H.5-7 FOR SHEAR
REINFORCEMENT PROVIDED.

Figure 3H.5-12
[Typical Reinforcement in Wall L]*

*NRC Staff approval is required prior to implementing a change in this information.




Figure 3H.5-13
Enhanced Shield Building Wall Panel Layout





Figure 3H.5-14
Elevation View of Tension Ring and Air Inlets



**Figure 3H.5-15
Shield Building Tension Ring**

Security-Related Information, Withheld Under 10 CFR 2.390d

For additional information, see Figure 6 of APP-GW-GLR-602 (Reference 1).

Figure 3H.5-16 (Sheet 1 of 2)
***[Design of Shield Building:
Surface Plates on Cylindrical Section – Developed View 90-270 Degrees]****

*NRC Staff approval is required prior to implementing a change in this information.

Security-Related Information, Withheld Under 10 CFR 2.390d

For additional information, see Figure 6 of APP-GW-GLR-602 (Reference 1).

Figure 3H.5-16 (Sheet 2 of 2)
***[Design of Shield Building:
Surface Plates on Cylindrical Section – Developed View 270-90 Degrees]****

*NRC Staff approval is required prior to implementing a change in this information.

Appendix 3I Evaluation for High Frequency Seismic Input

3I.1 Introduction

The seismic analysis and design of the AP1000 plant is based on the Certified Seismic Design Response Spectra (CSDRS) shown in [Subsection 3.7.1.1](#). These spectra are based on Regulatory Guide 1.60 with an increase in the 25 hertz region. Ground Motion Response Spectra (GMRS) for some Central and Eastern United States rock sites show higher amplitude at high frequency than the CSDRS. Evaluations are described in this appendix for an envelope response spectra with high frequency for the seismic input. The resulting spectra of this site are shown in [Figure 3I.1-1](#) and [Figure 3I.1-2](#) and compare this hard rock high frequency (HRHF) envelope response spectra at the foundation level against the AP1000 CSDRS for both the horizontal and vertical directions for 5% damping. The HRHF envelope response spectra exceed the CSDRS for frequencies above about 15 Hz.

High frequency seismic input is generally considered to be non-damaging as described in [Reference 1](#). The evaluation of the AP1000 nuclear island for the high frequency input is based on the analysis of a limited sample of structures, components, supports, and piping to demonstrate that the high frequency seismic response is non-damaging. The evaluation includes building structures, reactor pressure vessel and internals, primary component supports, primary loop nozzles, piping, and equipment.

This appendix describes the methodology and criteria used in the evaluation to confirm that the high frequency input is not damaging to equipment and structures qualified by analysis for the AP1000 CSDRS. It provides supplemental criteria for selection and testing of equipment whose function might be sensitive to high frequency. The results of the high frequency evaluation demonstrating that the AP1000 plant is qualified for this type of input are documented in a technical report ([Reference 2](#)). This report will provide a summary of the analysis and test results.

3I.2 High Frequency Seismic Input

Presented in [Figures 3I.1-1](#) and [3I.1-2](#) is a comparison of the horizontal and vertical HRHF envelope response spectra and the AP1000 CSDRS. The HRHF envelope response spectra presented are calculated at foundation level (39.5' below grade), at the upper most competent material and treated as an outcrop for calculation purposes.

For each direction, the HRHF envelope response spectra exceed the design spectra in higher frequencies (greater than 15 Hz horizontal and 20 Hz vertical). The spectra are used for the HRHF envelope response spectra. If necessary, the HRHF envelope response spectra are enhanced at low frequencies so that HRHF envelope response spectra fully envelope all of the hard rock sites.

These HRHF envelope response spectra are further limited in that the shear wave velocity limitation is defined at the bottom of the basemat equal to or higher than 7,500 fps, while maintaining a shear wave velocity equal to or above 8,000 fps at the lower depths.

3I.3 NI Models Used To Develop High Frequency Response

The NI20 nuclear island model described in [Appendix 3G](#) is analyzed in ACS SASSI using the HRHF time histories applied at foundation level to obtain the motion at the base.

A modal analysis of the NI05 model for both the auxiliary and shield buildings and containment internal structure (CIS) has been performed for each of these regions. Specific areas within each wall or floor where out-of-plane modes, which may respond to either CSDRS or HRHF input (including structures with modes less than 33 Hz and between 33 Hz to 50 Hz), have been identified. The

survey reveals that some regions, typically in the middle of a floor or wall, exhibit amplified behavior compared to the critical nodes at the corner and edge building locations. The amplified FRS for these regions is generated in addition to the typical set of critical nodes for building analysis by a single time history analysis of the NI05 building model subject to the HRHF time history input. Seismic response spectra for each of the “flexible” nodes are considered when selecting the pre-existing “group” spectra, which is the envelope of the entire floor in that area.

Evaluation of incoherent HRHF spectra has been performed. The CSDRS and HRHF seismic responses were compared with coherent and incoherent considerations at a number of locations in the nuclear island. There are some exceedances, mostly above the 15 hertz region, and these are typical of the plant comparative responses. The steel containment vessel (SCV) was excluded from the evaluation because the HRHF spectra at the base of the SCV are enveloped by the AP1000 CSDRS spectra at the base of the SCV.

Structures designed to the CSDRS input are adequately designed for the HRHF input because the HRHF coherent results are enveloped by the CSDRS results.

3I.4 Evaluation Methodology

The demonstration that the AP1000 nuclear power plant is qualified for the high frequency seismic response does not require the analysis of the total plant. The evaluations made are of representative systems, structures, and components, selected by screening, as potentially sensitive to high frequency input in locations where there were exceedances in the high frequency region. Acceptability of this sample is considered sufficient to demonstrate that the AP1000 is qualified.

The high frequency seismic analyses that are performed use time history or broadened response spectra. The analysis is not performed using the combination spectra of the CSDRS and the HRHF envelope response spectra. Separate analyses with each spectra are used.

The high frequency seismic analyses used the soil-structure interaction code ACS SASSI. The results presented in this report are based on the stochastic (multiple, statistical analyses) seismic incoherent soil-structure interaction analysis approach referred herein as the simulation approach.

The evaluations performed assess the ability of the system, structure, or component to maintain its safety function.

Supplementary analyses are performed as needed to show that high frequency floor response spectra exceedances are not damaging. These analyses can include: gap nonlinearities; material inelastic behavior; multi point response spectra analyses where the high frequency response excites a local part of the system. Tests on equipment are specified as needed where function cannot be demonstrated by analysis, or analysis is not appropriate.

3I.5 General Selection Screening Criteria

The following general screening criteria are used to identify representative AP1000 systems, structures, and components (SSCs) for the samples to be evaluated to demonstrate acceptability of the AP1000 nuclear power plant for the high frequency motion.

- Select systems, structures, and components based on their importance to safety. This includes the review of component safety function for the SSE event and its potential failure modes due to an SSE. Those components whose failure modes would result in safe shutdown are excluded.

- Select systems, structures, and components that are located in areas of the plant that experience large high frequency seismic response.
- Select systems, structures, and components that have significant modal response within the region of high frequency amplification. Significance is defined by such items as modal mass; participation factor, stress and/or deflection.
- Select systems, structures, and components that have significant stress as compared to allowable when considering load combinations that include seismic.

3I.6 Evaluation

In this section the portions of structures, the components, and the systems that are evaluated for the high frequency seismic response are identified. The sample to be evaluated, based on the screening criteria applicable to the SSCs consists of the following:

- Building Structures
 - Auxiliary Building – 3 locations
 - Shield Building – 8 locations
 - CIS – 2 locations
- Primary Coolant Loop
 - Reactor Vessel and Internals
 - Primary Component Supports
 - Reactor Coolant Loop Primary Equipment Nozzles
- Piping Systems – ASME Class 1, 2, and 3 piping systems will be evaluated for the HRHF GMRS. This evaluation is within the scope of the piping DAC (see COL Information Item 3.9-7).
- Electro-Mechanical Equipment – Equipment that is potentially sensitive to high frequency input (see [Table 3I.6-1](#))

These structures, systems, and equipment are discussed in more detail in the sections that follow.

3I.6.1 Building Structures

Maintaining the NI buildings structural integrity is important to the safety of the plant. Representative portions of the buildings that are evaluated for the effect of high frequency input are selected based on those areas that can experience high seismic shear and moment loads due to the seismic event. Areas chosen are at the base of the shield building, in the vicinity of auxiliary building floors that have fundamental frequencies in the high frequency region, and the corners of the auxiliary building. Three locations are selected on the auxiliary building that reflect the bottom of a wall where the shear and moment would be large, a wall in the vicinity of a floor that is influenced by high frequency response, and a corner intersection of walls. Eight locations are evaluated on the shield building. Four at elevation 107' and four at elevation 211'. These locations are located on the east, west, north and south sides. The south-west wall of the refueling canal is evaluated since it is a representative wall on

the refueling canal. The CA02 wall in the CIS building is evaluated since it is a representative wall associated with the IRWST.

The evaluation consists of a comparison of the loads from the high frequency input to those obtained from the AP1000 design spectra, shown in **Figures 3I.1-1** and **3I.1-2**, for these representative building structures. The NI building structures are considered qualified for the high frequency input if the seismic loads from the Regulatory Guide 1.60 (modified) envelope those from the high frequency input. If there is any exceedance, this is evaluated further to confirm that the existing design is adequate.

3I.6.2 Primary Coolant Loop

A failure within the reactor coolant loop could challenge the integrity of the reactor coolant pressure boundary. Therefore, it is chosen for evaluation. The components evaluated are as follows:

- Reactor vessel and internals
- Reactor vessel supports
- Steam generator supports
- Reactor coolant loop primary equipment nozzles

The reactor vessel and internals are selected since they are important to safety and their analysis is representative of major primary components. The building structure below the reactor vessel supports is fairly stiff and there may be significant vertical amplification at the supports of the reactor pressure vessel. Further, reactor vessel internals have relatively complex structural systems including gap nonlinearities and sliding elements. Also, they may be sensitive to high frequency input as summarized below:

- Vertical and horizontal modes of the upper internals and the reactor vessel modes are in the relatively high frequency range.
- Additional high frequencies are associated with nonlinear impact

The evaluation consists of a comparison of the loads from the high frequency input to those obtained from the Regulatory Guide 1.60 (modified) input. Qualification is shown for the high frequency input if the seismic loads from the Regulatory Guide 1.60 (modified) envelope those from the high frequency input. If there is exceedance, then comparison is made for the combination of the seismic with the design basis pipe break loads and steady state loads. Qualification is then shown if the high frequency loads are relatively insignificant compared to the other loads, or there are no required design changes.

Maintaining the integrity of the reactor vessel and steam generator supports is important to preserving the primary component safety function. They are representative of supports on components, and see high loads.

The reactor coolant loop nozzles at the cold and hot leg interfaces of the reactor pressure vessel, reactor coolant pumps, and steam generators are important to include in the evaluation since these are critical areas of components.

The evaluation of the primary component supports and reactor coolant loop nozzles consists of a comparison of the loads from the high frequency input to those obtained from the Regulatory Guide 1.60 (modified) input. These items are considered qualified for the high frequency input if the seismic loads from the Regulatory Guide 1.60 (modified) envelope those from the high frequency input. If there is any exceedance, then an evaluation is made combining the high frequency loads with the other load components (e.g., thermal, pressure, dead) and a comparison made to the design loads. If

the design loads envelope the load combinations that include the high frequency seismic input, then the nozzles and supports are considered qualified for the high frequency input.

3I.6.3 Piping Systems

ASME Class 1, 2, and 3 piping systems will be evaluated for the HRHF GMRS. This evaluation is within the scope of the piping DAC (see COL Information Item 3.9-7).

3I.6.4 Electrical and Electro-Mechanical Equipment

The groups of safety-related equipment considered for evaluation are those that may be sensitive to the high frequency input. This includes those cabinet-mounted equipment, field sensors, and appurtenants that may be sensitive to high frequency seismic inputs identified in [Table 3I.6-1](#).

Sample safety-related cabinets have been identified that are typically sensitive to seismic input. Evaluations were performed to verify these cabinets do not have excessive seismic excitation on their mounted equipment, the cabinet designs do not require changes due to the high frequency input, and the cabinets will maintain their structural integrity during the high frequency input. Time history analyses of these cabinets were performed for both the Regulatory Guide 1.60 (modified) and the high frequency inputs so that comparisons can be made to their seismic response from both seismic inputs. This analytical study reported in APP-GW-GLR-115 ([Reference 2](#)) concluded that safety-related equipment may be screened.

The AP1000 HRHF screening program for determination and evaluation of potential high frequency sensitive equipment is in compliance with the NRC requirements in Section 4.0, "Identification and Evaluation of HF Sensitive Mechanical and Electrical Equipment/Components," of COL/DC-ISG-1 ([Reference 3](#)). The AP1000 HRHF screening program is also consistent with the guidelines developed as part of an industry review document in the EPRI White Paper, "Seismic Screening of Components Sensitive to High Frequency Vibratory Motions" ([Reference 4](#)), transmitted to the NRC on June 28, 2007, for determining the safety-related equipment and components that may be HRHF sensitive, and screening procedures to ensure that any safety-related equipment and components sensitive to HRHF seismic excitation are screened out. This industry review of HF exceedance and further evaluations of SSCs performed by Westinghouse concluded that HRHF envelope response spectra are less harmful than the CSDRS except for the functionality of potential HRHF-sensitive components.

The AP1000 HRHF screening program is based on an HF evaluation study reported in APP-GW-GLR-115 ([Reference 2](#)). The HF evaluation study concluded that AP1000 In-Structure Response Spectra (ISRS) developed from the AP1000 CSDRS would, in the majority of cases, produce equipment stress results of the same magnitude or higher than the stress results produced from HRHF seismic excitation. The exception to this condition is when the dominant natural frequency of the equipment is in the HRHF exceedance range and there can be significantly more response because the frequency coincides with the input driving force. Under this condition, forces/stresses generated in the equipment could be due to the acceleration exceedance; therefore, the equipment will be subjected to HRHF seismic evaluation/testing to screen out equipment by verifying its performance and acceptability under HRHF excitation. Review of seismic test data for electrical and microprocessor based cabinets performed to generic and high frequency excitation concluded that seismic testing that peaks in the lower frequency range will produce larger displacements and velocities, and will result in higher stresses in the equipment.

The goal of the AP1000 HRHF screening program is to identify the potential safety-related equipment and components that have the potential to be HRHF-sensitive and show them to be acceptable for their specific application (screened-out). The AP1000 HRHF screening program is a two step process. The first step is an HRHF susceptibility review to identify potential high frequency sensitive

safety-related equipment. The second step is the screened-out equipment process to demonstrate its acceptability for the HRHF seismic excitation. Evaluation of screened-in equipment as defined in COL/DC-ISG-1 (Reference 3) is not performed because all safety-related equipment that is screened-in will be eliminated or shown to be acceptable through a design change process.

For the AP1000 HRHF screening program, the following conditions must exist:

1. Plant-specific HRHF GMRS exceeds the AP1000 CSDRS in the high frequency range at 5% critical damping.
2. Safety-related equipment has potential failure modes involving change of state, chatter, signal change/drift, and connection problems.

Table 3I.6-2 is a list of potential HRHF-sensitive AP1000 safety-related equipment developed based on Table 3.11-1 of Section 3.11, “Environmental Qualification of Mechanical and Electrical Equipment.” The equipment in Table 3.2-3 of Section 3.2, “AP1000 Classification of Mechanical and Fluid Systems, Components, and Equipment,” and Table 3I.6-3 is not HRHF-sensitive. The structural integrity and operability of equipment in Table 3.2-3 and Table 3I.6-3 will not be impacted by the high frequency excitation.

The HRHF susceptibility review of AP1000 safety-related equipment is not performed for potential failure modes associated with mounting, connections, fasteners, joints, and structural interface. These potential failure modes are addressed through the seismic qualification of the safety-related equipment to the AP1000 ISRS testing performed in compliance with IEEE Standard 344-1987. The AP1000 ISRS qualification testing generates higher displacements and velocities than those resulting from HRHF seismic excitation since the AP1000 ISRS is controlled by the lower frequency range. The higher displacement, velocities, and accelerations will detect these equipment structural failure modes if they exist.

At locations where HRHF response spectra show exceedance of the CSDRS and there is a likelihood of equipment damage, further evaluations would be performed to verify that the existing qualification is adequate for equipment not high frequency sensitive, as listed in Table 3I.6-3, under the following conditions:

- Safety-related equipment must have modes or natural frequencies in the range of interest.
- Evaluation will apply the same acceptance criteria and methodologies used in CSDRS qualification.

To demonstrate acceptability for both CSDRS and HRHF testing, the test response spectra must envelop the CSDRS and HRHF spectra, respectively, with margin over the frequency range of interest in compliance with IEEE Standard 344-1987. In the event that the CSDRS and/or HRHF response spectra would be revised after the qualification program has been completed, a reconciliation effort would be performed to verify that the CSDRS and HRHF testing is still valid. The reconciliation effort may result in requalification activities and qualification documentation revisions.

High Frequency Screening Process – Step 1

The potential failure modes of high frequency sensitive component types and assemblies are important considerations in the high frequency program. The following are potential failure modes of high frequency sensitive components/equipment:

- Inadvertent change of state
- Chatter
- Change in accuracy and drift in output signal or set-point

- Electrical connection failure or intermediacy (e.g., poor quality solder joints)
- Mechanical connection failure
- Mechanical misalignment/binding (e.g., latches, plungers)
- Fatigue failure (e.g., solder joints, ceramics, self-taping screws, spot welds)
- Improperly and unrestrained mounted components
- Inadequately secured/locked mechanical fasteners and connections

Components and equipment determined to have potential failure modes involve change of state, chatter, signal change/drift, and connection problems will be demonstrated to be acceptable through the performance of a supplemental high frequency screening test. Those high frequency sensitive components having failure modes associated with mounting, connections and fasteners, joints, and interface are considered to be acceptable as a result of the AP1000 ISRS qualification testing per IEEE Standard 344-1987 and/or require quality assurance inspection and process/design controls.

High Frequency Screening Process – Step 2

The HRHF susceptibility review is to verify that the subject equipment is capable of performing its safety-related function under HRHF seismic excitation. All AP1000 safety-related equipment will be qualified to the AP1000 ISRS, and the dominant natural frequencies of the equipment will be determined. The EPRI White Paper ([Reference 4](#)) identifies the following three evaluation methods to demonstrate that potential HRHF-sensitive safety-related equipment is not HRHF vulnerable:

1. Existing seismic qualification test data for potential high frequency sensitive equipment should be reviewed for applicability and adequacy of the test method to demonstrate sufficient high frequency content.
2. Systems/circuits containing potentially sensitive items should be reviewed for inappropriate/unacceptable system actions due to assumed change of state, contact chatter/intermittency, set point drifts, or loss of calibration.
3. HRHF vibration screening test is conducted to identify any HRHF sensitivities/abnormalities of the components. Several conventional test methods are recommended.

The first and third evaluation methods are part of the AP1000 HRHF screening program and are further detailed below. The AP1000 HRHF seismic screening evaluation will employ the AP1000 HRHF SSE response spectra as input in verifying potential HF sensitive safety-related equipment is not vulnerable to HRHF seismic excitation. Additional seismic test margin will be introduced into the HRHF seismic screening evaluation as needed.

Method 1: Review of Seismic Test Data

Available seismic test data can be used for AP1000 HRHF plant applications when:

- Seismic qualification testing performed on potential HRHF-sensitive safety-related equipment meets as a minimum the AP1000 ISRS in compliance with IEEE Standard 344-1987.
- Safe shutdown earthquake (SSE) test had sufficient energy content in the HRHF region to verify that the safety-related equipment is not vulnerable to HRHF seismic excitation.

No additional seismic testing is required for safety-related equipment previously tested and whose qualification level envelops the HRHF required response spectra (RRS).

IEEE Standard 344-1987 provides guidance to ensure that the seismic test input is generated and in compliance with the frequency range of interest. To demonstrate acceptability for frequency content, it is necessary to show that the frequency content of the test waveform is at least as broad as the

frequency content of the amplified region of the RRS except at the low frequencies where non-enveloping is permitted under certain conditions (refer to IEEE Standard 344-1987 subclauses 7.6.3.1(10) and 7.6.3.1(13)). An evaluation of the test input waveform should be conducted per IEEE Standard 344-1987 Annex B to verify the test data has sufficient content over the frequency range of interest throughout the input time history. If an evaluation of the test input is performed, and the data demonstrates sufficient frequency content in the high frequency range throughout the time history, then the data is acceptable.

Method 3: HRHF Screening Test

The HRHF screening test is a supplemental test to the required seismic qualification methods performed in accordance with IEEE Standard 344-1987 for those plants that have high frequency exceedance of the AP1000 CSDRS. The purpose of the HRHF screening test is to demonstrate that the potential HRHF-sensitive safety-related equipment will perform its safety-related function as required under HRHF seismic excitation. The HRHF screening test is performed in conjunction with the AP1000 ISRS seismic qualification testing, or it is performed as a supplemental test after completion of the AP1000 ISRS seismic qualification testing. The AP1000 ISRS and HRHF test input time histories have 30-second durations with frequency content up to the cutoff frequency developed in accordance with subclause 7.6.3 (Multiple-Frequency Tests) and Annex B (Frequency Content and Stationarity) of IEEE Standard 344-1987. During the AP1000 ISRS and HRHF testing, the equipment will be functional and monitored to verify the safety-related function was demonstrated. Screening testing will be performed using HRHF response spectra as defined in the EPRI White Paper (Reference 4) when AP1000 HRHF inputs are not available. The HRHF response spectra will be generated based on the 5g and 15g peak spectral acceleration at 5% critical damping in the 25 Hz to 50 Hz frequency range. If the HRHF screening test cannot demonstrate the equipment to be acceptable, then the safety-related equipment will be removed or modified and additional testing or justification will be required.

The AP1000 safety-related equipment will be seismic qualified to the AP1000 ISRS associated with the mounting location of the equipment as a minimum. Seismic qualification testing will consist of five AP1000 ISRS operating basis earthquakes (OBEs) followed by one SSE as a minimum. The OBE level will be at least one-half the SSE level. The OBE testing is used to vibration age and address low-cycle fatigue of equipment prior to SSE testing. Cyclic fatiguing of equipment for HRHF exceedance area is adequately addressed by performing five OBE (one-half the SSE) and a minimum of one SSE seismic test runs in compliance with IEEE Standard 344-1987 prior to performing the supplemental HRHF screening test. Additional OBE testing in the high frequency exceedance range is adequately addressed by the demonstration that the peak stress cycles required for five one-half SSE events using the AP1000 HRHF ISRS are equivalent to or enveloped by the peak stress cycles resulting from five one-half SSE events and one full SSE event using the AP1000 CSD ISRS.

The test results of AP1000 seismic qualification programs with multiple operational states (for example, relays have three possible operational states: de-energized, energized, and change of state) will be used to determine the most sensitive equipment electrical operational state. The HRHF test run is performed on the equipment in its most sensitive electrical operational state to demonstrate its safety-related function under HRHF seismic excitation. If this is not possible, additional HRHF screening tests will be performed as needed to address the other most sensitive electrical operation states.

3I.7 References

1. EPRI Draft White Paper, "Considerations for NPP Equipment and Structures Subjected to Response Levels Caused by High Frequency Ground Motions," Transmitted to NRC March 19, 2007.

2. APP-GW-GLR-115, “Effect of High Frequency Seismic Content on SSCs,” Westinghouse Electric Company LLC.
3. COL/DC-ISG-1, “Interim Staff Guidance on Seismic Issues of High Frequency Ground Motion,” May 19, 2008.
4. EPRI White Paper, “Seismic Screening of Components Sensitive to High Frequency Vibratory Motions,” June 2007.
5. Letter, R. Sisk (Westinghouse) to NRC, “AP1000 Response to Request for Additional Information (SRP3.10),” DCP/NRC2280, October 17, 2008.

Table 3I.6-1
Potential High Frequency Sensitive Equipment List

- Equipment or components with moving parts and required to perform a switching function during the seismic event (e.g., circuit breakers, contactors, auxiliary switches, molded case circuit breakers, motor control center starters, and pneumatic control assemblies)
- Components with moving parts that may bounce or chatter such as relays and actuation devices (e.g., shunt trips)
- Unrestrained components
- Potentiometers
- Process switches and sensors (e.g., pressure/differential pressure, temperature, level, limit/position, and flow)
- Components with accuracy requirements that may drift due to seismic loading
- Interfaces such as secondary contacts
 - Connectors and connections (including circuit board connections for digital and analog equipment)

**Table 3I.6-2 (Sheet 1 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Batteries	
IDSA 125V 60 Cell Battery 1A	IDSA-DB-1A
IDSA 125V 60 Cell Battery 1B	IDSA-DB-1B
IDSB 125V 60 Cell Battery 1A	IDSB-DB-1A
IDSB 125V 60 Cell Battery 1B	IDSB-DB-1B
IDSB 125V 60 Cell Battery 2A	IDSB-DB-2A
IDSB 125V 60 Cell Battery 2B	IDSB-DB-2B
IDSC 125V 60 Cell Battery 1A	IDSC-DB-1A
IDSC 125V 60 Cell Battery 1B	IDSC-DB-1B
IDSC 125V 60 Cell Battery 2A	IDSC-DB-2A
IDSC 125V 60 Cell Battery 2B	IDSC-DB-2B
IDSD 125V 60 Cell Battery 1A	IDSD-DB-1A
IDSD 125V 60 Cell Battery 1B	IDSD-DB-1B
Spare 125V 60 Cell Battery 1A	IDSS-DB-1A
Spare 125V 60 Cell Battery 1B	IDSS-DB-1B
Battery Chargers	
IDSA Battery Charger	IDSA-DC-1
IDSB Battery Charger	IDSB-DC-1
IDSB Battery Charger 2	IDSB-DC-2
IDSC Battery Charger 1	IDSC-DC-1
IDSC Battery Charger 2	IDSC-DC-2
IDSD Battery Charger	IDSD-DC-1
Spare Battery Charger	IDSS-DC-1

**Table 3I.6-2 (Sheet 2 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Distribution Panels	
IDSA 250 Vdc Dist Panel	IDSA-DD-1
IDSB 250 Vdc Dist Panel	IDSB-DD-1
IDSC 250 Vdc Dist Panel	IDSC-DD-1
IDSD 250 Vdc Dist Panel	IDSD-DD-1
IDSA 120 Vac Dist Panel 1	IDSA-EA-1
IDSA 120 Vac Dist Panel 2	IDSA-EA-2
IDSB 120 Vac Dist Panel 1	IDSB-EA-1
IDSB 120 Vac Dist Panel 2	IDSB-EA-2
IDSB 120 Vac Dist Panel 3	IDSB-EA-3
IDSC 120 Vac Dist Panel 1	IDSC-EA-1
IDSC 120 Vac Dist Panel 2	IDSC-EA-2
IDSC 120 Vac Dist Panel 3	IDSC-EA-3
IDSD 120 Vac Dist Panel 1	IDSD-EA-1
IDSD 120 Vac Dist Panel 2	IDSD-EA-2
Fuse Panels	
IDSA Fuse Panel	IDSA-EA-4
IDSB Fuse Panel	IDSB-EA-4
IDSB Fuse Panel	IDSB-EA-5
IDSB Fuse Panel	IDSB-EA-6
IDSC Fuse Panel	IDSC-EA-4
IDSC Fuse Panel	IDSC-EA-5
IDSC Fuse Panel	IDSC-EA-6
IDSD Fuse Panel	IDSD-EA-4

**Table 3I.6-2 (Sheet 3 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Transfer Switches	
IDSA Fused Transfer Switch Box 1	IDSA-DF-1
IDSB Fused Transfer Switch Box 1	IDSB-DF-1
IDSB Fused Transfer Switch Box 2	IDSB-DF-2
IDSC Fused Transfer Switch Box 1	IDSC-DF-1
IDSC Fused Transfer Switch Box 2	IDSC-DF-2
IDSD Fused Transfer Switch Box 1	IDSD-DF-1
IDSS Fused Transfer Switch Box 1	IDSS-DF-1
IDSS Spare Termination Box	IDSS-DF-2
IDSS Spare Termination Box	IDSS-DF-3
IDSS Spare Termination Box	IDSS-DF-4
IDSS Spare Termination Box	IDSS-DF-5
Motor Control Centers	
IDSA 250 Vdc MCC	IDSA-DK-1
IDSB 250 Vdc MCC	IDSB-DK-1
IDSC 250 Vdc MCC	IDSC-DK-1
IDSD 250 Vdc MCC	IDSD-DK-1
Switchboards	
IDSA 250 Vdc Switchboard 1	IDSA-DS-1
IDSB 250 Vdc Switchboard 1	IDSB-DS-1
IDSB 250 Vdc Switchboard 2	IDSB-DS-2
IDSC 250 Vdc Switchboard 1	IDSC-DS-1
IDSC 250 Vdc Switchboard 2	IDSC-DS-2
IDSD 250 Vdc Switchboard 1	IDSD-DS-1

Table 3I.6-2 (Sheet 4 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment

Description	AP1000 Tag Number
Transformers	
IDSA Regulating Transformer 1	IDSA-DT-1
IDSB Regulating Transformer 1	IDSB-DT-1
IDSC Regulating Transformer 1	IDSC-DT-1
IDSD Regulating Transformer 1	IDSD-DT-1
Inverters	
IDSA Inverter	IDSA-DU-1
IDSB Inverter 1	IDSB-DU-1
IDSB Inverter 2	IDSB-DU-2
IDSC Inverter 1	IDSC-DU-1
IDSC Inverter 2	IDSC-DU-2
IDSD Inverter	IDSD-DU-1
Switchgear	
RCP 1A 6900V Switchgear 31	ECS-ES-31
RCP 1A 6900V Switchgear 32	ECS-ES-32
RCP 2A 6900V Switchgear 51	ECS-ES-51
RCP 2A 6900V Switchgear 52	ECS-ES-52
RCP 1B 6900V Switchgear 41	ECS-ES-41
RCP 1B 6900V Switchgear 42	ECS-ES-42
RCP 2B 6900V Switchgear 61	ECS-ES-61
RCP 2B 6900V Switchgear 62	ECS-ES-62
Reactor Trip Switchgear	PMS-JD-RTSA01
Reactor Trip Switchgear	PMS-JD-RTSA02
Reactor Trip Switchgear	PMS-JD-RTSB01
Reactor Trip Switchgear	PMS-JD-RTSB02

**Table 3I.6-2 (Sheet 5 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Reactor Trip Switchgear	PMS-JD-RTSC01
Reactor Trip Switchgear	PMS-JD-RTSC02
Reactor Trip Switchgear	PMS-JD-RTSD01
Reactor Trip Switchgear	PMS-JD-RTSD02
Level Transmitters	
Core Makeup Tank A Narrow Range	PXS-JE-LE011A / PXS-JE-LT011A
Core Makeup Tank A Narrow Range	PXS-JE-LE011B / PXS-JE-LT011B
Core Makeup Tank A Narrow Range	PXS-JE-LE011C / PXS-JE-LT011C
Core Makeup Tank A Narrow Range	PXS-JE-LE011D / PXS-JE-LT011D
Core Makeup Tank B Narrow Range	PXS-JE-LE012A / PXS-JE-LT012A
Core Makeup Tank B Narrow Range	PXS-JE-LE012B / PXS-JE-LT012B
Core Makeup Tank B Narrow Range	PXS-JE-LE012C / PXS-JE-LT012C
Core Makeup Tank B Narrow Range	PXS-JE-LE012D / PXS-JE-LT012D
Core Makeup Tank A Narrow Range	PXS-JE-LE013A / PXS-JE-LT013A
Core Makeup Tank A Narrow Range	PXS-JE-LE013B / PXS-JE-LT013B
Core Makeup Tank A Narrow Range	PXS-JE-LE013C / PXS-JE-LT013C
Core Makeup Tank A Narrow Range	PXS-JE-LE013D / PXS-JE-LT013D
Core Makeup Tank B Narrow Range	PXS-JE-LE014A / PXS-JE-LT014A
Core Makeup Tank B Narrow Range	PXS-JE-LE014B / PXS-JE-LT014B
Core Makeup Tank B Narrow Range	PXS-JE-LE014C / PXS-JE-LT014C
Core Makeup Tank B Narrow Range	PXS-JE-LE014D / PXS-JE-LT014D
Containment Floodup Level	PXS-JE-LE050 / PXS-JE-LT050
Containment Floodup Level	PXS-JE-LE051 / PXS-JE-LT051
Containment Floodup Level	PXS-JE-LE052 / PXS-JE-LT052

Table 3I.6-2 (Sheet 6 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment

Description	AP1000 Tag Number
Neutron Detectors	
Source Range Neutron Detector	RXS-JE-NE001A
Source Range Neutron Detector	RXS-JE-NE001B
Source Range Neutron Detector	RXS-JE-NE001C
Source Range Neutron Detector	RXS-JE-NE001D
Intermediate Range Neutron Detector	RXS-JE-NE002A
Intermediate Range Neutron Detector	RXS-JE-NE002B
Intermediate Range Neutron Detector	RXS-JE-NE002C
Intermediate Range Neutron Detector	RXS-JE-NE002D
Power Range Neutron Detector (Lower)	RXS-JE-NE003A
Power Range Neutron Detector (Lower)	RXS-JE-NE003B
Power Range Neutron Detector (Lower)	RXS-JE-NE003C
Power Range Neutron Detector (Lower)	RXS-JE-NE003D
Power Range Neutron Detector (Upper)	RXS-JE-NE004A
Power Range Neutron Detector (Upper)	RXS-JE-NE004B
Power Range Neutron Detector (Upper)	RXS-JE-NE004C
Power Range Neutron Detector (Upper)	RXS-JE-NE004D
Radiation Monitors	
Containment High Range Area Monitor	PXS-JE-RE160
Containment High Range Area Monitor	PXS-JE-RE161
Containment High Range Area Monitor	PXS-JE-RE162
Containment High Range Area Monitor	PXS-JE-RE163
Control Room Supply Air Area Monitor	VBS-JE-RE001A
Control Room Supply Air Area Monitor	VBS-JE-RE001B

**Table 3I.6-2 (Sheet 7 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Speed Sensors	
RCP 1A Pump Speed	RCS-JE-ST281
RCP 1B Pump Speed	RCS-JE-ST282
RCP 2A Pump Speed	RCS-JE-ST283
RCP 2B Pump Speed	RCS-JE-ST284
Transmitters	
PCS Water Delivery Flow	PCS-JE-FT001
PCS Water Delivery Flow	PCS-JE-FT002
PCS Water Delivery Flow	PCS-JE-FT003
PCS Water Delivery Flow	PCS-JE-FT004
PCS Storage Tank Water Level	PCS-JE-LT010
PCS Storage Tank Water Level	PCS-JE-LT011
PRHR HX Flow	PXS-JE-FT049A
PRHR HX Flow	PXS-JE-FT049B
RCS Hot Leg 1 Flow	RCS-JE-FT101A
RCS Hot Leg 1 Flow	RCS-JE-FT101B
RCS Hot Leg 1 Flow	RCS-JE-FT101C
RCS Hot Leg 1 Flow	RCS-JE-FT101D
RCS Hot Leg 2 Flow	RCS-JE-FT102A
RCS Hot Leg 2 Flow	RCS-JE-FT102B
RCS Hot Leg 2 Flow	RCS-JE-FT102C
RCS Hot Leg 2 Flow	RCS-JE-FT102D
SG1 Startup Feedwater Flow	SGS-JE-FT055A
SG1 Startup Feedwater Flow	SGS-JE-FT055B
SG2 Startup Feedwater Flow	SGS-JE-FT-056A

Table 3I.6-2 (Sheet 8 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment

Description	AP1000 Tag Number
SG2 Startup Feedwater Flow	SGS-JE-FT056B
MCR Air Delivery Line Flow Rate – A	VES-JE-FT003A
MCR Air Delivery Line Flow Rate – B	VES-JE-FT003B
Plant Vent Flow	VFS-JE-FT101
IRWST Level	PXS-JE-LT045
IRWST Level	PXS-JE-LT046
IRWST Level	PXS-JE-LT047
IRWST Level	PXS-JE-LT048
RCS Hot Leg Water Level	RCS-JE-LT160A
RCS Hot Leg Water Level	RCS-JE-LT160B
PZR Level	RCS-JE-LT195A
PZR Level	RCS-JE-LT195B
PZR Level	RCS-JE-LT195C
PZR Level	RCS-JE-LT195D
SG1 Narrow Range Level	SGS-JE-LT001
SG1 Narrow Range Level	SGS-JE-LT002
SG1 Narrow Range Level	SGS-JE-LT003
SG1 Narrow Range Level	SGS-JE-LT004
SG2 Narrow Range Level	SGS-JE-LT005
SG2 Narrow Range Level	SGS-JE-LT006
SG2 Narrow Range Level	SGS-JE-LT007
SG2 Narrow Range Level	SGS-JE-LT008
SG1 Wide Range Level	SGS-JE-LT011
SG1 Wide Range Level	SGS-JE-LT012
SG1 Wide Range Level	SGS-JE-LT015

Table 3I.6-2 (Sheet 9 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment

Description	AP1000 Tag Number
SG1 Wide Range Level	SGS-JE-LT016
SG2 Wide Range Level	SGS-JE-LT013
SG2 Wide Range Level	SGS-JE-LT014
SG2 Wide Range Level	SGS-JE-LT017
SG2 Wide Range Level	SGS-JE-LT018
Spent Fuel Pool Level	SFS-JE-LT019A
Spent Fuel Pool Level	SFS-JE-LT019B
Spent Fuel Pool Level	SFS-JE-LT019C
Air Storage Tank Pressure – A	VES-JE-PT001A
Air Storage Tank Pressure – B	VES-JE-PT001B
Containment Pressure Normal Range	PCS-JE-PT005
Containment Pressure Normal Range	PCS-JE-PT006
Containment Pressure Normal Range	PCS-JE-PT007
Containment Pressure Normal Range	PCS-JE-PT008
Containment Pressure Extended Range	PCS-JE-PT012
Containment Pressure Extended Range	PCS-JE-PT013
Containment Pressure Extended Range	PCS-JE-PT014
RCS Wide Range Pressure	RCS-JE-PT140A
RCS Wide Range Pressure	RCS-JE-PT140B
RCS Wide Range Pressure	RCS-JE-PT140C
RCS Wide Range Pressure	RCS-JE-PT140D
PZR Pressure	RCS-JE-PT191A
PZR Pressure	RCS-JE-PT191B
PZR Pressure	RCS-JE-PT191C
PZR Pressure	RCS-JE-PT191D

**Table 3I.6-2 (Sheet 10 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Main Steam Line SG1 Pressure	SGS-JE-PT030
Main Steam Line SG1 Pressure	SGS-JE-PT031
Main Steam Line SG1 Pressure	SGS-JE-PT032
Main Steam Line SG1 Pressure	SGS-JE-PT033
Main Steam Line SG2 Pressure	SGS-JE-PT034
Main Steam Line SG2 Pressure	SGS-JE-PT035
Main Steam Line SG2 Pressure	SGS-JE-PT036
Main Steam Line SG2 Pressure	SGS-JE-PT037
Main Control Room Differential Pressure	VES-JE-PDT004A
Main Control Room Differential Pressure	VES-JE-PDT004B
Protection and Safety Monitoring Systems	
Protection and Safety Monitoring System Cabinets	Multiple
MCR/RSW Transfer Switch Panel A	PMS-JW-004A
MCR/RSW Transfer Switch Panel B	PMS-JW-004B
MCR/RSW Transfer Switch Panel C	PMS-JW-004C
MCR/RSW Transfer Switch Panel D	PMS-JW-004D
Source Range Neutron Flux Preamplifier Panel A	PMS-JW-005A
Source Range Neutron Flux Preamplifier Panel B	PMS-JW-005B
Source Range Neutron Flux Preamplifier Panel C	PMS-JW-005C
Source Range Neutron Flux Preamplifier Panel D	PMS-JW-005D
Intermediate Range Neutron Flux Preamplifier Panel A	PMS-JW-006A
Intermediate Range Neutron Flux Preamplifier Panel B	PMS-JW-006B
Intermediate Range Neutron Flux Preamplifier Panel C	PMS-JW-006C

**Table 3I.6-2 (Sheet 11 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Intermediate Range Neutron Flux Preamplifier Panel D	PMS-JW-006D
Power Range Neutron Flux High Voltage Distribution Box A	PMS-JW-007A
Power Range Neutron Flux High Voltage Distribution Box B	PMS-JW-007B
Power Range Neutron Flux High Voltage Distribution Box C	PMS-JW-007C
Power Range Neutron Flux High Voltage Distribution Box D	PMS-JW-007D
Main Control Room	
Operator Workstation A	N/A
Operator Workstation B	N/A
Supervisor Workstation	N/A
Switch Station (Including Switches)	N/A
QDPS MCR Display Unit	PMS-JY-001B
QDPS MCR Display Unit	PMS-JY-001C
Active Valves	
Containment Isolation – Air Out Solenoid Valve Limit Switch	CAS-PL-V014-S CAS-PL-V014-L
Containment Isolation – Inlet Limit Switch Motor Operator	CCS-PL-V200-L CCS-PL-V200-M
Containment Isolation – Outlet Limit Switch Motor Operator	CCS-PL-V207-L CCS-PL-V207-M
Containment Isolation – Outlet Limit Switch Motor Operator	CCS-PL-V208-L CCS-PL-V208-M

Table 3I.6-2 (Sheet 12 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment

Description	AP1000 Tag Number
RCS Purification Stop Valve Limit Switch Motor Operator	CVS-PL-V001-L CVS-PL-V001-M
RCS Purification Stop Valve Limit Switch Motor Operator	CVS-PL-V002-L CVS-PL-V002-M
RCS Letdown Stop Valve Limit Switch Motor Operator	CVS-PL-V003-L CVS-PL-V003-M
WLS Letdown IRC Isolation Limit Switch Solenoid Valve	CVS-PL-V045-L CVS-PL-V045-S1
Letdown Flow ORC Isolation Limit Switch Solenoid Valve	CVS-PL-V047-L CVS-PL-V047-S1
Auxiliary PZR Spray Isolation Limit Switch Solenoid Valve	CVS-PL-V084-L CVS-PL-V084-S
Makeup Line Containment Isolation Limit Switch Motor Operator	CVS-PL-V090-L CVS-PL-V090-M
Makeup Line Containment Isolation Limit Switch Motor Operator	CVS-PL-V091-L CVS-PL-V091-M

**Table 3I.6-2 (Sheet 13 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Zinc Addition Containment Isolation Limit Switch Solenoid Valve	CVS-PL-V092-L CVS-PL-V092-S
Zinc Addition IRC Isolation Valve Limit Switch Solenoid Valve	CVS-PL-V094-L CVS-PL-V094-S
Demineralizer Water System Isolation Limit Switch Solenoid Valve	CVS-PL-V136A-L CVS-PL-V136A-S
Demineralized Water System Isolation Limit Switch Solenoid Valve	CVS-PL-V136B-L CVS-PL-V136B-S
Hydrogen Injection Containment Isolation Limit Switch Solenoid Valve	CVS-PL-V219-L CVS-PL-V219-S
PCCWST Isolation Valve Limit Switch Solenoid Valve	PCS-PL-V001A-L PCS-PL-V001A-S1
PCCWST Isolation Valve Limit Switch Solenoid Valve	PCS-PL-V001B-L PCS-PL-V001B-S1
PCCWST Isolation Valve Limit Switch Motor Operator	PCS-PL-V001C-L PCS-PL-V001C-M
PCCWST Isolation Valve Limit Switch Motor Operator	PCS-PL-V002A-L PCS-PL-V002A-M
PCCWST Isolation Valve Limit Switch Motor Operator	PCS-PL-V002B-L PCS-PL-V002B-M

**Table 3I.6-2 (Sheet 14 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
PCCWST Isolation Valve Limit Switch Motor Operator	PCC-PL-V002C-L PCC-PL-V002C-M
Containment Isolation – Air Sample Line Limit Switch Solenoid Operator	PSS-PL-V008-L PSS-PL-V008-S
Containment Isolation – Liquid Sample Line Limit Switch Solenoid Operator	PSS-PL-V010A-L PSS-PL-V010A-S
Containment Isolation – Liquid Sample Line Limit Switch Solenoid Operator	PSS-PL-V010B-L PSS-PL-V010B-S
Containment Isolation – Liquid Sample Line Limit Switch Solenoid Valve	PSS-PL-V011A-L PSS-PL-V011A-S
Containment Isolation – Liquid Sample Line Limit Switch Solenoid Valve	PSS-PL-V011B-L PSS-PL-V011B-S
Containment Isolation - Sample Return Line Limit Switch Solenoid Valve	PSS-PL-V023-L PSS-PL-V023-S
Containment Isolation – Sample Return Line Limit Switch Solenoid Operator	PSS-PL-V024-L PSS-PL-V024-S
Containment Isolation - Air Sample Line Limit Switch Solenoid Valve	PSS-PL-V046-L PSS-PL-V046-S
Core Makeup Tank A Discharge Isolation Limit Switch Solenoid Valve	PXS-PL-V014A-L PXS-PL-V014A-S1

**Table 3I.6-2 (Sheet 15 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Core Makeup Tank B Discharge Isolation Limit Switch Solenoid Valve	PXS-PL-V014B-L PXS-PL-V014B-S1
Core Makeup Tank A Discharge Isolation Limit Switch Solenoid Valve	PXS-PL-V015A-L PXS-PL-V015A-S1
Core Makeup Tank B Discharge Isolation Limit Switch Solenoid Valve	PXS-PL-V015B-L PXS-PL-V015B-S1
Nitrogen Supply Outside Containment Isolation Limit Switch Solenoid Valve	PXS-PL-V042-L PXS-PL-V042-S
PRHR HX Discharge Isolation Limit Switch Solenoid Valve	PXS-PL-V108A-L PXS-PL-V108A-S1
PRHR HX Discharge Isolation Limit Switch Solenoid Valve	PXS-PL-V108B-L PXS-PL-V108B-S1
Recirc Sump A Isolation Limit Switch Squib Operator	PXS-PL-V118A-L PXS-PL-V118A-T
Recirc Sump B Isolation Limit Switch Squib Operator	PXS-PL-V118B-L PXS-PL-V118B-T

**Table 3I.6-2 (Sheet 16 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Recirc Sump A Limit Switch Squib Operator	PXS-PL-V120A-L PXS-PL-V120A-T
Recirc Sump B Limit Switch Squib Operator	PXS-PL-V120B-L PXS-PL-V120B-T
IRWST Injection A Limit Switch Squib Operator	PXS-PL-V123A-L PXS-PL-V123A-T
IRWST Injection B Limit Switch Squib Operator	PXS-PL-V123B-L PXS-PL-V123B-T
IRWST Injection A Limit Switch Squib Operator	PXS-PL-V125A-L PXS-PL-V125A-T
IRWST Injection B Limit Switch Squib Operator	PXS-PL-V125B-L PXS-PL-V125B-T
IRWST Gutter Drain Isolation A Limit Switch Solenoid Valve	PXS-PL-V130A-L PXS-PL-V130A-S1
IRWST Gutter Drain Isolation B Limit Switch Solenoid Valve	PXS-PL-V130B-L PXS-PL-V130B-S1

**Table 3I.6-2 (Sheet 17 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
First Stage ADS Limit Switch Motor Operator	RCS-PL-V001A-L RCS-PL-V001A-M
First Stage ADS Limit Switch Motor Operator	RCS-PL-V001B-L RCS-PL-V001B-M
Second Stage ADS Limit Switch Motor Operator	RCS-PL-V002A-L RCS-PL-V002A-M
Second Stage ADS Limit Switch Motor Operator	RCS-PL-V002B-L RCS-PL-V002B-M
Third Stage ADS Limit Switch Motor Operator	RCS-PL-V003A-L RCS-PL-V003A-M
Third Stage ADS Limit Switch Motor Operator	RCS-PL-V003B-L RCS-PL-V003B-M
Fourth Stage ADS Limit Switch Squib Operator	RCS-PL-V004A-L RCS-PL-V004A-T
Fourth Stage ADS Limit Switch Squib Operator	RCS-PL-V004B-L RCS-PL-V004B-T

**Table 3I.6-2 (Sheet 18 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Fourth Stage ADS Limit Switch Squib Operator	RCS-PL-V004C-L RCS-PL-V004C-T
Fourth Stage ADS Limit Switch Squib Operator	RCS-PL-V004D-L RCS-PL-V004D-T
First Stage ADS Isolation Limit Switch Motor Operator	RCS-PL-V011A-L RCS-PL-V011A-M
First Stage ADS Isolation Limit Switch Motor Operator	RCS-PL-V011B-L RCS-PL-V011B-M
Second Stage ADS Isolation Limit Switch Motor Operator	RCS-PL-V012A-L RCS-PL-V012A-M
Second Stage ADS Isolation Limit Switch Motor Operator	RCS-PL-V012B-L RCS-PL-V012B-M
Third Stage ADS Isolation Limit Switch Motor Operator	RCS-PL-V013A-L RCS-PL-V013A-M
Third Stage ADS Isolation Limit Switch Motor Operator	RCS-PL-V013B-L RCS-PL-V013B-M

**Table 3I.6-2 (Sheet 19 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Reactor Vessel Head Vent Limit Switch Solenoid Operator	RCS-PL-V150A-L RCS-PV-V150A-S
Reactor Vessel Head Vent Limit Switch Solenoid Operator	RCS-PL-V150B-L RCS-PL-V150B-S
Reactor Vessel Head Vent Limit Switch Solenoid Operator	RCS-PL-V150C-L RCS-PL-V150C-S
Reactor Vessel Head Vent Limit Switch Solenoid Operator	RCS-PL-V150D-L RCS-PL-V150D-S
RCS Inner Suction Isolation Limit Switch Motor Operator	RNS-PL-V001A-L RNS-PL-V001A-M
RCS Inner Suction Isolation Limit Switch Motor Operator	RNS-PL-V001B-L RNS-PL-V001B-M
RCS Outer Suction Isolation Limit Switch Motor Operator	RNS-PL-V002A-L RNS-PL-V002A-M
RCS Outer Suction Isolation Limit Switch Motor Operator	RNS-PL-V002B-L RNS-PL-V002B-M

Table 3I.6-2 (Sheet 20 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment

Description	AP1000 Tag Number
RHR Control/Isolation Valve Limit Switch Motor Operator	RNS-PL-V011-L RNS-PL-V011-M
RHR Pump Suction Header Isolation Limit Switch Motor Operator	RNS-PL-V022-L RNS-PL-V022-M
IRWST Suction Line Isolation Limit Switch Motor Operator	RNS-PL-V023-L RNS-PL-V023-M
RNS – CVS Containment Isolation Limit Switch Air Operator	RNS-PL-V061-L RNS-PL-V061-S
SDS – MCR Isolation Limit Switch Motor Operator	SDS-PL-V001-L SDS-PL-V001-M
SDS – MCR Isolation Limit Switch Motor Operator	SDS-PL-V002-L SDS-PL-V002-M
Containment Isolation Limit Switch Motor Operator	SFS-PL-V034-L SFS-PL-V034-M
Containment Isolation Limit Switch Motor Operator	SFS-PL-V035-L SFS- PL-V035-M
Containment Isolation Limit Switch Motor Operator	SFS-PL-V038-L SFS-PL-V038-M

**Table 3I.6-2 (Sheet 21 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
PORV Block Valve Limit Switch Motor Operator	SGS-PL-V027A-L SGS-PL-V027A-M
PORV Block Valve Limit Switch Motor Operator	SGS-PL-V027B-L SGS-PL-V027B-M
Steam Line Condensate Drain Isolation Limit Switch Solenoid Valve	SGS-PL-V036A-L SGS-PL-V036A-S
Steam Line Condensate Isolation Limit Switch Solenoid Valve	SGS-PL-V036B-L SGS-PL-V036B-S
Main Steam Line Isolation Limit Switch Solenoid Valve Solenoid Valve Solenoid Valve Solenoid Valve	SGS-PL-V040A-L SGS-PL-V040A-S1 SGS-PL-V040A-S2 SGS-PL-V040A-S3 SGS-PL-V040A-S4
Main Steam Line Isolation Limit Switch Solenoid Valve Solenoid Valve Solenoid Valve Solenoid Valve	SGS-PL-V040B-L SGS-PL-V040B-S1 SGS-PL-V040B-S2 SGS-PL-V040B-S3 SGS-PL-V040B-S4

**Table 3I.6-2 (Sheet 22 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Main Feedwater Isolation Limit Switch Solenoid Valve Solenoid Valve Solenoid Valve Solenoid Valve	SGS-PL-V057A-L SGS-PL-V057A-S1 SGS-PL-V057A-S2 SGS-PL-V057A-S3 SGS-PL-V057A-S4
Main Feedwater Isolation Limit Switch Solenoid Valve Solenoid Valve Solenoid Valve Solenoid Valve	SGS-PL-V057B-L SGS-PL-V057B-S1 SGS-PL-V057B-S2 SGS-PL-V057B-S3 SGS-PL-V057B-S4
Startup Feedwater Isolation Limit Switch Motor Operator	SGS-PL-V067A-L SGS-PL-V067A-M
Startup Feedwater Isolation Limit Switch Motor Operator	SGS-PL-V067B-L SGS-PL-V067B-M
SG Blowdown Isolation Limit Switch Solenoid Valve	SGS-PL-V074A-L SGS-PL-V074A-S
SG Blowdown Isolation Limit Switch Solenoid Valve	SGS-PL-V074B-L SGS-PL-V074B-S

**Table 3I.6-2 (Sheet 23 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
SG Series Blowdown Isolation Limit Switch Solenoid Valve	SGS-PL-V075A-L SGS-PL-V075A-S
SG Series Blowdown Isolation Limit Switch Solenoid Valve	SGS-PL-V075B-L SGS-PL-V075B-S
Steam Line Condensate Drain Isolation Solenoid Valve	SGS-PL-V086A-S
Steam Line Condensate Drain Isolation Solenoid Valve	SGS-PL-V086B-S
Power Operated Relief Valve Limit Switch Solenoid Valve	SGS-PL-V233A-L SGS-PL-V233A-S
Power Operated Relief Valve Limit Switch Solenoid Valve	SGS-PL-V233B-L SGS-PL-V233B-S
MSIV Bypass Isolation Valve Limit Switch Solenoid Valve Solenoid Valve	SGS- PL-V240A-L SGS-PL-V240A-S1 SGS-PL-V240A-S2
MSIV Bypass Isolation Valve Limit Switch Solenoid Valve Solenoid Valve	SGS-PL-V240B-L SGS-PL-V240B-S1 SGS-PL-V240B-S2

**Table 3I.6-2 (Sheet 24 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Main Feedwater Control Valve Limit Switch Solenoid Valve	SGS-PL-V250A-L SGS-PL-V250A-S
Main Feedwater Control Valve Limit Switch Solenoid Valve	SGS-PL-V250B-L SGS-PL-V250B-S
Startup Feedwater Control Valve Limit Switch Solenoid Valve	SGS-PL-V255A-L SGS-PL-V255A-S
Startup Feedwater Control Valve Limit Switch Solenoid Valve	SGS-PL-V255B-L SGS-PL-V255B-S
MCR Isolation Valve Limit Switch Motor Operator	VBS-PL-V186-L VBS-PL-V186-M
MCR Isolation Valve Limit Switch Motor Operator	VBS-PL-V187-L VBS-PL-V187-M
MCR Isolation Valve Limit Switch Motor Operator	VBS-PL-V188-L VBS-PL-V188-M
MCR Isolation Valve Limit Switch Motor Operator	VBS-PL-V189-L VBS-PL-V189-M

**Table 3I.6-2 (Sheet 25 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
MCR Isolation Valve Limit Switch Motor Operator	VBS-PL-V190-L VBS-PL-V190-M
MCR Isolation Valve Limit Switch Motor Operator	VBS-PL-V191-L VBS-PL-V191-M
Actuation Valve A Limit Switch Solenoid Operator	VES-PL-V005A-L VES-PL-V005A-S
Actuation Valve B Limit Switch Solenoid Operator	VES-PL-V005B-L VES-PL-V005B-S
Relief Isolation Valve A Limit Switch Solenoid Valve	VES-PL-V022A-L VES-PL-V022A-S
Relief Isolation Valve B Limit Switch Solenoid Valve	VES-PL-V022B-L VES-PL-V022B-S
Containment Purge Inlet Isolation Limit Switch Solenoid Valve	VFS-PL-V003-L VFS-PL-V003-S1
Containment Purge Inlet Isolation Limit Switch Solenoid Valve	VFS-PL-V004-L VFS-PL-V004-S1

**Table 3I.6-2 (Sheet 26 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Containment Purge Discharge Isolation Limit Switch Solenoid Valve	VFS-PL-V009-L VFS-PL-V009-S1
Containment Purge Discharge Isolation Limit Switch Solenoid Valve	VFS-PL-V010-L VFS-PL-V010-S1
Vacuum Relief Containment Isolation Valve A - ORC Limit Switch Motor Operator	VFS-PL-V800A-L VFS-PL-V800A-M
Vacuum Relief Containment Isolation Valve B - ORC Limit Switch Motor Operator	VFS-PL-V800B-L VFS-PL-V800B-M
Fan Cooler Supply Isolation Limit Switch Solenoid Valve	VWS-PL-V058-L VWS-PL-V058-S
Fan Cooler Return Isolation Limit Switch Solenoid Valve	VWS-PL-V082-L VWS-PL-V082-S
Fan Cooler Return Isolation Limit Switch Solenoid Valve	VWS-PL-V086-L VWS-PL-V086-S
Sump Containment Isolation IRC Limit Switch Solenoid Valve	WLS-PL-V055-L WLS-PL-V055-S1

Table 3I.6-2 (Sheet 27 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment

Description	AP1000 Tag Number
Sump Containment Isolation ORC Limit Switch Solenoid Valve	WLS-PL-V057-L WLS-PL-V057-S1
RCDT Gas Containment Isolation Limit Switch Solenoid Valve	WLS-PL-V067-L WLS-PL-V067-S
RCDT Gas Containment Isolation Limit Switch Solenoid Valve	WLS-PL-V068-L WLS-PL-V068-S
Hot Leg 1 Sample Isolation Limit Switch Solenoid Valve	PSS-PL-V001A-L PSS-PL-V001A-S
Hot Leg 2 Sample Isolation Limit Switch Solenoid Valve	PSS-PL-V001B-L PSS-PL-V001B-S
Core Makeup Tank A CL Inlet Isolation Limit Switch Motor Operator	PXS-PL-V002A-L PXS-PL-V002A-M
Core Makeup Tank B CL Inlet Isolation Limit Switch Motor Operator	PXS-PL-V002B-L PXS-PL-V002B-M
PRHR HX Inlet Isolation Limit Switch Motor Operator	PXS-PL-V101-L PXS-PL-V101-M
Recirc Sump A Isolation Limit Switch Motor Operator	PXS-PL-V117A-L PXS-PL-V117A-M

**Table 3I.6-2 (Sheet 28 of 28)
List of Potential High Frequency Sensitive
AP1000 Safety-Related electrical and
Electro-mechanical Equipment**

Description	AP1000 Tag Number
Recirc Sump B Isolation Limit Switch Motor Operator	PXS-PL-V117B-L PXS-PL-V117B-M
Fourth Stage ADS Isolation Limit Switch Motor Operator	RCS-PL-V014A-L RCS-PL-V014A-M
Fourth Stage ADS Isolation Limit Switch Motor Operator	RCS-PL-V014B-L RCS-PL-V014B-M
Fourth Stage ADS Isolation Limit Switch Motor Operator	RCS-PL-V014C-L RCS-PL-V014C-M
Fourth Stage ADS Isolation Limit Switch Motor Operator	RCS-PL-V014D-L RCS-PL-V014D-M

**Table 3I.6-3 (Sheet 1 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
Resistance Temperature Detectors		
PRHR HX Outlet Temperature	RCS-JE-TE161	1
RCS Cold Leg 1A Narrow Range Temperature	RCS-JE-TE121A	1
RCS Cold Leg 1A Narrow Range Temperature	RCS-JE-TE121D	1
RCS Cold Leg 1B Narrow Range Temperature	RCS-JE-TE121B	1
RCS Cold Leg 1B Narrow Range Temperature	RCS-JE-TE121C	1
RCS Cold Leg 2A Narrow Range Temperature	RCS-JE-TE122B	1
RCS Cold Leg 2A Narrow Range Temperature	RCS-JE-TE122C	1
RCS Cold Leg 2B Narrow Range Temperature	RCS-JE-TE122A	1
RCS Cold Leg 2B Narrow Range Temperature	RCS-JE-TE122D	1
RCS Hot Leg 1 Narrow Range Temperature	RCS-JE-TE131A	1
RCS Hot Leg 1 Narrow Range Temperature	RCS-JE-TE131C	1
RCS Hot Leg 1 Narrow Range Temperature	RCS-JE-TE132A	1
RCS Hot Leg 1 Narrow Range Temperature	RCS-JE-TE132C	1
RCS Hot Leg 1 Narrow Range Temperature	RCS-JE-TE133C	1
RCS Hot Leg 1 Narrow Range Temperature	RCS-JE-TE133A	1
RCS Hot Leg 2 Narrow Range Temperature	RCS-JE-TE131B	1
RCS Hot Leg 2 Narrow Range Temperature	RCS-JE-TE131D	1
RCS Hot Leg 2 Narrow Range Temperature	RCS-JE-TE132B	1
RCS Hot Leg 2 Narrow Range Temperature	RCS-JE-TE132D	1
RCS Hot Leg 2 Narrow Range Temperature	RCS-JE-TE133B	1
RCS Hot Leg 2 Narrow Range Temperature	RCS-JE-TE133D	1
RCS Cold Leg 1A Dual Range Temperature	RCS-JE-TE125A	1
RCS Cold Leg 1B Dual Range Temperature	RCS-JE-TE125C	1
RCS Cold Leg 2A Dual Range Temperature	RCS-JE-TE125B	1

**Table 3I.6-3 (Sheet 2 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
RCS Cold Leg 2B Dual Range Temperature	RCS-JE-TE125D	1
RCS Hot Leg 1 Wide Range Temperature	RCS-JE-TE135A	1
RCS Hot Leg 2 Wide Range Temperature	RCS-JE-TE135B	1
PZR Reference Leg Level Temperature	RCS-JE-TE193A	1
PZR Reference Leg Level Temperature	RCS-JE-TE193B	1
PZR Reference Leg Level Temperature	RCS-JE-TE193C	1
PZR Reference Leg Level Temperature	RCS-JE-TE193D	1
Thermocouples		1
Incore Thermocouples	IIS-JE-TE001-TE042	1
RCP 1A Bearing Water Temperature	RCS-JE-TE211A	1
RCP 1A Bearing Water Temperature	RCS-JE-TE211B	1
RCP 1A Bearing Water Temperature	RCS-JE-TE211C	1
RCP 1A Bearing Water Temperature	RCS-JE-TE211D	1
RCP 1B Bearing Water Temperature	RCS-JE-TE212A	1
RCP 1B Bearing Water Temperature	RCS-JE-TE212B	1
RCP 1B Bearing Water Temperature	RCS-JE-TE212C	1
RCP 1B Bearing Water Temperature	RCS-JE-TE212D	1
RCP 2A Bearing Water Temperature	RCS-JE-TE213A	1
RCP 2A Bearing Water Temperature	RCS-JE-TE213B	1
RCP 2A Bearing Water Temperature	RCS-JE-TE213C	1
RCP 2A Bearing Water Temperature	RCS-JE-TE213D	1
RCP 2B Bearing Water Temperature	RCS-JE-TE214A	1
RCP 2B Bearing Water Temperature	RCS-JE-TE214B	1
RCP 2B Bearing Water Temperature	RCS-JE-TE214C	1
RCP 2B Bearing Water Temperature	RCS-JE-TE214D	1

**Table 3I.6-3 (Sheet 3 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
Penetrations		
Penetrations (Mechanical)		1
Penetrations (Electrical)		1
Active Valves		
Containment Isolation – Air Out	CAS-PL-V014	2
Containment Isolation – Air In	CAS-PL-V015	2
Containment Isolation – Inlet	CCS-PL-V200	2
Service Air Supply Inside Containment Isolation	CAS-PL-V205	2
Containment Isolation – Inlet	CCS-PL-V201	2
Containment Isolation – Outlet	CCS-PL-V207	2
Containment Isolation – Outlet	CCS-PL-V208	2
CCS Containment Isolation Relief	CCS-PL-V220	2
CCS IRC Relief Valve	CCS-PL-V270	2
CCS IRC Relief Valve	CCS-PL-V271	2
RCS Purification Stop Valve	CVS-PL-V001	2
RCS Purification Stop Valve	CVS-PL-V002	2
RCS Letdown Stop Valve	CVS-PL-V003	2
Demineralizer Flush Line Relief Valve	CVS-PL-V042	2
WLS Letdown IRC Isolation	CVS-PL-V045	2
Letdown Flow ORC Isolation	CVS-PL-V047	2
CVS Makeup Line Bypass Check Valve	CVS-PL-V067	2
RCS Purification Check Valve	CVS-PL-V080	2
RCS Purification Stop Valve	CVS-PL-V081	2
RCS Purification Check Valve	CVS-PL-V082	2
Auxiliary PZR Spray Isolation	CVS-PL-V084	2
Auxiliary PZR Spray Isolation	CVS-PL-V085	2
Makeup Line Containment Isolation	CVS-PL-V090	2
Makeup Line Containment Isolation	CVS-PL-V091	2

**Table 3I.6-3 (Sheet 4 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
Zinc Addition Containment Isolation	CVS-PL-V092	2
Zinc Addition Containment Isolation	CVS-PL-V094	2
Zinc Injection Containment Isolation Thermal Overpressurization Relief Valve	CVS-PL-V098	2
Makeup Containment Isolation	CVS-PL-V100	2
Demineralizer Water System Isolation	CVS-PL-V136A	2
Demineralized Water System Isolation	CVS-PL-V136B	2
Hydrogen Injection Containment Isolation Check Valve	CVS-PL-V217	2
Hydrogen Injection Containment Isolation	CVS-PL-V219	2
DWS Containment Penetration Thermal Relief Valve	DWS-PL-V241	2
Demin Water Supply Containment Isolation – Inside	DWS-PL-V245	2
Fuel Transfer Tube Gate Valve	FHS-PL-V001	2
Fire Water Containment Supply Isolation – Inside	FPS-PL-V052	2
FPS Containment Penetration Thermal Relief Valve	FPS-PL-V702	2
PCCWST Isolation Valve	PCS-PL-V001A	2
PCCWST Isolation Valve	PCS-PL-V001B	2
PCCWST Isolation Valve	PCS-PL-V001C	2
PCCWST Isolation Valve	PCS-PL-V002A	2
PCCWST Isolation Valve	PCS-PL-V002B	2
PCCWST Isolation Valve	PCS-PL-V002C	2
PCCWST Fire Protection Isolation	PCS-PL-V005	2
PCCWST Emergency Spent Fuel Pool Makeup Isolation	PCS-PL-V009	2
Water Bucket Makeup Line Drain Valve	PCS-PL-V015	2
Water Bucket Makeup Line Isolation Valve	PCS-PL-V020	2
PCS Recirculation Isolation	PCS-PL-V023	2
PCCWST Long-Term Makeup Check Valve	PCS-PL-V039	2
PCCWST Long Term Makeup Isolation Drain Valve	PCS-PL-V042	2
PCCWST Long Term Makeup Isolation Valve	PCS-PL-V044	2
Emergency Makeup to the Spent Fuel Pool Isolation Valve	PCS-PL-V045	2

Table 3I.6-3 (Sheet 5 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
PCCWST Recirculation Return Isolation Valve	PCS-PL-V046	2
Emergency Makeup to the Spent Fuel Pool Drain Isolation Valve	PCS-PL-V049	2
Spent Fuel Pool Long Term Makeup Isolation Valve	PCS-PL-V050	2
Spent Fuel Pool Emergency Makeup Lower Isolation Valve	PCS-PL-V051	2
Shutoff Valve for Leakage Sensor	PCS-PL-V060A	2
Shutoff Valve for Leakage Sensor	PCS-PL-V060B	2
Containment Isolation – Air Sample Line	PSS-PL-V008	2
Containment Isolation – Liquid Sample Line	PSS-PL-V010A	2
Containment Isolation – Liquid Sample Line	PSS-PL-V010B	2
Containment Isolation – Liquid Sample Line	PSS-PL-V011A	2
Containment Isolation – Liquid Sample Line	PSS-PL-V011B	2
Containment Isolation – Sample Return Line	PSS-PL-V023	2
Containment Isolation Sample Return	PSS-PL-V024	2
Containment Isolation – Air Sample Line	PSS-PL-V046	2
PWS MCR Isolation	PWS-PL-V418	2
PWS MCR Isolation	PWS-PL-V420	2
PWS MCR Vacuum Relief	PWS-PL-V498	2
Core Makeup Tank A Discharge Isolation	PXS-PL-V014A	2
Core Makeup Tank B Discharge Isolation	PXS-PL-V014B	2
Core Makeup Tank A Discharge Isolation	PXS-PL-V015A	2
Core Makeup Tank B Discharge Isolation	PXS-PL-V015B	2
Core Makeup Tank A Discharge	PXS-PL-V016A	2
Core Makeup Tank B Discharge	PXS-PL-V016B	2
Core Makeup Tank A Discharge	PXS-PL-V017A	2
Core Makeup Tank B Discharge	PXS-PL-V017B	2
Accumulator A Pressure Relief	PXS-PL-V022A	2
Accumulator B Pressure Relief	PXS-PL-V022B	2
Accumulator A Discharge	PXS-PL-V028A	2

**Table 3I.6-3 (Sheet 6 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
Accumulator B Discharge	PXS-PL-V028B	2
Accumulator A Discharge	PXS-PL-V029A	2
Accumulator B Discharge	PXS-PL-V029B	2
Nitrogen Supply Outside Containment Isolation	PXS-PL-V042	2
IRC Nitrogen Supply Inside Containment Isolation	PXS-PL-V043	2
PRHR HX Discharge Isolation	PXS-PL-V108A	2
PRHR HX Discharge Isolation	PXS-PL-V108B	2
Recirc Sump A Isolation	PXS-PL-V118A	2
Recirc Sump B Isolation	PXS-PL-V118B	2
Recirc Sump A Isolation	PXS-PL-V119A	2
Recirc Sump B Isolation	PXS-PL-V119B	2
Recirc Sump A Isolation	PXS-PL-V120A	2
Recirc Sump B Isolation	PXS- PL-V120B	2
IRWST Injection A	PXS-PL-V122A	2
IRWST Injection B	PXS-PL-V122B	2
IRWST Injection A	PXS-PL-V123A	2
IRWST Injection B	PXS-PL-V123B	2
IRWST Injection A	PXS-PL-V124A	2
IRWST Injection B	PXS-PL-V124B	2
IRWST Injection A	PXS-PL-V125A	2
IRWST Injection B	PXS-PL-V125B	2
IRWST Gutter Drain Isolation A	PXS-PL-V130A	2
IRWST Gutter Drain Isolation B	PXS-PL-V130B	2
First Stage ADS	RCS-PL-V001A	2
First Stage ADS	RCS-PL-V001B	2

Table 3I.6-3 (Sheet 7 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
Second Stage ADS	RCS-PL-V002A	2
Second Stage ADS	RCS-PL-V002B	2
Third Stage ADS	RCS-PL-V003A	2
Third Stage ADS	RCS-PL-V003B	2
Fourth Stage ADS	RCS-PL-V004A	2
Fourth Stage ADS	RCS-PL-V004B	2
Fourth Stage ADS	RCS-PL-V004C	2
Fourth Stage ADS	RCS-PL-V004D	2
PZR Safety Valve	RCS-PL-V005A	2
PZR Safety Valve	RCS-PL-V005B	2
ADS Discharge Header A Relief	RCS-PL-V010A	2
ADS Discharge Header B Relief	RCS-PL-V010B	2
First Stage ADS Isolation	RCS-PL-V011A	2
First Stage ADS Isolation	RCS-PL-V011B	2
Second Stage ADS Isolation	RCS-PL-V012A	2
Second Stage ADS Isolation	RCS-PL-V012B	2
Third Stage ADS Isolation	RCS-PL-V013A	2
Third Stage ADS Isolation	RCS-PL-V013B	2
Reactor Vessel Head Vent	RCS-PL-V150A	2
Reactor Vessel Head Vent	RCS-PL-V150B	2
Reactor Vessel Head Vent	RCS-PL-V150C	2
Reactor Vessel Head Vent	RCS-PL-V150D	2
RCS Inner Suction Isolation	RNS-PL-V001A	2
RCS Inner Suction Isolation	RNS-PL-V001B	2
RCS Outer Suction Isolation	RNS-PL-V002A	2

Table 3I.6-3 (Sheet 8 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
RCS Outer Suction Isolation	RNS-PL-V002B	2
RCS Thermal Relief	RNS-PL-V003A	2
RCS Thermal Relief	RNS-PL-V003B	2
RHR Control/Isolation Valve	RNS-PL-V011	2
RNS Discharge Containment Isolation Valve Test Connection	RNS-PL-V012	2
RNS Discharge Containment Isolation	RNS-PL-V013	2
RNS Discharge RCP B Isolation	RNS-PL-V015A	2
RNS Discharge RCP B Isolation	RNS-PL-V015B	2
RNS Discharge RCP B Isolation	RNS-PL-V017A	2
RNS Discharge RCP B Isolation	RNS-PL-V017B	2
RNS Hot Leg Suction Relief	RNS-PL-V021	2
RHR Pump Suction Header Isolation	RNS-PL-V022	2
IRWST Suction Line Isolation	RNS-PL-V023	2
RNS Pump Discharge Relief	RNS-PL-V045	2
RNS – CVS Containment Isolation	RNS-PL-V061	2
Containment Isolation	SFS-PL-V034	2
Containment Isolation	SFS-PL-V035	2
SFS Discharge Containment Isolation	SFS-PL-V037	2
Containment Isolation	SFS-PL-V038	2
SFS Cask Loading Pit to SFS Pump	SFS-PL-V042	2
SFS Pump to Cask Loading Pit	SFS-PL-V045	2
Cask Loading Pit to WLS	SFS-PL-V049	2
Spent Fuel Pool to Cask Washdown Pit Isolation	SFS-PL-V066	2
SFS Containment Isolation Relief	SFS-PL-V067	2
Cask Washdown Pit Drain Isolation	SFS-PL-V068	2

Table 3I.6-3 (Sheet 9 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
Refueling Cavity to SG Compartment	SFS-PL-V071	2
Refueling Cavity to SG Compartment	SFS-PL-V072	2
PORV Block Valve	SGS-PL-V027A	2
PORV Block Valve	SGS-PL-V027B	2
Steam Safety Valve SG01	SGS-PL-V030A	2
Steam Safety Valve SG02	SGS-PL-V030B	2
Steam Safety Valve SG01	SGS-PL-V031A	2
Steam Safety Valve SG02	SGS-PL-V031B	2
Steam Safety Valve SG01	SGS-PL-V032A	2
Steam Safety Valve SG02	SGS-PL-V032B	2
Steam Safety Valve SG01	SGS-PL-V033A	2
Steam Safety Valve SG02	SGS-PL-V033B	2
Steam Safety Valve SG01	SGS-PL-V034A	2
Steam Safety Valve SG02	SGS-PL-V034B	2
Steam Safety Valve SG01	SGS-PL-V035A	2
Steam Safety Valve SG02 Steam Line Condensate	SGS-PL-V035B	2
Drain Isolation	SGS-PL-V036A	2
Steam Line Condensate Isolation	SGS-PL-V036B	2
Main Steam Line Isolation	SGS-PL-V040A	2
Main Steam Line Isolation	SGS-PL-V040B	2
Main Feedwater Isolation	SGS-PL-V057A	2
Main Feedwater Isolation	SGS-PL-V057B	2
Startup Feedwater Isolation	SGS-PL-V067A	2
Startup Feedwater Isolation	SGS-PL-V067B	2
SG Blowdown Isolation	SGS-PL-V074A	2

**Table 3I.6-3 (Sheet 10 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
SG Blowdown Isolation	SGS-PL-V074B	2
SG Series Blowdown Isolation	SGS-PL-V075A	2
SG Series Blowdown Isolation	SGS-PL-V075B	2
Steam Line Condensate Drain Isolation	SGS-PL-V086A	2
Steam Line Condensate Drain Isolation	SGS-PL-V086B	2
Power-Operated Relief Valve	SGS-PL-V233A	2
Power-Operated Relief Valve	SGS-PL-V233B	2
MSIV Bypass Isolation Valve	SGS-PL-V240A	2
MSIV Bypass Isolation Valve	SGSPL-V240B	2
Main Feedwater Control Valve	SGS-PL-V250A	2
Main Feedwater Control Valve	SGS-PL-V250B	2
Startup Feedwater Control Valve	SGS-PL-V255A	2
Startup Feedwater Control Valve	SGS-PL-V255B	2
MCR Isolation Valve	VBS-PL-V186	2
MCR Isolation Valve	VBS-PL-V187	2
MCR Isolation Valve	VBS-PL-V188	2
MCR Isolation Valve	VBS-PL-V189	2
MCR Isolation Valve	VBS-PL-V190	2
MCR Isolation Valve	VBS-PL-V191	2
Air Delivery Isolation Valve	VES-PL-V001	2
Pressure Regulator Valve A	VES-PL-V002A	2
Pressure Regulator Valve B	VES-PL-V002B	2
Actuation Valve A	VES-PL-V005A	2
Actuation Valve B	VES-PL-V005B	2
Relief Isolation Valve A	VES-PL-V022A	2
Relief Isolation Valve B	VES-PL-V022B	2

**Table 3I.6-3 (Sheet 11 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
Air Tank Safety Relief Valve A	VES-PL-V040A	2
Air Tank Safety Relief Valve B	VES-PL-V040B	2
Air Tank Safety Relief Valve C	VES-PL-V040C	2
Air Tank Safety Relief Valve D	VES-PL-V040D	2
Main Air Flow Path Isolation Valve	VES-PL-V044	2
Containment Purge Inlet Isolation	VFS-PL-V003	2
Containment Purge Inlet Isolation	VFS-PL-V004	2
Containment Purge Discharge Isolation	VFS-PL-V009	2
Containment Purge Discharge Isolation	VFS-PL-V010	2
Vacuum Relief Containment Isolation Valve A - ORC	VFS-PL-V800A	2
Vacuum Relief Containment Isolation Valve B - ORC	VFS-PL-V800B	2
Vacuum Relief Containment Isolation Check Valve A - IRC	VFS-PL-V803A	2
Vacuum Relief Containment Isolation Check Valve B - IRC	VFS-PL-V803B	2
VWS Containment Penetration Thermal Relief Valve	VWS-PL-V053	2
VWS Containment Penetration Thermal Relief Valve	VWS-PL-V057	2
Fan Cooler Supply Isolation	VWS-PL-V058	2
Fan Cooler Supply Isolation	VWS-PL-V062	2
VWS Containment Isolation Relief	VWS-PL-V080	2
Fan Cooler Return Isolation	VWS-PL-V082	2
Fan Cooler Return Isolation	VWS-PL-V086	2
Sump Containment Isolation IRC	WLS-PL-V055	2
Sump Containment Isolation ORC	WLS-PL-V057	2
WLS Containment Isolation Relief	WLS-PL-V058	2
RCDT Gas Containment Isolation	WLS-PL-V067	2
RCDT Gas Containment Isolation	WLS-PL-V068	2
CVS To Sump	WLS-PL-V071 A	2
PXS A To Sump	WLS-PL-V071 B	2

Table 3I.6-3 (Sheet 12 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
PXS B To Sump	WLS-PL-V071 C	2
CVS To Sump	WLS-PL-V072 A	2
PXS A To Sump	WLS-PL-V072 B	2
PXS B To Sump	WLS-PL-V072 C	2
Miscellaneous		
Nonactive Valves		
Containment Penetration Test Connection Isolation	CAS-PL-V027	2
Service Air Supply Outside Containment Isolation	CAS-PL-V204	2
Containment Penetration Test Connection Isolation	CAS-PL-V219	2
Containment Isolation Valve Test Connection – Outlet Line	CCS-PL-V209	2
CCS Supply Containment Isolation – IRC	CCS-PL-V214	2
CCS Supply Containment Isolation Valve Test Connection – IRC	CCS-PL-V215	2
Containment Leak Test Outlet Line – IRC	CCS-PL-V216	2
Containment Isolation Valve V207 Body Test Connection Valve	CCS-PL-V217	2
Containment Isolation Valve Test Connection – Inlet Line	CCS-PL-V257	2
Resin Flush IRC Isolation	CVS-PL-V040	2
Resin Flush ORC Isolation	CVS-PL-V041	2
Letdown PZR Instrument Root	CVS-PL-V046	2
Zinc Addition – IRC Shutoff	CVS-PL-V065	2
Zinc Add Cont Isolation Test Connection	CVS-PL-V095	2
Zinc Addition Containment Isolation Test Connection	CVS-PL-V096	2
Hydrogen Injection Containment Isolation Test Connection Valve	CVS-PL-V218	2
Demin Water Supply Containment Isolation – Outside	DWS-PL-V244	2
Containment Penetration Test Connection Isolation	DWS-PL-V248	2
Fire Water Containment Test Connection Isolation	FPS-PL-V049	2
Fire Water Containment Supply Isolation	FPS-PL-V050	2

Table 3I.6-3 (Sheet 13 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
Fire Water Containment Test Connection Isolation	FPS-PL-V051	2
Flow Transmitter FT001 Root Valve	PCS-PL-V010A	2
Flow Transmitter FT001 Root Valve	PCS-PL-V010B	2
Flow Transmitter FT002 Root Valve	PCS-PL-V011A	2
Flow Transmitter FT001 Root Valve	PCS-PL-V011B	2
Flow Transmitter FT003 Root Valve	PCS-PL-V012A	2
Flow Transmitter FT003 Root Valve	PCS-PL-V012B	2
Flow Transmitter FT004 Root Valve	PCS-PL-V013A	2
Flow Transmitter FT004 Root Valve	PCS-PL-V013B	2
PCCWST Drain Isolation Valve	PCS-PL-V016	2
PCCWST Isolation Valve Leakage Detection Drain	PCS-PL-V029	2
PCCWST Isolation Valve Leakage Detection Crossconn	PCS-PL-V030	2
PCCWST Level Instrument Root Valve	PCS-PL-V031A	2
PCCWST Level Instrument Root Valve	PCS-PL-V031B	2
Recirculation Pump Suction from Long Term Makeup Isolation Valve	PCS-PL-V033	2
Spent Fuel Pool Emergency Makeup Isolation	PLS-PL-V052	2
Recirculation Header Discharge to SFS Pool Vent Isolation Valve	PCS-PL-V303	2
Recirculation Header Discharge to SFS Pool Drain Isolation Valve	PCS-PL-V304	2
PCCWST Recirculation Return Drain Isolation Valve	PCS-PL-V305	2
Hot Leg 1 Sample Isolation	PSS-PL-V001A	2
Hot Leg 2 Sample Isolation	PSS-PL-V001B	2
Pressurizer Sample Isolation	PSS-PL-V003	2
PXS Accumulator Sample Isolation	PSS-PL-V004A	2
PXS Accumulator Sample Isolation	PSS-PL-V004B	2
PXS CMT A Sample Isolation	PSS-PL-V005A	2
PXS CMT B Sample Isolation	PSS-PL-V005B	2
PXS CMT A Sample Isolation	PSS-PL-V005C	2

Table 3I.6-3 (Sheet 14 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
PXS CMT B Sample Isolation	PSS-PL-V005D	2
Liquid Sample Isolation Valve	PSS-PL-V012A	2
Liquid Sample Check Valve	PSS-PL-V012B	2
RCS Pressurizer Sample Isolation Valve	PSS-PL-V013	2
RCS Hot Leg 1 Sample Isolation Valve	PSS-PL-V014A	2
RCS Hot Leg 2 Sample Isolation Valve	PSS-PL-V014B	2
PXS Accumulator Sample Isolation Valve	PSS-PL-V015A	2
PXS Accumulator Sample Isolation Valve	PSS-PL-V015B	2
PXS CMT A Sample Isolation Valve	PSS-PL-V016A	2
PXS CMT B Sample Isolation Valve	PSS-PL-V016B	2
PXS CMT A Sample Isolation Valve	PSS-PL-V016C	2
PXS CMT B Sample Isolation Valve	PSS-PL-V016D	2
Containment Testing Boundary Isolation Valve	PSS-PL-V076A	2
Containment Testing Boundary Isolation Valve	PSS-PL-V076B	2
Containment Isolation Test Connection Isolation Valve	PSS-PL-V082	2
Containment Isolation Test Connection Isolation Valve	PSS-PL-V083	2
Containment Isolation Test Connection Isolation Valve	PSS-PL-V085	2
Containment Isolation Test Connection Isolation Valve	PSS-PL-V086	2
Core Makeup Tank A CL Inlet Isolation	PXS-PL-V002A	2
Core Makeup Tank B CL Inlet Isolation	PXS-PL-V002B	2
Core Makeup Tank A Upper Sample	PXS-PL-V010A	2
Core Makeup Tank B Upper Sample	PXS-PL-V010B	2
Core Makeup Tank A Lower Sample	PXS-PL-V011A	2
Core Makeup Tank B Lower Sample	PXS-PL-V011B	2
Core Makeup Tank A Drain	PXS-PL-V012A	2
Core Makeup Tank B Drain	PXS-PL-V012B	2
Core Makeup Tank Discharge Manual Isolation	PXS-PL-V013A	2
Core Makeup Tank B Discharge Manual Isolation	PXS-PL-V013B	2
RNS to CMT Injection Line A Drain	PXS-PL-V019A	2
RNS to CMT Injection Line B Drain	PXS-PL-V019B	2
IRWST Injection Line A Drain	PXS-PL-V020A	2
IRWST Injection Line B Drain	PXS-PL-V020B	2
Accumulator A N ₂ Vent	PXS-PL-V021A	2
Accumulator B N ₂ Vent	PXS-PL-V021B	2

Table 3I.6-3 (Sheet 15 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
Accumulator A PZR Transmitter Isolation	PXS-PL-V023A	2
Accumulator B PZR Transmitter Isolation	PXS-PL-V023B	2
Accumulator A PZR Transmitter Isolation	PXS-PL-V024A	2
Accumulator B PZR Transmitter Isolation	PXS-PL-V024B	2
Accumulator A Sample	PXS-PL-V025A	2
Accumulator B Sample	PXS-PL-V025B	2
Accumulator A Drain	PXS-PL-V026A	2
Accumulator B Drain	PXS-PL-V026B	2
Accumulator A Discharge Isolation	PXS-PL-V027A	2
Accumulator B Discharge Isolation	PXS-PL-V027B	2
Core Makeup Tank A Highpoint Vent	PXS-PL-V030A	2
Core Makeup Tank B Highpoint Vent	PXS-PL-V030B	2
Core Makeup Tank A Highpoint Vent	PXS-PL-V031A	2
Core Makeup Tank B Highpoint Vent	PXS-PL-V031B	2
Accumulator A Check Valve Drain	PXS-PL-V033A	2
Accumulator B Check Valve Drain	PXS-PL-V033B	2
Accumulator N ₂ Containment Penetration Test Connection	PXS-PL-V052	2
CMT A Wide Level Upper Root	PXS-PL-V080A	2
CMT B Wide Level Upper Root	PXS-PL-V080B	2
CMT A Wide Level Lower Root	PXS-PL-V081A	2
CMT B Wide Level Lower Root	PXS-PL-V081B	2
CMT A Upper Level A Isolation 1	PXS-PL-V082A	2
CMT B Upper Level A Isolation 1	PXS-PL-V082B	2
CMT A Upper Level A Isolation 2	PXS-PL-V083A	2
CMT B Upper Level A Isolation 2	PXS-PL-V083B	2
CMT A Upper Level A Vent	PXS-PL-V084A	2

Table 3I.6-3 (Sheet 16 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
CMT B Upper Level A Vent	PXS-PL-V084B	2
CMT A Upper Level A Drain	PXS-PL-V085A	2
CMT B Upper Level A Drain	PXS-PL-V085B	2
CMT A Upper Level B Isolation 1	PXS-PL-V086A	2
CMT B Upper Level B Isolation 1	PXS-PL-V086B	2
CMT A Upper Level B Isolation 2	PXS-PL-V087A	2
CMT B Upper Level B Isolation 2	PXS-PL-V087B	2
CMT A Upper Level B Vent	PXS-PL-V088A	2
CMT B Upper Level B Vent	PXS-PL-V088B	2
CMT A Upper Level B Drain	PXS-PL-V089A	2
CMT B Upper Level B Drain	PXS-PL-V089B	2
CMT A Lower Level A Isolation 1	PXS-PL-V092A	2
CMT B Lower Level A Isolation 1	PXS-PL-V092B	2
CMT A Lower Level A Isolation 2	PXS-PL-V093A	2
CMT B Lower Level A Isolation 2	PXS-PL-V093B	2
CMT A Lower Level A Vent	PXS-PL-V094A	2
CMT B Lower Level A Vent	PXS-PL-V094B	2
CMT A Lower Level A Drain	PXS-PL-V095A	2
CMT B Lower Level A Drain	PXS-PL-V095B	2
CMT A Lower Level B Isolation 1	PXS-PL-V096A	2
CMT B Lower Level B Isolation 1	PXS-PL-V096B	2
CMT A Lower Level B Isolation 2	PXS-PL-V097A	2
CMT B Lower Level B Isolation 2	PXS-PL-V097B	2
CMT A Lower Level B Vent	PXS-PL-V098A	2
CMT B Lower Level B Vent	PXS-PL-V098B	2

Table 3I.6-3 (Sheet 17 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
CMT A Lower Level B Drain	PXS-PL-V099A	2
CMT B Lower Level B Drain	PXS-PL-V099B	2
PRHR HX Inlet Isolation	PXS-PL-V101	2
PRHR HX Inlet Head Vent	PXS-PL-V102A	2
PRHR HX Inlet Head Drain	PXS-PL-V102B	2
PRHR HX Outlet Head Vent	PXS-PL-V103A	2
PRHR HX Outlet Head Drain	PXS-PL-V103B	2
PRHR HX Flow Transmitter A Isolation	PXS-PL-V104A	2
PRHR HX Flow Transmitter B Isolation	PXS-PL-V104B	2
PRHR HX Flow Transmitter A Isolation	PXS-PL-V105A	2
PRHR HX Flow Transmitter B Isolation	PXS-PL-V105B	2
Containment Recirculation A Highpoint Vent	PXS-PL-V106	2
Containment Recirculation A Highpoint Vent	PXS-PL-V107	2
PRHR HX/RCS Return Isolation	PXS-PL-V109	2
PRHR HX Highpoint Vent	PXS-PL-V111A	2
PRHR HX Highpoint Vent	PXS-PL-V111B	2
PRHR HX PZR Transmitter Isolation	PXS-PL-V113	2
Containment Recirculation A Drain	PXS-PL-V115A	2
Containment Recirculation B Drain	PXS-PL-V115B	2
Containment Recirculation A Drain	PXS-PL-V116A	2
Containment Recirculation B Drain	PXS-PL-V116B	2
Recirc Sump A Isolation	PXS-PL-V117A	2
Recirc Sump B Isolation	PXS-PL-V117B	2
IRWST Line A Isolation	PXS-PL-V121A	2
IRWST Line B Isolation	PXS-PL-V121B	2
IRWST Injection Check Test	PXS-PL-V126A	2

**Table 3I.6-3 (Sheet 18 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
IRWST Injection Check Test	PXS-PL-V126B	2
IRWST Injection Line A Drain	PXS-PL-V127	2
IRWST Injection Check Test	PXS-PL-V128A	2
IRWST Injection Check Test	PXS-PL-V128B	2
IRWST Injection Check Test	PXS-PL-V129A	2
IRWST Injection Check Test	PXS-PL-V129B	2
IRWST Injection Line A Drain	PXS-PL-V131A	2
IRWST Injection Line B Drain	PXS-PL-V131B	2
IRWST Injection Line A Drain	PXS-PL-V132A	2
IRWST Injection Line B Drain	PXS-PL-V132B	2
IRWST Injection Line A Highpoint Vent	PXS-PL-V133A	2
IRWST Injection Line B Highpoint Vent	PXS-PL-V133B	2
IRWST Injection Line A Highpoint Vent	PXS-PL-V134A	2
IRWST Injection Line B Highpoint Vent	PXS-PL-V134B	2
IRWST Injection Line A Highpoint Vent Isolation	PXS-PL-V135A	2
IRWST Injection Line B Highpoint Vent Isolation	PXS-PL-V135B	2
RNS Suction Pump Line Drain	PXS-PL-V149	2
IRWST Level Transmitter A Isolation	PXS-PL-V150A	2
IRWST Level Transmitter B Isolation	PXS-PL-V150B	2
IRWST Level Transmitter C Isolation	PXS-PL-V150C	2
IRWST Level Transmitter D Isolation	PXS-PL-V150D	2
IRWST Level Transmitter A Isolation	PXS-PL-V151A	2
IRWST Level Transmitter B Isolation	PXS-PL-V151B	2
IRWST Level Transmitter C Isolation	PXS-PL-V151C	2
IRWST Level Transmitter D Isolation	PXS-PL-V151D	2
PRHR Flow Transmitter A Vent	PXS-PL-V170A	2
PRHR Flow Transmitter B Vent	PXS-PL-V170B	2
PRHR Flow Transmitter A Vent	PXS-PL-V171A	2
PRHR Flow Transmitter B Vent	PXS-PL-V171B	2
Accumulator A Leak Test	PXS-PL-V201A	2

**Table 3I.6-3 (Sheet 19 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
Accumulator B Leak Test	PXS-PL-V201B	2
Accumulator A Leak Test	PXS-PL-V202A	2
Accumulator B Leak Test	PXS-PL-V202B	2
RNS Discharge Leak Test	PXS-PL-V205A	2
RNS Discharge Leak Test	PXS-PL-V205B	2
RNS Discharge Leak Test	PXS-PL-V206	2
RNS Suction Leak Test	PXS-PL-V207A	2
RNS Suction Leak Test	PXS-PL-V207B	2
RNS Suction Leak Test	PXS-PL-V208A	2
Core Makeup Tank A Fill Isolation	PXS-PL-V230A	2
Core Makeup Tank B Fill Isolation	PXS-PL-V230B	2
Core Makeup Tank A Fill Check	PXS-PL-V231A	2
Core Makeup Tank B Fill Check	PXS-PL-V231B	2
Accumulator A Fill/Drain Isolation	PXS-PL-V232A	2
Accumulator B Fill/Drain Isolation	PXS-PL-V232B	2
CMT A Check Valve Test Valve	PXS-PL-V250A	2
CMT B Check Valve Test Valve	PXS-PL-V250B	2
CMT A Check Valve Test Valve	PXS-PL-V251A	2
CMT B Check Valve Test Valve	PXS-PL-V251B	2
CMT A Check Valve Test Valve	PXS-PL-V252A	2
CMT B Check Valve Test Valve	PXS-PL-V252B	2
ADS Test Valve	RCS-PL-V007A	2
ADS Test Valve	RCS-PL-V007B	2
ADS Test Valve	RCS-PL-V007C	2
ADS Valve Leakage Check Valve	RCS-PL-V008	2
Fourth Stage ADS Isolation	RCS-PL-V014A	2
Fourth Stage ADS Isolation	RCS-PL-V014B	2
Fourth Stage ADS Isolation	RCS-PL-V014C	2

Table 3I.6-3 (Sheet 20 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
Fourth Stage ADS Isolation	RCS-PL-V014D	2
Hot Leg 2 Level Instrument Root	RCS-PL-V095	2
Hot Leg 2 Level Instrument Root	RCS-PL-V096	2
Hot Leg 1 Level Instrument Root	RCS-PL-V097	2
Hot Leg 1 Level Instrument Root	RCS-PL-V098	2
Hot Leg 1 Flow Instrument Root	RCS-PL-V101A	2
Hot Leg 1 Flow Instrument Root	RCS-PL-V101B	2
Hot Leg 1 Flow Instrument Root	RCS-PL-V101C	2
Hot Leg 1 Flow Instrument Root	RCS-PL-V101D	2
Hot Leg 1 Flow Instrument Root	RCS-PL-V101E	2
Hot Leg 1 Flow Instrument Root	RCS-PL-V101F	2
Hot Leg 2 Flow Instrument Root	RCS-PL-V102A	2
Hot Leg 2 Flow Instrument Root	RCS-PL-V102B	2
Hot Leg 2 Flow Instrument Root	RCS-PL-V102C	2
Hot Leg 2 Flow Instrument Root	RCS-PL-V102D	2
Hot Leg 2 Flow Instrument Root	RCS-PL-V102E	2
Hot Leg 2 Flow Instrument Root	RCS-PL-V102F	2
PRHR HX Outlet Line Drain	RCS-PL-V103	2
Hot Leg 1 Sample Isolation	RCS-PL-V108A	2
Hot Leg 2 Sample Isolation	RCS-PL-V108B	2
PZR Spray Valve	RCS-PL-V110A	2
PZR Spray Valve	RCS-PL-V110B	2
PZR Spray Block Valve	RCS-PL-V111A	2
PZR Spray Block Valve	RCS-PL-V111B	2
Cold Leg 1A Bend Instrument Root	RCS-PL-V171A	2

Table 3I.6-3 (Sheet 21 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
Cold Leg 1A Bend Instrument Root	RCS-PL-V171B	2
Cold Leg 1B Bend Instrument Root	RCS-PL-V172A	2
Cold Leg 1B Bend Instrument Root	RCS-PL-V172B	2
Cold Leg 2A Bend Instrument Root	RCS-PL-V173A	2
Cold Leg 2A Bend Instrument Root	RCS-PL-V173B	2
Cold Leg 2B Bend Instrument Root	RCS-PL-V174A	2
Cold Leg 2B Bend Instrument Root	RCS-PL-V174B	2
PZR Manual Vent	RCS-PL-V204	2
PZR Manual Vent	RCS-PL-V205	2
PZR Spray Bypass	RCS-PL-V210A	2
PZR Spray Bypass	RCS-PL-V210B	2
PZR Level Steam Space Instrument Root	RCS-PL-V225A	2
PZR Level Steam Space Instrument Root	RCS-PL-V225B	2
PZR Level Steam Space Instrument Root	RCS-PL-V225C	2
PZR Level Steam Space Instrument Root	RCS-PL-V225D	2
PZR Level Liquid Space Instrument Root	RCS-PL-V226A	2
PZR Level Liquid Space Instrument Root	RCS-PL-V226B	2
PZR Level Liquid Space Instrument Root	RCS-PL-V226C	2
PZR Level Liquid Space Instrument Root	RCS-PL-V226D	2
Wide Range PZR Level Steam Space Instrument Root	RCS-PL-V228	2
Wide Range PZR Level Liquid Space Instrument Root	RCS-PL-V229	2
Manual Head Vent	RCS-PL-V232	2
Head Vent Isolation	RCS-PL-V233	2
ADS Valve Discharge Header Drain Isolation	RCS-PL-V241	2
RCP 1A Flush	RCS-PL-V260A	2

Table 3I.6-3 (Sheet 22 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
RCP 1B Flush	RCS-PL-V260B	2
RCP 2A Flush	RCS-PL-V260C	2
RCP 2B Flush	RCS-PL-V260D	2
RCP 1A Drain	RCS-PL-V261A	2
RCP 1B Drain	RCS-PL-V261B	2
RCP 2A Drain	RCS-PL-V261C	2
RCP 2B Drain	RCS-PL-V261D	2
RCS Pressure Boundary Valve Thermal Relief Isolation	RNS-PL-V004A	2
RCS Pressure Boundary Valve Thermal Relief Isolation	RNS-PL-V004B	2
RNS Pump A Suction Isolation	RNS-PL-V005A	2
RNS Pump B Suction Isolation	RNS-PL-V005B	2
RNS HX A Outlet Flow Control	RNS-PL-V006A	2
RNS HX B Outlet Flow Control	RNS-PL-V006B	2
RNS Pump A Discharge Isolation	RNS-PL-V007A	2
RNS Pump B Discharge Isolation	RNS-PL-V007B	2
RNS HX A Bypass Flow Control	RNS-PL-V008A	2
RNS HX B Bypass Flow Control	RNS-PL-V008B	2
RNS Discharge Containment Isolation Valve Test	RNS-PL-V010	2
RNS Discharge Containment Isolation Valve Test Connection	RNS-PL-V014	2
RNS Discharge Containment Penetration Isolation Valves Test	RNS-PL-V016	2
RNS Discharge to IRWST Isolation	RNS-PL-V024	2
RNS Discharge to CVS	RNS-PL-V029	2
RNS Train A Discharge Flow Instrument Isolation	RNS-PL-V031A	2
RNS Train B Discharge Flow Instrument Isolation	RNS-PL-V031B	2
RNS Train A Discharge Flow Instrument Isolation	RNS-PL-V032A	2

Table 3I.6-3 (Sheet 23 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
RNS Train B Discharge Flow Instrument Isolation	RNS-PL-V032B	2
RNS Pump A Suction Pressure Instrument Isolation	RNS-PL-V033A	2
RNS Pump B Suction Pressure Instrument Isolation	RNS-PL-V033B	2
RNS Pump A Discharge Pressure Instrument Isolation	RNS-PL-V034A	2
RNS Pump B Discharge Pressure Instrument Isolation	RNS-PL-V034B	2
RNS Pump A Suction Piping Drain Isolation	RNS-PL-V036A	2
RNS Pump B Suction Piping Drain Isolation	RNS-PL-V036B	2
RNS Pump Seal Cooler A Vent Isolation	RNS-PL-V048A	2
RNS Pump Seal Cooler B Vent Isolation	RNS-PL-V048B	2
RNS Pump Seal Cooler A Drain Isolation	RNS-PL-V049A	2
RNS Pump Seal Cooler B Drain Isolation	RNS-PL-V049B	2
RNS Pump A Casing Drain Isolation	RNS-PL-V050	2
RNS Pump B Casing Drain Isolation	RNS-PL-V051	2
RNS Suction from SFP Isolation	RNS-PL-V052	2
RNS Discharge to SFP Isolation	RNS-PL-V053	2
RNS Suction from Cask Loading Pit Isolation Valve	RNS-PL-V055	2
RNS Pump Suction to Cask Loading Pit Isolation	RNS-PL-V056	2
RNS Train A Miniflow Isolation Valve	RNS-PL-V057A	2
RNS Train B Miniflow Isolation Valve	RNS-PL-V057B	2
RNS Pump Suction Containment Isolation Test Connection	RNS-PL-V059	2
RNS Discharge Drain Valve	RNS-PL-V065	2
RNS Discharge to DVI Line A Drain	RNS-PL-V066A	2
RNS Discharge to DVI Line B Drain	RNS-PL-V066B	2
RNS Discharge to DVI Line A Drain	RNS-PL-V067A	2
RNS Discharge to DVI Line B Drain	RNS-PL-V067B	2
RNS Discharge to IRWST Drain	RNS-PL-V068	2

Table 3I.6-3 (Sheet 24 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
RNS Pump A Miniflow Vent	RNS-PL-V069A	2
RNS Pump B Miniflow Vent	RNS-PL-V069B	2
RNS HX A Channel Head Drain Isolation	RNS-PL-V071A	2
RNS HX B Channel Head Drain Isolation	RNS-PL-V071B	2
RNS HX A Channel Head Drain Isolation	RNS-PL-V072A	2
RNS HX B Channel Head Drain Isolation	RNS-PL-V072B	2
RNS HX A Channel Head Drain Isolation	RNS-PL-V073A	2
RNS HX B Channel Head Drain Isolation	RNS-PL-V073B	2
RNS HX A Channel Head Drain Isolation	RNS-PL-V074A	2
RNS HX B Channel Head Drain Isolation	RNS-PL-V074B	2
RNS HX A Channel Head Drain Isolation	RNS-PL-V075A	2
RNS HX B Channel Head Drain Isolation	RNS-PL-V075B	2
IRWST Suction Line Vent	RNS-PL-V080	2
RNS Cask Loading Pit Suction Line Vent	RNS-PL-V081	2
RNS Discharge Drain	RNS-PL-V082	2
LT019A Root Isolation Valve	SFS-PL-V024A	2
LT019B Root Isolation Valve	SFS-PL-V024B	2
LT019C Root Isolation Valve	SFS-PL-V024C	2
LT020 Root Isolation Valve	SFS-PL-V028	2
SFS Refueling Cavity Drain To SGS Compartment Isolation	SFS-PL-V031	2
SFS Refueling Cavity Suction Isolation	SFS-PL-V032	2
SFS Refueling Cavity Drain to Containment Sump Isolation	SFS-PL-V033	2
SFS Suction Line from IRWST Isolation	SFS-PL-V039	2
SFS Fuel Transfer Canal Suction Isolation	SFS-PL-V040	2
SFS Cask Loading Pit Suction Isolation	SFS-PL-V041	2
SFS CVS Makeup Reverse Flow Prevention	SFS-PL-V043	2

Table 3I.6-3 (Sheet 25 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
SFS Containment Penetration Test Connection	SFS-PL-V048	2
SFS Containment Penetration Test Connection Isolation	SFS-PL-V056	2
SFS Containment Isolation Valve V034 Test	SFS-PL-V058	2
SFS Containment Floodup Isolation Valve	SFS-PL-V075	2
LT001 Root Isolation Valve	SGS-PL-V001A	2
LT005 Root Isolation Valve	SGS-PL-V001B	2
LT001 Root Isolation Valve	SGS-PL-V002A	2
LT005 Root Isolation Valve	SGS-PL-V002B	2
LT002 Root Isolation Valve	SGS-PL-V003A	2
LT006 Root Isolation Valve	SGS-PL-V003B	2
LT002 Root Isolation Valve	SGS-PL-V004A	2
LT006 Root Isolation Valve	SGS-PL-V004B	2
LT003 Root Isolation Valve	SGS-PL-V005A	2
LT007 Root Isolation Valve	SGS-PL-V005B	2
LT003 Root Isolation Valve	SGS-PL-V006A	2
LT007 Root Isolation Valve	SGS-PL-V006B	2
LT004 Root Isolation Valve	SGS-PL-V007A	2
LT008 Root Isolation Valve	SGS-PL-V007B	2
LT004 Root Isolation Valve	SGS-PL-V008A	2
LT008 Root Isolation Valve	SGS-PL-V008B	2
LT011 Root Isolation Valve	SGS-PL-V010A	2
LT013 Root Isolation Valve	SGS-PL-V010B	2
LT011 Root Isolation Valve	SGS-PL-V011A	2
LT013 Root Isolation Valve	SGS-PL-V011B	2
LT012 Root Isolation Valve	SGS-PL-V012A	2
LT014 Root Isolation Valve	SGS-PL-V012B	2
LT012 Root Isolation Valve	SGS-PL-V013A	2
LT014 Root Isolation Valve	SGS-PL-V013B	2
FT021 Root Isolation Valve	SGS-PL-V015A	2

**Table 3I.6-3 (Sheet 26 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
FT023 Root Isolation Valve	SGS-PL-V015B	2
FT020 Root Isolation Valve	SGS-PL-V016A	2
FT022 Root Isolation Valve	SGS-PL-V016B	2
FT021 Root Isolation Valve	SGS-PL-V017A	2
FT023 Root Isolation Valve	SGS-PL-V017B	2
FT020 Root Isolation Valve	SGS-PL-V018A	2
FT022 Root Isolation Valve	SGS-PL-V018B	2
Main Steam Line Vent Isolation	SGS-PL-V019A	2
Main Steam Line Vent Isolation	SGS-PL-V019B	2
PT030 Root Isolation Valve	SGS-PL-V022A	2
PT034 Root Isolation Valve	SGS-PL-V022B	2
PT031 Root Isolation Valve	SGS-PL-V023A	2
PT035 Root Isolation Valve	SGS-PL-V023B	2
PT032 Root Isolation Valve	SGS-PL-V024A	2
PT036 Root Isolation Valve	SGS-PL-V024B	2
PT033 Root Isolation Valve	SGS-PL-V025A	2
PT037 Root Isolation Valve	SGS-PL-V025B	2
Steam Line 1 Nitrogen Supply Isolation	SGS-PL-V038A	2
Steam Line 2 Nitrogen Supply Isolation	SGS-PL-V038B	2
MSIV Bypass Control Isolation	SGS-PL-V042A	2
MSIV Bypass Control Isolation	SGS-PL-V042B	2
MSIV Bypass Control Isolation	SGS-PL-V043A	2
MSIV Bypass Control Isolation	SGS-PL-V043B	2
SG1 Condensate Pipe Drain Valve	SGS-PL-V045A	2
SG2 Condensate Pipe Drain Valve	SGS-PL-V045B	2
LT015 Root Isolation Valve	SGS-PL-V046A	2
LT017 Root Isolation Valve	SGS-PL-V046B	2
LT015 Root Isolation Valve	SGS-PL-V047A	2
LT017 Root Isolation Valve	SGS-PL-V047B	2
LT016 Root Isolation Valve	SGS-PL-V048A	2

Table 3I.6-3 (Sheet 27 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive

Description	AP1000 Tag Number	Comment
LT018 Root Isolation Valve	SGS-PL-V048B	2
LT016 Root Isolation Valve	SGS-PL-V049A	2
LT018 Root Isolation Valve	SGS-PL-V049B	2
LT044 Root Isolation Valve	SGS-PL-V050A	2
LT046 Root Isolation Valve	SGS-PL-V050B	2
LT044 Root Isolation Valve	SGS-PL-V051A	2
LT046 Root Isolation Valve	SGS-PL-V051B	2
LT045 Root Isolation Valve	SGS-PL-V052A	2
LT047 Root Isolation Valve	SGS-PL-V052B	2
LT045 Root Isolation Valve	SGS-PL-V053A	2
LT047 Root Isolation Valve	SGS-PL-V053B	2
PT062 Root Isolation Valve	SGS-PL-V056A	2
PT063 Root Isolation Valve	SGS-PL-V056B	2
Main Feedwater Check	SGS-PL-V058A	2
Main Feedwater Check	SGS-PL-V058B	2
FT055A Root Isolation Valve	SGS-PL-V062A	2
FT056A Root Isolation Valve	SGS-PL-V062B	2
FT055A Root Isolation Valve	SGS-PL-V063A	2
FT056A Root Isolation Valve	SGS-PL-V063B	2
FT055A Root Isolation Valve	SGS-PL-V064A	2
FT056A Root Isolation Valve	SGS-PL-V064B	2
FT055A Root Isolation Valve	SGS-PL-V065A	2
FT056A Root Isolation Valve	SGS-PL-V065B	2
SG1 Nitrogen Sparging Isolation	SGS-PL-V084A	2
SG2 Nitrogen Sparging Isolation	SGS-PL-V084B	2
Orifice Isolation Valve	SGS-PL-V093A	2
Orifice Isolation Valve	SGS-PL-V093B	2
Orifice Cleanout Line Isolation Valve	SGS-PL-V094A	2
Orifice Cleanout Line Isolation Valve	SGS-PL-V094B	2
Orifice Isolation Valve	SGS-PL-V095A	2
Orifice Isolation Valve	SGS-PL-V095B	2
Steam Line Condensate Drain Level Isolation Valve	SGS-PL-V096A	2
Steam Line Condensate Drain Level Isolation Valve	SGS-PL-V096B	2
Steam Line Condensate Drain Level Isolation Valve	SGS-PL-V097A	2
Steam Line Condensate Drain Level Isolation Valve	SGS-PL-V097B	2

**Table 3I.6-3 (Sheet 28 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
Startup Feedwater Drain Isolation Valve	SGS-PL-V100A	2
Startup Feedwater Drain Isolation Valve	SGS-PL-V100B	2
Main Feedwater Drain Isolation Valve	SGS-PL-V101A	2
Main Feedwater Drain Isolation Valve	SGS-PL-V101B	2
Startup Feedwater Vent Isolation Valve	SGS-PL-V102A	2
Startup Feedwater Vent Isolation Valve	SGS-PL-V102B	2
Main Feedwater Vent Isolation Valve	SGS-PL-V103A	2
Main Feedwater Vent Isolation Valve	SGS-PL-V103B	2
Main Feedwater Drain Isolation Valve	SGS-PL-V104A	2
Main Feedwater Drain Isolation Valve	SGS-PL-V104B	2
Startup Feedwater Check Valve	SGS-PL-V256A	2
Startup Feedwater Check Valve	SGS-PL-V256B	2
Air Delivery Line Pressure Instrument Isolation Valve A	VES-PL-V006A	2
Air Delivery Line Pressure Instrument Isolation Valve B	VES-PL-V006B	2
Temporary Instrument Isolation Valve A	VES-PL-V016	2
Temporary Instrument Isolation Valve A	VES-PL-V018	2
Temporary Instrument Isolation Valve B	VES-PL-V019	2
Temporary Instrument Isolation Valve B	VES-PL-V020	2
Air Tank Isolation Valve A	VES-PL-V024A	2
Air Tank Isolation Valve B	VES-PL-V024B	2
Air Tank Isolation Valve A	VES-PL-V025A	2
Air Tank Isolation Valve B	VES-PL-V025B	2
Refill Line Isolation Valve	VES-PL-V038	2
DP Instrument Line Isolation Valve A	VES-PL-V043A	2
DP Instrument Line Isolation Valve B	VES-PL-V043B	2
Containment Isolation Test Connection	VFS-PL-V008	2
Containment Isolation Test Connection	VFS-PL-V012	2
Containment Isolation Test Connection	VFS-PL-V015	2
Main Equipment Hatch Test Connection	VUS-PL-V015	2
Maintenance Equipment Hatch Test Connection	VUS-PL-V016	2
Personnel Hatch Test Connection	VUS-PL-V017	2
Personnel Hatch Test Connection	VUS-PL-V018	2
Personnel Hatch Test Connection	VUS-PL-V019	2
Personnel Hatch Test Connection	VUS-PL-V020	2
Personnel Hatch Test Connection	VUS-PL-V021	2
Personnel Hatch Test Connection	VUS-PL-V022	2
Fuel Transfer Tube Test Connection	VUS-PL-V023	2

**Table 3I.6-3 (Sheet 29 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
Spare Penetration Test Connection	VUS-PL-V140	2
Spare Penetration Test Connection	VUS-PL-V141	2
Spare Penetration Test Connection	VUS-PL-V142	2
VWS Supply Containment Penetration IRC Test Connection/Vent	VWS-PL-V424	2
VWS Return Containment Penetration ORC Test Connection/Vent	VWS-PL-V425	2
WWS MCR Isolation Valve	WWS-PL-V506	2
Heat Exchangers		
Normal Residual Heat Removal Heat Exchanger A	RNS-ME-01A	3
Normal Residual Heat Removal Heat Exchanger B	RNS-ME-01B	3
Tanks		
Spent Fuel Pool	FHS-MT-01	3
Fuel Transfer Canal	FHS-MT-02	3
Spent Fuel Cask Loading Pit	FHS-MT-05	3
Passive Containment Cooling Water Storage Tank	PCS-MT-01	3
Water Distribution Bucket	PCS-MT-03	3
Water Collection Troughs	PCS-MT-04	3
Passive RHR Heat Exchanger	PXS-ME-01	3
Accumulator Tank A	PXS-MT-01A	3
Accumulator Tank B	PXS-MT-01B	3
Core Makeup Tank A	PXS-MT-02A	3
Core Makeup Tank B	PXS-MT-02B	3
In-Containment Refueling Water Storage Tank	PXS-MT-03	3
Emergency Air Storage Tank 01	VES-MT-01	3
Emergency Air Storage Tank 02	VES-MT-02	3
Emergency Air Storage Tank 03	VES-MT-03	3
Emergency Air Storage Tank 04	VES-MT-04	3
Emergency Air Storage Tank 05	VES-MT-05	3
Emergency Air Storage Tank 06	VES-MT-06	3
Emergency Air Storage Tank 07	VES-MT-07	3
Emergency Air Storage Tank 08	VES-MT-08	3
Emergency Air Storage Tank 09	VES-MT-09	3
Emergency Air Storage Tank 10	VES-MT-10	3
Emergency Air Storage Tank 11	VES-MT-11	3
Emergency Air Storage Tank 12	VES-MT-12	3
Emergency Air Storage Tank 13	VES-MT-13	3
Emergency Air Storage Tank 14	VES-MT-14	3

**Table 3I.6-3 (Sheet 30 of 30)
List Of AP1000 Safety-Related Electrical
and Mechanical Equipment Not High Frequency Sensitive**

Description	AP1000 Tag Number	Comment
Emergency Air Storage Tank 15	VES-MT-15	3
Emergency Air Storage Tank 16	VES-MT-16	3
Emergency Air Storage Tank 17	VES-MT-17	3
Emergency Air Storage Tank 18	VES-MT-18	3
Emergency Air Storage Tank 19	VES-MT-19	3
Emergency Air Storage Tank 20	VES-MT-20	3
Emergency Air Storage Tank 21	VES-MT-21	3
Emergency Air Storage Tank 22	VES-MT-22	3
Emergency Air Storage Tank 23	VES-MT-23	3
Emergency Air Storage Tank 24	VES-MT-24	3
Emergency Air Storage Tank 25	VES-MT-25	3
Emergency Air Storage Tank 26	VES-MT-26	3
Emergency Air Storage Tank 27	VES-MT-27	3
Emergency Air Storage Tank 28	VES-MT-28	3
Emergency Air Storage Tank 29	VES-MT-29	3
Emergency Air Storage Tank 30	VES-MT-30	3
Emergency Air Storage Tank 31	VES-MT-31	3
Emergency Air Storage Tank 32	VES-MT-32	3
Main Feed Pump A Status	ECS-ES-3-XXX	4
Main Feed Pump B Status	ECS-ES-4-XXX	4
Main Feed Pump C Status	ECS-ES-5-XXX	4

Notes:

- Rugged AP1000 safety-related equipment with no moving parts required in demonstrating functional operability during a seismic event is considered to be not sensitive to HRHF seismic loadings. Seismic qualification is based on the seismic loads associated with the mounting location of the safety-related equipment as a minimum. AP1000 CSDRS seismic loads at the mounting location of the safety-related equipment produce comparable or higher equipment stresses and deflections than the HRHF seismic loadings based on the work reported in APP-GW-GLR-115, "Effect of High Frequency Seismic Content on SSCs." For rugged safety-related line-mounted equipment being qualified by test, seismic testing will be performed in compliance with IEEE Standard 382-1996 with a required input motion (RIM) curve extended to 64 Hz typically to a peak acceleration of 6g.
- AP1000 safety-related valves are seismic qualified in accordance with ASME code for structural integrity to a maximum acceleration of 6g in all three principal orthogonal axes. AP1000 CSDRS seismic loads at the mounting location of the safety-related equipment produce comparable or higher equipment stresses and deflections than the HRHF seismic loadings based on the work reported in APP-GW-GLR-115, "Effect of High Frequency Seismic Content on SSCs." For rugged safety-related line-mounted equipment being qualified by test, seismic testing will be performed in compliance with IEEE Standard 382-1996 with a required input motion (RIM) curve extended to 64 Hz typically to a peak acceleration of 6g.
- Seismic qualification is based on structural integrity alone to the seismic loadings associated with the mounting location of the safety-related equipment as a minimum. AP1000 CSDRS seismic loads at the mounting location of the safety-related equipment produce comparable or higher equipment stresses and deflections than the HRHF seismic loadings based on the work reported in APP-GW-GLR-115, "Effect of High Frequency Seismic Content on SSCs."
- Seismic qualification is not required.




Figure 3I.1-1
Comparison of Horizontal AP1000 CSDRS and HRHF Envelope Response Spectra




Figure 3I.1-2

Comparison of Vertical AP1000 CSDRS and HRHF Envelope Response Spectra