



Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.

James A. FitzPatrick NPP
P.O. Box 110
Lycoming, NY 13093
Tel 315-342-3840

William C. Drews
Regulatory Assurance Manager

JAFP-16-0110
June 29, 2016

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Subject: Correction to the 2014 Annual Radioactive Effluent Release Report

James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
License No. DPR-59

References: ENOI letter, 2014 Annual Radioactive Effluent Release Report, JAFP-15-0051, dated April 29, 2015

Dear Sir or Madam:

This letter submits a correction to the James A. FitzPatrick Nuclear Power Plant's (JAF) Annual Radioactive Effluent Release Report, for the period of January 1, 2014, through December 31, 2014 previously submitted in the Reference letter in April 2015. The correction is for a typographical error in Table 1B Gaseous Effluents – Elevated Release (Continuous Mode) on Page 7 for the TOTAL summation of Quarter 2 Fission gases. The Reference Report incorrectly identified a TOTAL of 5.00E+011 (curies) whereas the actual summation total should have been correctly reported as 5.00E+01 (curies).

The Reference Report was submitted in accordance with the Reporting Requirements of the Technical Specifications Section 5.6.3, and Appendix H of the Technical Requirements Manual "Offsite Dose Calculation Manual (ODCM)", Part 1, Section 6.2 Radioactive Effluent Release Report. The Enclosure to this letter contains the corrected Page 7 to the previously submitted report.

There are no new regulatory commitments contained in this letter.

If you have any questions concerning the enclosed report, please contact Robert Heath, Radiation Protection / Chemistry Manager, at (315) 349-6635.

Sincerely,



William C. Drews
Regulatory Assurance Manager

WD/RH/dc

Enclosure: Corrected Page 7 of 2014 Annual Radioactive Effluent Release Report

cc:

Mr. Daniel H. Dorman
Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
2100 Renaissance Boulevard, Suite 100
King of Prussia, PA 19406-2713

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
James A. FitzPatrick Nuclear Power Plant
P.O. Box 136
Lycoming, NY 13093

Mr. William Huffman, Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

R. Heath (Chemistry JAF)
K. Stoffle (Chemistry NMP)

JAFP-16-0110

Enclosure

Corrected Page 7 of 2014 Annual Radioactive Effluent Release Report
(1 Page)

ENTERGY NUCLEAR OPERATIONS, INC.
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
 JANUARY 2014 - DECEMBER 2014

TABLE 1B
GASEOUS EFFLUENTS - ELEVATED RELEASE

CONTINUOUS MODE

NUCLIDES RELEASED

<u>1. Fission Gases</u>	<u>UNIT</u>	<u>QUARTER 1</u>	<u>QUARTER 2</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>
Argon-41	Ci	1.95E+01	3.75E+00	6.43E+00	8.59E+00
Krypton-85m	Ci	9.65E-01	1.62E+00	2.54E+00	1.61E+00
Krypton-87	Ci	5.18E+00	5.63E+00	4.50E-01	ND
Krypton-88	Ci	2.85E+00	3.52E+00	1.87E+00	1.37E+00
Xenon-133	Ci	7.09E-01	3.91E-01	2.64E+00	6.04E-01
Xenon-135	Ci	7.18E+00	6.67E+00	3.70E-01	2.22E-02
Xenon-135m	Ci	1.10E+01	6.93E+00	8.53E-01	ND
Xenon-137	Ci	8.01E-01	ND	ND	ND
Xenon-138	Ci	3.04E+01	2.15E+01	3.46E+00	ND
TOTAL	Ci	7.86E+01	5.00E+01	1.86E+01	1.22E+01
<u>2. Iodines</u>					
Iodine-131	Ci	1.65E-05	3.15E-05	1.60E-05	1.18E-05
Iodine-132	Ci	ND	3.11E-05	ND	ND
Iodine-133	Ci	4.97E-05	8.92E-05	5.97E-05	3.78E-05
Iodine-135	Ci	ND	6.56E-05	7.87E-06	ND
TOTAL	Ci	6.62E-05	2.17E-04	8.36E-05	4.96E-05
<u>3. Particulates</u>					
Cobalt-60	Ci	ND	ND	6.12E-07	ND
Cesium-137	Ci	2.61E-06	ND	ND	ND
Manganese-54	Ci	ND	ND	6.92E-07	ND
Strontium-89	Ci	ND	ND	8.88E-07	5.52E-07
Zinc-65	Ci	ND	ND	5.64E-07	ND
TOTAL	Ci	2.61E-06	ND	2.76E-06	5.52E-07
<u>4. Tritium</u>					
Hydrogen-3	Ci	4.32E-01	2.39E-01	1.88E-01	2.41E-01

Note: There were no batch releases for this report period.