## **RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION**

#### APR1400 Design Certification

# Korea Electric Power Corporation / Korea Hydro & Nuclear Power Co., LTD

Docket No. 52-046

RAI No.:	446-8535
SRP Section:	19 - Probabilistic Risk Assessment and Severe Accident Evaluation Application Section
Application Section:	19.1
Date of RAI Issue:	03/16/2016

## Question No. 19-98

The staff reviewed KHNP's revised response to RAI Question 19-4 dated September 30, 2015. In response to RAI Question 19-4, KHNP proposed that a new table be added to the DCD, Table 19.1-93, Summary of Analysis Results for Plant Operating States (POSs). This table shows:

- 1. The anticipated decay heat level and the associated time post shutdown
- 2. The size and locations of any RCS vents
- 3. The assumed RCS water level
- 4. The time to RCS boiling given a loss of the decay heat removal function
- 5. The time to core uncovery
- 6. The thermal-hydraulic code used to assess the POS and a discussion of the acceptability of the code to assess that POS.

In addition, based on staff review of: (1) proposed DCD Table 19.1-93, (2) the staff's confirmatory midloop MELCOR calculation, and (3) the midloop loss of core cooling calculation referenced in Fukushima Technical Report, Section A.5.3 Shutdown Condition with SGs not Available, the staff is requesting the following additional information to be added to the proposed DCD Table 19.1-93:

- a. RCP seal leakage rate for each POS. Please confirm if this leakage rate is the same rate referenced in the Fukushima Technical Report (25 gpm/pump).
- b. Leakage rate from temporary seals used for the Incore Instrumentation for each applicable POS.
- c. The definition of hot leg top level (for POS 4 only).

- d. The definition of midloop operation level (for POS 5 only). Please confirm if this level is the same midloop vessel level referenced in Section A.5.3 of the Fukushima Technical Report.
- e. Clarification in POS 4A, with the RCS closed except for the open Reactor Coolant System Gas Vent System (RCGVS), whether the RCS is being drained with a cover gas.
- f. Clarification in each POS where reflux cooling is being credited, the assumed initial SG secondary side level and the number of SGs with secondary inventory.
- g. Clarification in each POS whether the vessel head is installed.

#### **Response**

The responses are as follows;

- a. RCS pump seal leakage is not considered for POS 3 through 13 (Mode 4 and 5), because RCS pressure is low since SCS is in-service or RCS is not intact (pressurizer manway is open).
- b. The temporary seal is not used during refueling, since the BM-ICI system uses a fixed ICI system.
- c. The definition of hot leg top level (for POS 4 only) is the upper end level of hot leg inside diameter (Hotleg Top Level: 119' 1"), and it will be added in Table 19.1-93.
- d. The definition of midloop operation level (for POS 5 only) is as follows;
  - High Level: 117' 11",
  - Low Level: 117' 7.28",
  - Low-Low Level: 117' 6"

These are the same midloop vessel level referenced in Section A.5.3 of the Fukushima Technical Report. And it will be added in Table 19.1-93.

- e. Instrument air is ported to the RCS through the pressurizer vent path before the pressurizer manway is opened. This alignment prevents the RCS from drawing a vacuum and speeds draining.
- f. POS 3 and POS 13 have two (2) SGs and POS 4A has one (1) SG. And it will be added in Table 19.1-93.
- g. Vessel head is removed in POS 6 and installed in POS 10. And it will be added in Table 19.1-93.

#### Impact on DCD

Table 19.1-93 will be revised as shown in Attachment.

#### Impact on PRA

There is no impact on the PRA.

### Impact on Technical Specifications

There is no impact on the Technical Specifications.

#### Impact on Technical/Topical/Environmental Reports

There is no impact on any Technical, Topical, or Environmental Report.

			~~~~~	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	$\sim$	~~~~~	RAI 42-7	945_Questic	on 19-4
``				Table 19.1-93	8 (1 of 4)		RAI 446-	8535_Quest	ion 19-98
			<u>Summary o</u>	f Analysis Results	for Plant Opera	ating States			
POS 03A	Description Cooldown with Shutdown Cooling System to 212°F	Anticipated Decay Heat Level (MWt) 24.6	Associated Time Post Shutdown (hrs) 32.9	Size and Locations of any RCS Vents RCS is intact and LTOP valves are in auto protection mode	Minimum RCS Water Level During POS Normal operation level	Number of SGs and SG Water Level Two of SGs and Wet Lay- up water level	Cases Base LTOP B Stuck-open at t=0 LOCA through CVCS Letdown line	Time to RCS Boiling 16801 sec (4.67 hrs) 190 sec (0.05 hrs) 13103 sec (3.64 hrs)	Time to Core Uncovery 19943 sec (5.54 hrs) 3061 sec (0.85 hrs) 19837 sec (5.51 hrs)
03B	Cooldown with Shutdown Cooling System to 140°F	24.6	37.5	RCS is intact and LTOP valves are in auto protection mode	Normal operation level	Two of SGs and Wet Lay- up water level	N/A	N/A	N/A
04A	Reactor Coolant System drain-down (pressurizer manway closed) <sup>(3)</sup>	18.6	75.1	RCGVS (Reactor Coolant System Gas Vent System) is open and LTOP valves are in auto protection mode	Normal operation level	One of SG and Wet Lay-up water level	Base LOCA through CVCS Letdown line	10728 sec (2.98 hrs) 9724 sec (2.70 hrs)	48146 sec (13.37 hrs) 47646 sec (13.24 hrs)

RAI 446-8535 - Question 19-98

Attachment (2/4)

Table 19.1-93 (2 of 4)							RAI 446-8535_Question 19-98			
POS 04B	Description Reactor Coolant System drain-down (pressurizer manway open)	Anticipated Decay Heat Level (MWt) 18.5	Associated Time Post Shutdown (hrs) 76.4	Size and Locations of any RCS Vents Pressurizer manway open. RCGS (Reactor Coolant System Gas Vent System) open and LTOP valves are in auto protection mode	Minimum RCS Water Level During POS Hot leg top level <sup>(1)</sup>	Number of SGs and SG Water Level	Cases Base LOCA through CVCS Letdown line	Time to RCS Boiling 134 sec (0.04 hrs) 38 sec (0.01 hrs)	Time to Core Uncovery 5599 sec (1.56 hrs) 5502 sec (1.53 hrs)	
05	Reduced Inventory operation and nozzle dam installation	16.8	96.7	Pressurizer manway open. Steam generators manway open. RCGVS (Reactor Coolant System Gas Vent System) open and LTOP valves are in auto protection mode	Mid-loop Operation level (2)	-	LOCA through CVCS Letdown line	400 sec (0.11 hrs) 398 sec (0.11 hrs)	4582 sec (1.27 hrs) 4161 sec (1.16 hrs)	
06	Fill for refueling	15.7	113.5	Pressurizer manway open. ICI tubes open. RCGVS (Reactor Coolant System) open and LTOP valves are in auto protection mode. Nozzle dam installed Vessel head is removed	Reactor vessel flange level	-	Base LOCA through CVCS Letdown line	364 sec (0.10 hrs) 362 sec (0.10 hrs)	6020 sec (1.67 hrs) 5924 sec (1.65 hrs)	

RAI 446-8535 - Question 19-98

Attachment (3/4)

Table 19.1-93 (3 of 4)							RAI 446-8535_Question 19-98		
POS 10	Description Reactor Coolant System drain-down to Reduced Inventory after refueling	Anticipated Decay Heat Level (MWt) 9.3	Associated Time Post Shutdown (hrs) 435.9	Size and Locations of any RCS Vents Pressurizer manway open. ICI tubes open. RCGVS (Reactor Coolant System Gas Vent System) open and LTOP valves are in auto protection mode. Nozzle dam installed Vescel head is	Minimum RCS Water Level During POS Reactor vessel flange level	Number of SGs and SG Water Level	Cases Base LOCA through CVCS Letdown line	Time to RCS Boiling 861 sec (0.24 hrs) 850 sec (0.24 hrs)	Time to Core Uncovery 10248 sec (2.85 hrs) 10133 sec (2.81 hrs)
11	Reduced Inventory operation with steam generator manway closed	8.7	521.7	resser near is installed. Pressurizer manway open. Steam generators manway open. RCGVS (Reactor Coolant System Gas Vent System) open and LTOP valves are in auto protection mode	Mid-loop operation level (2)	-	Base LOCA through CVCS Letdown line	1258 sec (0.35 hrs) 1233 sec (0.34 hrs)	9874 sec (2.74 hrs) 9914 sec (2.75 hrs)
12A	Refill Reactor Coolant System (pressurizer manway open)	8.6	534.9	Pressurizer manway open. LTOP valves are in auto protection mode	Hot leg center +13" level	-	Base LOCA through CVCS Letdown line	455 sec (0.13 hrs) 451 sec (0.13 hrs)	20094 sec (5.58 hrs) 19579 sec (5.44 hrs)

RAI 446-8535 - Question 19-98

Attachment (4/4)

Table 19.1-93 (4 of 4)							RAI 446-8535_Question 19-98		
POS 12B	Description Refill Reactor Coolant System (manway closed)	Anticipated Decay Heat Level (MWt) 8.6	Associated Time Post Shutdown (hrs) 539.1	Size and Locations of any RCS Vents RCGVS (Reactor Coolant System) Gas Vent System) open and LTOP valves are in auto protection mode.	Minimum RCS Water Level During POS 28.2% Pressurizer level	Number of SGs and SG Water Level	Cases Base LOCA through CVCS Letdown line	Time to RCS Boiling 37176 sec (10.33 hrs) 16713 sec (4.64 hrs)	Time to Core Uncovery No core uncovery (simulation time 25.0 hrs) 85395 sec (23.72 hrs)
13	Reactor Coolant System heat-up with Shutdown Cooling System isolation at 350°F	8.4	562.3	RCS is intact and LTOP valves are in auto protection mode.	Normal operation level	Two of SGs and Wet Lay- up water level	Base LOCA through CVCS Letdown	53063 sec (14.74 hrs) 13703 sec (3.81 hrs)	60661 sec (16.85 hrs) 59294 sec (16.47 hrs)

(2) The midloop operation level are High Level : 117' 11", Low Level : 117' 7.28", and Low-Low Level : 117' 6". These are the same with the Fukushima Technical Report

(3) Instrument air is ported to the RCS through the pressurizer vent path before the pressurizer manway is opened. This alignment prevents the RCS from drawing a vacuum and speeds draining.

• RCS pump seal leakage is not considered for POS 3 through 13 which are Mode 4 and 5 because RCS pressure is low since SCS is in-service or RCS is not intact (pressurizer manway is open).

• ICI seal leaks of ICI system is not considered because it is a fixed ICI system of "U" type BM-ICI system preventing seal leaks.