

Vogtle PEmails

From: Hoellman, Jordan
Sent: Wednesday, July 13, 2016 3:13 PM
To: Vogtle PEmails
Subject: FW: RAI 8661 Question 03.02.02-1

From: Kallan, Paul
Sent: Wednesday, July 13, 2016 3:09 PM
To: Hoellman, Jordan <Jordan.Hoellman2@nrc.gov>
Subject: RAI 8661 Question 03.02.02-1

Hi Jordan,

Can you this RAI for Vogtle in ADAMS:

The License Amendment Request LAR-16-004 for Vogtle Units 3 and 4 requires changes to the Updated Final Safety Analysis Report (UFSAR) and COL Appendix C and AP1000 DCD Tier 1 information. LAR-16-004, Section 2.4 describes the changes to the air filtration system (VFS). As stated in LAR-16-004 Enclosure 3 page 2 of 9, piping VFS-L832 is added to the containment purge discharge from containment line. UFSAR Figure 9.4.7-1 provides a simplified containment VFS. LAR-16-004 Section 2.4 states that VFS-L832 is a piping line located between the containment purge exhaust containment penetration and the parallel outside containment isolation valve VFS-PL-V010 and outside containment vacuum relief valves VFS-PL-V800A and VFS-PL-V800B. The licensee is requested to provide a mark-up to UFSAR Figure 9.4.7-1 to indicate the new piping VFS-L832 and its ASME Section III Code Quality Group classification.

Paul Kallan

Office of New Reactors
Division of New Reactor Licensing
Licensing Branch 4
Tel: (301) 415-2809
Paul.Kallan@nrc.gov

Hearing Identifier: Vogtle_COL_Docs_Public
Email Number: 38

Mail Envelope Properties (29d2aa2267704005b3e521238712e307)

Subject: FW: RAI 8661 Question 03.02.02-1
Sent Date: 7/13/2016 3:12:47 PM
Received Date: 7/13/2016 3:12:48 PM
From: Hoellman, Jordan

Created By: Jordan.Hoellman2@nrc.gov

Recipients:
"Vogtle PEmails" <Vogtle.PEmails@nrc.gov>
Tracking Status: None

Post Office: HQPWMSMRS01.nrc.gov

Files	Size	Date & Time
MESSAGE	1335	7/13/2016 3:12:48 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: