

10 CFR 21.21

July 5, 2016

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

SUBJECT: CLOSURE OF INTERIM 10 CFR PART 21 REPORTS

This letter is being provided to update the status of seven recent interim reports submitted by WECTEC (previously CB&I Power) in accordance with 10 CFR 21.21. These interim reports were provided by letters as identified in the following list:

<u>Report Date</u>	<u>NRC Log No.</u>	<u>Subject</u>
10/29/2015	2015-76-00	Interim Part 21 Report Regarding Nonconforming Rebar Cross-Ties for V. C. Summer Unit 3 AP1000 Project
01/21/2016	2015-78-01	Updated Interim Part 21 Report Regarding Passive Core Cooling System Pipe Supports for the Vogtle Unit 3 AP1000 Project
12/10/2015	2015-84-00	Interim Report Regarding Nondestructive Examination of Weldable Couplers for Vogtle Unit 3 AP1000 Project
01/05/2016	2016-02-00	Interim Report Regarding Leak Chase Deviations for Vogtle Unit 4 and V. C. Summer Unit 3 AP1000 Projects
04/14/2016	2016-17-00	Interim Report Regarding Shield Wall Panel Dimensions for V. C. Summer Unit 2 AP1000 Project
04/22/2016	2016-18-00	Interim Part 21 Report Regarding Disposition Of A Nonconformance On Submodule CA03-16 For The V. C. Summer Unit 2 AP1000 Project
05/06/2016	2016-25-00	Interim Part 21 Report Regarding a Weld Deviation on Structural Module CB36 for the Vogtle Unit 3 AP1000 Project

Evaluations of the conditions identified in these interim reports have been completed. The conditions have been determined to be not reportable in accordance with 10 CFR Part 21.

If you have any questions pertaining to this information, please contact Curtis Castell, Licensing Manager, at 980-859-6373.

Sincerely,



David Durham
President
WECTEC LLC

cc: Regional Administrator, USNRC, Region II

IE19
NRD