

# CORRECTIVE ACTION REQUEST

ASME  NON-ASME

CAR # 2032

Date Issued: 11/5/12

Internal / External : Internal

Originated By: John DeKleine

Title: Director Quality Assurance

Responsible Department: Operations

Program/Regulatory Reference: NRC Routine Vendor Inspection reference Docket number 999013777, Report number 2012-201 Nonconformance -02 required a satisfactory review for suitability of application safety related materials.

Description of Deficiency: Contrary to the above, during the NRC Inspection it revealed Enertech's technical justifications for addressing acceptance of material certification and the basis for the use of sampling when perform dedication activities were not documented.

**Recommendations:**

1. Establish cause
2. Prepare appropriate corrective and preventative actions

Response Due: 11/30/12

**This section is to be completed by the referenced Department Manager/Supplier Representative only. You are hereby requested to investigate the above described condition and identify the cause, the fix, and the corrective action taken to preclude recurrence. Please complete this section of the form, or an attachment addressing the concern, and return by the specified Response Due Date.**


Cause & Extent of Noted Deficiency: While Engineering technical justification for material verification and sampling were documented in CGI Evaluating and EOP 3140, it did not meet the NRC expectations, due to its generic nature.

Corrective/Remedial Action to Correct the Deficiency: Document the technical justification for acceptance method of material and sampling methods in CGI evaluation MA24945 (Diffuser) and MA24946 (Retaining Ring), in accordance with identified critical characteristics, including the requirements for Lot homogeneity for each sampling plan. Correct CGI Dedication Plan D8740S for Lot 40316.

Corrective/Preventative Action to Preclude a Reoccurrence: Revise EOP 3140, to state the requirements for satisfactory documentation of technical justification for acceptance and sampling methods. Revise CGI Dedication Plan D8740S.  
  
Provide training on revised EOP.

Proposed Completion Date: 12/31/2012


Responding Person's Signature/Title



Date: 11.20.12

Date CAR Response Received in Enertech QA Department: 11-20-12

QA Evaluation & Approval of Response



Date: 11-20-12

# CORRECTIVE ACTION REQUEST

2032

Enertech's Verification of Corrective Action Taken:

Method of Verification     Re-Audit         Administrative Review of Objective Evidence

Summary of Verification:

Verified revision to EOP and subsequent training records.

Verification Date: 12-21-12    By: Jed L. Gray    Title: VP-OP&M

Enertech Management Review for 10CFR Part 21 Applicability:     - Applicable;         - Not Applicable

Review performed By: Jed L. Gray

Results of Verification:

Satisfactory     Incomplete     Unsatisfactory\*  
 Remains Open     Closed (\* Additional Action Required)

Closed Date: 12-21-12    By: Jed L. Gray    Title: VP-OP&M

[Redacted]

[Redacted]  
\_\_\_\_\_  
[Redacted]  
\_\_\_\_\_  
[Redacted]  
\_\_\_\_\_  
[Redacted]  
\_\_\_\_\_  
[Redacted]  
\_\_\_\_\_

THE DATA PROVIDED HEREIN IS PROPRIETARY DATA AND IS THE PROPERTY OF ENERTECH, A BUSINESS UNIT OF CURTISS-WRIGHT FLOW CONTROL COMPANY. THIS DATA SHALL NOT BE DISCLOSED IN WHOLE OR IN PART FOR ANY PURPOSE OTHER THAN FOR EVALUATION BY THE RECIPIENT, HIS EMPLOYEES OR HIS CLIENTS. THE RECIPIENT SHALL HAVE THE RIGHT TO DUPLICATE, USE OR DISCLOSE THIS DATA FOR THE SOLE PURPOSE OF CORRESPONDING WITH ENERTECH. ANY OTHER USE IS STRICTLY PROHIBITED WITHOUT THE PRIOR WRITTEN CONSENT OF ENERTECH.



2950 Birch Street, Brea, CA 92821 U.S.A.  
 Phone: 714.528.2301 Fax: 714.528.0128

CUSTOMER  
**STANDARD**

REV.  
**A**

DRAWING NUMBER  
**MA24945**

Page 2 of 15

CGI EVALUATION - DIFFUSER, PASSIVE N. O. NOZZLE  
 CHECK VALVE

**RECORD OF REVISION**

REV LEVEL	ECO NO.	PREPARED BY	DATE	CHECKED BY	DATE	APPROVED BY	DATE
A	5-21537	<i>[Signature]</i>	11/16/12	<i>[Signature]</i>	11/16/12	<i>[Signature]</i>	11/16/12

**ORIGINAL**

THE DATA PROVIDED HEREIN IS PROPRIETARY DATA AND IS THE PROPERTY OF ENERTECH, A BUSINESS UNIT OF CURTISS-WRIGHT FLOW CONTROL COMPANY. THIS DATA SHALL NOT BE DISCLOSED IN WHOLE OR IN PART FOR ANY PURPOSE OTHER THAN FOR EVALUATION BY THE RECIPIENT, HIS EMPLOYEES OR HIS CLIENTS. THE RECIPIENT SHALL HAVE THE RIGHT TO DUPLICATE, USE OR DISCLOSE THIS DATA FOR THE SOLE PURPOSE OF CORRESPONDING WITH ENERTECH. ANY OTHER USE IS STRICTLY PROHIBITED WITHOUT THE PRIOR WRITTEN CONSENT OF ENERTECH.



2950 Birch Street, Brea, CA 92821 U.S.A.  
Phone: 714.528.2301 Fax: 714.528.0128

CUSTOMER  
**STANDARD**

REV.  
**B**

DRAWING NUMBER  
**MA24946**

Page 2 of 11

CGI EVALUATION - RETAINING RING, PASSIVE N. O.  
NOZZLE CHECK VALVE

**RECORD OF REVISION**

REV LEVEL	ECO NO.	PREPARED BY	DATE	CHECKED BY	DATE	APPROVED BY	DATE
A	5-21546	IJ Silverman	11/21/2012	H Mkrtchyan	11/26/12	P Schaller	11/30/12
B	5-21663	IJ Silverman	12/20/2012	<i>[Signature]</i>	12/21/12	<i>[Signature]</i>	12/28/12

**ORIGINAL**

**INFORMATION ONLY**

**Description:** Casting, Diffuser

**Production Order No.** \_\_\_\_\_

**Design Function:** Maintain disc shaft and spring in proper position and orientation for correct operation.  
**Safety Function:** Same as design function.

**Functional Mode (NP-6629):** \_\_\_ Active \_\_\_ Passive \_\_\_ X Not Applicable **Reference CGI Evaluation:** MA24945 – Diffuser, Passive N.O. Nozzle Check Valve

**Qualifications:**

- \_\_\_ Environmentally qualified per \_\_\_\_\_ X Environmental qualification does not apply.
- \_\_\_ Seismically qualified per \_\_\_\_\_ X Seismic qualification does not apply.
- \_\_\_ Original Qualifications are maintained by compliance to the original design/drawing requirements.

**Eligibility of Commercial Grade item:**

- X Not subject to design specification requirements that are unique to nuclear facilities.
- X Used in applications other than nuclear facilities.
- X Purchased on the basis of specifications set forth in the manufacturer's published product description.

**Basis for Selection of Critical Characteristics for Acceptance:**

Material: Provides assurance that the item material has not changed such that the design basis or the original qualification may become invalid.  
 Dimensions & Configuration: Provides assurance that the item has not changed as to jeopardize its ability to interface with its parent component.  
 Functions: Provides a reasonable assurance that the item will operate within its design parameters.  
 Markings: Provide an indication if the item is not the one purchased for the intended application.

**The selected Acceptance Method, Sampling Plan and/or Notes apply only when invoked.**

**Acceptance Method:**

1. Special Test and Inspections
2. Commercial Grade Survey
3. Source Inspection

**Sampling Plan:**

- A. 100% (All items)
- B1. EOP 3140, Tighten (Table -1)
- B2. EOP 3140, Normal (Table -1)

- B3. EOP 3140, Reduced (Table -1)
- C. One sample per lot (destructive test or disassembly (Note 1) or CGI Survey)
- D. EOP 3140, Normal (Table -2)

**Notes:**

1. Disassembly to access internal parts is not recommended. Lot homogeneity (EOP 3140) and testing of accessible items provide reasonable assurance that internal items materials are correct.
2. Assembly and Functional Test provide reasonable assurance that subcomponents are manufactured correctly and interface dimensions (i.e. connection ports) are correct.
3. Acceptance of commercial CMTR requires PMT, traceability marking on item and CMTR compliance with material specification.
4. Verification of other categories (i.e. material, dimensions, configuration and workmanship) provides reasonable assurance that the item will perform its function.
5. Verification of this critical characteristic is requested by Customer; it is not mandated by the referenced CGI Evaluation.

Rev.	ECO No.	Drawn By/Date	Checked By/Date	Approved By/Date
A	5-21632	<i>[Signature]</i> 12/21/12	<i>[Signature]</i> 12/21/12	<i>[Signature]</i> 12/21/12

For previous revision records see Document Control archive.



**CGI DEDICATION PROCEDURE**

**Description:** Casting, Diffuser

**Production Order No.** 119185 - (Lot# 40316)

**Design Function:** Maintain disc shaft and spring in proper position and orientation for correct operation.  
**Safety Function:** Same as design function.

8/11/12

**Functional Mode (NP-6629):** \_\_\_ Active \_\_\_ Passive \_\_\_ Not Applicable

**Reference CGI Evaluation:** MA22004 - Non-Pressure Retaining Valve Parts

**Qualifications:**

- Environmentally qualified per \_\_\_ X \_\_\_ Environmental qualification does not apply.
- Seismically qualified per \_\_\_ X \_\_\_ Seismic qualification does not apply.
- Original Qualifications are maintained by compliance to the original design/drawing requirements.

**Eligibility of Commercial Grade item:**

- Not subject to design specification requirements that are unique to nuclear facilities.
- Used in applications other than nuclear facilities.
- Purchased on the basis of specifications set forth in the manufacturer's published product description.

**Basis for Selection of Critical Characteristics for Acceptance:**

**Material:** Provides assurance that the item material has not changed such that the design basis or the original qualification may become invalid.  
**Dimensions & Configuration:** Provides assurance that the item has not changed as to jeopardize its ability to interface with its parent component.  
**Functions:** Provides a reasonable assurance that the item will operate within its design parameters.  
**Markings:** Provide an indication if the item is not the one purchased for the intended application.

The selected **Acceptance Method, Sampling Plan and/or Notes apply only when invoked.**

**Acceptance Method:**

1. Special Test and Inspections
2. Commercial Grade Survey
3. Source Inspection

**Sampling Plan:**

- A. 100% (All items)
- B1. EOP 3140, Tighten (Table -1)
- B2. EOP 3140, Normal (Table -1)
- B3. EOP 3140, Reduced (Table -1)
- C. One sample per lot (destructive test or disassembly (Note 1) or CGI Survey)
- D. EOP 3140, Normal (Table -2)

**Notes:**

1. Disassembly to access internal parts is not recommended. Lot homogeneity (EOP 3140) and testing of accessible items provide reasonable assurance that internal items materials are correct.
2. Assembly and Functional Test provide reasonable assurance that subcomponents are manufactured correctly and interface dimensions (i.e. connection ports) are correct.
3. Acceptance of commercial CMTR requires PMI, traceability marking on item and CMTR compliance with material specification.
4. Verification of other categories (i.e. material, dimensions, configuration and workmanship) provides reasonable assurance that the item will perform its function.
5. Verification of this critical characteristic is requested by Customer; it is not mandated by the referenced CGI Evaluation.

**LF-CONTROLLED**  
Not Valid for Manufacturing

Released For Manufacturing

Production of Purchased Parts

MA22004 119185

Initial RS Date MAY 18 2011

Rev.	ECO No.	Drawn By/Date	Checked By/Date	Approved By/Date
0	INITIAL RELEASE	T. Riley 5/4/11	R. J. Smith 5/4/11	[Signature] 5/4/11

For previous revision records see Document Control archive.

**ORIGINAL**



**ENERTECH Operating Procedure**

EOP 3140

REV AK

PAGE 1 OF 15

Title PROCEDURE FOR THE DEDICATION OF COMMERCIAL GRADE ITEMS/SERVICES  
 Prepared By L. Beard Date 5-21-93  
 Approved By A. Shelcoviz David J. Powell Date 5/24/93  
 QA Approval J.I. Rosen Date 24 May 93

RECORD OF REVISIONS							
REV	DESCRIPTION	BY	DATE	APP'D	DATE	QA	DATE
Ø							
F							
G							
H							
I							
J							
K							
L							
M							
N							
O							
P							
Q							
R							
S							
T							
U							
V							
W							
Y							
Z							
AA							
AB							
AC							
AD							
AE							
AF							
AG							
AH							
AI							
AJ							
AK	Revise para 4.2, 4.3 and 4.5; 8.3, 8.4.8, 8.4.10, 8.4.12 and 8.11	F.A.	12/21/12	<i>[Signature]</i>	12-21-12	<i>[Signature]</i>	12/24/12

Please refer to original cover sheet in archives for signatures and record of revisions.

Brea, California 92821

**QUALITY ASSURANCE PROGRAM**

TRAINING RECORD			
Written by:	Theresa Ruiz	Date:	12/21/12
Instructor:	Ararat Torosyan	Title:	Director of Operations
Date/Place/Duration:	, Brea Office, Hours		
Name (print or type)	Signature	Department/Title	
Theresa Ruiz		Operations / Engineering Specialist	
Richard Afsharian		Engineering / Project Manager	
Felipe Alvarez		Engineering / Project Manager	
Tsolag Apelian		Project Sales - Valves / Engineer	
Jonathan Arndt		Engineering / Project Engineer	
Alex Capatina		Engineering / Design Engineer	
Viktor Genjoyan		Engineering / Design Engineer	
Frank Goei		Engineering / Design Engineer	
Brandon Hernandez		Engineering / Design Engineer	
Ryan Hill		Engineering / Design Engineer	
Serj Jarkhedian		Engineering / Design Engineer	
Keith Johnson		Engineering / Project Engineer	
Sirak Kalayci		Engineering / Engineering Intern	
Kelvin Kao		Engineering / Project Engineer, Parts	
Guy Levy		Engineering / Project Manager	
Pascal Lim		Engineering / Project Engineer	
Kevin Martin		Engineering / Project Manager	
Robert McCandliss		Engineering / Engineering Intern	
Kennie McCanless		Engineering / Project Manager	
Haykaz Mkrtchyan		Engineering / Principal Analysis Engineer	
Andrew Norris		Engineering / Manufacturing Engineer	
Simon Rantisi		Engineering / Project Engineer	
Joseph Rosca		Engineering / Project Manager	
Marius Rosca		Engineering / Design Engineer	
Carlos Sahagun		Engineering / Project Engineer	
Avi Shelcoviz		Director, Technology, Manufactured Products	
Ira Silverman		Project Sales - Valves / Senior Principal Engineer	
Ben Snodgrass		Engineering / Engineering Intern	
Sonali Vasa		Engineering / Engineer	
Gnoui Yengoian		Project Sales - Pumps / Analysis Engineer	

Lesson Content: (Include document revisions and/or dates, as applicable)  
 Review of CAR 2030  
 Review of CAR 2032, which includes the following:  
 EOP 3140, Rev AK - Dedication of Commercial Grade Items  
 CGI D8740S, Rev A - Casting, Diffuser  
 MA24945, Rev A - CGI Evaluation - Diffuser, Passive N.O. Nozzle Check Valve  
 MA24946, Rev B - CGI Evaluation - Retaining Ring, Passive N.O. Nozzle Check Valve

PATRICK SCHALLER

OPERATIONS / PROJECT MANAGER



# CORRECTIVE ACTION REQUEST

ASME  NON-ASME

CAR # 2033 Date Issued: Nov. 5, 2012

Originated By: John DeKleine Internal / External : Internal  
Title: Director Quality Assurance

Responsible Department: Design Engineering/Equipment Qualification

Program/Regulatory Reference: NRC Routine Vendor Inspection reference Docket number 99901377, Report number 2012-201 Nonconformance -03. Procedure MA22989 rev B dated 4/30/12 states, in part, that " the purpose of this procedure ..is to successfully qualify the valve per ASME QME-1-2007 section QV-7500". Section QV-2000 states that " the purpose of section QV is ...to demonstrate performance under **all** specified operating and design basis conditions.

Description of Deficiency: Contrary to the above, during the NRC Inspection Enertech failed to establish a test program to ensure that it had identified **all** tests necessary to demonstrate that the valve will perform satisfactorily in service. Specifically Enertech's test program did not identify and perform qualification testing to demonstrate operability under all QME-1(2007Edition) specified operating and design basis conditions.

Recommendations:

- 1.

Response Due: 11/30/12

**This section is to be completed by the referenced Department Manager/Supplier Representative only. You are hereby requested to investigate the above described condition and identify the cause, the fix, and the corrective action taken to preclude recurrence. Please complete this section of the form, or an attachment addressing the concern, and return by the specified Response Due Date.**

Cause & Extent of Noted Deficiency: Enertech's test program and procedure MA22989 initially have not included high pressure impact test because we assumed (with concurrence from customer (WEC) system designer) that the other tests (flow test at low pressure and high pressure with no flow) in the procedure already enveloped all operating and design basis conditions per QME-1.

While this gap was identified during NRC meeting on 4/4/12 prior to testing, it was premature for Enertech to add the additional test to the procedure because the detailed where under review by the customer. The extent of this unique deficiency is limited to this valve only.

[Redacted]


[Redacted]

[Redacted]

[Redacted]

# CORRECTIVE ACTION REQUEST

2033

Corrective/Remedial Action to Correct the Deficiency:	Following receipt of WEC new PO on 10/4/12, revise procedure MA22989 to include high pressure impact test of the valve.	
Corrective/Preventative Action to Preclude a Reoccurrence	Provide training: 1. To qualification and project engineers to ensure written procedure reflects current customer requirements.	
Proposed Completion Date:	12/31/12	
Responding Person's Signature/Title		Date: 11/29/12

Date CAR Response Received in Enertech QA Department: 11-29-12

QA Evaluation & Approval of Response:  Date: 11/29/12

Enertech's Verification of Corrective Action Taken:

Method of Verification     Re-Audit         Administrative Review of Objective Evidence

Summary of Verification:  
  
Verified records    completed training    per attached training records






Verification Date: 12/27/12    By: Jud H. Gray    Title: VP-OPEX

Enertech Management Review for 10CFR Part 21 Applicability:     - Applicable;     - Not Applicable

Review performed By: Jud H. Gray

Results of Verification:  
  
 Satisfactory    [ ] Incomplete    [ ] Unsatisfactory\*  
[ ] Remains Open     Closed (\* Additional Action Required)

Closed Date: 12-27-12    By: Jud H. Gray    Title: VP-OPEX

 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

THE DATA PROVIDED HEREIN IS PROPRIETARY DATA AND IS THE PROPERTY OF ENERTECH, A BUSINESS UNIT OF CURTISS-WRIGHT FLOW CONTROL COMPANY. THIS DATA SHALL NOT BE DISCLOSED IN WHOLE OR IN PART FOR ANY PURPOSE OTHER THAN FOR EVALUATION BY THE RECIPIENT, HIS EMPLOYEES OR HIS CLIENTS. THE RECIPIENT SHALL HAVE THE RIGHT TO DUPLICATE, USE OR DISCLOSE THIS DATA FOR THE SOLE PURPOSE OF CORRESPONDING WITH ENERTECH. ANY OTHER USE IS STRICTLY PROHIBITED WITHOUT THE PRIOR WRITTEN CONSENT OF ENERTECH.



2950 Birch Street, Brea, CA 92821 U.S.A.  
Phone: 714.528.2301 Fax: 714.528.0128

CUSTOMER  
WESTINGHOUSE

REV.  
C

DRAWING NUMBER  
MA 22874

Page 1 of 8

**EQUIPMENT QUALIFICATION PLAN  
FOR ENERTECH 8 INCH ANSI CLASS 1707  
TYPE ERV-Z N.O. NOZZLE CHECK VALVE**

**EQUIPMENT QUALIFICATION PLAN  
FOR  
ENERTECH 8 INCH ANSI CLASS 1707  
TYPE ERV-Z  
N.O. NOZZLE CHECK VALVE  
PREPARED FOR**

**WESTINGHOUSE ELECTRIC COMPANY, LLC  
PURCHASE ORDER 4500322510  
ENERTECH PROJECT 960029**

Haykaz Mkrtchyan  
Prepared by:

1/15/10  
Date

Avi Shelcoviz  
Checked by:

1/15/10  
Date

Patrick Schaller  
Approved by:

1/15/10  
Date

**ORIGINAL**

THE DATA PROVIDED HEREIN IS PROPRIETARY DATA AND IS THE PROPERTY OF ENERTECH, A BUSINESS UNIT OF CURTISS-WRIGHT FLOW CONTROL COMPANY. THIS DATA SHALL NOT BE DISCLOSED IN WHOLE OR IN PART FOR ANY PURPOSE OTHER THAN FOR EVALUATION BY THE RECIPIENT, HIS EMPLOYEES OR HIS CLIENTS. THE RECIPIENT SHALL HAVE THE RIGHT TO DUPLICATE, USE OR DISCLOSE THIS DATA FOR THE SOLE PURPOSE OF CORRESPONDING WITH ENERTECH. ANY OTHER USE IS STRICTLY PROHIBITED WITHOUT THE PRIOR WRITTEN CONSENT OF ENERTECH.



2950 Birch Street, Brea, CA 92821 U.S.A.  
 Phone: 714.528.2301 Fax: 714.528.0128

CUSTOMER  
**WESTINGHOUSE**

REV.  
**C**

DRAWING NUMBER  
**MA 22874**

Page 2 of 8

**EQUIPMENT QUALIFICATION PLAN  
 FOR ENERTECH 8 INCH ANSI CLASS 1707  
 TYPE ERV-Z N.O. NOZZLE CHECK VALVE**

**RECORD OF REVISION**

REV LEVEL	ECO NO.	PREPARED BY	DATE	CHECKED BY	DATE	APPROVED BY	DATE
A	5-21131	H. Mkrtchyan	8/9/12	P. Schaller	8/9/12	P. Schaller	8/9/12
B	5-21200	H. Mkrtchyan	8/30/12	I. Silverman	8/30/12	A. Torosyan	8/30/12
C	5-21836	<i>Haykaz M</i>	<i>08/11/12</i>	<i>[Signature]</i>	<i>12/11/12</i>	<i>[Signature]</i>	<i>12/11/12</i>

ORIGINAL

THE DATA PROVIDED HEREIN IS PROPRIETARY DATA AND IS THE PROPERTY OF ENERTECH, A BUSINESS UNIT OF CURTISS-WRIGHT FLOW CONTROL COMPANY. THIS DATA SHALL NOT BE DISCLOSED IN WHOLE OR IN PART FOR ANY PURPOSE OTHER THAN FOR EVALUATION BY THE RECIPIENT, HIS EMPLOYEES OR HIS CLIENTS. THE RECIPIENT SHALL HAVE THE RIGHT TO DUPLICATE, USE OR DISCLOSE THIS DATA FOR THE SOLE PURPOSE OF CORRESPONDING WITH ENERTECH. ANY OTHER USE IS STRICTLY PROHIBITED WITHOUT THE PRIOR WRITTEN CONSENT OF ENERTECH.



2950 Birch Street, Brea, CA 92821 U.S.A.  
Phone: 714.528.2301 Fax: 714.528.0128

CUSTOMER  
**WESTINGHOUSE**

REV.  
**0**

DRAWING NUMBER  
**MAA22989**

Page 1 of 8

**ADDENDUM TO EQUIPMENT  
QUALIFICATION PROCEDURE  
FOR ENERTECH 8"- CLASS 1707 ERV-Z  
NOZZLE CHECK VALVE**

**ADDENDUM TO THE EQUIPMENT QUALIFICATION PROCEDURE**

**FOR**

**ENERTECH 8"- CLASS 1707**

**TYPE ERV-Z**


**NOZZLE CHECK VALVE**


**PREPARED FOR**


**WESTINGHOUSE ELECTRIC COMPANY, LLC**

**PURCHASE ORDER 4500450302**


**ENERTECH PROJECT 960029**


  
Prepared by: \_\_\_\_\_

  
Date \_\_\_\_\_

  
Checked by: \_\_\_\_\_

  
Date \_\_\_\_\_

  
Approved by: \_\_\_\_\_

  
Date \_\_\_\_\_

**ORIGINAL**



Brea, California 92821

QUALITY ASSURANCE PROGRAM

TRAINING RECORD

Written by: John DeKleine

Date: 11/29/12

Instructor: Avi Shelcoviz

Title: Director of Technology

Date/Place/Duration: 12/26/12 , Brea Office, 1 Hour

Name (print or type)	Signature	Department/Title
Markus Metcher		Sales/Technology
Fred Swanson		Sales/Technology
Joseph Pelin		Sales/Technology
GNOU NI YENGOIAN		Sales/Technology

Lesson Content: (Include document revisions and/or dates, as applicable)

CAR 2033  
 NRC NON 99901377 2012-201-03  
 QME-1 Test Plan requirements review  
 Scheduling Customers for witness activities

Brea, California 92821

#### QUALITY ASSURANCE PROGRAM

### TRAINING RECORD

Written by: John DeKleine	Date: 11/29/12
Instructor: Ed Buzby/John DeKleine	Title: Contracts Manager/Director QA
Date/Place/Duration: 12/27/12 , Brea Office, 1/2 Hours	

Name (print or type)	Signature	Department/Title
DENNIS GELBMAN	<i>[Signature]</i>	QUALITY / QAE
Nareg Mekhitarian	<i>[Signature]</i>	Asst. QAE
DAVID E. WHITAKER	<i>[Signature]</i>	QA/QAE
LORETTA ANAYA	<i>[Signature]</i>	QA/QAE

Lesson Content: (Include document revisions and/or dates, as applicable)

Enertech CAR 2033  
NRC NON# 99901377-2012-201—03

Scheduling of Customer witness testing

# CORRECTIVE ACTION REQUEST

ASME  NON-ASME

CAR # 2034 Date Issued: 11/5/12

Originated By: John DeKleine Internal / External : Internal  
Title: Director Quality Assurance

Responsible Department: Design Engineering / Technology

Program/Regulatory Reference: Criterion III, "Design Control," of Appendix B, "Quality Assurance Program Criteria for Nuclear Power Plants and Fuel Reprocessing Plants," to Title 10 of the Code of Federal Regulations (10 CFR) Part 50, "Domestic Licensing of Production and Utilization Facilities," states, in part, that "measures shall also be established for the selection and review for suitability of application of materials, parts, equipment, and processes that are essential to the safety-related functions of the structures, systems, and components."

Description of Deficiency: Enertech failed to review for suitability of application materials, systems, and components. Specifically, Enertech did not perform the following:  
The commercial grade survey performed by Enertech at USU did not verify the calibration quality of the instruments used during the American Society of Mechanical Engineers (ASME) QME-1 functional flow tests to identify and record safety-related test data. These instruments [REDACTED] which were commercially calibrated and accepted by USU and Enertech without verification of the calibration suppliers.

Recommendations:  
1.

Response Due: 11/30/12

**This section is to be completed by the referenced Department Manager/Supplier Representative only. You are hereby requested to investigate the above described condition and identify the cause, the fix, and the corrective action taken to preclude recurrence. Please complete this section of the form, or an attachment addressing the concern, and return by the specified Response Due Date.**

Cause & Extent of Noted Deficiency: Our Technical Evaluation to support the Dedication of Testing Services does not adequately document establishing reasonable assurance the calibration quality characteristic.

Corrective/Remedial Action to Correct the Deficiency: Revise the Technical Evaluation for Testing Services to document how reasonable assurance is established. Further regarding the subject current testing, Enertech confirmed satisfactory accuracy of the M&TE used during USU testing by Enertech post-test accuracy verification.

Corrective/Preventative Action to Preclude a Reoccurrence: Revised EOP 8185 to require the Enertech Survey Team when evaluating a commercial grade supplier using calibration controls as an EPRI Method 2 acceptance credit to determine the supplier has appropriate controls when subcontracting calibration, or in-house calibration procedures are implemented that is surveyed and accepted by Enertech Survey Team.

Proposed Completion Date: 12/31/12

Responding Person's Signature/Title: *[Signature]* Director Technology Date: 11/30/12

Date CAR Response Received in Enertech QA Department: 11-30-12

QA Evaluation & Approval of Response: *[Signature]* Date: 11-30-12



# CORRECTIVE ACTION REQUEST

2034

Enertech's Verification of Corrective Action Taken:

Method of Verification     Re-Audit         Administrative Review of Objective Evidence

Summary of Verification:

Reviewed revision to EOP 8185, calibration  
verification ~~total~~ records + training records.

Verification Date: 12-27-12    By: And L. Guy    Title: VP-OPEX

Enertech Management Review for 10CFR Part 21 Applicability:    - Applicable;        - Not Applicable

Review performed By: And L. Guy

Results of Verification:

Satisfactory    [ ] Incomplete        [ ] Unsatisfactory\*  
[ ] Remains Open     Closed (\* Additional Action Required)

Closed Date: 12-27-12    By: And L. Guy    Title: VP-OPEX

[REDACTED]

[REDACTED]

[REDACTED] \_\_\_\_\_

[REDACTED] \_\_\_\_\_

[REDACTED] \_\_\_\_\_

[REDACTED] \_\_\_\_\_

[REDACTED] \_\_\_\_\_

[REDACTED] \_\_\_\_\_

[REDACTED]

THE DATA PROVIDED HEREIN IS PROPRIETARY DATA AND IS THE PROPERTY OF ENERTECH, A BUSINESS UNIT OF CURTISS-WRIGHT FLOW CONTROL COMPANY. THIS DATA SHALL NOT BE DISCLOSED IN WHOLE OR IN PART FOR ANY PURPOSE OTHER THAN FOR EVALUATION BY THE RECIPIENT, HIS EMPLOYEES OR HIS CLIENTS. THE RECIPIENT SHALL HAVE THE RIGHT TO DUPLICATE, USE OR DISCLOSE THIS DATA FOR THE SOLE PURPOSE OF CORRESPONDING WITH ENERTECH. ANY OTHER USE IS STRICTLY PROHIBITED WITHOUT THE PRIOR WRITTEN CONSENT OF ENERTECH.



2950 Birch Street, Brea, CA 92821 U.S.A.  
 Phone: 714.528.2301 Fax: 714.528.0128

CUSTOMER  
**STANDARD**

REV.  
**A**

DRAWING NUMBER  
**MA24560**

Page 2 of 10

**CGS EVALUATION – PERFORMANCE TESTING SERVICES**

**RECORD OF REVISION**

REV. LEVEL	ECO NO.	PREPARED BY	DATE	CHECKED BY	DATE	APPROVED BY	DATE
A	5-21687	<i>[Signature]</i>	12/26/12	<i>[Signature]</i>	12/26/12	<i>[Signature]</i>	12/27/12

The purpose of this document in its current form is to provide Enertech personnel with a reference guideline for writing CGS Dedication Procedures for testing services. This document is intended to enable Enertech to efficiently utilize its capability in conducting the CGS dedication procedure.

**ORIGINAL**

**TO: Enertech Engineering**

**FROM:** [REDACTED]


**SUBJECT: Calibration Verification**

**DATE: 12/27/12**

In an effort to ensure that test results obtained from Utah Water Research Lab (UTWRL) are acceptable for Enertech's normally open nozzle check valve performance verification under the simulated flow conditions, Enertech has performed verification of calibration on the following test instruments:

1. Fluke Digital Multimeter (FMD) Model 87, ID: 2105 XMTR
2. Fluke Digital Multimeter (FMD) Model 87, ID: 3039 XMTR
3. Rosemount Pressure Transmitter Model 3051S1CD3AE12A1AB4M5Q4, S/N: 0312105
4. Rosemount Pressure Transmitter Model 3051S1CD3AE12A1AB4M5Q4, S/N: 0353039

Enertech engineering has reviewed the Inspection and Verification reports of these instruments, more specifically, the maximum full scale errors in the measurements, and found them to be acceptable based on the measured values and customer specified flow performance requirements.



**INSPECTION & VERIFICATION REPORT, REV. 0**

**DATE:** 10/16/2012

**RECEIVE / INSPECTION:**

[REDACTED] The FDM looked to be in good condition and no shipping damage was noted.

**SCOPE OF WORK:**

The FDM was received to verify the displayed signal values/readings of the FDM under Enertech's Quality Assurance program.

**VERIFICATION:**

[REDACTED]

**CONCLUSION:**

The result of the verification showed that the FDM passed successfully by being within the specified/published manufacturer tolerances of the full-scale reading.



Marius Rosca  
Calibration Technician

10/16/2012

Date

**INSPECTION & VERIFICATION REPORT, REV. 0**

**DATE:** 10/16/2012

**RECEIVE / INSPECTION:**

[REDACTED] The FDM looked to be in good condition and no shipping damage was noted.

**SCOPE OF WORK:**


The FDM was received to verify the displayed signal values/readings of the FDM under Enertech's Quality Assurance program.

**VERIFICATION:**

[REDACTED]

**CONCLUSION:**

The result of the verification showed that the FDM passed successfully by being within the specified/published manufacturer tolerances of the full-scale reading.



Marius Rosca  
Calibration Technician

10/16/2012

Date

**INSPECTION & VERIFICATION REPORT, REV. 0**

[REDACTED]

**DATE:** 10/16/2012

**RECEIVE / INSPECTION:**

[REDACTED] The RPT looked to be in good condition and no shipping damage was noted.

**SCOPE OF WORK:**

The RPT was received to verify the pressure values/readings of the RPT under Enertech's Quality Assurance program.

**VERIFICATION:**

[REDACTED]

**CONCLUSION:**

The result of the verification showed that the RPT was showing a maximum instrument full-scale error of 0.00%. For further detail in regard to the test result, reference the test results data sheet.

Enertech's QA Manual requires that any instrument used as a standard for testing should be four (4) times more accurate than the instrument under test (four to one accuracy ratio). With the instrument standard used for this test, Enertech is able to certify the RPT to a 0.25% full-scale error.

  
\_\_\_\_\_  
Marius Rosca  
Calibration Technician

10/16/2012  
\_\_\_\_\_  
Date

**INSPECTION & VERIFICATION REPORT, REV. 0**

**DATE:** 10/16/2012

**RECEIVE / INSPECTION:**

[REDACTED] The RPT looked to be in good condition and no shipping damage was noted.

**SCOPE OF WORK:**


The RPT was received to verify the pressure values/readings of the RPT under Enertech's Quality Assurance (QA) program.

**VERIFICATION:**

**CONCLUSION:**

The result of the verification showed that the RPT was showing a maximum instrument full-scale error of 0.92%. For further detail in regard to the test result, reference the test results data sheet.

Enertech's QA Manual requires that any instrument used as a standard for testing should be four (4) times more accurate than the instrument under test (four to one accuracy ratio). With the instrument standard used for this test, Enertech is able to certify the RPT to a 1.00% full-scale error.

  
\_\_\_\_\_  
Marius Rosca  
Calibration Technician

10/16/2012  
\_\_\_\_\_  
Date







# ENERTECH Operating Procedure

EOP	8185	REV	I	PAGE 1 OF 7
-----	------	-----	---	-------------

Title PROCEDURE FOR COMMERCIAL GRADE SURVEY

Prepared By John DeKleine Date May 26, 2005

Approved By Herbert Ellsworth Date May 27, 2005

QA Approval John DeKleine Date May 27, 2005

RECORD OF REVISIONS							
REV	DESCRIPTION	BY	DATE	APP'D	DATE	QA	DATE
Ø	Please refer to original cover sheet in archives for signatures and record of revisions.						
A							
B							
C							
D							
E							
F							
G							
H							
I	Added new par: 7.3.1.7.5. Revised par.: 7.4.3		11/15/12		11/15/12		11/19/12