



**KHNP**

**KOREA HYDRO & NUCLEAR POWER CO., LTD**

70-1312-gil, Yuseong-daero, Yuseong-gu, Daejeon, 305-343, KOREA

Tel: +82-42-870-5740 / Fax: +82-42-870-5779

<http://www.khnp.co.kr>

July 22, 2016  
Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attention: Mr. Jeff Ciocco  
Division of New Reactor Licensing

Docket No. 52-046  
MKD/NW-16-0800L

**Subject: Revised Response to RAI 117-8061 for the Question 03.05.01.01-4**

**References: 1) NRC Request for Additional Information 117-8061, dated July 27, 2015**  
**2) KHNP Letter MKD/NW-15-0268L, Response to 117-8061, dated January 29, 2016**

KHNP is hereby submitting the response to RAI 117-8061, dated July 27, 2015. The RAI revised response addresses Question 03.05.01.01-4 to specifically state that ASME Section III vessels are not sources of internal missiles. The enclosure provides the revised response to RAI 117-8061 for the Question 03.05.01.01-4 (Non-Proprietary).

If additional information or clarification is required, please contact Daegeun Ahn, Director of KHNP Washington DC Center at [ahn.daegeun@khnp.co.kr](mailto:ahn.daegeun@khnp.co.kr) or 703-388-0592.

Sincerely,

A handwritten signature in black ink that reads "Jae-yong Lee".

---

Jae-yong Lee  
Project Manager  
Advanced Reactors Development Laboratory  
Korea Hydro and Nuclear Power Co., Ltd

Enclosure: Revised Response to RAI 117-8061 for the Question 03.05.01.01-4 (Non-Proprietary)

**Enclosure**

Revised Response to RAI 117-8061 for the Question 03.05.01.01-4

(Non-Proprietary)

July 22, 2016