



July 21, 2016

NG-16-0146  
10 CFR 2.201

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Duane Arnold Energy Center  
Docket No. 50-331  
Renewed Op. License No. DPR-49

**NextEra Energy Duane Arnold, LLC Completion of Corrective Actions for  
Notice of Violation; VIO 05000331/2014010-01**

- References:
- 1) NRC letter, Duane Arnold Energy Center – NRC Follow-up Inspection Report 05000331/2014010 and Notice of Violation, dated September 19, 2014 (ML14266A423)
  - 2) Letter, Vehec (NextEra) to NRC, "NextEra Energy Duane Arnold, LLC Reply to Notice of Violation: VIO 05000331/2014010-01," NG-14-0235, dated October 20, 2014

In Reference 1, the Nuclear Regulatory Commission (NRC) issued Notice of Violation VIO 05000331/2014010-01 to NextEra Energy Duane Arnold, LLC (hereafter NextEra Energy Duane Arnold). Pursuant to the provisions of 10 CFR 2.201, Reference 2 provided NextEra Energy Duane Arnold's reply to Notice of Violation VIO 05000331/2014010-01.

The purpose of this letter is to inform you that NextEra Energy Duane Arnold has completed the corrective actions committed to in Reference 2. Specifically, this letter documents the completion of the following:

- NextEra Energy Duane Arnold has completed installation of seamless plastic inner conduits and replacement cables as described in the Enclosure to Reference 2. This corrective action has returned the nine conduits discussed in the NOV to the designed, dry condition.

*IEDI  
NRR*

Document Control Desk

NG-16-0146

Page 2 of 2

- NextEra Energy Duane Arnold has achieved full compliance for the nine conduits cited in Notice of Violation VIO 05000331/2014010-01.

If you have any questions, please contact J. Michael Davis at (319) 851-7032.



T. A. Vehec

Vice President, Duane Arnold Energy Center

NextEra Energy Duane Arnold, LLC

cc: Administrator, Region III, USNRC  
Project Manager, DAEC, USNRC  
Senior Resident Inspector, DAEC, USNRC