

GO2-16-104
Enclosure 1, Attachment 3

Emergency Action Level (EAL) Classification Matrix (Wallcharts)

(For information only)

GENERAL EMERGENCY

SITE AREA EMERGENCY

ALERT

UNUSUAL EVENT

Release of gaseous radioactivity resulting in offsite dose greater than 1,000 mrem TEDE or 5,000 mrem thyroid CDE

Release of gaseous radioactivity resulting in offsite dose greater than 100 mrem TEDE or 500 mrem thyroid CDE

Release of gaseous or liquid radioactivity resulting in offsite dose greater than 10 mrem TEDE or 50 mrem thyroid CDE

Release of gaseous or liquid radioactivity greater than 2 times the ODCM limits for 60 minutes or longer

RG1.1 [1 2 3 4 5 DEF]

(1) Reading on any Table 3 effluent radiation monitor GT column "GE" for GE 15 min.
OR
(2) Dose assessment using actual meteorology indicates doses GT 1,000 mrem TEDE or GT 5000 mrem thyroid CDE at or beyond the SITE BOUNDARY
(Notes 1, 2, 3, 4)

RG1.2 [1 2 3 4 5 DEF]

Field survey results indicate EITHER of the following at or beyond the SITE BOUNDARY:

- Closed window dose rates GT 1,000 mR/hr expected to continue for GE 60 min.
- Analyses of field survey samples indicate thyroid CDE GT 5,000 mrem for 60 min. of inhalation.

RS1.1 [1 2 3 4 5 DEF]

(1) Reading on any Table 3 effluent radiation monitor GT column "SAE" for GE 15 min.
OR
(2) Dose assessment using actual meteorology indicates doses GT 100 mrem TEDE or GT 500 mrem thyroid CDE at or beyond the SITE BOUNDARY
(Notes 1, 2, 3, 4)

RS1.2 [1 2 3 4 5 DEF]

Field survey results indicate EITHER of the following at or beyond the SITE BOUNDARY:

- Closed window dose rates GT 100 mR/hr expected to continue for GE 60 min.
- Analyses of field survey samples indicate thyroid CDE GT 500 mrem for 60 min. of inhalation.

RA1.1 [1 2 3 4 5 DEF]

(1) Reading on any Table 3 effluent radiation monitor GT column "ALERT" for GE 15 min.
OR
(2) Dose assessment using actual meteorology indicates doses GT 10 mrem TEDE or GT 50 mrem thyroid CDE at or beyond the SITE BOUNDARY
(Notes 1, 2, 3, 4)

RA1.2 [1 2 3 4 5 DEF]

Analysis of a liquid effluent sample indicates a concentration or release rate that would result in doses GT 10 mrem TEDE or GT 50 mrem thyroid CDE at or beyond the SITE BOUNDARY for 60 min. of exposure (Notes 1, 2)

RA1.3 [1 2 3 4 5 DEF]

Field survey results indicate EITHER of the following at or beyond the SITE BOUNDARY:

- Closed window dose rates GT 10 mR/hr expected to continue for GE 60 min.
- Analyses of field survey samples indicate thyroid CDE GT 50 mrem for 60 min. of inhalation.

RU1.1 [1 2 3 4 5 DEF]

(1) Reading on any Table 3 effluent radiation monitor GT column "UE" for GE 60 min.
OR
(2) Sample analyses for a gaseous or liquid release indicates a concentration or release rate > 2 x ODCM limits for GE 60 min.
(Notes 1, 2, 3)

Spent fuel pool level cannot be restored to at least the top of the fuel racks for 60 minutes or longer

RG2.1 [1 2 3 4 5 DEF]

Spent fuel pool level cannot be restored to at least 0.5 ft for GE 60 min. (Note 1)

Spent fuel pool level at the top of the fuel racks

RS2.1 [1 2 3 4 5 DEF]

Lowering of spent fuel pool level to 0.5 ft

Significant lowering of water level above, or damage to, irradiated fuel

RA2.1 [1 2 3 4 5 DEF]

Uncovery of irradiated fuel in the REFUELING PATHWAY

RA2.2 [1 2 3 4 5 DEF]

Damage to irradiated fuel resulting in a release of radioactivity
AND
High alarm on any of the following radiation monitors:

- ARM-RIS-1 Reactor Building Fuel Pool Area
- ARM-RIS-2 Reactor Building Fuel Pool Area
- ARM-RIS-34 Reactor Building Elevation 606
- REA-RIS-609A-D Rx Bldg Vent

RA2.3 [1 2 3 4 5 DEF]

Lowering of spent fuel pool level to 10 ft

Unplanned loss of water level above irradiated fuel

RU2.1 [1 2 3 4 5 DEF]

UNPLANNED water level drop in the REFUELING PATHWAY as indicated by EITHER of the following:

- SFP level LE 22.3 ft
- SFP low level alarm

AND

UNPLANNED rise in area radiation levels as indicated by any of the following radiation monitors:

- ARM-RIS-1 Reactor Building Fuel Pool Area
- ARM-RIS-2 Reactor Building Fuel Pool Area
- ARM-RIS-34 Reactor Building Elevation 606

| Release Point | Monitor | GE | SAE | Alert | UE |
|---------------------------|---------------|-----------------|-----------------|-----------------|-----------------|
| Reactor Building Exhaust | PRM-RE-1B (I) | ---- | ---- | ---- | 6.00E+03 cps |
| | PRM-RE-1C (H) | 2.00E+04 cps | 2.00E+03 cps | 4.00E+02 cps | ---- |
| Turbine Building Exhaust | TEA-RIS-13 | 8.35E-02 µCi/cc | 8.35E-03 µCi/cc | 8.35E-04 µCi/cc | 1.02E-04 µCi/cc |
| Radwaste Building Exhaust | WEA-RIS-14 | 3.45E-01 µCi/cc | 3.45E-02 µCi/cc | 3.45E-03 µCi/cc | 1.98E-03 µCi/cc |
| Radwaste Effluent | FDR-RIS-606 | ---- | ---- | ---- | 2 X HI-HI alarm |
| TSW Effluent | TSW-RIS-5 | ---- | ---- | ---- | 3.00E-05 µCi/cc |
| Service Water Process A | SW-RIS-604 | ---- | ---- | ---- | 1.00E+02 cps |
| Service Water Process B | SW-RIS-605 | ---- | ---- | ---- | 1.00E+02 cps |

| Room/Area | Modes Applicability |
|--|---------------------|
| RW 467 Radwaste Control Room (RHR flush to RW tanks) | 3 |
| RW 467 Vital Island (RHR-V-9 disconnect) | 3 |
| RB 422 B RHR Pump Rm (local pump temperatures) | 3 |
| RB 454 B RHR Pump Rm (operate RHR-V-85B) | 3 |

None

Radiation levels that IMPEDE access to equipment necessary for normal plant operations, cooldown or shutdown

RA3.1 [1 2 3 4 5 DEF]

(1) Dose rates GT 15 mR/hr in Control Room (ARM-RIS-19) or CAS (by survey)
OR
(2) An UNPLANNED event results in radiation levels that prohibit or IMPEDE access to any Table 9 rooms or areas (Note 5)

Damage to a loaded cask CONFINEMENT BOUNDARY

EU1.1 [Storage Operations]

Damage to a loaded canister (MPC) CONFINEMENT BOUNDARY as indicated by measured dose rates on a loaded overpack GT EITHER:

- 20 mrem/hr (gamma + neutron) on the top of the overpack
- 100 mrem/hr (gamma + neutron) on the side of the overpack, excluding inlet and outlet ducts

None

HOSTILE ACTION within the PROTECTED AREA

HS1.1 [1 2 3 4 5 DEF]

A HOSTILE ACTION is occurring or has occurred within the PROTECTED AREA as reported by the Security Sergeant or Security Lieutenant

HOSTILE ACTION within the OWNER CONTROLLED AREA or airborne attack threat within 30 minutes

HA1.1 [1 2 3 4 5 DEF]

(1) A HOSTILE ACTION is occurring or has occurred within the OWNER CONTROLLED AREA as reported by the Security Sergeant or Security Lieutenant
OR
(2) A validated notification from NRC of an aircraft attack threat within 30 min. of the site

Confirmed SECURITY CONDITION or threat

HU1.1 [1 2 3 4 5 DEF]

(1) A SECURITY CONDITION that does not involve a HOSTILE ACTION as reported by the Security Sergeant or Security Lieutenant
OR
(2) Notification of a credible security threat directed at the site
OR
(3) A validated notification from the NRC providing information of an aircraft threat

None

None

[See CA6.1/MA8.1 for potential for upgrade to an Alert based on degraded safety system performance or damage]

Seismic event GT OBE levels

HU2.1 [1 2 3 4 5 DEF]

Seismic event GT Operating Basis Earthquake (OBE) as indicated by H13.P851.S1.5-1 (OPERATING BASIS EARTHQUAKE EXCEEDED) activated

Notes

- The Emergency Director should declare the event promptly upon determining that time limit has been exceeded, or will likely be exceeded
- If an ongoing release is detected and the release start time is unknown, assume that the release duration has exceeded the specified time limit
- If the effluent flow past an effluent monitor is known to have stopped, indicating that the release path is isolated, the effluent monitor reading is no longer VALID for classification purposes
- The pre-calculated effluent monitor values presented in EALs RA1.1, RS1.1 and RG1.1 should be used for emergency classification assessments until the results from a dose assessment using actual meteorology are available
- If the equipment in the listed room or area was already inoperable or out-of-service before the event occurred, then no emergency classification is warranted
- If CONTAINMENT CLOSURE is re-established prior to exceeding the 30-minute time limit, declaration of a General Emergency is **not** required
- This EAL does not apply to routine traffic impediments such as fog, snow, ice, or vehicle breakdowns or accidents
- A manual scram action is any operator action, or set of actions, which causes the control rods to be rapidly inserted into the core, and does **not** include manually driving in control rods or implementation of boron injection strategies

None

[See CA6.1/MA8.1 for potential for upgrade to an Alert based on degraded safety system performance or damage]

Hazardous event

HU3.1 [1 2 3 4 5 DEF]

(1) A tornado strike within the PROTECTED AREA
OR
(2) Volcanic ash fallout requiring plant shutdown

HU3.2 [1 2 3 4 5 DEF]

Internal room or area FLOODING of a magnitude sufficient to require manual or automatic electrical isolation of a SAFETY SYSTEM component needed for the current operating mode

HU3.3 [1 2 3 4 5 DEF]

(1) Movement of personnel within the PROTECTED AREA is IMPEDED due to an offsite event involving hazardous materials (e.g., an offsite chemical spill, 618-11 event or toxic gas release)
OR
(2) A hazardous event that results in on-site conditions sufficient to prohibit the plant staff from accessing the site via personal vehicles (Note 7)

None

None

[See CA6.1/MA8.1 for potential for upgrade to an Alert based on degraded safety system performance or damage]

FIRE potentially degrading the level of safety of the plant

HU4.1 [1 2 3 4 5 DEF]

A FIRE is not extinguished within 15 min. of any of the following FIRE detection indications (Note 1):

- Report from the field (i.e., visual observation)
- Receipt of multiple (more than 1) fire alarms or indications
- Field verification of a single fire alarm

AND

The FIRE is located within any Table 5 area

HU4.2 [1 2 3 4 5 DEF]

Receipt of a single fire alarm (i.e., no other indications of a FIRE)
AND
The fire alarm is indicating a FIRE within any Table 5 area
AND
The existence of a FIRE is not verified within 30 min. of alarm receipt (Note 1)

HU4.3 [1 2 3 4 5 DEF]

(1) A FIRE within the ISFSI or plant PROTECTED AREA not extinguished within 60 min. of the initial report, alarm or indication (Note 1)
OR
(2) A FIRE within the ISFSI or plant PROTECTED AREA that requires firefighting support by an offsite fire response agency to extinguish

None

None

Gaseous release IMPEDING access to equipment necessary for normal plant operations, cooldown or shutdown

HA5.1 [1 2 3 4 5 DEF]

Release of a toxic, corrosive, asphyxiant or flammable gas into any Table 9 rooms or areas
AND
Entry into the room or area is prohibited or IMPEDED (Note 5)

Control Room evacuation resulting in transfer of plant control to alternate locations

HA6.1 [1 2 3 4 5 DEF]

An event has resulted in plant control being transferred from the Control Room to the Remote Shutdown Panel or Alternate Remote Shutdown Panel

None

Other conditions existing which in the judgment of the Emergency Director warrant declaration of General Emergency

HG7.1 [1 2 3 4 5 DEF]

Other conditions exist which, in the judgment of the Emergency Director, indicate that events are in progress or have occurred which involve actual or IMMINENT substantial core degradation or melting with potential for loss of containment integrity or HOSTILE ACTION that results in an actual loss of physical control of the facility. Releases can be reasonably expected to exceed EPA Protective Action Guideline exposure levels offsite for more than the immediate site area.

Other conditions existing which in the judgment of the Emergency Director warrant declaration of Site Area Emergency

HS7.1 [1 2 3 4 5 DEF]

Other conditions exist which, in the judgment of the Emergency Director, indicate that events are in progress or have occurred which involve actual or likely major failures of plant functions needed for protection of the public or HOSTILE ACTION that results in intentional damage or malicious acts, (1) toward site personnel or equipment that could lead to the likely failure of or, (2) that prevent effective access to equipment needed for the protection of the public. Any releases are not expected to result in exposure levels which exceed EPA Protective Action Guideline exposure levels beyond the SITE BOUNDARY.

Other conditions existing which in the judgment of the Emergency Director warrant declaration of an Alert

HA7.1 [1 2 3 4 5 DEF]

Other conditions exist which, in the judgment of the Emergency Director, indicate that events are in progress or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant or a security event that involves probable life threatening risk to site personnel or damage to site equipment because of HOSTILE ACTION. Any releases are expected to be limited to small fractions of the EPA Protective Action Guideline exposure levels.

Other conditions existing which in the judgment of the Emergency Director, indicate that events are in progress or have occurred which indicate a potential degradation of the level of safety of the plant or indicate a security threat to facility protection has been initiated. No releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of SAFETY SYSTEMS occurs.

HU7.1 [1 2 3 4 5 DEF]

Modes: [1] [2] [3] [4] [5] [DEF]
Power Operations Startup Hot Shutdown Cold Shutdown Refueling Defueled




Prepared for Energy Northwest by: Operations Support Services, Inc. - 7/18/16 (Draft E6)

| | | GENERAL EMERGENCY | SITE AREA EMERGENCY | ALERT | UNUSUAL EVENT | | | | | | | | | | | | | | | | | | | | | | | |
|---|---------------------------------------|---|---|---|---|-----|-----|----------------------------------|---|--|--|------------------------|---|---|--|---|---|--|--|---|--|---|---|---|--|---|---|------|
| M System Malfnct. | 1 Loss of Emergency AC Power | Prolonged loss of all offsite and all onsite AC power to emergency buses MG1.1 [1 2 3] Loss of all offsite AND all onsite AC power capability to emergency buses SM-7 and SM-8 AND EITHER: Restoration of emergency bus SM-7 or SM-8 in LT 4 hours is <u>not</u> likely (Note 1) OR RPV level <u>cannot</u> be restored and maintained GT -186 in. Loss of all emergency AC and vital DC power sources for 15 minutes or longer MG1.2 [1 2 3] | Loss of all offsite and all onsite AC power to emergency buses for 15 minutes or longer MS1.1 [1 2 3] Loss of all offsite and all onsite AC power capability to emergency buses SM-7 and SM-8 for GE 15 min. (Note 1) | Loss of all but one AC power source to emergency buses for 15 minutes or longer MA1.1 [1 2 3] AC power capability, Table 2, to emergency buses SM-7 and SM-8 reduced to a single power source for GE 15 min. (Note 1) AND Any additional single power source failure will result in loss of all AC power to emergency buses SM-7 and SM-8 | Loss of all offsite AC power capability to emergency buses for 15 minutes or longer MU1.1 [1 2 3] Loss of all offsite AC power capability, Table 2, to emergency buses SM-7 and SM-8 for GE 15 min. (Note 1) | | | | | | | | | | | | | | | | | | | | | | | |
| | | Indicated voltage is LT 108 VDC on both 125 VDC buses DP-S1-1 and DP-S1-2 for GE 15 min. (Note 1) | Loss of all vital DC power for 15 minutes or longer MS2.1 [1 2 3] Indicated voltage is LT 108 VDC on both 125 VDC buses DP-S1-1 and DP-S1-2 for GE 15 min. (Note 1) | None | None | | | | | | | | | | | | | | | | | | | | | | | |
| | 2 Loss of Vital DC Power | None | None | UNPLANNED loss of Control Room indications for 15 minutes or longer with a significant transient in progress MA3.1 [1 2 3] An UNPLANNED event results in the inability to monitor one or more Table 10 parameters from within the Control Room for GE 15 min. (Note 1) AND Any Table 11 transient event in progress | UNPLANNED loss of Control Room indications for 15 minutes or longer MU3.1 [1 2 3] An UNPLANNED event results in the inability to monitor one or more Table 10 parameters from within the Control Room for GE 15 min. (Note 1) | | | | | | | | | | | | | | | | | | | | | | | |
| | 3 Loss of Control Room Indications | None | None | Table 10 Safety System Parameters • Reactor power • RPV level • RPV pressure • Primary containment pressure • Wetwell level • Wetwell temperature | Table 2 AC Power Sources Offsite • Startup Transformer TR-S • Backup Transformer TR-B • Backfeed 500 KV power through Main Transformers (if already aligned in modes 4, 5, def only) Onsite • DG1 • DG2 • Main Generator via TR-N1/N2 | | | | | | | | | | | | | | | | | | | | | | | |
| | 4 RCS Activity | None | Table 5 Plant Structures Containing Safe Shutdown Systems or Components • Vital portions of the Rad Waste/Control Building: - 467' elevation vital island - 487' elevation cable spreading room - Main Control Room and vertical cable chase - 525' elevation HVAC area • Reactor Building • Vital portions of the Turbine Building - DEH pressure switches - RPS switches on turbine throttle valves - Main steam line radiation monitors - Turbine Building ventilation radiation monitors - Main steam line piping up to MS-V-146 and the first stop valves • Standby Service Water Pump Houses • Diesel Generator Building | Table 11 Transient Events • Reactor scram • Runback GT 25% thermal reactor power • Electrical load rejection GT 25% full electrical load • ECCS injection • Thermal power oscillations GT 10% | Reactor coolant activity greater than Technical Specification allowable limits MU4.1 [1 2 3] SJAE CONDSR OUTLET RAD HI-HI alarm (P602) MU4.2 [1 2 3] Coolant activity GT 0.2 µCi/gm dose equivalent I-131 | | | | | | | | | | | | | | | | | | | | | | | |
| | 5 RCS Leakage | None | None | Automatic or manual scram fails to shut down the reactor, and subsequent manual actions taken at the reactor control consoles are <u>not</u> successful in shutting down the reactor MA6.1 [1 2] An automatic OR manual scram fails to shut down the reactor AND Manual scram actions taken at the reactor control console (mode switch in shutdown, manual push buttons or ARI) are <u>not</u> successful in shutting down the reactor as indicated by reactor power GT 5% (Note 8) | RCS leakage for 15 minutes or longer MU5.1 [1 2 3] (1) RCS unidentified or pressure boundary leakage GT 10 gpm for GE 15 min. OR (2) RCS identified leakage GT 25 gpm for GE 15 min. OR (3) Leakage from the RCS to a location outside containment GT 25 gpm for GE 15 min. | | | | | | | | | | | | | | | | | | | | | | | |
| | 6 RPS Failure | None | Inability to shut down the reactor causing a challenge to RPV water level or RCS heat removal MS6.1 [1 2] An automatic OR manual scram fails to shut down the reactor AND All actions to shut down the reactor are <u>not</u> successful as indicated by reactor power GT 5% AND EITHER: RPV level <u>cannot</u> be restored and maintained above -186 in. or <u>cannot</u> be determined OR WW temperature and RPV pressure <u>cannot</u> be maintained below the HCTL | Automatic or manual scram fails to shut down the reactor MA6.1 [1 2] An automatic OR manual scram fails to shut down the reactor AND A subsequent automatic scram OR manual scram action taken at the reactor control console (mode switch in shutdown, manual push buttons or ARI) is successful in shutting down the reactor as indicated by reactor power LE 5% (APRM downscale) (Note 8) | Automatic or manual scram fails to shut down the reactor MU6.1 [1 2] An automatic OR manual scram did <u>not</u> shut down the reactor AND A subsequent automatic scram OR manual scram action taken at the reactor control console (mode switch in shutdown, manual push buttons or ARI) is successful in shutting down the reactor as indicated by reactor power LE 5% (APRM downscale) (Note 8) | | | | | | | | | | | | | | | | | | | | | | | |
| | 7 Loss of Comm. | Offsite calling capability from the Control Room via direct telephone and fax lines Long distance calling capability on the commercial phone system | Table 4 Communication Methods <table border="1"><thead><tr><th>System</th><th>Onsite</th><th>ORO</th><th>NRC</th></tr></thead><tbody><tr><td>Plant Public Address (PA) System</td><td>X</td><td></td><td></td></tr><tr><td>Plant Telephone System</td><td>X</td><td>X</td><td></td></tr><tr><td>Plant Radio System Operations and Security Channels</td><td>X</td><td></td><td></td></tr><tr><td>Offsite calling capability from the Control Room via direct telephone and fax lines</td><td></td><td>X</td><td>X</td></tr><tr><td>Long distance calling capability on the commercial phone system</td><td></td><td>X</td><td>X</td></tr></tbody></table> | System | Onsite | ORO | NRC | Plant Public Address (PA) System | X | | | Plant Telephone System | X | X | | Plant Radio System Operations and Security Channels | X | | | Offsite calling capability from the Control Room via direct telephone and fax lines | | X | X | Long distance calling capability on the commercial phone system | | X | X | None |
| System | Onsite | ORO | NRC | | | | | | | | | | | | | | | | | | | | | | | | | |
| Plant Public Address (PA) System | X | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Plant Telephone System | X | X | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Plant Radio System Operations and Security Channels | X | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Offsite calling capability from the Control Room via direct telephone and fax lines | | X | X | | | | | | | | | | | | | | | | | | | | | | | | | |
| Long distance calling capability on the commercial phone system | | X | X | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 Hazardous Event Affecting Safety Systems | None | Table 8 Hazardous Events • Seismic event • Internal or external FLOODING event • High winds • Tornado strike • FIRE • EXPLOSION • Volcanic ash fallout • Other events with similar hazard characteristics as determined by the Shift Manager | Hazardous event affecting a SAFETY SYSTEM needed for the current operating mode MA8.1 [1 2 3] The occurrence of any Table 8 hazardous event AND EITHER: Event damage has caused indications of degraded performance in at least one train of a SAFETY SYSTEM needed for the current operating mode OR The event has caused VISIBLE DAMAGE to a SAFETY SYSTEM component or structure, Table 5, needed for the current operating mode | None | | | | | | | | | | | | | | | | | | | | | | | | |

| F Fission Product Barrier Degradation | FG1.1 [1 2 3] Loss of any two barriers AND Loss of potential loss of the third barrier (Table F-1) | FS1.1 [1 2 3] Loss of potential loss of any two barriers (Table F-1) | FA1.1 [1 2 3] Any loss or any potential loss of EITHER Fuel Clad or RCS barrier (Table F-1) | None |
|--|---|---|--|------|
|--|---|---|--|------|

| Table F-1 Fission Product Barrier Threshold Matrix | | | | | | |
|--|--|---|---|---|---|--|
| | FC - Fuel Clad Barrier | | RCS - Reactor Coolant System Barrier | | PC - Containment Barrier | |
| | Loss | Potential Loss | Loss | Potential Loss | Loss | Potential Loss |
| A RPV Water Level | SAG entry required | RPV level <u>cannot</u> be restored and maintained GT -161 in. or <u>cannot</u> be determined. | RPV level <u>cannot</u> be restored and maintained GT -161 in. or <u>cannot</u> be determined. | None | None | SAG entry required |
| B RCS Leak Rate | None | None | UNISOLABLE break in <u>any</u> of the following: • Main Steam Line • RCIC Steam Line • RWCU • Feedwater OR Emergency RPV Depressurization is required | UNISOLABLE primary system leakage that results in exceeding EITHER: RB area temperature alarm level (PPM 5.3.1 Table 23) OR RB area radiation alarm level (PPM 5.3.1 Table 24) | UNISOLABLE primary system leakage that results in exceeding EITHER: RB area maximum safe operating temperature (PPM 5.3.1 Table 23) OR RB area maximum safe operating radiation (PPM 5.3.1 Table 24) | None |
| C PC Conditions | None | None | PC pressure GT 1.68 psig due to RCS leakage | None | UNPLANNED rapid drop in PC pressure following PC pressure rise OR PC pressure response <u>not</u> consistent with LOCA conditions | PC pressure GT 45 psig OR Explosive mixture exists inside PC (H ₂ GE 6% and O ₂ GE 5%) OR WW temperature and RPV pressure <u>cannot</u> be maintained below the HCTL |
| D PC Rad / RCS Activity | Containment Radiation Monitor CMS-RIS-27E or CMS-RIS-27F reading GT 3,600 R/hr OR Primary coolant activity GT 300 µCi/gm Dose Equivalent I-131 | None | Containment Radiation Monitor CMS-RIS-27E or CMS-RIS-27F reading GT 70 R/hr | None | None | Containment Radiation Monitor CMS-RIS-27E or CMS-RIS-27F reading GT 14,000 R/hr |
| E PC Integrity or Bypass | None | None | None | None | UNISOLABLE direct downstream pathway to the environment exists after PC isolation signal OR Intentional PC venting per EOPs | None |
| F Emergency Director Judgment | Any condition in the opinion of the Emergency Director that indicates loss of the fuel clad barrier | Any condition in the opinion of the Emergency Director that indicates potential loss of the Fuel Clad barrier | Any condition in the opinion of the Emergency Director that indicates loss of the RCS barrier | Any condition in the opinion of the Emergency Director that indicates potential loss of the RCS barrier | Any condition in the opinion of the Emergency Director that indicates loss of the Containment barrier | Any condition in the opinion of the Emergency Director that indicates potential loss of the Containment barrier |

| | | | | | | | | |
|---------------|------------------------|---------------|--------------------|---------------------|-----------------|------------------|---|---|
| Modes: | [1] Power Operations | [2] Startup | [3] Hot Shutdown | [4] Cold Shutdown | [5] Refueling | [DEF] Defueled |  | 13.1.1A EAL Classification Matrix Page 2 of 3 HOT CONDITIONS (RCS GT 200°F) |
| | | | | | | | | |

GENERAL EMERGENCY

SITE AREA EMERGENCY

ALERT

UNUSUAL EVENT

1
RPV Level

Loss of RPV inventory affecting fuel clad integrity with containment challenged

CG1.1 [] [] [] [4] [5] []

RPV level LT -161 in. for GE 30 min. (Note 1)
AND
Any of the following indications of containment challenge:

- CONTAINMENT CLOSURE not established (Note 6)
- Explosive mixture inside PC (H₂ GE 6% and O₂ GE 5%)
- UNPLANNED rise in PC pressure
- RB area radiation GT any Maximum Safe Operating level (PPM 5.3.1 Table 24)

CG1.2 [] [] [] [4] [5] []

RPV level cannot be monitored for GE 30 min. (Note 1)
AND
Core uncover is indicated by any of the following:

- UNPLANNED wetwell level rise GT 2 inches (PPM 5.2.1 entry condition)
- VALID indication of RB room flooding as identified by high level alarms (PPM 5.3.1 Table 25)
- Observation of UNISOLABLE RCS leakage outside primary containment of sufficient magnitude to indicate core uncover

AND
Any of the following indications of containment challenge:

- CONTAINMENT CLOSURE not established (Note 6)
- Explosive mixture inside PC (H₂ GE 6% and O₂ GE 5%)
- UNPLANNED rise in PC pressure
- RB area radiation GT any Maximum Safe Operating level (PPM 5.3.1 Table 24)

Loss of RPV inventory affecting core decay heat removal capability

CS1.1 [] [] [] [4] [5] []

(1) CONTAINMENT CLOSURE not established
AND
RPV level LT -129 in.
OR
(2) CONTAINMENT CLOSURE established
AND
RPV level LT -161 in.

CS1.2 [] [] [] [4] [5] []

RPV level cannot be monitored for GE 30 min. (Note 1)
AND
Core uncover is indicated by any of the following:

- UNPLANNED wetwell level rise GT 2 inches (PPM 5.2.1 entry condition)
- VALID indication of RB room flooding as identified by high level alarms (PPM 5.3.1 Table 25)
- Observation of UNISOLABLE RCS leakage outside primary containment of sufficient magnitude to indicate core uncover

Significant loss of RPV inventory

CA1.1 [] [] [] [4] [5] []

(1) Loss of RPV inventory as indicated by RPV level LT -50 in.
OR
(2) RPV level cannot be monitored for GE 15 min. (Note 1)
AND
UNPLANNED increase in any Table 1 sump or pool levels due to a loss of RPV inventory

Table 1 Sumps/Pool

- Any valid Hi-Hi level alarm on R-1 through R-5 sumps
- EDR GE 25 GPM
- FDR GE 10 GPM
- Wetwell level rise
- Observation of UNISOLABLE RCS leakage

Unplanned loss of RPV inventory

CU1.1 [] [] [] [4] [5] []

(1) UNPLANNED loss of reactor coolant results in RPV level less than a required lower limit for GE 15 min. (Note 1)
OR
(2) RPV level cannot be monitored
AND
UNPLANNED increase in any Table 1 sump or pool levels due to a loss of RPV inventory

Table 2 AC Power Sources

Offsite

- Startup Transformer TR-S
- Backup Transformer TR-B
- Backfeed 500 KV power through Main Transformers (if already aligned in modes 4, 5, def only)

Onsite

- DG1
- DG2
- Main Generator via TR-N1/N2

C
Cold SD/
Refuel
System
Malfunct.

2
Loss of
Emergency
AC Power

None

None

Loss of all offsite and all onsite AC power to emergency buses for 15 minutes or longer

CA2.1 [] [] [] [4] [5] [DEF]

Loss of all offsite and all onsite AC power capability to emergency buses SM-7 and SM-8 for GE 15 min. (Note 1)

Loss of all but one AC power source to emergency buses for 15 minutes or longer

CU2.1 [] [] [] [4] [5] [DEF]

AC power capability, Table 2, to emergency buses SM-7 and SM-8 reduced to a single power source for GE 15 min. (Note 1)
AND
Any additional single power source failure will result in loss of all AC power to emergency buses SM-7 and SM-8

3
RCS
Temp.

None

Table 7 RCS Reheat Duration Thresholds

* If an RCS heat removal system is in operation within this time frame and RCS temperature is being reduced the EAL is not applicable

| RCS Status | Containment Closure Status | Heat-up Duration |
|------------|----------------------------|------------------|
| Intact | N/A | 60 min. * |
| Not intact | established | 20 min. * |
| | <u>not</u> established | 0 min. |

Inability to maintain plant in cold shutdown

CA3.1 [] [] [] [4] [5] []

UNPLANNED increase in RCS temperature to GT 200°F for GT Table 7 duration (Note 1)
OR
UNPLANNED RPV pressure increase GT 10 psig

UNPLANNED increase in RCS temperature

CU3.1 [] [] [] [4] [5] []

UNPLANNED increase in RCS temperature to GT 200°F

CU3.2 [] [] [] [4] [5] []

Loss of all RCS temperature and RPV water level indication for GE 15 min. (Note 1)

4
Loss of
Vital DC
Power

None

None

None

Loss of vital DC power for 15 minutes or longer

CU4.1 [] [] [] [4] [5] []

Indicated voltage LT 108 VDC on required 125 VDC buses DP-S1-1 and DP-S1-2 for GE 15 min. (Note 1)

5
Loss of
Comm.

Table 4 Communication Methods

| System | Onsite | ORO | NRC |
|---|--------|-----|-----|
| Plant Public Address (PA) System | X | | |
| Plant Telephone System | X | X | |
| Plant Radio System Operations and Security Channels | X | | |
| Offsite calling capability from the Control Room via direct telephone and fax lines | | X | X |
| Long distance calling capability on the commercial phone system | | X | X |

None

None

Loss of all onsite or offsite communications capabilities

CU5.1 [] [] [] [4] [5] [DEF]

Loss of all Table 4 onsite communication methods
OR
Loss of all Table 4 ORO communication methods
OR
Loss of all Table 4 NRC communication methods

6
Hazardous
Events
Affecting
Safety
Systems

None

Table 8 Hazardous Events

- Seismic event
- Internal or external FLOODING event
- High winds
- Tornado strike
- FIRE
- EXPLOSION
- Volcanic ash fallout
- Other events with similar hazard characteristics as determined by the Shift Manager

Hazardous event affecting a SAFETY SYSTEM needed for the current operating mode

CA6.1 [] [] [] [4] [5] []

The occurrence of any Table 8 hazardous event
AND EITHER:
Event damage has caused indications of degraded performance in at least one train of a SAFETY SYSTEM needed for the current operating mode
OR
The event has caused VISIBLE DAMAGE to a SAFETY SYSTEM component or structure, Table 5, needed for the current operating mode

None

Table 5 Plant Structures Containing Safe Shutdown Systems or Components

- Vital portions of the Rad Waste/Control Building:
 - 467' elevation vital island
 - 487' elevation cable spreading room
 - Main Control Room and vertical cable chase
 - 525' elevation HVAC area
- Reactor Building
- Vital portions of the Turbine Building
 - DEH pressure switches
 - RPS switches on turbine throttle valves
 - Main steam line radiation monitors
 - Turbine Building ventilation radiation monitors
 - Main steam line piping up to MS-V-146 and the first stop valves
- Standby Service Water Pump Houses
- Diesel Generator Building

Modes:

| | | | | | |
|------------------|----------|--------------|---------------|-----------|------------|
| 1 | 2 | 3 | 4 | 5 | DEF |
| Power Operations | Startup | Hot Shutdown | Cold Shutdown | Refueling | Defueled |



13.1.1A
EAL Classification Matrix
Page 3 of 3
COLD CONDITIONS
(RCS ≤ 200°F)