

KHNPDCDRAIsPEm Resource

From: Ciocco, Jeff
Sent: Monday, August 01, 2016 2:58 PM
To: apr1400rai@khnp.co.kr; KHNPDCDRAIsPEm Resource; Jung-ho Kim (jhokim082@gmail.com); Andy Jiyong Oh; James Ross
Cc: Kent, Lauren; Junge, Michael; Ward, William; Williams, Donna
Subject: APR1400 Design Certification Application RAI 510-8650 (18 - Human Factors Engineering)
Attachments: APR1400 DC RAI 510 HOIB 8650.pdf

KHNP,

The attachment contains the subject request for additional information (RAI). This RAI was sent to you in draft form. Your licensing review schedule assumes technically correct and complete responses within 30 days of receipt of RAIs.

Please submit your RAI response to the NRC Document Control Desk.

Thank you,

Jeff Ciocco
New Nuclear Reactor Licensing
301.415.6391
jeff.ciocco@nrc.gov



Hearing Identifier: KHNP_APR1400_DCD_RAI_Public
Email Number: 568

Mail Envelope Properties (7e71af96a70b4712af190e4abac34df3)

Subject: APR1400 Design Certification Application RAI 510-8650 (18 - Human Factors Engineering)
Sent Date: 8/1/2016 2:57:54 PM
Received Date: 8/1/2016 2:57:55 PM
From: Ciocco, Jeff
Created By: Jeff.Ciocco@nrc.gov

Recipients:

"Kent, Lauren" <Lauren.Kent@nrc.gov>
Tracking Status: None
"Junge, Michael" <Michael.Junge@nrc.gov>
Tracking Status: None
"Ward, William" <William.Ward@nrc.gov>
Tracking Status: None
"Williams, Donna " <Donna.Williams@nrc.gov>
Tracking Status: None
"apr1400rai@khnp.co.kr" <apr1400rai@khnp.co.kr>
Tracking Status: None
"KHNPDCDRAIsPEm Resource" <KHNPDCDRAIsPEm.Resource@nrc.gov>
Tracking Status: None
"Jungcho Kim (jhokim082@gmail.com)" <jhokim082@gmail.com>
Tracking Status: None
"Andy Jiyong Oh" <jiyong.oh5@gmail.com>
Tracking Status: None
"James Ross" <james.ross@aecom.com>
Tracking Status: None

Post Office: HQPWMSMRS07.nrc.gov

Files	Size	Date & Time
MESSAGE	498	8/1/2016 2:57:55 PM
APR1400 DC RAI 510 HOIB 8650.pdf		
image001.jpg	5040	87974

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

REQUEST FOR ADDITIONAL INFORMATION 510-8650

Issue Date: 08/01/2016
Application Title: APR1400 Design Certification Review – 52-046
Operating Company: Korea Hydro & Nuclear Power Co. Ltd.
Docket No. 52-046
Review Section: 18 - Human Factors Engineering
Application Section: 18.6

QUESTIONS

18-127

Title 10 of the Code of Federal Regulations (10CFR) Section 52.47(a)(8) requires an applicant for a design certification to provide an FSAR [Final Safety Analysis Report] which includes the information necessary to demonstrate compliance with any technically relevant portions of the Three Mile Island requirements set forth in 10 CFR 50.34(f), with certain exceptions. Section 10 CFR 50.34(f)(2)(ii) requires an applicant to "Establish a program, to begin during construction and follow into operation, for integrating and expanding current efforts to improve plant procedures. The scope of the program shall include.....human factors engineering..." The current NRC guidance for developing a human factors engineering (HFE) program is NUREG-0711, Rev 3, "Human Factors Engineering Program Review Model." The applicant stated in the FSAR, Tier 2, Chapter 18 "Human Factors Engineering," that it was working in accordance with the criteria of NUREG-0711 in establishing its HFE program.

NUREG-0711, Criterion 7.4(1), states: "The applicant should identify risk-important human actions (RIHAs) from the PRA/HRA [Probabilistic Risk Assessment/Human Risk Assessment]. The human factors engineering staff is responsible for ensuring that RIHAs included in the HFE design process are the same as those identified in Chapter 19 ["Probabilistic Risk Assessment and Severe Accident Evaluation"]."

The response to RAI 128-7980, Question 18-13 (ADAMS Accession No. [ML15352A246](#)), included a list of risk-important human actions (RIHAs), and stated that the list would be included in the treatment of important human actions (TIHA) results summary report (ReSR). The ReSR is the product prepared by the COL [combined license] applicant to complete the TIHA program element.

The staff reviewed the list and compared it to the list of "key operator actions" in FSAR Tier 2, Chapter 19, Rev 0, Tables 19.1-24, 25, 38, 39, 55, 56, 61, 62, 72, 73, 78, 79, 104, 105, 117, 118, 130, 131, 145, 146, 159, and 160. The staff found that some of the actions listed in these tables were not on the list provided in response to Question 18-13.

Further, APR1400-E-I-NR-14006, "Treatment of Important Human Actions Implementation Plan" (TIHA IP), which will be used by a COL applicant to complete the TIHA program element, does not provide enough detail to ensure that a person with the qualifications described in the TIHA IP (which do not include knowledge of PRA) will be able to identify and include all of the RIHAs listed in FSAR Tier 2 Chapter 19 in the

REQUEST FOR ADDITIONAL INFORMATION 510-8650

HFE program. These RIHAs should be clearly labeled and listed in Chapter 19 as part of the design process.

Because of the reasons stated above, the staff finds the response to Question 18-13 inadequate and asks the applicant to address the following issues in order to close this issue.

1. Provide in FSAR Tier 2, Chapter 19, a list of risk-important human actions identified from the PRA/HRA per Criterion 7.4(1).
2. Revise APR1400-E-I-NR-14006 to reference the list in FSAR Tier 2, Chapter 19 that contains the RIHAs to ensure that the RIHAs included in the HFE design process are the same as those identified in Chapter 19.

