

EP File No. _____

Statement #
DW 4, 5, 13, 14, 16, 17, &
19

TECHNICAL BASES FOR GU1, GA1, GS1, & GG1 EALs
INCREASED RADIATION RELEASE TO THE ENVIRONMENT

Prepared: D.E. Larson
September 12, 1994

Threshold values for Emergency Action Levels under Initiating Condition GU1 were established at two times the applicable ODCM limit. For gaseous effluents, the threshold takes into account the partitioning of total allowable release between the release points. The high alarm is used for the elevated release intermediate range monitor and the high-high alarm is used for the radwaste and turbine building low range monitors. Liquid effluent thresholds for SW and TSW are based on high alarms and take into account the 80% of allowable setting of the alarm. The FDR threshold is based on 100% of the high-high alarm.

Liquid effluent thresholds of 200 times the ODCM limits under Initiating Condition GA1 use the same bases as the unusual event EALs.

Gaseous effluent EALs for GA1, GS1, and GG1 are not based on alarm levels, but on emergency dose projection results using accident source term embedded in the QEDPS code. Threshold monitor readings were calculated by equating effluent monitor readings to Site Boundary doses through reiterative use of the QEDPS code.

For those cases where standby gas treatment was noted to be in service, one train was assumed to be operating with a design flow of 5380 CFM. This assumption is considered to be conservative for the following reasons. The assumed flow 5380 exceeds the Technical Specification required flow for a single train of $4457 \pm 10\%$ CFM. PPM 4.12.4.6 directs the Control Room staff to secure one SGT train per PPM 2.3.5 if a single train will maintain $-1.7''$ wg. PPM 2.3.5 notes that $-1.7''$ wg is the vacuum indication required to assure $-0.25''$ wg in all areas of the reactor building. Technical Specification 3.6.5.1 requires an 18 month surveillance with one train of SGT running for one hour maintaining $-0.25''$ wg or better with flow less than 2240 CFM.

Where standby gas treatment is not applicable, the building design flow rate was used as follows: Reactor Building 86,000 cfm, Turbine Building 320,000 cfm, and Radwaste Building 84,000 cfm. In all cases wind speed was set at 5 mph with E stability class to represent annual average meteorological conditions per FD Quinn. Duration of release was set at one hour. QEDPS assumes no decay of source term prior to release.

Results were compared with values previously provided to the EAL upgrade project. The QEDPS monitor inputs were also entered into BEDPS under like conditions.

Calculations used in the previous submittal assumed two trains of Standby Gas Treatment in operation for the duration of the release. As noted above, only one train is expected to be in operation after the first few minutes of an event. A factor of two increase in the threshold is therefore expected in those cases where SGT is on.

Differences between QEDPS and BEDPS results for identical inputs can be summarized as follows:

For Radwaste and Turbine Building exhaust monitors, both low and extended range, BEDPS calculates a result approximately 4 times higher than QEDPS.

For the Reactor Building exhaust monitors, BEDPS calculates a dose nearly equal to QEDPS when Standby Gas Treatment is off.

When Standby Gas Treatment is operating, BEDPS calculates a TEDE 10 times QEDPS results and Thyroid CDE approximately 5 times QEDPS.

These differences are considered to be well within the acceptable tolerances of the emergency dose projection models.

CLASSIFICATION	MONITOR & READING	BASIS FOR THRESHOLD
NOUE	PRM-RE-1B 905,000 CPS	$2 \times \text{ODCM} = 5 \times \text{Hi ALARM} = 5 \times 181,000 \text{ CPS}$ (Ref ISCR 1197)
NOUE	TEA-RIS-13 16,750 CPM	$2 \times \text{ODCM} = 5 \times \text{H-H ALARM} = 5 \times 3350 \text{ CPM}$ (Ref ISCR 1086)
NOUE	WEA-RIS-14 120,000 CPM	$2 \times \text{ODCM} = 10 \times \text{H-H ALARM} = 10 \times 12,000 \text{ CPM}$ (Ref ISCR 318)
NOUE	SW-RE-4 200 CPS	$2 \times \text{ODCM} = 2 \times \text{Hi ALARM} = 2 \times 80/0.8$ (Ref ISCR 1085)
NOUE	SW-RE-5 200 CPS	$2 \times \text{ODCM} = 2 \times \text{Hi ALARM} = 2 \times 80/0.8$ (Ref ISCR 995)
NOUE	FDR-RE-6 2 x Hi-Hi	$2 \times \text{ODCM} = 2 \times \text{H-H ALARM}$ (Ref ODCM 2.5)
NOUE	TSW-RE-5 3900 CPM	$2 \times \text{ODCM} = 2 \times \text{H-H ALARM}/0.8 = 2 \times 1250/0.8$ (Ref ISCR 1080)
ALERT	PRM-RE-1C 850 CPS	10 mr/hr TEDE or 50 mr/hr thyroid CDE (Ref QEDPS run 1 Attached)
ALERT	TEA-RIS-13 44,000 CPM	10 mr/hr TEDE or 50 mr/hr thyroid CDE (Ref QEDPS run 5 Attached)
ALERT	WEA-RIS-14 167,000 CPM	10 mr/hr TEDE or 50 mr/hr thyroid CDE (Ref QEDPS run 6 Attached)

CLASSIFICATION	MONITOR & READING	BASIS FOR THRESHOLD
ALERT	SW-RE-4 20,000 CPS	$200 \times \text{ODCM} = 200 \times \text{Hi ALARM}/0.8 = 200 \times 80/0.8$ (Ref ISCR 1085)
ALERT	SW-RE-5 20,000 CPS	$200 \times \text{ODCM} = 200 \times \text{Hi ALARM}/0.8 = 200 \times 80/0.8$ (Ref ISCR 995)
ALERT	FDR-RE-6 200 x Hi-Hi	$200 \times \text{ODCM} = 200 \times \text{H-H ALARM}$ (Ref ODCM 2.5)
ALERT	TSW-RE-5 390,000 CPM	$200 \times \text{ODCM} = 200 \times \text{H-H ALARM}/0.8 = 200 \times 1250/0.8$ (ISCR 1080)
SAE	PRM-RE-1C 6500 CPS	100 mr/hr TEDE or 500 mr/hr CDE SGTS on (Ref QEDPS run 7 Attached)
SAE	TEA-RE-13 440,000 CPM	100 mr/hr TEDE or 500 mr/hr CDE (Ref QEDPS run 8 Attached)
SAE	WEA-RE-14 1,670,000 CPM	100 mr/hr TEDE or 500 mr/hr CDE (Ref QEDPS run 9 Attached)
GE	PRM-RE-1C 65,000 CPS	1000 mr/hr TEDE or 5000 mr/hr CDE, SGTS on (Ref QEDPS run 2 Attached)
GE	TEA-RIS-13A 8 PMU	1000 mr/hr TEDE or 5000 mr/hr CDE (Ref QEDPS run 3 Attached)
GE	WEA-RIS-14A 26 PMU	1000 mr/hr TEDE or 5000 mr/hr CDE (Ref QEDPS run 4 Attached)



WASHINGTON STATE
DEPARTMENT OF ECOLOGY
ORIGINAL

INSTRUMENT SETPOINT CHANGE REQUEST

ISCR Number:

Page 1 of

1080

O
R
I
G
I
N
A
L
T
O
R

Quality Class: 1 ☐ 2 ☒ 2+ ☐ G ☐ MEL EPN: FSW-RIS-5
Technical Specification Instr. YES ☒ No ☐
Calculation Required YES ☐ No ☒
Original Calc. No.: _____ ORIGINATED BY: Allen T. L...

Tech. Spec. Section: 3.1 3.2.11 Table 3.3.7.11-1

Tech. Spec. Limit: 30% of 137 lbs Mpc as per Section 2 of C OCM

Affected Procedures / System Components: 17PM CFT 2.4.3.7.11.5
CC 7.4.3.7.11.4

Existing Setpoint / Range HV OP 1050 LLD -2.75
(Admin. Limit/Calib. Tol.) HV INOP 1000 ULD -14.0 -13.2 Pa

Reason For Change: Radioactive Recalibration (Periodic)
More operations parameters

New Setpoint / Range HV OP 1075 LLD -2.75
(Admin. Limit/Calib. Tol.) HV INOP 1025 ULD -14.0 Volts

A
P
P
R
O
V
A
L
S

Plant Technical Control Sys. Eng.: M. Widmeyer Date: 7/31/91

System Engineer: Will S. K. Date: 7-29-91

Plant Engineering Supervisor: B. B. B. Date: 7/31/91

+ HP Chem Manager / Operations: P. J. J. Date: 7-31-91

++ Plant Oper. Committee (or PMR#): J. B. B. Date: 8/1/91

+ HP / Chemistry Manager required only on Rad Monit Setpoints / Operations required only for Administrative Limits and Calibration tolerances for instruments addressed in the Tech. Spec.

++ Required for Technical Specifications Quality Class I, Fire Protection or Security Changes if PMR has not been previously approved by POC.

SEE NEXT PAGE FOR TEMPORARY SETPOINT CHANGE APPROVALS

INSTRUMENT SETPOINT
CHANGE REQUEST

1080

P
P
R
O
V
A
L
S

TEMPORARY SETPOINT CHANGE APPROVALS

Shift Manager: NA Date: NAPlant Engineer: / Date: /+ HP Chem Manager / Date: /Affected Procedure(s) Deviated: / Date: /

Procedure No.

+ HP / Chemistry Manager required only on Rad Monit Setpoints / Operations required only for Administrative Limits and Calibration tolerances for instruments addressed in the Tech. Spec.

Forward to Plant Technical Control Systems Engineer

Necessary Approvals Obtained

Control System Engineer: M. Widmeyer Date: 8/1/91

PROCEDURE REVISIONS / DEVIATIONS

PROCEDURE NUMBER	REV. No.	DEVIATION No.	INITIAL	Date Comp.
<u>NA</u>				
<u>/</u>				

I
M
P
L
E
M
E
N
T
A
T
I
O
NSetpoint Change MWR No: AR 5210 Date: 9/20/91
7299+Original Revised MDS to Plant Records: gm Date: 8/5/91

Copy of MDS & ISCR Distributed to

DEPARTMENT	COMPLETED BY	DATE
I & C MAINTENANCE	<u>OLA</u>	<u>8/5/91</u>
OPERATIONS	<u>OLA</u>	<u>8/5/91</u>
HP / CHEMISTRY	<u>OLA</u>	<u>8/5/91</u>
NUCLEAR LICENSE TRAINING	<u>OLA</u>	<u>8/5/91</u>
PROCEDURES	<u>OLA</u>	<u>8/5/91</u>

SAFETY RELATED

10 CFR 50.59 REVIEW

CONTROLLED COPY

Implementing Doc. No. TSUR#1080

p.3

Implementing Activity Description Radiochemical Calibration of the turbine Service Water
Monitor, TSW-RIS-51. Is a change to the WNP-2 Technical Specifications necessary to implement this activity?
(If response is yes, then the activity may not be fully implemented without prior
NRC staff approval)

YES

NO

☐☒2. Does this implementing activity constitute a change to WNP-2 which could functionally
affect a safety related SSC as described in the LBD?☐☒3. Does this implementing activity constitute a change to WNP-2 which could affect nuclear
safety in a manner not previously evaluated?☐☒4. Does this implementing activity change or affect the intent of a procedure or process from
the intent of the commitments described, outlined, or summarized in the LBD?☐☒5. Does this implementing activity represent a special test or experiment not previously
described in the LBD that might affect safe operation of the Plant?☐☒If there is a yes response to either question 2, 3, 4, or 5,
then a Safety Evaluation must be completed

If the responses to questions 2 through 5 are all NO, a written justification is required. the setpoints have been
adjusted in accordance with the performance of the radiochemical calibration. these adjust-
ments ensure that the monitor will continue to provide alarms at the existing tech.
spec limits in accordance with the referenced LBD's.

Is additional justification
information attached?

YES

NO

☐☒References 1/5 3/4, 3.7.11 table 3.3, 7.11-1 & 3.11.1.1ODCM Section 2 (Liquids)FSAR 11.5.1.1.2; 11.5.2.2.2.4; table 11.5-2P.P.M.'s 7.4.3.7.11.4, ^{per} 5, 22; 12.13.17; 12.13.25Is additional reference
information attached?

YES

NO

☐☒

Prepared by

A. J. Davis

Date

26 July 1991

Reviewed by

John R. Allen

Date

7-28-91

SAFETY RELATED

CONTROLLED COPY

**SUMMARY OF RADIOLOGICAL CALIBRATION
TURBINE SERVICE WATER MONITOR TSW-RIS-5**

Date of Calibration 25 July 1991

ISCR #1080 p.4

Primary Calibration:

Date of Primary Calibration 8 Nov 1983

Liquid Calibration Factor 6.76 ± 7 cpm/μCi/ml

Transfer Source Identification No. 2-83-85E Isotope ¹³⁷Cs Activity 0.54 μCi

Transfer Source Calibration Factor 1.61 ± 5 cpm/μCi

Current Calibration:

Transfer Source Current Activity 0.4432 μCi

Transfer Source Count Rate 72081 ± 422 @ 1σ % Error

Transfer Source Calibration Factor 1.626 ± 5 cpm/μCi

Current Transfer Source to Primary Calibration Ratio $\frac{1.626 \pm 5}{1.61 \pm 5} = 1.0099$

Recalculated Liquid Calibration Factor 6.827 ± 7 cpm/μCi/ml

Instrument Parameters

Detector:

High Voltage Operate 1075 Volts

High Voltage Load 1025 Volts

Upper Level Discriminator -14 Volts

Lower Level Discriminator -2.75 Volts

Alarm Setpoints from PPM 7.4.3.7.11.4

Low disabled cpm High 610 cpm High High 1250 cpm

*Wally - The cal's have
not been totally revised
but the portions relating
to the attached ISCR
have been & they are
OK. John R Alb
7-28-91*

Remarks: _____

Prepared By: Albert J. Davis Date 7-25-91

Attachment A

PROCEDURE NUMBER	REVISION NUMBER	PAGE NUMBER
7.4.3.7.11.22	2	7.4.3.7.11.22-4 of 4



WASHINGTON PLANT FUEL
SUPPLY SYSTEM

ORIGINAL

**INSTRUMENT SETPOINT
CHANGE REQUEST**

ISCR Number:

Page 1 of

1085

O
R
I
G
I
N
A
T
O
R

Quality Class: 1 ☒ 2 ☐ 2+ ☐ G ☐ MEL EPN: SW-RIS-604
Technical Specification Instr. YES ☒ No ☐
Calculation Required YES ☐ No ☒
Original Calc. No.: 5.52.036 ORIGINATED BY: A.I.DAVIS

Tech. Spec. Section: 3/4.3.7.11

Tech. Spec. Limit: NA

Affected Procedures / System Components: 7.4.3.7.11.7, 7.4.3.7.11.6A

Existing Setpoint / Range HV Oper 1000 V PHD Voltage 8.50 V
(Admin. Limit/Calib. Tol.) HV INOP 950 V

Reason For Change:

Radiometric Recalibration and reset operating parameters.

Note: No change to HV parameters. IMDS should be changed to reflect new PHD value.

New Setpoint / Range HV Operating: 1000 V PHD : 8.40 V
(Admin. Limit/Calib. Tol.) HV INOP: 950 V

A
P
P
R
O
V
A
L
S

Plant Technical Control Sys. Eng.: M. Widmeyer Date: 9/4/91

System Engineer: W.P.K. Date: 9-4-91

Plant Engineering Supervisor: R. Babin Date: 9-4-91

+ HP Chem Manager / Operations: [Signature] Date: 9-6-91

++ Plant Oper. Committee (or PMR#): J. Baker Date: 9-6-91

+ HP / Chemistry Manager required only on Rad Monit Setpoints / Operations required only for Administrative Limits and Calibration tolerances for instruments addressed in the Tech. Spec.

++ Required for Technical Specifications Quality Class I, Fire Protection or Security Changes if PMR has not been previously approved by POC.

SEE NEXT PAGE FOR TEMPORARY SETPOINT CHANGE APPROVALS

WASHINGTON PUBLIC POWER
SUPPLY SYSTEM**ORIGINAL****INSTRUMENT SETPOINT
CHANGE REQUEST**

ISCR Number:

Page of

1085A
P
P
R
O
V
A
L
S**TEMPORARY SETPOINT CHANGE APPROVALS**Shift Manager: NA Date: _____Plant Engineer: NA Date: _____+HP Chem Manager NA Date: _____Affected Procedure(s) Deviated: NA Date: _____

Procedure No.

+ HP / Chemistry Manager required only on Rad Monit Setpoints / Operations required only for Administrative Limits and Calibration tolerances for instruments addressed in the Tech. Spec.

Forward to Plant Technical Control Systems Engineer

Necessary Approvals Obtained

Control System Engineer:

M. Widmeyer

Date:

9/6/91**PROCEDURE REVISIONS / DEVIATIONS**

PROCEDURE NUMBER	REV. No.	DEVIATION No.	INITIAL	Date Comp.
NA	NA	NA	NA	NA
✓				

I
M
P
L
E
M
E
N
T
A
T
I
O
N

Setpoint Change MWR No:

AR5565

Date:

9/25/91

Original Revised MDS to Plant Records:

OLA

Date:

9/10/91

Copy of MDS & ISCR Distributed to

DEPARTMENT	COMPLETED BY	DATE
I & C MAINTENANCE	OLA	9/10/91
OPERATIONS	OLA	9/10/91
HP / CHEMISTRY	OLA	9/10/91
NUCLEAR LICENSE TRAINING	OLA	9/10/91

ORIGINAL**10CFR50.59 REVIEW**Implementing Doc. No. ISCR 1085
p. 3Implementing Activity Description Radiological calibration of the RHR Loop A Service Water monitor.
SW-RIS-604, and resetting of operating parameters.

- | | YES | NO |
|---|--------------------------|-------------------------------------|
| 1. Is a change to the WNP-2 Technical Specifications necessary to implement this activity?
(If response is yes, then the activity may not be fully implemented without prior NRC staff approval) | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 2. Does this implementing activity constitute a change to WNP-2 which could functionally affect a safety related SSC as described in the LBD? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 3. Does this implementing activity constitute a change to WNP-2 which could affect nuclear safety in a manner not previously evaluated? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 4. Does this implementing activity change or affect the intent of a procedure or process from the intent of the commitments described, outlined, or summarized in the LBD? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 5. Does this implementing activity represent a special test or experiment not previously described in the LBD that might affect safe operation of the Plant? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

If there is a yes response to either question 2, 3, 4, or 5,
then a Safety Evaluation must be completed

If the responses to questions 2 through 5 are all NO, a written justification is required. The setpoints have been adjusted as part of the performance of the radiological calibration per the referenced surveillance procedures to ensure that the monitor will continue to provide alarms at the existing ODCM Limits in accordance with the referenced LBD's.

Is additional justification information attached?	YES	NO
	<input type="checkbox"/>	<input checked="" type="checkbox"/>

References T/S 3/4.3.7.11ODCM Section 2.9, 2.9.1FSAR 11.5.2.2.2.1 table 11.5-2PPM 7.4.3.7.11.7, 7.4.3.7.11.6A, 7.4.3.7.11.24PPM 12.13.13

Is additional reference information attached?	YES	NO
	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Prepared by A.I. DAVISDate 29 JULY '91Reviewed by JOHN R. ALLENDate 8-27-91

SAFETY RELATED

ORIGINAL

CONTROLLED COPY

SUMMARY OF RADIOLOGICAL CALIBRATION
RHR SERVICE WATER MONITOR SW-RIS-604

ISCR 1085
P. 4
SW-RIS-604

Date of Calibration 24 July 1991

Primary Calibration:

Date of Primary Calibration 26 June 1987

Liquid Calibration Factor 4.4898 ± 6 cps/μCi/ml

Transfer Source Identification No. 2-83-25E Isotope ¹³⁷Cs Activity 0.482 μCi

Transfer Source Calibration Factor 4110.9 cps/μCi

Current Calibration:

Transfer Source Current Activity 0.4433 μCi

Transfer Source Count Rate 1827.2 ± 0.24% @ 1 σ % Error

Transfer Source Calibration Factor 4110.9 cps/μCi

Current Transfer Source to Primary Calibration Ratio $\frac{4110.9}{4110.9} = \underline{1.00267}$

Recalculated Liquid Calibration Factor 4.5018 ± 6 cps/μCi/ml

Instrument Parameters

Detector:

High Voltage Operate 1000 Volts

High Voltage Inop 950 Volts

Pulse Height Discriminator 8.40 Volts

Alarm Setpoints from PPM 7.4.3.7.11.6A

Low 0.5 cps High 80 cps High High 155 cps

Remarks: _____

Prepared By: A. D. Harris Date 7-26-91

Attachment A

PROCEDURE NUMBER	REVISION NUMBER	PAGE NUMBER
7.4.3.7.11.24	2	7.4.3.7.11.24-4 of 4

ORIGINAL

INSTRUMENT SETPOINT CHANGE REQUEST		ISCR No. <u>995</u>
O R I G I N A L	1. Quality Class: I. <input checked="" type="checkbox"/> II. <input type="checkbox"/> G. <input type="checkbox"/> Technical Spec. Instr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Calculation Required Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Orig Calc _____	
	2. Originated by <u>Albert J Davis</u> Date <u>6 June 1990</u>	
	3. MEL No. and Function <u>SW-RIS-605 RHR Loop B Part Mon.</u>	
	4. Tech. Spec. Section <u>7.4.3.2.11</u>	
	5. Tech. Spec. Limit <u>None - Off Site Acc. Calc. Manual</u>	
	6. Affected Procedures/System Components <u>OP 7.4.3.2.11.7</u> <u>me 7.4.3.2.11.6 B.</u>	
	7. Existing Setpoint/Range <u>H.V. OP 1000 LLD 7.2 V/Lt.</u> (Admin. Limit/Calib. Tol.) <u>NO 950</u>	
	8. Reason For Change <u>Real Recal. High Voltage 1025 grams</u> <u>975 Inq.</u> <u>LLD 6.4</u>	
	9. New Setpoint/Range (Admin. Limit/Calib. Tol.)	
E N G I N E E R	1. Necessary Approvals Obtained <u>M. Widmeyer</u> <u>6/6/90</u> Control Systems Eng. Date	
	2. Orig revised MOS to Plant Records <u>DLA</u> <u>1</u> <u>6/7/90</u> Date	
	3. Copy of MOS & ISCR to I&C Maint. <u>DLA</u> <u>1</u> <u>6/7/90</u> Date	
	4. Copy of MOS & ISCR to Operations <u>DLA</u> <u>1</u> <u>6/7/90</u> Date	
	HP Chem <u>DLA</u> <u>1</u> <u>6/7/90</u> Date	
	Nuclear License Training <u>DLA</u> <u>1</u> <u>6/7/90</u> Date	
	5. Setpoint Changes; Calibration Date <u>NA</u>	
6. Affected Procedures Revised/Deviated <u>NA</u> <u>1</u> No. Date		

Attachment A
Page 1 of 2

PROCEDURE NUMBER 1.4.3	REVISION NUMBER 9	PAGE NUMBER 1.4.3-8 of 11
----------------------------------	-----------------------------	-------------------------------------

SAFETY RELATED**CONTROLLED COPY****10CFR50.59 EVALUATION PROCESS FLOW CHART**ISCR # 925
sh. 3 of 6

NOTE: The 10CFR50.59 Evaluation implementing processes will typically address items 1 through 4 only and the USQ Analysis would be processed only if required by an affirmative response to question 2, 3, or 4.

	YES	NO
1. Is a change to the WNP-2 Technical Specification necessary to implement this activity?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2. Does this implementing activity constitute a physical change to WNP-2 as described in the FSAR or not in the FSAR and affects nuclear safety in a way not previously evaluated?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3. Does this implementing activity constitute a change to a procedural commitment as described in the FSAR?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4. Does this implementing activity represent a special test or experiment not previously described in the FSAR?	<input type="checkbox"/>	<input checked="" type="checkbox"/>

If question 1 is answered YES, then prior NRC approval is required prior to implementation.

If either question 2, 3 or 4 are answered YES, then an USQ Analysis must be performed.

YES (1)

YES (2,3,4)

5. Does the Unreviewed Safety Question Analysis identify the implementing activity as representing an USQ? Refer to Attachment B.	<input type="checkbox"/> YES	<input type="checkbox"/> NO
--	---------------------------------	--------------------------------

YES

(1,2,3,4) NO

ND

Activity may not be fully implemented without prior NRC staff approval.	NRC Staff Authorization Received	Implement Activity
---	----------------------------------	--------------------

NOTE: Upon POC approval, partial implementation may occur without prior NRC staff approval.

Prepared by Albert J. Davis Date 6 June 1996
Approved by [Signature] Date 6-6-90

Attachment A

PROCEDURE NUMBER	REVISION NUMBER	PAGE NUMBER
1.3.43	1	1.3.43-10 of 17

SAFETY RELATED

CONTROLLED COPY

**INSTRUMENT SETPOINT
CALCULATION**

1 ISCR # 995
2 Sheet 4 of 6
3 Date 6-6-90

4 EPN SW-RIS-605 5 Description RHR Loop B Rad Mon.
6 Purpose Rad Recal.

7 References:

Document #	Rev	Description
7.4.3.7.11.25	1	Rad Cal of SW-RIS-605

8 Setpoint Derivation (Attach additional sheets as required)

Attachment A of 7.4.3.7.11.25
(measured - data).

Engineer Albert J. Davis Date 6 June 90

- 9 ☒ Verification Checklist (or) ☐ Alternate Calculation (attached)
- | |
|---|
| <input checked="" type="checkbox"/> Accuracy of Input Data |
| <input checked="" type="checkbox"/> Validity of Assumptions |
| <input checked="" type="checkbox"/> Appropriateness of Method |
| <input checked="" type="checkbox"/> Arithmetical Accuracy |
- ☒ 10CFR50.59 Review

[Signature]
I&C Engineer or HP/Chemistry Support Supervisor

6-6-90
Date

10 Approval:

[Signature]
HP/Chemistry Manager or Plant Engineering
Supervisor, Control Systems

6-6-90
Date

Attachment A
Page 1 of 2

PROCEDURE NUMBER
1.4.12

REVISION NUMBER
3

PAGE NUMBER

1.4.12-6 of 8

SAFETY RELATED**CONTROLLED COPY****SUMMARY OF RADIOLOGICAL CALIBRATION
RHR SERVICE WATER MONITOR SW-RIS-605**

ISCR # 995

sk. 6 of 6

SW-RIS-605

Date of Calibration 5 March 90**Primary Calibration:**Date of Primary Calibration 26 June 1987Liquid Calibration Factor 4.4298E+6 cps/ μ Ci/mlTransfer Source Identification No. 2-83-85E Isotope ^{132}I Activity 0.427 μ CiTransfer Source Calibration Factor 2991.0 cps/ μ Ci**Current Calibration:**Transfer Source Current Activity 0.4576 μ CiTransfer Source Count Rate 1844.6 \pm 0.64 @ 1% ErrorTransfer Source Calibration Factor 4031 cps/ μ CiCurrent Transfer Source to Primary Calibration Ratio $\frac{4031}{2991} = 1.010$ Recalculated Liquid Calibration Factor 4.535E6 cps/ μ Ci/ml**Instrument Parameters****Detector:**High Voltage Operate 1025 VoltsHigh Voltage Inop 975 VoltsUpper Level Discriminator N/A VoltsLower Level Discriminator 6.4 Volts

Alarm Setpoints from PPM 7.4.3.7.11.68

Low 0.5 cpm High 80 cpm High High 105 cpm

Remarks: _____

Reviewers:Responsible HP or Radiochemist [Signature] Date 5 March 1990HP Support Supervisor [Signature] Date 3-13-90

Attachment A

PROCEDURE NUMBER	REVISION NUMBER	PAGE NUMBER
7.4.3.7.11.25	1	7.4.3.7.11.25-4 of 4

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

WNP-2

INSTRUMENT MASTER DATA SHEET

DIC 1801.1

Rev. No.: 12

E.P. No.: SW-RIS-605 (D17-K605)	Location: 2-E-CP-H13/P604+ N1/9.5
Service: RHR Service Water (Loop B)	BTdg.: W Elev.: 501'
Manufacturer: GE	Sys. No.: 36.0
Model: 368X103AAG001	Flow Diag.: M524 Sh.2 H-14
Serial: 6578410	Logic Diag.: M620 Sh. 524-21
Inst. Range: .1 - 10 ⁵ CPS	Dwg. No. CVI No.
CVI No.: 2-94-1401	Elem. Diag. 807ET68TC-7 2-02-01,5
Quality Class: 1 Seismic Class: 2	Elem. Diag.
Input From E.P. No.: SW-RT-2	Anlg Loop
Output to E.P. No.: K601-4B, SW-RR-2	Instl Detl M619 SH. 174
Acc. Rated: Req.: + 20%	Wiring Diag. GEK-45808 02-02-01,51,1
Loop No.: SW-RIS-605	Parts List
Alarm Location: Local NA	Alarm Location: Remote P602 A5/5-3, 5-5, 3-4
Power Supply and Location: DP-SO-B Bkr. 2	MCR 24 VDC Instr. Bus B See Addenda (2)
Computer Point: NA	Computer Input Term: NA
Surv Proc/PM: CFI 7.4.3.7.11.7/CC 7.4.3.7.11.6B	I&C Cal Procedure: Use Surveillance Proc.

INST. PARAMETERS

Input	Desired Output and Tolerance	Loop Check Data
CPS	METER (Note Addenda)	SW-RR-2 (Green Pen)
1	1 CPS + .2	1 CPS + .2
10	10 CPS + 2	10 CPS + 2
10 ²	10 ² CPS + 20	10 ² CPS + 20
10 ³	10 ³ CPS + 200	10 ³ CPS + 200
10 ⁴	10 ⁴ CPS + 2000	10 ⁴ CPS + 2000
10 ⁵	10 ⁵ CPS + 20000	10 ⁴ CPS + 20000
PB or Gain	Reset	Rate
NA	NA	NA
		Direct Reverse NA

SWITCH FUNCTIONAL DATA

Switch No.	Set/Trip Point + Tolerance	Desired Reset	Trip Indication + Tolerance	Logic Affected
*See Addenda				
Z 16B	(D)0.5 CPS + .1(CC)	Record	0.5 CPS	Failure Alarm
Z 17A	(I)75 CPS + 15(CC)	Record	75 CPS	High Alarm
Z 17B	(I)10 ⁵ + .2 x 10 ⁵	Record	10 ⁵ CPS	High High Alarm

Reviewed By:

M. Widmeyer

Date:

90/6/6

Original!

Re Issue

INSTRUMENT SETPOINT CHANGE REQUEST

ISCR No. 973

O
R
I
G
I
N
A
T
O
R

1. Quality Class: I. II. ✓ G.
 Technical Spec. Instr. Yes ✓ No
 Calculation Required Yes ✓ No Orig Calc

2. Originated by Albert Salas Date 9 July 1990 reissue

3. MEL No. and Function WFA-RIS-14 RW Bldg N6 Off. Mon.

4. Tech. Spec. Section 3/4, 3.11. 2.2 3/4, 3.11. 2.5

5. Tech. Spec. Limit Alarm 202/500mA/sec ODCM 3.6.2

6. Affected Procedures/System Components CFT 7.4.3.7.12.17

Existing Setpoint/Range HVOP 900V LLD -0.497

7. (Admin. Limit/Calib. Tol.) HV ZOP 850V LLD -12.48

8. Reason For Change

Radioactive Recalibration

HV OP 925

HV ZOP 875

U.LD -12.5

LLD -0.5

9. New Setpoint/Range (Admin. Limit/Calib. Tol.)

E
N
G
I
N
E
E
R

1. Necessary Approvals Obtained M. W. Wilmeyer 7/10/90
 Control Systems Eng. Date

2. Orig revised MDS to Plant Records R.S. 7-10-90
 Date

3. Copy of MDS & ISCR to I&C Maint. R.S. 7-10-90
 Date

4. Copy of MDS & ISCR to Operations R.S. 7-10-90
 Date

HP Chem R.S. 7-10-90
 Date

Nuclear License Training R.S. 7-10-90
 Date

5. Setpoint Changes; Calibration Date NA

6. Affected Procedures Revised/Deviated NA 1
 No. Date

Attachment A
 Page 1 of 2

PROCEDURE NUMBER

1.4.3

REVISION NUMBER

9

PAGE NUMBER

1.4.3-8 of 11

SAFETY RELATED**CONTROLLED COPY****10CFR50.59 EVALUATION PROCESS FLOW CHART**

ISCR 973

Sh. 3 of 4

NOTE: The 10CFR50.59 Evaluation implementing processes will typically address items 1 through 4 only and the USQ Analysis would be processed only if required by an affirmative response to question 2, 3, or 4.

YES (1)	1. Is a change to the WNP-2 Technical Specification necessary to implement this activity?	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO
	2. Does this implementing activity constitute a physical change to WNP-2 as described in the FSAR or not in the FSAR and affects nuclear safety in a way not previously evaluated?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	3. Does this implementing activity constitute a change to a procedural commitment as described in the FSAR?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	4. Does this implementing activity represent a special test or experiment not previously described in the FSAR?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<p>If question 1 is answered YES, then prior NRC approval is required prior to implementation.</p> <p>If either question 2, 3 or 4 are answered YES, then an USQ Analysis must be performed.</p>			
YES (2,3,4)			
YES	5. Does the Unreviewed Safety Question Analysis identify the implementing activity as representing an USQ? Refer to Attachment B.	<input type="checkbox"/> YES	<input type="checkbox"/> NO
		(1,2,3,4)	
Activity may not be fully implemented without prior NRC staff approval.		NRC Staff Authorization Received	Implement Activity

NOTE: Upon POC approval, partial implementation may occur without prior NRC staff approval.

Prepared by Albert J. Davis Date 9 July 1990Approved by [Signature] Date 7-9-90

Attachment A

PROCEDURE NUMBER	REVISION NUMBER	PAGE NUMBER
1.3.43	1	1.3.43-10 of 17

SAFETY RELATED**CONTROLLED COPY****INSTRUMENT SETPOINT
CALCULATION***Re-Issue.*1 ISCR # 9732 Sheet 4 of 43 Date 9 July 19904 EPN WEA-RIS-14 5 Description RW Bldg Eff (VC) Mon.6 Purpose Real Re Cal for Detector/Monitor Parameters

7 References:

Document #	Rev	Description
PPM 7.4, 3.7, 12.33	1	Real Cal of WEA-RIS-14
12.13.10	6	RW Bldg Gas off Mon
12.13.26	3	HV plenum of 13-Sect.

8 Setpoint Derivation (Attach additional sheets as required)

*Measured via P.P.M. 12.13.26 and Summarized
on PPM 7.4, 3.7, 12.33*

Engineer *A. Davis* Date 9 July 90

- 9 ☐ Verification Checklist (or) ☐ Alternate Calculation (attached)
- ☐ Accuracy of Input Date
 - ☐ Validity of Assumptions
 - ☐ Appropriateness of Method
 - ☐ Arithmetical Accuracy
- ☐ 106FR50-59 Review

[Signature]
I&C Engineer or HP/Chemistry Support Supervisor7-9-90
Date

10 Approval: *[Signature]*
HP/Chemistry Manager or Plant Engineering
Supervisor, Control Systems

7-9-90
DateAttachment A
Page 1 of 2

PROCEDURE NUMBER 1.4.12	REVISION NUMBER 3	PAGE NUMBER 1.4.12-6 of 8
----------------------------	----------------------	------------------------------

Quality Class: 1. II. ☒ G.
Tech. Spec. Instr. Yes ☒ No

No. 318

Instrument Setpoint Change Request

O
R
I
G
I
N
A
T
O
R

1. Originated by R. G. Graybeal Date 7/26/84
2. MEL No. and Function WEA-RIS-14 Radwaste Building Low Range EEC/Gen + (Gas) monitor
3. Tech. Spec. Section 3.11.2.1, 3.11.2.2, 3.11.2.5 (OXM 3.62)
4. Tech. Spec. Limit 20 % 500 mrem/yr - 1500 mrem/yr
5. Existing Setpoint/Range Low 10 cpm Hi 1350 cpm HiHi 2700 cpm
6. Reason For Change Set point were reviewed based on AUSE-13.10 evaluation of calibration data and in response to a set of Burns & Roe setpoint calculation. New data (calibration) and assumptions were used to determine revised setpoint levels. Burns and Roe used outdated data for their determination of level and their setpoints are not valid.

I
&
C

E
N
G
I
N
E
E
R

1. New Setpoint/Range Low 10 cpm Hi 6000 cpm HiHi 12000 cpm ←
2. Necessary Approvals Obtained M. Hollman 12/14/84
I&C Eng. Date
3. Copy to Originator and I&C Maint. Sup. R. S. 1 9-14-84
I&C Eng. Date
4. Master Data Sheet Index R. S. 1 9-14-84
I&C Eng. Date
5. Setpoint Changes; Calibration Date 9/14/84
6. Operations notified to review and revise Operating Procedures as applicable R. S. 1 9-14-84
I&C Eng. Date



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

ORIGINAL
INSTRUMENT SETPOINT
CHANGE REQUEST

Page 1 of 6
1197

O
R
I
G
I
N
A
T
O
R

Quality Class: 1 ☐ 2 ☐ 2+ ☒ G ☐ MEL EPN: PRM-RR-3

Technical Specification Instr. YES ☒ No ☐

Calculation Required YES ☒ No ☐

Original Calc. No.: 5.52.036

ORIGINATED BY: W.F.Krueger

Tech. Spec. Section: 3/4.3.7.5

Tech. Spec. Limit: NA

Affected Procedures / System Components: 4.602.A5-3.5, EOP's

Existing Setpoint / Range
(Admin. Limit/Calib. Tol.) 100,000 CPM (REA-RIS-19)

Reason For Change:

Implement new setpoint for the RB elevated release as a result of of PMR 90-0305 Stack Monitor Project and preoperational test 8.3.286.

New Setpoint / Range PRM-RR-3 (CHANNEL 1): 180,000 CPS
(Admin. Limit/Calib. Tol.) (8.51vdc \pm 0.3vdc)

A
P
P
R
O
V
A
L
S

Plant Technical Control Sys. Eng.: Alvin L. Orman Date: 7-12-93

System Engineer: W.F. Krueger Date: 7-12-93

Plant Engineering Supervisor: J. L. Seibert Date: 7-12-93

+ HP Chem Manager / Operations: J. Palmer Date: 7-12-93

++ Plant Oper. Committee (or PMR#): 90-0305-3 / 8.3.286 ^{PPM} Date:

+ HP / Chem Manager required only on Rad Monit Setpoints; Operations required only for Admin. Limits and Calibration tolerances for instruments addressed in the Tech. Spec.

++ Required for Technical Specifications Quality Class I, Fire Protection or Security Changes if PMR has not been previously approved by POC.

SEE NEXT PAGE FOR TEMPORARY SETPOINT CHANGE APPROVALS

~~ORIGINAL~~
CHANGE REQUEST

1197

TEMPORARY SETPOINT CHANGE APPROVALSA
P
P
R
O
V
A
L
S

Shift Manager: _____ Date: _____

Plant Engineer: _____ Date: _____

+ HP Chem Manager _____ Date: _____

Affected Procedure(s) Deviated: _____ Date: _____

Procedure No.

+ HP/Chemistry Manager required only on Rad Monit Setpoints; Operations required only for Administrative Limits and Calibration tolerances for instruments addressed in the Tech. Spec.
Forward to Plant Technical Control Systems Engineer

Necessary Approvals ObtainedControl System Engineer: Dennis L. Overman Date: 7/12/93**PROCEDURE REVISIONS / DEVIATIONS**

PROCEDURE NUMBER	REV. No.	DEVIATION No.	INITIAL	Date Comp.
4.602.A5	5		<i>ma</i>	3/7/94
EOP's	Setpt part in EOP the log required		<i>ma</i>	4/19/94

I
M
P
L
E
M
E
N
T
A
T
I
O
NSetpoint Change MWR No: MWR AP4204 Date: 7-22-93Original Revised MDS to Plant Records: R-S Date: 7-16-93**Copy of MDS & ISCR Distributed to**

DEPARTMENT	COMPLETED BY	DATE
I & C MAINTENANCE	R-S	7-16-93
OPERATIONS	R-S	7-16-93
HP / CHEMISTRY	R-S	7-16-93
NUCLEAR LICENSE TRAINING	R-S	



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

ORIGINAL
10 CER 50.59 REVIEW

Implementing Doc. No.

ISCR 1197

(p. 3 of 6)

IMPLEMENTING ACTIVITY DESCRIPTION: This activity implements the High Radiation setpoint as calculated in PPM 8.3.286. That procedure performed radiological calibration of the new gamma spectroscopy system installed for the RB elevated release effluent monitoring. This ISCR implements the new setpoint in accordance with step 8.42.2 of PPM 8.3.286. The new setpoint is 180,000 CPS, corresponding to the ODCM limit of 200 mRem/yr for the Site Boundary dose attributable to RB effluent.

- | | YES | NO |
|---|--------------------------|-------------------------------------|
| 1. Is a change to the WNP-2 Technical Specifications necessary to implement this activity ?
(If response is yes then the activity may not be fully implemented without prior NRC staff approval.) | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 2. Does this implementing activity constitute a change to WNP-2 which could, directly or indirectly, affect the design, design safety function, or method of performing the design safety function of an important to safety SSC as described in the LBD? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 3. Does this implementing activity constitute a change to WNP-2 which could affect nuclear safety in a manner not previously evaluated ? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 4. Does the implementing activity change or affect the intent of a procedure or process from the intent of the comments described, outlined, or summarized in the LBD ? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 5. Does the implementing activity represent a special test or experiment not previously described in the LBD that might affect safe operation of the plant ? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

If there is a yes response to either question 2,3,4 or 5, then a Safety Evaluation must be completed.

If the response to questions 2 through 5 are all NO, a written justification is required. Implementation of the new setpoint allows annunciation in the Main Control Room when Reactor Building effluent reaches 40% of the site boundary. This ensures that the dose rate in the unrestricted areas due to noble gases do not exceed 500 mRem/yr to the whole body or 3000 mRem/yr to the skin as referenced in the LBD.

Is additional justification
information attached ?

YES
☐

NO
☒

References:

Tech. Spec. 3/4.3.7.5, TS Table 3/4.3.7.5-1 (item 31), TSAS #81, (pp. 3/4 3-70 thru 74); TS Bases 3/4.3.7.5 p.B3/4 3-5; ODCM sections 3.2.1, 3.6; ODCM Tables 6.1.2.1-1 (p.122) and 6.1.2.1-1 (p.125); ODCM SCN 93-060; BDC 90-0305-3D DSA Safety Evaluation 93-065; FSAR 11.5.2.2.1.5, FSAR SCN 93-020; PPM 8.3.286 (Reactor Building Stack Effluent Radiation Monitoring System Preoperational Test)

Is additional reference
information attached ?

YES
☐


NO
☒

Prepared by: W.F. KRUEGER

Date: 7/12/93

Reviewed by:

Date: 7/13/93



ORIGINAL
INSTRUMENT SETPOINT
CHANGE REQUEST

1197

INSTRUMENT SETPOINT CALCULATION

MEL EPN: PRM-RR-3 (channel 1)

DESCRIPTION: RB Stack Effluent Rad Monitor

PURPOSE: High Radiation Alarm Setpoint

REFERENCE Doc. No.	REV.	DESCRIPTION
PPM 8.3.286	0	Stack Monitor Preoperational Test
ODCM	Amend.12	Offsite Dose Calculation Manual
PMR 90-0305	0,1,3,5	Project Modification packages
TS 3/4.3.7.5	Amend.117	WNP-2 Technical Specifications
CVI 02-776-00,1,1-6		Stack monitor vendor information

SETPOINT DERIVATION: (Attach additional sheets as required)

Reference attached IOM (Davis to Krueger, dated 7/11/93).

Calculation performed by and attached within preoperational test PPM 8.3.286.


SETPOINT PROVIDED IS 1.8×10^5 CPS. RANGE IS 10^1 TO 10^6 (5 DECADES).

$$\% \text{ of Full scale} = \frac{\log(\text{value:span})}{\text{span}} = \frac{\log(1.024)}{5} = .051$$

$$.851 (10 \text{ VOLT SPAN}) = 8.51 \text{ VOLTS}$$

PRM-HCRM-1B TOLERANCE IS $\pm 0.3VDC$

8.21 JUTS: $[(.821\%)(5 \text{ MCARDS})]_{\text{ALOG}} = 1.2735 \approx 1.3E4 \approx 1.3E5$

8.81 VOLTS: $[.881](5)$ $]_{ACQ} = 2.5409 \approx 2.524 - 2.5$ Engineer 

8.81 VOLTS: $\bar{V}_{AC} = 2.5409$ Engineer

☐ Verification Checklist (or) ☒ Alternate Calculation

 Accuracy of Input Data (attached)

Validity of Assumptions

Appropriateness of Method

Arithmetical Accuracy

☒ 10CFR50.59 Review

I&C Engineer or HP/Chem Support Supervisor Date

Approval:

HP/Chem Manager or Plant Engineering Supervisor, Control Systems Date



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

**INSTRUMENT SETPOINT
CHANGE REQUEST**

ISCR #: Page 5 of 6

1197

INSTRUMENT SETPOINT CALCULATION
CALIB. TOL./ADMIN. LIMIT

MEL EPN: PRM-RR-3 / PRM-LCRM-1B

SERVICE: Stack monitor Intermediate Range radiation

TECH. SPEC. REF	PAGE No.	TRIP SETPOINT	ALLOWABLE VALUE
Table 3/4.3.7.5-1 item 31	3/4 3-70	NA	NA

	HIGH	LOW	REFERENCE
Trip Setpoint / Calibration Tol.			
Admin Limit			
Trip Setpoint / Calibration Tol.			
Admin Limit			
Trip Setpoint / Calibration Tol.			
Admin Limit			

NORMAL OPERATING RANGE	
OPERATING TRANSIENT RANGE	

COMMENT:

	CPS	VDC*
TRIP	1.8×10^5	8.51
Low	1.3×10^5	8.21
HIGH	2.5×10^5	8.81

* UTILIZED FOR
CAL PURPOSES.



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

ISCR 1197
p. 6 of 6

INTEROFFICE MEMORANDUM

DATE: July 11, 1993

TO: W. F. Krueger

System Engineer

PE 27

FROM: A. I. Davis *AK*

R.C.

927H

SUBJECT: Setpoint Calculations for the Reactor Building Effluent Monitoring System.

REFERENCE: ODCM Table 3-3, 6.2.1; FSAR Table 11.34-7, Chapt. 11.3

The set point for the Rx effluent system is based on the stack flow of 97000 cfm, a χ/Q value of $2.7 \text{ E-}07 \text{ sec/m}^3$, and the ODCM limit of 200 mRem/yr for the boundary dose due to the reactor effluent.

Isotope	Whole body dose fraction	Reactor stack $\mu\text{Ci/sec}$	γ conversion factor	Monitor response cps
^{87}Kr	0.052	$6.37\text{E}+3$	0.837	$5.33\text{E}+3$
^{88}Kr	0.13	$6.55\text{E}+3$	1.372	$8.99\text{E}+3$
$^{131\text{m}}\text{Xe}$	0.00064	$5.26\text{E}+3$	0.0196	$1.03\text{E}+2$
^{133}Xe	0.064	$1.61\text{E}+5$	0.367	$5.91\text{E}+4$
$^{135\text{m}}\text{Xe}$	0.41	$9.74\text{E}+4$	0.81	$7.89\text{E}+4$
^{135}Xe	0.18	$7.37\text{E}+4$	0.939	$2.20\text{E}+4$
^{138}Xe	0.18	$1.51\text{E}+4$	1.222	$5.87\text{E}+3$

The sum of the monitor response column is $1.80\text{E}+5$. The addition of the constant background of 800 cps yields the total of $1.81\text{E}+5$ cps. The $\text{cps}/\mu\text{Ci/cc}$ factor for the mid range monitor is $1.457\text{E}+7$.

If there are any questions, contact me.



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

ORIGINAL

UMENT SETPOINT CHANGE REQUEST

ISCR Number:

Page 1 of

1086

Quality Class: 1 ☒ 2 ☒ 2+ ☐ G ☐ MEL EPN: TEA -R15-13
Technical Specification Instr. YES ☒ No ☐
Calculation Required YES ☐ No ☒
Original Calc. No.: _____ ORIGINATED BY: CD Davis

Tech. Spec. Section: 3/4 3.7.12 3/4 . 11.2

Tech. Spec. Limit: 40% & 500 mRem/yr ODCM 3.3, 3.6.2

Affected Procedures / System Components: PPM. 7.4.3.7.12.11
7.4.3.7.12.12

Existing Setpoint / Range HV OP 940' LLD -0.7' Hi = 1730 cpm
(Admin. Limit/Calib. Tol.) HV WOP 890' LLD -12.6' Hi:Hi = 3460 cpm

Reason For Change: Radio metric Recalibration and parameter
evaluation.

Note: Slight Change from old HV settings, old settings would not
trigger detector. New values HV OP 965 volts

HV WOP 915 volts

LLD -0.7 volts

LLD -12.7 volts

NEW HIGH SETPOINT = (1732) (.9692) = 1679 ≈ 1680 cpm

NEW HI-HI SETPOINT = (3462) (.9692) = 3355 ≈ 3350 cpm

New Setpoint / Range HV OP 965 volts LLD -0.7 volts Hi = 1680 cpm
(Admin. Limit/Calib. Tol.) HV WOP 915 volts LLD -12.7 volts Hi-Hi = 3350 cpm

Plant Technical Control Sys. Eng.: W. Widmeyer Date: 9/5/91

System Engineer: Will P. Date: 9-4-91

Plant Engineering Supervisor: [Signature] Date: 9-6-91

+ HP Chem Manager / Operations: [Signature] Date: 9-6-91

++ Plant Oper. Committee (or PMR#): [Signature] Date: 9-6-91

+ HP / Chemistry Manager required only on Rad Monit Setpoints / Operations required only
for Administrative Limits and Calibration tolerances for instruments addressed in the Tech.
Spec.

++ Required for Technical Specifications Quality Class I, Fire Protection or Security Changes
if PMR has not been previously approved by POC.

SEE NEXT PAGE FOR TEMPORARY SETPOINT CHANGE APPROVALS

ORIGINAL

INSTRUMENT SETPOINT CHANGE REQUEST

ISCR NUMBER:

Page 2 of

1086

TEMPORARY SETPOINT CHANGE APPROVALS

APPROVALS

Shift Manager: NA Date: NA

Plant Engineer: _____	Date: _____
-----------------------	-------------

+HP Chem Manager _____ Date: _____

Affected Procedure(s) Deviated: _____ Date: _____

Procedure No. _____

+ HP / Chemistry Manager required only on Rad Monit Setpoints / Operations required only for Administrative Limits and Calibration tolerances for instruments addressed in the Tech. Spec.

Forward to Plant Technical Control Systems Engineer

Necessary Approvals Obtained

Control System Engineer: M. Widmeyer

Date: 9/6/91

PROCEDURE REVISIONS / DEVIATIONS

PROCEDURE NUMBER	REV. No.	DEVIATION No.	INITIAL	Date Comp.
4.602.A5 (4.4)				
EOP's (No chg required)				

IMPLEMENTATION

Setpoint Change MWR No: AR5609 Date: 9/24/91

Original Revised MDS to Plant Records: OLA Date: 2/10/91

Copy of MDS & ISCR Distributed to

DEPARTMENT	COMPLETED BY	DATE
I & C MAINTENANCE	OLA	9/10/91
OPERATIONS	OLA	9/10/91
HP / CHEMISTRY	OLA	9/10/91
NUCLEAR LICENSE TRAINING	OLA	9/10/91
PROCEDURES	OLA	9/10/91

ORIGINAL

SAFETY RELATED**10 CFR 50.59 REVIEW****CONTROLLED COPY**Implementing Doc. No. ISCR 1086P.3Implementing Activity Description Radiological Calibration of turbine Building Effluent
gas monitor TEA-RIS-13

1. Is a change to the WNP-2 Technical Specifications necessary to implement this activity?
(If response is yes, then the activity may not be fully implemented without prior
NRC staff approval)

YES

NO

☐☒

2. Does this implementing activity constitute a change to WNP-2 which could functionally
affect a safety related SSC as described in the LBD?

☐☒

3. Does this implementing activity constitute a change to WNP-2 which could affect nuclear
safety in a manner not previously evaluated?

☐☒

4. Does this implementing activity change or affect the intent of a procedure or process from
the intent of the commitments described, outlined, or summarized in the LBD?

☐☒

5. Does this implementing activity represent a special test or experiment not previously
described in the LBD that might affect safe operation of the Plant?

☐☒

If there is a yes response to either question 2, 3, 4, or 5,
then a Safety Evaluation must be completed

If the responses to questions 2 through 5 are all NO, a written justification is required. the setpoints have been
adjusted as part of the performance of the radiological calibration test the
referenced surveillance procedures to ensure the monitor will continue to
provide alarm functions at the existing technical specification limits in
accordance with the referenced LBD's.

Is additional justification
information attached?

YES

NO

☐☒References 1.5, 3/4, 3.7.12, 3/4, 11.2ODCM 3.3, 3.6.2PSAR 11.5.1.1.2, 11.5.2.2.1.6, table 11.5-1P.P.M. 7.4.3.7.12.11, 7.4.3.7.12.12, 7.4.3.7.12.32P.P.M. 12.13.26, 12.13.9

Is additional reference
information attached?

YES

NO

☐☒

Prepared by

Albert J. Davis

Date

29 July '91

Reviewed by

John R. Allen

Date

8-27-91

558-24431 R1 (12/90) PPM 1.3.43

ATTACHMENT

7.1

PROCEDURE NUMBER
1.3.43REVISION NUMBER
2

PAGE NUMBER

15 of 28