NRR-PMDAPEm Resource

From: Wiebe, Joel

Sent: Wednesday, August 03, 2016 9:14 AM

To: Mitchel Mathews

Cc: Jessica Krejcie; Joseph Bauer

Subject: Request for Additional Information Regarding Relief Request I4R-01

Mitch,

Let me know if you need a teleconference regarding this RAI.

In reviewing the Exelon Generation Company, LLC (Exelon's) submittal dated April 15, 2016 (Agencywide Documents and Access Management System Accession No. ML16106A116), related to relief request I4R-01, for the Byron Station, Unit Nos. 1 and 2, the NRC staff has determined that the following information is needed in order to complete its review:

Provide information regarding: examinations/system/components/degradation mechanisms/class, etc. similar to that provided in Tables 2 and 3 of your letter dated September 7, 2007 (Agencywide Documents Access and Management System Accession No. ML072530024). The information should show a summary of the changes in inspections from the Section XI program and changes from the previous risk informed-inservice inspection (RI-ISI) program (3rd ISI interval) to the proposed RI-ISI program (4th ISI interval). The information should also provide a summary of any deviations from the planned inspections for the previous RI-ISI program (3rd ISI interval) and the reasons for those changes.

Hearing Identifier: NRR_PMDA

Email Number: 2973

Mail Envelope Properties (Joel.Wiebe@nrc.gov20160803091300)

Subject: Request for Additional Information Regarding Relief Request I4R-01

Sent Date: 8/3/2016 9:13:58 AM **Received Date:** 8/3/2016 9:13:00 AM

From: Wiebe, Joel

Created By: Joel.Wiebe@nrc.gov

Recipients:

"Jessica Krejcie" <Jessica.Krejcie@exeloncorp.com>

Tracking Status: None

"Joseph Bauer" < Joseph.Bauer@exeloncorp.com>

Tracking Status: None

"Mitchel Mathews" < Mitchel. Mathews@exeloncorp.com>

Tracking Status: None

Post Office:

Files Size Date & Time

MESSAGE 1111 8/3/2016 9:13:00 AM

Options

Priority:StandardReturn Notification:NoReply Requested:NoSensitivity:Normal

Expiration Date: Recipients Received: