

**From:** [Darby, Paul H:\(GenCo-Nuc\)](#)  
**To:** [Guzman, Richard](#)  
**Cc:** [Furio, Patricia S:\(GenCo-Nuc\)](#); [Mcquighan, James P:\(GenCo-Nuc\)](#); [Jeff Quinn \(jdq@epm-inc.com\)](#); [Bobyock, Stephen J:\(GenCo-Nuc\)](#)  
**Subject:** [External\_Sender] CCNPP NFPA 805 License Amendment Request: Clarifications to final integrated response Recovery Actions for earlier RAIs  
**Date:** Tuesday, August 02, 2016 3:50:08 PM

---

Richard:

Thank you for the opportunity today to discuss the CCNPP NFPA LAR. The final integrated response described in our letter dated April 22, 2016 (ADAMS - ML16117A499 (Reference 15)) provided updated Attachments C and G that supersede our response to SSA RAI 15C and SSA RAI 14.

Recovery actions (RAs) described in our letter dated April 13, 2015 (ADAMS -ML15107A029 (Ref. 11)) provided a response to SSA RAI 15C. Specifically, RAs for VFDRs 18-16-2, 19-01-1, 20-02-1, 21-02-1, and 22-05-2 associated with the loss instrument air were clarified. Subsequent analysis associated with the final integrated plant response determined that RAs for the above VFDRs were not required. The CCNPP response to SSA RAI 15C is superseded by the information in the April 22, 2016 letter.

Recovery actions (RAs) described in our letter dated February 9, 2015 (ADAMS - ML15229A143 (Ref. 9)) provided a response to SSA RAI 14. Specifically, RAs that cross-tie Unit 1 and Unit 2 systems for Fire Areas 18, 19, 20, 22, 25 and 34 were clarified. Subsequent analysis associated with the final integrated plant response determined that RAs to cross-tie Unit 1 and Unit 2 systems were not required. The CCNPP response to SSA RAI 14 is superseded by the information in the April 22, 2016 letter.

Thanks,

**Paul Darby**  
**NFPA-805 Project**  
**Electrical Engineer**  
**410-495-3715**

This Email message and any attachment may contain information that is proprietary, legally privileged, confidential and/or subject to copyright belonging to Exelon Corporation or its affiliates ("Exelon"). This Email is intended solely for the use of the person(s) to which it is addressed. If you are not an intended recipient, or the employee or agent responsible for delivery of this Email to the intended recipient(s), you are hereby notified that any dissemination, distribution or copying of this Email is strictly prohibited. If you have received this message in error, please immediately notify the sender and permanently delete this Email and any copies. Exelon policies expressly prohibit employees from making defamatory or offensive statements and infringing any copyright or any other legal right by Email

communication. Exelon will not accept any liability in respect of such communications. -  
EXCIP