



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**  
WASHINGTON, D.C. 20555-0001

August 11, 2016

Mr. Bryan C. Hanson  
President and Chief Nuclear Officer  
Exelon Nuclear  
4300 Winfield Road  
Warrenville, IL 60555

**SUBJECT: PEACH BOTTOM ATOMIC POWER STATION, UNITS 2 AND 3 –  
CORRECTION TO AMENDMENT NOS. 308 AND 312 REGARDING  
SURVEILLANCE REQUIREMENTS FOR HIGH PRESSURE COOLANT  
INJECTION SYSTEM AND REACTOR CORE ISOLATION COOLING SYSTEM  
(CAC NOS. MF6774 AND MF6775)**

Dear Mr. Hanson:

By letter dated July 5, 2016 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16159A148), the U.S. Nuclear Regulatory Commission (NRC) staff issued Amendments Nos. 308 and 312 to Renewed Facility Operating License Nos. DPR-44 and DPR-56 for the Peach Bottom Atomic Power Station (PBAPS), Units 2 and 3. The amendments: (1) revised the allowable test pressure band in the technical specification (TS) surveillance requirements (SRs) for the pump flow testing of the high pressure coolant injection system and the reactor core isolation system; (2) revised the surveillance frequency requirements for verifying the sodium pentaborate enrichment of the standby liquid control system; and (3) deleted SRs associated with verifying the manual transfer capability of the normal and alternate power supplies for certain motor-operated valves associated with the suppression pool spray and drywell spray sub-systems of the residual heat removal system.

In preparation for implementation of the above referenced amendments, the Exelon Generation Company, LLC (Exelon) staff informed the NRC staff that several of the TS pages revised by Amendment Nos. 308 and 312, did not reflect changes made in PBAPS, Units 2 and 3, Amendment Nos. 297 and 300, issued by the NRC staff on June 30, 2015 (ADAMS Accession No. ML15154A614). The error resulted, in part, due to the wrong camera ready pages being provided by Exelon in support of the issuance of Amendment Nos. 308 and 312. The corrected pages are enclosed.

B. Hanson

- 2 -

If you have any questions, I can be reached at (301) 415-1420 or by e-mail at [Rick.Ennis@nrc.gov](mailto:Rick.Ennis@nrc.gov).

Sincerely,

A handwritten signature in black ink, appearing to read 'RBE', with a long horizontal flourish extending to the right.

Richard B. Ennis, Senior Project Manager  
Plant Licensing Branch I-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-277 and 50-278

Enclosures:

1. Corrected TS pages for Amendment No. 308 to Renewed DPR-44
2. Corrected TS pages for Amendment No. 312 to Renewed DPR-56

cc w/enclosures: Distribution via Listserv

CORRECTIONS TO LICENSE AMENDMENT NO. 308  
PEACH BOTTOM ATOMIC POWER STATION, UNIT 2  
RENEWED FACILITY OPERATING LICENSE NO. DPR-44  
DOCKET NO. 50-277

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change.

Remove  
3.5-13  
3.6-30  
3.6-30b

Insert  
3.5-13  
3.6-30  
3.6-30b

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.5.3.1     Verify the RCIC System locations susceptible to gas accumulation are sufficiently filled with water.</p>	<p>In accordance with the Surveillance Frequency Control Program.</p>
<p>SR 3.5.3.2     -----NOTE----- Not required to be met for system vent flow paths opened under administrative control. -----  Verify each RCIC System manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.</p>	<p>In accordance with the Surveillance Frequency Control Program.</p>
<p>SR 3.5.3.3     -----NOTE----- Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. -----  Verify, with reactor pressure <math>\leq</math> 1053 psig and <math>\geq</math> 915 psig, the RCIC pump can develop a flow rate <math>\geq</math> 600 gpm against a system head corresponding to reactor pressure.</p>	<p>In accordance with the Surveillance Frequency Control Program.</p>
<p>SR 3.5.3.4     -----NOTE----- Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. -----  Verify, with reactor pressure <math>\leq</math> 175 psig, the RCIC pump can develop a flow rate <math>\geq</math> 600 gpm against a system head corresponding to reactor pressure.</p>	<p>In accordance with the Surveillance Frequency Control Program.</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.2.4.1    Verify each RHR suppression pool spray subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position is in the correct position or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program.
SR 3.6.2.4.2    Verify each suppression pool spray nozzle is unobstructed.	In accordance with the Surveillance Frequency Control Program.
SR 3.6.2.4.3    Deleted	
SR 3.6.2.4.4    -----NOTE----- HPSW system related components are excluded. -----  Verify RHR suppression pool spray subsystem locations susceptible to gas accumulation are sufficiently filled with water.	In accordance with the Surveillance Frequency Control Program.

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.2.5.1	Verify each RHR drywell spray subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position is in the correct position or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program.
SR 3.6.2.5.2	Verify each drywell spray nozzle is unobstructed.	In accordance with the Surveillance Frequency Control Program.
SR 3.6.2.5.3	Deleted	
SR 3.6.2.5.4	<p>-----NOTE-----  HPSW system related components are excluded.  -----</p> <p>Verify RHR drywell spray subsystem locations susceptible to gas accumulation are sufficiently filled with water.</p>	In accordance with the Surveillance Frequency Control Program.

CORRECTIONS TO LICENSE AMENDMENT NO. 312  
PEACH BOTTOM ATOMIC POWER STATION, UNIT 3  
RENEWED FACILITY OPERATING LICENSE NO. DPR-56  
DOCKET NO. 50-278

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change.

Remove  
3.5-13  
3.6-30  
3.6-30b

Insert  
3.5-13  
3.6-30  
3.6-30b

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.5.3.1	Verify the RCIC System locations susceptible to gas accumulation are sufficiently filled with water.	In accordance with the Surveillance Frequency Control Program.
SR 3.5.3.2	<p>-----NOTE-----            Not required to be met for system vent flow paths opened under administrative control.            -----</p> <p>Verify each RCIC System manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.</p>	In accordance with the Surveillance Frequency Control Program.
SR 3.5.3.3	<p>-----NOTE-----            Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test.            -----</p> <p>Verify, with reactor pressure <math>\leq 1053</math> psig and <math>\geq 915</math> psig, the RCIC pump can develop a flow rate <math>\geq 600</math> gpm against a system head corresponding to reactor pressure.</p>	In accordance with the Surveillance Frequency Control Program.
SR 3.5.3.4	<p>-----NOTE-----            Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test.            -----</p> <p>Verify, with reactor pressure <math>\leq 175</math> psig, the RCIC pump can develop a flow rate <math>\geq 600</math> gpm against a system head corresponding to reactor pressure.</p>	In accordance with the Surveillance Frequency Control Program.

(continued)



SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.2.4.1	Verify each RHR suppression pool spray subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position is in the correct position or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program.
SR 3.6.2.4.2	Verify each suppression pool spray nozzle is unobstructed.	In accordance with the Surveillance Frequency Control Program.
SR 3.6.2.4.3	Deleted	
SR 3.6.2.4.4	<p>-----NOTE-----  HPSW system related components are excluded.  -----</p> <p>Verify RHR suppression pool spray subsystem locations susceptible to gas accumulation are sufficiently filled with water.</p>	In accordance with the Surveillance Frequency Control Program.

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.2.5.1	Verify each RHR drywell spray subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position is in the correct position or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program.
SR 3.6.2.5.2	Verify each drywell spray nozzle is unobstructed.	In accordance with the Surveillance Frequency Control Program.
SR 3.6.2.5.3	Deleted	
SR 3.6.2.5.4	<p>-----NOTE-----  HPSW system related components are excluded.  -----</p> <p>Verify RHR drywell spray subsystem locations susceptible to gas accumulation are sufficiently filled with water.</p>	In accordance with the Surveillance Frequency Control Program.

B. Hanson

- 2 -

If you have any questions, I can be reached at (301) 415-1420 or by e-mail at [Rick.Ennis@nrc.gov](mailto:Rick.Ennis@nrc.gov).

Sincerely,

*/RA/*

Richard B. Ennis, Senior Project Manager  
Plant Licensing Branch I-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-277 and 50-278

Enclosures:

1. Corrected TS pages for Amendment No. 308 to Renewed DPR-44
2. Corrected TS pages for Amendment No. 312 to Renewed DPR-56

DISTRIBUTION:

PUBLIC	RidsNrrPMPeachBottom Resource
LPL1-2 R/F	RidsNrrLALRonewicz Resource
RidsNrrDorlDpr Resource	RidsACRS_MailCTR Resource
RidsNrrDorlLpl1-2 Resource	RidsRgn1MailCenter Resource
Records Amend	RidsNrrDssStsb Resource

**ADAMS Accession No.: ML16217A008**

OFFICE	DORL/LPL1-2/PM	DORL/LPL1-2/LA	DORL/LPL1-2/BC	DORL/LPL1-2/PM
NAME	REnnis	LRonewicz	DBroaddus	REnnis
DATE	8/10/2016	8/09/2016	8/10/2016	8/11/2016

OFFICIAL RECORD COPY