

Docket File Information

SAFETY INSPECTION REPORT AND COMPLIANCE INSPECTION

1. LICENSEE/LOCATION INSPECTED: DLZ American Drilling, Inc. 4041 Martel Street Melvindale, MI 48122 REPORT NUMBER(S) 2016001	2. NRC/REGIONAL OFFICE Region III U. S. Nuclear Regulatory Commission 2443 Warrenville Road, Suite 210 Lisle, IL 60532-4352
--	---

3. DOCKET NUMBER(S) 030-38854	4. LICENSE NUMBER(S) 21-35256-01	5. DATE(S) OF INSPECTION July 12, 2016
--------------------------------------	---	---

6. INSPECTION PROCEDURES USED 87124	7. INSPECTION FOCUS AREAS All
--	--------------------------------------

SUPPLEMENTAL INSPECTION INFORMATION

1. PROGRAM CODE(S) 03121	2. PRIORITY 5	3. LICENSEE CONTACT Gopalan Govender, PE - RSO	4. TELEPHONE NUMBER (313) 961-4040
---------------------------------	----------------------	---	---

Main Office Inspection Next Inspection Date: 07/12/2021

Field Office Inspection _____

Temporary Job Site Inspection _____

PROGRAM SCOPE

This was an announced initial inspection of a geotechnical consulting firm authorized by a byproduct materials license issued on September 14, 2015, to use or store Troxler portable moisture density gauges at its facility in Melvindale, Michigan, and to use these gauges at temporary job sites in NRC jurisdiction. At the time of the inspection, the licensee possessed one gauge, which it received in May 2016 from the company's office in Columbus, Ohio. The licensee expected to transfer an additional gauge from Columbus to Melvindale in the near future. The company had seven authorized users at the Melvindale office, though only two were considered active. These individuals had so far used the licensee's gauge on two construction projects in eastern Michigan starting in June 2016. The licensee had access to a survey instrument from its Columbus office.

PERFORMANCE OBSERVATIONS

The inspector toured the facility in Melvindale to evaluate the licensee's measures for materials security, hazard communication and exposure control. The inspector conducted independent surveys in and around the gauge storage location; readings at the surface of the gauge were consistent with those indicated in the device's Safety Evaluation in the Sealed Source and Device Registry, while readings in the vicinity of the storage room were indistinguishable from background. The inspector also confirmed that the licensee maintained at least two barriers to secure gauges in storage. The inspector was unable to observe any licensed activities, as none were scheduled or in-progress at the time of the inspection. Instead, the licensee's staff demonstrated the implementation of established procedures for use, transport, emergency response, and routine maintenance of portable gauges. The inspector also discussed with the licensee's management the conduct of gauge user training, periodic audits, and the implementation of tracking mechanisms for various periodic requirements. Through these demonstrations and other discussions, the inspector found the licensee's staff to be knowledgeable of radiation protection principles and regulatory requirements.

The inspector also reviewed a selection of licensee records, including utilization logs, leak test results, inventories, gauge user training, and the licensee's operating and emergency procedures.

BB for ATM