



Entergy Operations, Inc.
1448 S.R. 333
Russellville, AR 72802
Tel 479-858-3110

Clay C. Warren
Acting Vice President, Operations
Arkansas Nuclear One

OCAN081601

August 4, 2016

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
11555 Rockville Pike
Rockville, MD 20852

SUBJECT: Revision to the Entergy Update to the Communication Submittals Associated with Near-Term Task Force Recommendation 9.3
Arkansas Nuclear One – Units 1 and 2
Docket Nos. 50-313 and 50-368
License Nos. DPR-51 and NPF-6

REFERENCE: Entergy Update to the Communication Submittals Associated with Near-Term Task Force Recommendation 9.3, dated January 12, 2016 (OCAN011602) (ML16012A263)

Dear Sir or Madam:

By the above reference, Entergy Operations, Inc. (Entergy), provided an update to the communications assessment for Arkansas Nuclear One (ANO). The purpose of this submittal is to provide a revision to the update to the communications assessment provided in the above reference. Subsequent to the submittal of the above reference, Entergy was informed by the vendor that there was an error in the uninterruptible power supply (UPS) run-time capability analysis. In Sections 4.12.1, 4.12.4, and 4.12.5 of the attachment to the above reference the following revisions are being provided:

4.12.1 – A new UPS has been installed to power the multiplexer and associated equipment. A portable generator is available to provide power beyond the UPS run-time capability.

4.12.4 – A UPS has been installed to provide power for the T1 multiplexer and fiber optic modem. A portable generator is available to be used beyond the UPS run-time capability.

4.12.5 – Additional UPS capability has been installed in the Telephone Room to provide power for the credited equipment in this room. A portable generator is available to be used beyond the UPS run-time capability.

There are no new commitments identified in this submittal. Should you have any questions concerning the content of this letter, please contact Stephenie Pyle at 479.858.4704.

I declare under penalty of perjury that the foregoing is true and correct. Executed on August 4, 2016.

Sincerely,

ORIGINAL SIGNED BY CLAY C. WARREN

CCW/nbm

Regional Administrator
U. S. Nuclear Regulatory Commission, Region IV
1600 East Lamar Boulevard
Arlington, TX 76011-4511

NRC Senior Resident Inspector
Arkansas Nuclear One
P.O. Box 310
London, AR 72847

U. S. Nuclear Regulatory Commission
Attn: Mr. Stephen Koenick
MS O8 B1A
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

U. S. Nuclear Regulatory Commission
Attn: Mr. Peter Bamford
MS O13F15M
One White Flint North
11555 Rockville Pike
Rockville, MD 20852