



August 17, 2016

NRC 2016-0037
10 CFR 50.71(e)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Point Beach Nuclear Plant, Units 1 and 2
Dockets 50-266 and 50-301
License Nos. DPR-24 and DPR-27

Technical Requirements Manual Change Summary

In accordance with 10 CFR 50.71(e), NextEra Energy Point Beach, LLC (NextEra), is submitting changes made to the Point Beach Nuclear Plant Technical Requirements Manual (TRM).

The enclosure contains the TRM change summary for the period January 1, 2015, through December 31, 2015. NextEra previously submitted the TRM change summary for January 1, 2014, through December 31, 2014, on August 11, 2015 (ML15223B293).

This letter contains no new commitments and no revisions to existing commitments.

If you have any questions or require additional information, please contact me at (920) 755-7599.

Sincerely,

NextEra Energy Point Beach, LLC

A handwritten signature in blue ink that reads "Bryan Woyak".

Bryan Woyak
Licensing Manager

Enclosure

cc: Administrator, Region III, USNRC
Project Manager, Point Beach Nuclear Plant, USNRC
Resident Inspector, Point Beach Nuclear Plant, USNRC

ENCLOSURE

NEXTERA ENERGY POINT BEACH, LLC POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

TECHNICAL REQUIREMENTS MANUAL CHANGE SUMMARY FOR 2015

<u>Affected Section</u>	<u>Date of Change</u>	<u>Affected Page(s)</u>	<u>Summary</u>
2.1 (U1)	10/26/15	All	New Core Operating Limits for Unit 1 Cycle 36.
2.1 (U2)	10/15/15	All	New Core Operating Limits for Unit 2 Cycle 35.
2.2	9/24/15	All	References were updated in the Reactor Coolant System Pressure and Temperature Limits Report.
3.3.2	3/16/15	3.3.2-1	Leading Edge Flow Meter (LEFM). Changed "LEFM inoperable" to "LEFM non-functional" to reflect use of functionality vs. operability.
3.7.7	5/14/15	3.7.7-1, 3.7.7-7, 3.7.7-9, 3.7.7-13	Removed reference to 1P-29, turbine driven auxiliary feedwater pump. This pump is no longer impacted by Service Water limitations due to a station modification that resulted in no longer using Service Water for pump bearing cooling.
3.7.7	11/20/15	3.7.7-13	Added "Amendments 199 and 204, Service Water," as a new reference.
4.18	9/24/15	4.18-4	Added NUREG-1022, 10 CFR 50.72, 10 CFR 50.73, and NextEra procedure LI-AA-102-1001 as references for reporting requirements.