

Pollution Control Auth.

DATE OF DOCUMENT:

Nov. 19, 1970

DATE RECEIVED

Feb. 1, 1971

NO.:

439

29211

George ... name

TO:

LTR.

MEMO:

REPORT:

OTHER:

X

ORIG.:

CC:

OTHER:

ACTION NECESSARY

NO ACTION NECESSARY

CONCURRENCE

COMMENT

DATE ANSWERED:

BY:

CLASSIF:

U

POST OFFICE

REG. NO:

FILE CODE:

50-269 50-270 50-287 (ENVIRO FILE)

DESCRIPTION: (Must Be Unclassified)

Ltr trans the following:

REFERRED TO

DATE

RECEIVED BY

DATE

Long

2-2-71

w/4 cys for ACTION

DISTRIBUTION:

Reg File(3)(1 ea docket)

AEC PDR(3)(1 ea docket)

Henderson

Felton

Klecker

Shapar-OGC-Ba-P-506-A

DiNunno

Boyd

DeYoung

DO NOT REMOVE

B. Price SLR

N. Dube

ACKNOWLEDGED

P. Howe(2)

Compliance(2)

Morris/Schroeder

439

ENCLOSURES:

Ltr fm S.C. Dept of Health adv permit to construct cooling water system for Oconee Nuclear Station has been approved .....

(1 cy encl rec'd)

REMARKS:

\*NOTE ABOVE HAND CARRIED & REC'D IN REG RECORDS 1-28-71. CYS MADE FM ORIG & RET TO PAUL BARTON, DUKE POWER CO. REC'D FOR DOCKETING 2-1-71

DL

U.S. ATOMIC ENERGY COMMISSION

MAIL CONTROL FORM FORM AEC-326S (8-60)

50-269 270-287

# South Carolina Pollution Control Authority

PHB

**AUTHORITY MEMBERS**

BERT W. TURNER . . . . CHARLESTON  
CHAIRMAN  
N. MILLER, M.D. . . . . COLUMBIA  
FRANK MIXSON . . . . . GEORGETOWN  
K E. POWERS . . . . . SIMPSONVILLE  
LIAM M. BRICE, JR. . . . . YORK  
F. LAU . . . . . GREENWOOD  
MARION SHIVER, JR. . . . . CAMDEN



HUBERT J. WEBB, PH.D.  
EXECUTIVE DIRECTOR

OWEN BUILDING  
1321 LADY STREET P. O. BOX 11628  
Columbia, South Carolina 29211

**AUTHORITY MEMBERS  
EX-OFFICIO**

E. KENNETH AYCOCK, M.D. . . . . COLUMBIA  
JAMES W. WEBB . . . . . COLUMBIA  
CLAIR P. GUESS, JR. . . . . COLUMBIA  
BOB HICKMAN . . . . . COLUMBIA  
LEWIS E. HENDRICKS . . . . . COLUMBIA  
J. BONNER MANLY . . . . . COLUMBIA


AREA CODE 803  
TELEPHONE: 758-2915

November 19, 1970.

Duke Power Company  
P. O. Box 2178  
Charlotte, North Carolina 28201

Regulatory

File CY-



Attention: Mr. W. S. Lee  
Vice President, Engineering

Re: Oconee Nuclear Station  
Oconee County  
Cooling Water

Dear Sir:

After careful study of plans and data submitted by you, we are happy to forward herewith our Permit to Construct the cooling water system for your Oconee Nuclear Station.

Please let us know when the work is completed so that we may make a pre-operational inspection.


By direction of H. J. Webb, Ph.D., Executive Director, Pollution Control Authority.

Very truly yours,

*George A. Rhame*

George A. Rhame  
Assistant Director

GAR/dkw



439

OK



South Carolina State Board of Health  
Division of Sanitary Engineering  
AND  
Pollution Control Authority  
COLUMBIA, SOUTH CAROLINA

November 19, 1970

Received w/ file dated 11-19-70

Duke Power Company  
P. O. Box 2178  
Charlotte, North Carolina 28201

Regulatory File Cy.

Oconee Nuclear Station

The following project has this day been approved for construction as complying with the Rules and Regulations of the State Board of Health and the South Carolina Pollution Control Authority:

OCONEE COUNTY: Intake and discharge structures for condenser water for the Oconee Nuclear Station.

Water to be taken near the bottom of Lake Keowee from the Little River side and returned to the Toxaway River side.

Maximum water use to be 3,040 mgd.

Temperature requirements of the South Carolina Water Quality Standards to be met at all times.

Approved:

\_\_\_\_\_  
E. Kenneth Aycok, M.D.

*George A. Rhame*

~~XXXXXXXXXX~~ G. A. Rhame, Asst. Dir.  
for H. J. Webb, Exec. Dir.

S. C. State Board of Health File No. \_\_\_\_\_

Pollution Control Construction Permit No. 1727

GAR/dkw

c.c.: County Health Dept., PCA Lab, Mr. Jefferson C. Fuller, Army Engrs.