



**KHNP**

**KOREA HYDRO & NUCLEAR POWER CO., LTD**

70-1312-gil, Yuseong-daero, Yuseong-gu, Daejeon, 305-343, KOREA

Tel: +82-42-870-5400 / Fax: +82-42-870-5449

<http://www.khnp.co.kr>

August 19, 2016  
Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attention: Mr. Jeff Ciocco  
Division of New Reactor Licensing

Docket No. 52-046  
MKD/NW-16-0909L

**Subject: Revised Response to RAI 334-8373 for the Question 03.12-16**

**References: 1) NRC Request for Additional Information 334-8373, dated December 14, 2015**  
**2) KHNP Letter MKD/NW-16-0712L, Response to RAI 334-8373 for Question 03.12-16, dated June 30, 2016**

KHNP is hereby submitting a revised response to RAI 334-8373, dated December 14, 2015. The revised response addresses Question 03.12-16 to clarify the scope of design basis pipe breaks (DBPB) and branch line pipe breaks (BLPB) and the applicability of various Service Level loads.

The enclosure provides the revised response to RAI 334-8373 for the Question 03.12-16 (Non-Proprietary).

If additional information or clarification is required, please contact Daegeun Ahn, Director of KHNP Washington DC Center at [ahn.daegeun@khnp.co.kr](mailto:ahn.daegeun@khnp.co.kr) or 703-388-0592.

Sincerely,

---

Jae-yong Lee  
Project Manager  
Advanced Reactors Development Laboratory  
Korea Hydro and Nuclear Power Co., Ltd

Enclosure: Revised Response to RAI 334-8373 for the Question 03.12-16 (Non-Proprietary)

## **Enclosure**

Revised Response to RAI 334-8373 for the Question 03.12-16

(Non-Proprietary)

August 19, 2016