

NRR-PMDAPem Resource

From: Yale, Ken (DEQ) <YALEK@michigan.gov>
Sent: Thursday, August 18, 2016 11:13 AM
To: Goetz, Sujata
Cc: Skutt, David (DEQ); Keyes, Jennifer (DEQ)
Subject: [External_Sender] RE: Fermi 2 - NRC Issuance of Amendment associated with Surveillance Requirement (SR) 3.5.1.4

Ms. Goetz,

The State of Michigan has no comment on the proposed license amendment described below.

Thank you for providing us with the opportunity to comment.

Sincerely,

Ken

Ken Yale
Chief, Radiological Protection Section
Office of Waste Management and Radiological Protection
Michigan Dept. of Environmental Quality
Constitution Hall, 4th Floor South
525 West Allegan
PO Box 30241, Lansing, MI 48909-7741
Telephone: **517-930-5784**
Fax: 517-373-4797
email: yalek@michigan.gov
Website: www.michigan.gov/deq

From: Goetz, Sujata [mailto:Sujata.Goetz@nrc.gov]
Sent: Wednesday, August 17, 2016 3:26 PM
To: Yale, Ken (DEQ)
Cc: Goetz, Sujata
Subject: RE: Fermi 2 - NRC Issuance of Amendment associated with Surveillance Requirement (SR) 3.5.1.4

Mr. Yale,

The Nuclear Regulatory Commission (NRC) is in the process of approving a license amendment request from DTE Electric Company, for Fermi 2.

The proposed amendment would allow for permanent extension of the Type A primary containment integrated leak rate test interval to 15 years and extension of the Type C test interval up to 75 months. The amendment also proposes two administrative changes. The first change revises Technical Specification (TS) 5.5.12 to remove a one-time extension of the Type A test frequency. The second change would revise the Fermi 2 Operating License, Section D, to remove a reference to an exemption regarding Appendix J testing of containment air lock.

The NRC staff's proposed no significant hazard consideration determination was published in the Federal Register on June 7, 2016 (81 FR 36613).

Please let me know if you have any comments on this action. I can be reached at 301-415-8004.

Thanks,
Sue

Sujata Goetz
Project Manager
NRC, Office of Nuclear Reactor Regulation
NRC/NRR/DORL/LPL3-1, O8C10
Washington, DC 20555-0001
301.415.8004, 301.415.3313 (fax)
Mail Stop O8H4A

Hearing Identifier: NRR_PMDA
Email Number: 3002

Mail Envelope Properties (BN3PR09MB0419731BF28344DBFA807688DE150)

Subject: [External_Sender] RE: Fermi 2 - NRC Issuance of Amendment associated with Surveillance Requirement (SR) 3.5.1.4
Sent Date: 8/18/2016 11:12:37 AM
Received Date: 8/18/2016 11:12:44 AM
From: Yale, Ken (DEQ)

Created By: YALEK@michigan.gov

Recipients:
"Skutt, David (DEQ)" <SkuttD@michigan.gov>
Tracking Status: None
"Keyes, Jennifer (DEQ)" <KEYESJ@michigan.gov>
Tracking Status: None
"Goetz, Sujata" <Sujata.Goetz@nrc.gov>
Tracking Status: None

Post Office: BN3PR09MB0419.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	2006	8/18/2016 11:12:44 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: