

1717 Wakonade Drive  
Welch, MN 55089

800.895.4999  
xcelenergy.com



**AUG 24 2016**

L-PI-16-074  
10 CFR 21

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Prairie Island Nuclear Generating Plant Units 1 and 2  
Dockets 50-282 and 50-306  
Renewed Facility Operating License Nos. DPR-42 and DPR-60

Followup to Interim Report Submitted under 10 CFR 21.21(a)(2)

Reference:

1. S. Northard, NSPM, letter to NRC Document Control Desk, "Interim Report of a Deviation or Failure to Comply," L-PI-16-036, 4/14/2016 (ADAMS Accession Number ML16106A207)

Northern States Power Company, a Minnesota corporation, doing business as Xcel Energy (hereafter "NSPM") submits this followup report to the interim report (Reference 1) submitted pursuant to 10 CFR 21.21(a)(2).

NSPM has completed its evaluation of a high contact resistance discovered during bench testing of a new undervoltage relay manufactured by ABB (Part number 27N411T0375). The relays were returned to the supplier for testing, and all testing of the relay was satisfactory. No nonconformance was identified, and the relay was not modified, nor altered, nor repaired. The condition is not reportable under Part 21.

If there is any question or if additional information is needed, please contact Dr. Glenn A. Carlson, P.E., at 651-267-1755.

Summary of Commitments

This letter contains no new commitment nor revision to an existing commitment.

A handwritten signature in black ink, appearing to read 'Scott Northard'.

Scott Northard  
Site Vice President – Prairie Island Nuclear Generating Plant  
Northern States Power Company – Minnesota

cc: Regional Administrator, Region III, USNRC  
Project Manager, Prairie Island Nuclear Generating Plant, USNRC  
Resident Inspector, Prairie Island Nuclear Generating Plant, USNRC  
State of Minnesota