



*David S. Hoffman  
H. B. Robinson Steam  
Electric Plant Unit 2  
Director – Nuclear Org Effectiveness*

*Duke Energy Progress  
3581 West Entrance Road  
Hartsville, SC 29550*

*O: 843 857 5239  
F: 843 857 1319*

*David.hoffman@duke-energy.com*

10 CFR 72.212(b)(2)

Serial: RNP-RA/16-0069

**AUG 25 2016**

Document Control Desk  
Director, Division of Spent Fuel Storage and Transportation  
Office of Nuclear Material Safety and Safeguards  
United States Nuclear Regulatory Commission  
Washington, DC 20555-0001

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261/RENEWED LICENSE NO. DPR-23

INDEPENDENT SPENT FUEL STORAGE INSTALLATION  
DOCKET NO. 72-60

**REGISTRATION OF USE OF SPENT FUEL CASKS**

Ladies and Gentlemen:

Pursuant to 10 CFR 72.212(b)(2), Duke Energy Progress, hereby provides the following information to register the use of three casks to store spent nuclear fuel in dry storage in the Independent Spent Fuel Storage Installation (ISFSI) at the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2. The fuel is stored under the conditions of a general license.

**Cask Information:**

Licensee Name:	Duke Energy Progress
Licensee Address:	H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2 3581 West Entrance Road Hartsville, SC 29550
Reactor License Number:	DPR-23
Reactor Docket Number:	50-261
ISFSI Docket Number:	72-1004
Information Contact:	Tony Pilo, Manager (Acting) – Nuclear Regulatory Affairs 843-857-1409.
Cask Certificate Number:	1004, Amendment 13
Cask Model Number:	NUHOMS®- 24PTH

Cask Specific Information:

<b>Cask Identification Number</b>	<b>Date Placed in Service</b>	<b>Horizontal Storage Module Number</b>	<b>Heat Load (kW)</b>
RNP24PTH-L-1C-HZ19	07/29/2016	HSM27	26.51
RNP24PTH-L-1C-HZ20	08/03/2016	HSM29	30.70
RNP24PTH-L-1C-HZ21	08/10/2016	HSM28	33.21

The above operations campaign was performed in accordance with the Dry Fuel Storage Cask Certificate of Compliance (CoC) No. 1004, Amendment Number 13.

Sincerely,



David S. Hoffman  
Director – Nuclear Organization Effectiveness

DSH/am

cc: NRC Regional Administrator, NRC, Region II  
Mr. Robert Carrion, NRC, Region II, ISFSI Coordinator  
NRC Resident Inspector, HBRSEP, Unit No. 2  
Mr. Dennis Galvin, NRC Project Manager, NRR