



KHNP

KOREA HYDRO & NUCLEAR POWER CO., LTD

70-1312-gil, Yuseong-daero, Yuseong-gu, Daejeon, 305-343, KOREA

Tel: +82-42-870-5400 / Fax: +82-42-870-5449

<http://www.khnp.co.kr>

August 26, 2016
Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Attention: Mr. Jeff Ciocco
Division of New Reactor Licensing

Docket No. 52-046
MKD/NW-16-0927L

Subject: Revised Response to RAI 91-7867 for Question 14.02-3 (Rev. 2)

- References:**
- 1) NRC Request for Additional Information 91-7867, dated July 20, 2015**
 - 2) KHNP Letter MKD/NW-15-0312L, Response to RAI 91-7867 for Questions on a 60-Day Response Cycle, dated December 9, 2015**
 - 3) KHNP Letter MKD/NW-16-0507L, Revised Response to RAI 91-7867 for Question 14.02-3, dated May 17, 2016**

KHNP is hereby submitting a revised response to RAI 91-7867, dated June 15, 2015. The revised response addresses Question 14.02-3 and adds checks into the ECCS test plans to ensure that the system vents are closed prior to starting the associated pumps. The enclosure provides the revised response to RAI 91-7867 for Question 14.02-3 (Rev. 2) (Non-Proprietary).

If additional information or clarification is required, please contact Daegeun Ahn, Director of KHNP Washington DC Center at ahn.daegeun@khnp.co.kr or 703-388-0592.

Sincerely,

Jae-yong Lee
Project Manager
Advanced Reactors Development Laboratory
Korea Hydro and Nuclear Power Co., Ltd

Enclosure: Revised Response to RAI 91-7867 for Question 14.02-3 (Rev. 2) (Non-Proprietary)

Enclosure

Revised Response to RAI 91-7867 for Question 14.02-3 (Rev. 2)

(Non-Proprietary)

August 26, 2016