

SAFETY EVALUATION OF PROPOSED CHANGES
TO TECHNICAL SPECIFICATIONS OF
OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3

AUXILIARY ELECTRICAL SYSTEMS AND EMERGENCY POWER SYSTEM
SURVEILLANCE AND PERIODIC TESTING

I. INTRODUCTION

The Duke Power Company, by letters dated January 12, 1978, February 1, 1978, and August 22, 1979, submitted a request for amendments to the Technical Specifications related to the auxiliary electrical systems and emergency power system periodic testing for Oconee, Units 1, 2, and 3.

The proposed changes are to:

1. Provide the definition of the emergency power supply system;
2. Provide flexibility in the limiting conditions for operation and surveillance requirements for the 125 Vdc systems;
3. Change the inoperable conditions in terms of the time period from 24 hours for each constituent to 72 hours for one complete single string of the 125 Vdc system;
4. Reword the descriptions of the dc system capacity; and
5. Revise the periodic testing and surveillance of the emergency power sources.

II. BACKGROUND

The offsite power system (see FSAR Figure 8-2) for Oconee Nuclear Power Station, Units 1, 2, and 3 consists of six 230 kV transmission lines to the 230 kV station switchyard and two 500 kV transmission lines to a 500 kV switchyard. The 500 kV switchyard is connected to the 230 kV switchyard via an auto transformer. Offsite power is available to each of the three Oconee units via 230/4.16 kV startup transformers. The switchyards are arranged in breaker-and-a-half configuration and each circuit breaker is provided with dual trip coils supplied from 125-V dc station switching power systems which are independent from the Oconee unit's Class 1E dc systems. The circuit protection is provided by redundant relaying.

Onsite power is provided by two 87.5 MVA hydroelectric generators. This power is available either through the 230 kV switchyard and the 45/60 MVA startup transformers or through a 13.8 kV underground feeder which utilizes its own 12/16/20 MVA transformer (Transf. No. CT4) and supplies two 4160 V main feeder buses in each of the three units. The maximum emergency power demand upon initiation of accident conditions would be 4.8 MVA per unit.

7912180 324

Three divisional 4.16 kV buses per unit are provided for engineered safety feature loads. The divisional buses of each unit can be connected to either of their respective 4.16 kV main feeder buses. The sources of power which are automatically connected to the main feeder buses, in the order that they are connected, are:

1. The 230 kV switchyard via each unit's startup transformer;
2. The preselected hydro unit via the 13.8 kV underground feeder and the station's standby buses; and
3. The other hydro unit via a 230 kV overhead lines, the 230 kV switchyard and each unit's startup transformer.

Also, the following sources of power or startup transformers can be made available manually:

1. One of the gas turbines located 30 miles away at the Lee Steam Station via an independent overhead 100 kV transmission system and the station's standby buses; and
2. The three startup transformers can be manually cross connected via the station's emergency startup buses.

The use of the Keowee Hydro Station and power supply transmission lines including transformers which have been under the direct control of the Oconee Nuclear Power Station was originally reviewed and found acceptable as the stand-by emergency power supply for the Oconee Station during the operating license review.

III. ACCEPTANCE CRITERIA

The criteria that were applied in determining the acceptability of the Technical Specification changes for the ac and dc onsite power supply systems are:

1. General Design Criterion (GDC 17), "Electrical Power Systems," of Appendix A, 10 CFR Part 50;
2. IEEE Std. 308-1974, "Class 1E Power Systems for Nuclear Power Generating Station";
3. IEEE Std. 338-1975, "Periodic Testing of Nuclear Power Generating Station Class 1E Power and Protection Systems";
4. 10 CFR Part 50, Section 50.36 (C) (2), "Limiting Conditions for Operation";
5. Regulatory Guide 1.93, "Availability of Electric Power Sources";
6. Regulatory Guide 1.108, "Periodic Testing of Diesel Generators Used an Onsite Electric Power Systems at Nuclear Power Plants"; and

7. Regulatory Guide 1.6, "Independence Between Redundant Standby (Onsite) Power Sources and Between Their Distribution System."

IV. EVALUATION

In the following five sections, we identify those portions of the Oconee Nuclear Station's Technical Specifications where the licensee has proposed changes, we address the details of our evaluation and the bases for our conclusion on each of the proposed changes.

1. The proposed change to the Section 3.7.1(c) of the Technical Specifications improves the definition of the two emergency power supply systems to precisely describe the components in the two emergency power paths. One path consists of the Keowee hydro unit, the underground feeder, transformer CT 4, and a 4160 volt standby bus. The other path consists of the second Keowee hydro unit, 230 kV overhead lines, breaker PCB 9, and the 230 kV switchyard yellow bus, through the respective operating unit's startup transformer or the aligned and connected alternate startup transformer. The two paths are independent and redundant, and in accordance with IEEE 308-1974, Section 5.2.4.(1) described as "the standby power supply shall consist of all components from the stored energy to the connection to the distribution system's supply circuit breaker."

Each 4160 volt main feeder bus of each unit can receive power from the 230 kV switchyard through the unit's startup transformer, or the aligned and connected alternate startup transformer or through the unit's auxiliary transformer back-fed from the main step-up transformer. The 4160 volt main feeder bus for each unit can also receive power from the 4160 volt standby bus through the 13.8 kV underground feeder supplying transformer CT 4.

Additionally, Specification 3.7.1.(f) has been revised to allow operation utilizing the redundancy present in the 125 Vdc Instrumentation and Control System (I&C). The 125 Vdc I&C power system consists of two batteries, three battery chargers, and two I&C distribution centers per unit. Each of the 125 Vdc I&C distribution (e.g., IDCA or IDCB) centers is normally supplied power from its associated battery charger. One I&C battery and associated charger, however, is capable of supplying two I&C control distribution centers (e.g., IDCA and IDCB) and their associated panel board loads. All reactor protection and engineered safety feature loads on this system can be powered from either the Units 1 and 2 or the Units 2 and 3 or Units 3 and 1, 125 Vdc I&C distribution centers (see FSAR Figure 8-5). Thus, a maximum of only five I&C batteries, with their respective chargers are required to be operable if all three reactors are operating.

The proposed changes to the Technical Specification 3.7.1 demonstrate this installed redundancy and satisfaction of single failure criterion in accordance with Regulatory Guide 1.6, Position D.1, "The electrically powered safety loads (a-c and d-c) should be separated into redundant load groups such that loss of any one group will not prevent the minimum safety functions." We find these changes acceptable.

2. The proposed changes to Section 3.7.2 (a) through (e) of the Technical Specifications provide the limiting conditions for operation on a complete string of power supply rather than on individual components of the ac and dc power supply systems, as is done in the current Standard Technical Specifications. The changes incorporate the definition of the onsite standby power paths in Specification 3.7.1. The licensee's proposals provide more stringent limiting condition for operation (LCO) than the LCO in the current Technical Specifications.

Allowance has also been made for specific test operations associated with 125 Vdc systems. When the discharge test is required to be performed on each battery annually, the accompanying equalizer battery charges required 48 hours more than the 24 hours authorized for inoperability in 125 Vdc systems. The battery charger can supply all connected ESF and reactor protection steady state loads while its battery is returned to or maintained in equalizing charge. The battery discharge service test does not affect adversely the capability and availability of the 125 VDC system during the subsequent 72 hours when the battery is on equalizing charge. We find the proposed changes of Specification 3.7.2 acceptable.

3. The licensee proposed to change the descriptions of and provide the actual maximum load conditions for the bases of the dc system capacity. The actual load condition shown in the revised dc capacity bases is lighter and more practical than that stated in the current Technical Specifications. The changes provide more margin in dc capacity. We find these changes acceptable.
4. The proposed changes to Sections 4.6.9 through 4.6.12 of the Technical Specifications regarding the periodic surveillance testing for the batteries improve the surveillance in terms of test procedures. The surveillance requirements comply with the criteria of IEEE Std. 450 and Regulatory Guide 1.32. Therefore, we find the proposed changes acceptable.
5. The proposed change to Section 4.6.2 is to test the entire emergency underground power path from Keowee hydro unit to engineering safety features (ESF) loads of a shutdown within 25 seconds. Promptly following the above test, the hydro unit will be loaded to at least the combined load of the auxiliaries actuated by ESF signal in one unit and the auxiliaries of the

other two units in hot shutdown by synchronizing the hydro unit to the offsite power system and assuming the load at the maximum practical rate. The current Technical Specification 4.6.2 requires that a Keowee hydro unit carry the equivalent of the maximum safeguards load of one unit within 25 seconds of a simulated requirement for engineered safety features. Under a postulated requirement for emergency power, each Keowee hydro unit is capable of starting and providing necessary power within 25 seconds. If the test were accomplished with a unit shutdown and all of the systems associated with the unit were fully operational, there still would not be sufficient load to run the test. It is not possible to provide the required load within 25 seconds for the test without adverse impact on the operating units. (The test could not be accomplished with a unit operating without causing a reactor trip to occur.) Based on IEEE 338-1975, Standard Criteria for the Periodic Testing of Nuclear Power Generating Station Class 1E Power and Protection Systems, Section 6 (2), "the overlap tests are permitted where full functional tests are not practical," the sequential tests and overlap tests are acceptable. Furthermore, each hydro unit is started and operated daily at power levels in excess of the worst case requirements of the Oconee Station. Starting times of 17 to 19 seconds are typically experienced during these operations. In addition to these daily operations, the automatic controls of the 230 kV switchyard have been qualified as Class 1E and are tested annually for proper operation of the 230 kV switchyard breakers. Therefore, the proposed changes to Technical Specification, which require that each Keowee hydro unit be verified capable of carrying load and available to the ESF load of a shutdown unit on 4160 volt emergency buses with 25 seconds of a simulated requirement for engineered safety features, are acceptable.

V. CONCLUSIONS

Based on our review of:

1. The definition of power paths and the surveillance requirements of the 125 Vdc;
2. The limiting condition for operation of ac and dc power supply;
3. The maximum actual load condition for dc system capacity;
4. The periodic testing surveillance for the batteries; and
5. The test procedure of the ac emergency power supply (Keowee hydro unit),

we conclude that the proposed changes to the Technical Specifications are acceptable.

VI. REFERENCES

1. 10 CFR 50, Appendix A, General Design Criterion 17, Electrical Power System.
2. 10 CFR 50, Section 50.36 (c), (2) Limiting Conditions for Operation.
3. IEEE Std. 308-1974, IEEE Standard Criteria for Class IE Power Systems for Nuclear Power Generating Stations.
4. IEEE Std. 450-1975, IEEE Recommended Practice for Maintenance, Testing and Replacement of Large Lead Storage Batteries for Generating Stations and Substations.
5. Regulatory Guide 1.93, Availability of Electric Power Sources, dated December 1974.
6. Oconee Nuclear Station Technical Specifications, Section 3.7 and 4.6.
7. Letter from Mr. W. O. Parker, Jr. (Duke Power Co) to Mr. E. G. Case (NRC) dated February 1, 1978.
8. Letter from Mr. W. O. Parker, Jr. (DPCO) to Mr. E. G. Case (NRC) dated June 12, 1978.
9. Letter from Mr. W. O. Parker, Jr. (DPCO) to Mr. H. R. Denton (NRC) dated October 31, 1978.
10. Final Safety Analysis Report Oconee, Units 2 and 3.

*DOCKETING & SET
"Sec."
"H" ST*



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

November 7, 1979

11/7/79

Docket Nos: 50-269, 50-270, 50-287,
50-302, 50-312, 50-313,
50-346



TO: ALL BABCOCK & WILCOX (B&W) OPERATING PLANTS
(EXCEPT THREE MILE ISLAND, UNIT 1)

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - BAW REPORT 1564, "INTEGRATED
CONTROL SYSTEM RELIABILITY ANALYSIS"

By letters dated August 31, 1979, each B&W operating plant licensee indicated a general endorsement of B&W's generic report BAW-1564, "Integrated Control System Reliability Analysis."

Our joint review of this report with Oak Ridge National Laboratory has progressed sufficiently to assure ourselves that the recommendations that the report offers with regard to potential areas of improvement in ICS reliability are reasonable. Therefore, we request that you address these recommendations and discuss your followup action plans in this matter. Response to the enclosed request for additional information should be submitted within 14 days of receipt of this letter.

As part of the continuing review of this report, additional areas may be highlighted as requiring improvement. In that event, we will provide additional requests in these specific areas as necessary.

If you cannot meet this schedule or if you require any clarification of these matters please contact Mr. Robert Capra on (301) 492-7745.

Sincerely,

Morton B. Faircliff for


Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Operating Reactors

Enclosure:
As stated

cc: J. Anderson, ORNL
Met-Ed
See attached lists

[Faint, illegible markings]

Enclosure

REQUEST FOR ADDITIONAL INFORMATION
ON REPORT BAW-1564

For the following recommendations from report BAW-1564,

- Describe how you plan to implement the recommendation; and
- The schedule for the implementation; or
- Basis for not implementing the recommendation at your plant.

1. ICS-Related

a. NNI/ICS power supply reliability

NOTE: This area is of particular importance because it is listed as the source of most of the ICS input failures. The staff is not only concerned with the "reliability" of the power supplies, but also the design philosophy of the power supply implementation. It appears that power supply failures can lead to multiple problems such as the Rancho Seco event of March, 1978.

b. Reliability of input signal from the NI/RPS system to the ICS - specifically, the RC flow signal.

c. ICS/BOP system tuning, particularly feedwater condensate systems and the ICS controls.

NOTE: Although this concern is related to tuning, it appears that more basic design and/or operational problems in the feedwater (and related) system may exist.

Therefore, include a discussion of the following items:

- (1) Any particular operational (startup, etc.) problems experienced at your plant with respect to the ICS. Reference to previously submitted information is acceptable.

- (2) Bases for operator intervention in place of automatic ICS action (including start-up, power operation and shutdown activities).
- (3) Procedures used by the operator to perform the operation described in 1c(2) above.
- (4) Additional training provided to the operator.

2. Balance of Plant

- a. Main feedwater pump turbine drive minimum speed control - to prevent loss of main feedwater or indication of main feedwater.
- b. A means to prevent or mitigate the consequences of a stuck-open main feedwater startup valve.
- c. A means to prevent or mitigate the consequences of a stuck-open turbine bypass valve.

BABCOCK & WILCOX ADDRESSEES

RELATED CORRESPONDENCE

Mr. William O. Parker, Jr.
Vice President - Steam Production
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Mr. William Cavanaugh, III
Vice President, Generation
and Construction
Arkansas Power & Light Company
P. O. Box 551
Little Rock, Arkansas 72203


Mr. R. C. Arnold
Senior Vice President
Metropolitan Edison Company
260 Cherry Hill Road
Parsippany, New Jersey 07054

Mr. J. J. Mattimoe
Assistant General Manager and
Chief Engineer
Sacramento Municipal Utility District
6201 S Street
P. O. Box 15830
Sacramento, California 95813

Mr. Lowell E. Roe
Vice President, Facilities
Development
Toledo Edison Company
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652

Mr. W. P. Stewart
Manager, Nuclear Operations
Florida Power Corporation
P. O. Box 14042, Mail Stop C-4
St. Petersburg, Florida 33733

Mr. James H. Taylor
Manager, Licensing
Babcock & Wilcox Company
Power Generation Group
P. O. Box 1260
Lynchburg, Virginia 24505



Arkansas Power & Light Company

Phillip K. Lyon, Esq.
House, Holms & Jewell
1550 Tower Building
Little Rock, Arkansas 72201

Mr. David C. Trimble
Manager, Licensing
Arkansas Power & Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Mr. James P. O'Hanlon
General Manager
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Mr. William Johnson
U. S. Nuclear Regulatory Commission
P. O. Box 2090
Russellville, Arkansas 72801

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 420, 7735 Old Georgetown Road
Bethesda, Maryland 20014

Troy B. Conner, Jr., Esq.
Conner, Moore & Corber
1747 Pennsylvania Avenue, N.W.
Washington, D.C. 20006

Honorable Ermil Grant
Acting County Judge of Pope County
Pope County Courthouse
Russellville, Arkansas 72801

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection Agency
Region VI Office
ATTN: EIS COORDINATOR
1201 Elm Street
First International Building
Dallas, Texas 75270

Director, Bureau of Environmental
Health Services
4815 West Markham Street
Little Rock, Arkansas 72201

Duke Power Company

Mr. William L. Porter
Duke Power Company
Post Office Box 2178
422 South Church Street
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esquire
DeBevoise & Liberman
700 Shoreham Building
806 15th Street, N.W.
Washington, D. C. 20005

Honorable James M. Phinney
County Supervisor of Oconee County
Walhalla, South Carolina 29621

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection Agency
Region IV Office
ATTN: EIS COORDINATOR
345 Courtland Street, N.E.
Atlanta, Georgia 30308

U. S. Nuclear Regulatory Commission
Region II
Office of Inspection and Enforcement
ATTN: Mr. Francis Jape
P. O. Box 85
Seneca, South Carolina 29678

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 420, 7735 Old Georgetown Road
Bethesda, Maryland 20014

Manager, LIS
NUS Corporation
2536 Countryside Boulevard
Clearwater, Florida 33515

Office of Intergovernmental Relations
116 West Jones Street
Raleigh, North Carolina 27603

Florida Power Corporation

Mr. S. A. Brandimore
Vice President and General Counsel
P. O. Box 14042
St. Petersburg, Florida 33733

Mr. Wilbur Langely, Chairman
Board of County Commissioners
Citrus County
Iverness, Florida 36250

U. S. Environmental Protection Agency
Region IV Office
ATTN: EIS COORDINATOR
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection Agency
Crystal Mall #2
Arlington, Virginia 20460

Mr. J. Shreve
The Public Counsel
Room 4 Holland Bldg.
Tallahassee, Florida 32304

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
Montgomery Building
2562 Executive Center Circle, E.
Tallahassee, Florida 32301

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 420, 7735 Old Georgetown Road
Bethesda, Maryland 20014

Bureau of Intergovernmental
Relations
660 Apalachee Parkway
Tallahassee, Florida 32304

Dr. Walter H. Jordan
881 W. Outer Drive
Oak Ridge, Tennessee 37830

Dr. Linda W. Little
5000 Hermitage Drive
Raleigh, North Carolina 27612

Mr. Marvin I. Lewis
6504 Bradford Terrace
Philadelphia, Pennsylvania 19149

Walter W. Cohen, Consumer Advocate
Department of Justice
Strawberry Square, 14th Floor
Harrisburg, Pennsylvania 17127

Robert L. Knupp, Esq.
Assistant Solicitor
Knupp and Andrews
P.O. Box P
407 N. Front Street
Harrisburg, Pennsylvania 17108

John E. Minnich, Chairman
Dauphin Co. Board of Commissioners
Dauphin County Courthouse
Front and Market Sts.
Harrisburg, Pennsylvania 17101

* Atomic Safety and Licensing Appeal Board
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

* Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

* Docketing and Service Section
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Robert Q. Pollard
Chesapeake Energy Alliance
609 Montpelier Street
Baltimore, Maryland 21218

Chauncey Kepford
Judith H. Johnsrud
Environmental Coalition on Nuclear Power
433 Orlando Avenue
State College, Pennsylvania 16801

Ms. Frieda Berryhill, Chairman
Coalition for Nuclear Power Plant
Postponement
2610 Grendon Drive
Wilmington, Delaware 19808

Mrs. Rhoda D. Carr
1402 Marene Drive
Harrisburg, Pennsylvania 17109

Holly S. Keck
Anti-Nuclear Group Representing
York
245 W. Philadelphia Street
York, Pennsylvania 17404

John Levin, Esq.
Pennsylvania Public Utilities Comm.
Box 3265
Harrisburg, Pennsylvania 17120

Jordan D. Cunningham, Esq.
Fox, Farr and Cunningham
2320 North 2nd Street
Harrisburg, Pennsylvania 17110

Theodore A. Adler, Esq.
WIDOFF REAGER SELKOWITZ & ADLER
Post Office Box 1547
Harrisburg, Pennsylvania 17105

Ms. Marjorie M. Aamodt
R.D. #5
Coatesville, Pennsylvania 19320

Ms. Karen Sheldon
Sheldon, Harmon, Roisman & Weiss
1725 I Street, N. W.
Suite 506
Washington, D. C. 20006

Earl B. Hoffman
Dauphin County Commissioner
Dauphin County Courthouse
Front and Market Streets
Harrisburg, Pennsylvania 17101

Ellyn Weiss, Esq.
Sheldon, Harmon, Roisman & Weiss
1725 I Street, N.W.
Suite 506
Washington, D.C. 20006

Mr. Steven C. Sholly
304 South Market Street
Mechanicsburg, Pennsylvania 17055

Mr. Thomas Gerusky
Bureau of Radiation Protection
Department of Environmental Resources
P.O. Box 2063
Harrisburg, Pennsylvania 17120

Metropolitan Edison Company

-2-

G. F. Trowbridge, Esquire
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

GPU Service Corporation
Richard W. Heward, Project Manager
Mr. E. G. Wallace
Licensing Manager
260 Cherry Hill Road
Parsippany, New Jersey 07054

Pennsylvania Electric Company
Mr. R. W. Conrad
Vice President, Generation
1001 Broad Street
Johnstown, Pennsylvania 15907

Miss Mary V. Southard, Chairman
Citizens for a Safe Environment
Post Office Box 405
Harrisburg, Pennsylvania 17108

Dr. Edward O. Swartz
Board of Supervisors
Londonderry Township
RFD#1 - Geyers Church Road
Middletown, Pennsylvania 17057

U. S. Environmental Protection Agency
Region III Office
ATTN: EIS COORDINATOR
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

Mr. J. G. Herbein
Vice President
Metropolitan Edison Company
P. O. Box 480
Middletown, Pennsylvania 17057

Ms. Jane Lee
R.D. 3; Box 3521
Etters, Pennsylvania 17319

Karin W. Carlor, Esq.
505 Executive House
P. O. Box 2357
Harrisburg, Pennsylvania 17120

Honorable Mark Cohen
512 E-3 Main Capital Building
Harrisburg, Pennsylvania 17120

Dauphin County Office Emergency
Preparedness
Court House, Room 7
Front & Market Streets
Harrisburg, Pennsylvania 17101

Department of Environmental Resources
ATTN: Director, Office of Radiological
Health
Post Office Box 2063
Harrisburg, Pennsylvania 17105

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection Agency
Crystal Mall #2
Arlington, Virginia 20460

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 420, 7735 Old Georgetown Road
Bethesda, Maryland 20014

* Ivan W. Smith, Esq.
Atomic Safety & Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Governor's Office of State Planning
and Development
ATTN: Coordinator, Pennsylvania
State Clearinghouse
P. O. Box 1323
Harrisburg, Pennsylvania 17120

Sacramento Municipal Utility
District

David S. Kaplan, Secretary and
General Counsel
6201 S Street
P. O. Box 15830
Sacramento, California 95813

Sacramento County
Board of Supervisors
827 7th Street, Room 424
Sacramento, California 95814

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection Agency
Region IX Office
ATTN: EIS COORDINATOR
215 Fremont Street
San Francisco, California 94111

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 420, 7735 Old Georgetown Road
Bethesda, Maryland 20014

Herbert H. Brown, Esq.
Lawrence Coe Lanpher, Esq.
Hill, Christopher and Phillips, P. C.
1900 M St., NW
Washington, D. C. 20036

Christopher Ellison, Esq.
Dian Gruefich, Esq.
California Energy Commission
1111 Howe Avenue
Sacramento, California 95825

Ms. Eleanor Schwartz
California State Office
600 Pennsylvania Avenue, S.E., Rm. 201
Washington, D.C. 20003

Docketing and Service Section
Office of the Secretary
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Michael L. Glaser, Esq.
1150 17th Street, N.W.
Washington, D.C. 20036

Dr. Richard F. Cole
Atomic Safety and Licensing Board
Panel
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Frederick J. Shon
Atomic Safety and Licensing Board
Panel
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Timothy V. A. Dillon, Esq.
Suite 380
1850 K Street, N.W.
Washington, D.C. 20006

James S. Reed, Esq.
Michael H. Remy, Esq.
Reed, Samuel & Remy
717 K Street, Suite 405
Sacramento, California 95814

Mr. Michael R. Eaton
Energy Issues Coordinator
Sierra Club Legislative Office
1107 9th St., Room 1020
Sacramento, CA 95814

Sacramento Municipal Utility
District

Atomic Safety and Licensing Board
Panel
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Atomic Safety and Licensing Appeal
Board Panel
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Richard D. Castro
2231 K Street
Sacramento, California 95814

Mr. Gary Hursh, Esq.
520 Capital Mall
Suite 700
Sacramento, California 95814

California Department of Health
ATTN: Chief, Environmental
Radiation Control Unit
Radiological Health Section
714 P Street, Room 498
Sacramento, California 95814

Toledo Edison Company

Mr. Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Gerald Charnoff, Esq.
Shaw, Pittman, Potts
and Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Leslie Henry, Esq.
Fuller, Seney, Henry and Hodge
300 Madison Avenue
Toledo, Ohio 43604

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 420, 7735 Old Georgetown Road
Bethesda, Maryland 20014

President, Board of County
Commissioners of Ottawa County
Port Clinton, Ohio 43452

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43215

Harold Kahn, Staff Scientist
Power Siting Commission
361 East Broad Street
Columbus, Ohio 43216,

Docketing and Service Section
Office of the Secretary
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: EIS COORDINATOR
230 South Dearborn Street
Chicago, Illinois 60604

Mr. Samuel J. Chilk, Secretary
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

The Honorable Tim McCormack
Ohio Senate
Statehouse
Columbus, Ohio 43216

The Honorable Tim McCormack
170 E. 209th Street
Euclid, Ohio 44123

Bruce Churchill, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Atomic Safety & Licensing Board Panel
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Atomic Safety and Licensing Appeal Panel
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Toledo Edison Company

Ivan W. Smith, Esq.
Atomic Safety and Licensing Board Panel
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. Cadet H. Hand, Jr.
Director, Bodega Marine Laboratory
University of California
P. O. Box 247
Bodega Bay, California 94923

Dr. Walter H. Jordan
881 W. Outer Drive
Oak Ridge, Tennessee 37830

Ms. Jean DeJuljak
381 East 272
Euclid, Ohio 44117

Mr. Rick Jagger
Industrial Commission
State of Ohio
2323 West 5th Avenue
Columbus, Ohio 43216

Ohio Department of Health
ATTN: Director of Health
450 East Town Street
Columbus, Ohio 43216