



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

September 15, 2016

Mr. Bryan C. Hanson
Senior Vice President
Exelon Generation Company, LLC
President and Chief Nuclear Officer (CNO)
Exelon Nuclear
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: LASALLE COUNTY STATION, UNITS 1 AND 2, CORRECTION LETTER FOR -
LICENSE AMENDMENT NOS. 220 AND 206 RE: REDUCTION IN THE
REACTOR STEAM DOME PRESSURE SPECIFIED IN THE TECHNICAL
SPECIFICATION 2.1.1, "REACTOR CORE SLS" (CAC NOS. MF7109 AND
MF7110)

Dear Mr. Hanson:

By letter dated August 23, 2016 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16155A110), the Nuclear Regulatory Commission (NRC) staff issued Amendment Nos. 220 and 206 to Facility Operating License Nos. NPF-11 and NPF-18 for the LaSalle County Station, Units 1 and 2, respectively. The amendments were in response to your application dated November 19, 2015 (ADAMS Accession No. ML15324A309), as supplemented by letter dated April 11, 2016 (ADAMS Accession No. ML16102A329).


The NRC staff has noticed that for each unit, the amendment numbers on Page 3 of the license, which was issued with the amendment were not updated. The enclosure to this letter provides the corrected Page 3 of the license for each unit. Please note that these corrections do not affect the Safety Evaluation and Conclusions associated with the amendments.

B. C. Hanson

- 2 -

Please contact me if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "B. K. Vaidya", written in a cursive style.

Bhalchandra K. Vaidya, Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosure:
As stated

cc w/encls: Distribution via ListServ

ENCLOSURE

CORRECTION LETTER

CORRECTED PAGES

LASALLE COUNTY STATION

FACILITY OPERATING LICENSE NO. NPF-11 AMENDMENT NO. 220

AND

FACILITY OPERATING LICENSE NO. NPF-18, AMENDMENT NO. 206

DOCKET NOS. 50-373 AND 50-374

Replace the following pages of the Facility Operating Licenses and Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove

License NPF-11
Page 3

License NPF-18
Page 3

Insert

License NPF-11
Page 3

License NPF-18
Page 3

- AM. 146
01/12/01 (4) Exelon Generation Company, LLC, pursuant to the Act and 1 O CFR Parts 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
- Am. 202
07/21/11 (5) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of LaSalle County Station, Units 1 and 2, and such Class Band Class C low-level radioactive waste as may be produced by the operation of Braidwood Station, Units 1 and 2, Byron Station, Units 1 and 2, and Clinton Power Station, Unit 1.

C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 1 O CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

- Am. 198
09/16/10 (1) Maximum Power Level
The licensee is authorized to operate the facility at reactor core power levels not in excess of full power (3546 megawatts thermal).
- Am. 220
08/23/16 (2) Technical Specifications and Environmental Protection Plan
The Technical Specifications contained in Appendix A, as revised Through Amendment No. 220 , and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.
- Am. 194
08/28/09 (3) DELETED
- Am. 194
08/28/09 (4) DELETED
- Am. 194
08/28/09 (5) DELETED
- Am. 194
(6) DELETED
- Am. 194
08/28/09 (7) DELETED

Amendment No. 220

Correction Letter Dated September 15, 2016

Am. 189
07/21/11 (5) Pursuant to the Act and 10 CFR Parts 30, 40, and 70 possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of LaSalle County Station, Units 1 and 2, and such Class B and Class C low-level radioactive waste as may be produced by the operation of Braidwood Station, Units 1 and 2, Byron Station, Units 1 and 2, and Clinton Power Station, Unit 1.

C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

Am. 185
09/16/10 (1) Maximum Power Level

The licensee is authorized to operate the facility at reactor core power n excess of full power (3546 megawatts thermal). Items in Attachment 1 shall be completed as specified. Attachment 1 is hereby incorporated into this license.

Am.206
08 /23/16 (2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 206, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

Am. 181
08/28/09 (3) DELETED

Am. 181
08/28/09 (4) DELETED

Am. 181
08/28/09 (5) DELETED

Am. 181
08/28/09 (6) DELETED

Am. 181
08/28/09 (7) DELETED

Am. 181
08/28/09 (8) DELETED

Am. 181
08/28/09 (9) DELETED

Amendment No. 206

Correction Letter Dated September 15, 2016

B. C. Hanson

- 2 -

Please contact me if you have any questions.

Sincerely,

/RA/

Bhalchandra K. Vaidya, Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosure:
As stated

cc w/encls: Distribution via ListServ

DISTRIBUTION:

PUBLIC	LPL3-2 R/F	RidsNrrPMLaSalle Resource	RidsOgcRp Resource
RidsNrrDirsltsb Resource		RidsRgn3MailCenter Resource	RidsNrrDorlLpl3-2 Resource
RidsNrrDorlDpr Resource		RidsAcrsAcnw_MailCTR Resource	RecordsAmend Resource
J.Mitchell, NRR/DLR		RidsNrrLASRohrer Resource	

ADAMS Accession No. ML16246A153

OFFICE	LPL3-2/PM	LPL3-2/LA	OGC-NLO	LPL3-2/BC	LPL3-2/PM
NAME	BVaidya	SRohrer	JLindell	GEMiller	BVaidya
DATE	09/12/2016	09/06/2016	09/12/2016	09/14/2016	09/15/2016

OFFICIAL RECORD COPY