



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

September 16, 2016

Mr. Peter A. Gardner
Site Vice President
Northern States Power Company - Minnesota
Monticello Nuclear Generating Plant
2807 West County Road 75
Monticello, MN 55362-9637

SUBJECT: MONTICELLO NUCLEAR GENERATING PLANT - INTERIM STAFF
RESPONSE TO REEVALUATED FLOOD HAZARDS SUBMITTED IN
RESPONSE TO 10 CFR 50.54(f) INFORMATION REQUEST – FLOOD-
CAUSING MECHANISM REEVALUATION (CAC NO. MF7712)

Dear Mr. Gardner:

The purpose of this letter is to provide a summary of the U.S. Nuclear Regulatory Commission (NRC) staff's assessment of the reevaluated flood-causing mechanisms described in the May 12, 2016 (Agencywide Document Access and Management System (ADAMS) Accession No. ML16145A233), flood hazard reevaluation report (FHRR) submitted by Northern States Power Company, a Minnesota corporation (the licensee), doing business as Xcel Energy, for Monticello Nuclear Generating Plant (Monticello), as well as supplemental information resulting from the NRC's audit of the FHRR.

By letter dated March 12, 2012, the NRC issued a request for information pursuant to Title 10 of the *Code of Federal Regulations*, Section 50.54(f) (hereafter referred to as the 50.54(f) letter) (ADAMS Accession No. ML12053A340). The request was issued as part of implementing lessons learned from the accident at the Fukushima Dai-ichi nuclear power plant. Enclosure 2 to the 50.54(f) letter requested licensees to reevaluate flood-causing mechanisms using present-day methodologies and guidance. Concurrent with the reevaluation of flooding hazards, licensees were required to develop and implement mitigating strategies in accordance with NRC Order EA-12-049, "Requirements for Mitigation Strategies for Beyond-Design-Basis External Events" (ADAMS Accession No. ML12054A735). On March 30, 2015, the Commission provided the staff requirements memoranda (SRM) (ADAMS Accession No. ML15089A236) to COMSECY-14-0037, "Integration of Mitigating Strategies for Beyond-Design-Basis External Events and the Reevaluation of Flooding Hazards," dated November 21, 2014 (ADAMS Accession No. ML14309A256), affirming that licensees need to address the reevaluated flooding hazards within their mitigating strategies for beyond-design-basis external events.

The NRC staff has reviewed the information submitted by the licensee and has summarized the results of the NRC's review in the tables provided as an enclosure to this letter. Table 1 provides the current design-basis flood hazard mechanisms. Table 2 provides reevaluated

flood hazard mechanisms; however, reevaluated hazard mechanisms bounded by the current design-basis (Table 1) are not included.

The NRC staff has concluded that the licensee's reevaluated flood hazards information, as summarized in the enclosure, is suitable for the assessment of mitigating strategies developed in response to Order EA-12-049 (i.e., defines the mitigating strategies flood hazard information described in guidance documents currently being finalized by the industry and NRC staff) for Monticello. Further, the NRC staff has concluded that the licensee's reevaluated flood hazard information is a suitable input for other assessments associated with Near-Term Task Force Recommendation 2.1, "Flooding." The NRC staff plans to issue a staff assessment documenting the basis for these conclusions at a later time.

Revision 2 of Nuclear Energy Institute (NEI) 12-06 includes a methodology to perform a mitigating strategies assessment (MSA) with respect to the reevaluated flood hazards. On February 29, 2016 the NRC staff published Japan Lessons-Learned Division (JLD) Interim Staff Guidance (ISG) JLD-ISG-2012-01 Revision 1 "Compliance with Order EA-12-049, Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events" (ADAMS Accession No. ML15357A142) in the *Federal Register* (81 FR 10283). This ISG endorses Revision 2 of NEI 12-06 (ADAMS Accession No. ML16005A625), dated December 2015. Based on the guidance provided in Revision 2 of NEI 12-06, flood event duration parameters and applicable flood associated effects should be considered as part of the MSA. The NRC staff will evaluate the flood event duration parameters (including warning time and period of inundation) and flood-related associated effects developed by the licensee during the NRC's review of the MSA.


As stated above, Table 2 of the enclosure to this letter describes the reevaluated flood hazards that exceed the current design-basis. In order to complete its response to the information requested by Enclosure 2 to the 50.54(f) letter, the licensee is expected to submit an integrated assessment or a focused evaluation, as appropriate, to address these reevaluated flood hazards, as described in the NRC letter, "Coordination of Request for Information Regarding Flooding Hazard Reevaluation and Mitigating Strategies for Beyond-Design-Basis External Events" (ADAMS Accession No. ML15174A257). This letter describes the changes in the NRC's approach to the flood hazard reevaluations that were approved by the Commission in its SRM to COMSECY-15-0019, "Closure Plan for the Reevaluation of Flooding Hazards for Operating Nuclear Power Plants" (ADAMS Accession No. ML15209A682).

P. Gardner

- 3 -

If you have any questions, please contact me at (301) 415-1056 or e-mail at Lauren.Gibson@nrc.gov.

Sincerely,

A handwritten signature in cursive script that reads "Lauren K. Gibson".

Lauren K. Gibson, Project Manager
Hazards Management Branch
Japan Lessons-Learned Division
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure:
Summary of Results of Flooding
Hazard Re-Evaluation Report

cc w/encl: Distribution via Listserv

ENCLOSURE:

SUMMARY TABLES OF
REEVALUATED FLOOD HAZARD LEVELS

Table 1. Current Design Basis Flood Hazards for Use in the MSA

Mechanism	Stillwater Elevation	Waves/Runup	Design Basis Hazard Elevation	Reference
Local Intense Precipitation	Not included in DB	Not included in DB	Not included in DB	FHRR Section 1.5, 2.1.3 & Table 5
Streams and Rivers				
Mississippi River Probable Maximum Precipitation	939.2 ft NGVD29	Not applicable	939.2 ft NGVD29	FHRR Section 1.5.1
Failure of Dams and Onsite Water Control/Storage Structures	Not included in DB	Not included in DB	Not included in DB	FHRR Section 1.5
Storm Surge	Not included in DB	Not included in DB	Not included in DB	FHRR Section 1.5
Seiche	Not included in DB	Not included in DB	Not included in DB	FHRR Section 1.5
Tsunami	Not included in DB	Not included in DB	Not included in DB	FHRR Section 1.5
Ice-Induced Flooding	No Impact on the Site Identified	No Impact on the Site Identified	No Impact on the Site Identified	FHRR Section 1.5.2
Channel Migrations/Diversions	Not included in DB	Not included in DB	Not included in DB	FHRR Section 1.5

Note 1: Reported values are rounded to the nearest one-tenth of a foot.

Table 2. Reevaluated Flood Hazards for Flood-Causing Mechanisms for Use in the MSA

Mechanism	Stillwater Elevation	Waves/ Runup	Reevaluated Hazard Elevation	Reference
Local Intense Precipitation	935.8 ft NGVD29	Minimal	935.8 ft NGVD29	FHRR Section 2.1.2 & Tables 5 and 6

Note 1: The licensee is expected to develop flood event duration parameters and applicable flood associated effects to conduct the MSA. The staff will evaluate the flood event duration parameters (including warning time and period of inundation) and flood associated effects during its review of the MSA.

Note 2: Reevaluated hazard mechanisms bounded by the current design basis (see Table 1) are not included in this table

Note 3: Reported values are rounded to the nearest one-tenth of a foot.

P. Gardner

- 3 -

If you have any questions, please contact me at (301) 415-1056 or e-mail at Lauren.Gibson@nrc.gov.

Sincerely,

/RA/

Lauren K. Gibson, Project Manager
Hazards Management Branch
Japan Lessons-Learned Division
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure:
Summary of Results of Flooding
Hazard Re-Evaluation Report

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC	JLD R/F	RidsNRRJLD Resource
LGibson, NRR	LQuinn-Willingham, NRO	RidsNroDsea Resource
RidsNrrDorLpl3-1 Resource	RidsNrrDorI Resource	RidsNrrPMMonticello Resource
RidsRgn3MailCenter Resource	RidsNrrLASLent	RidsOgcMailCenter Resource
RidsOpaMail Resource	RidsAcrcsAcnw_MailCtr Resource	CCook, NRO
ARivera-Varona, NRO	KErwin, NRO	ACampbell, NRO
PChaput, NRO	RRivera-Lugo, NRO	BHarvey, NRO
MShams, NRR		

ADAMS Accession Nos.: PKG ML16248A004; LTR: ML16248A003; ENCL: ML16245A720 *via email

OFFICE	NRR/JLD/JHMB/PM	NRR/JLD/LA	NRO/DSEA/RHM2/TR*	NRO/DSEA/RHM2/BC*
NAME	LKGibson	SLent	PChaput	ARiveraVarona
DATE	09/13 /2016	09/ 9 /2016	09/1/2016	09/1/2016
OFFICE	NRR/JLD/JHMB/BC (A)	NRR/JLD/JHMB/PM		
NAME	GBowman	LKGibson		
DATE	09/ 15/2016	09/16 /2016		

OFFICIAL RECORD COPY