



Scott L. Batson
Vice President
Oconee Nuclear Station

Duke Energy
ON01VP | 7800 Rochester Hwy
Seneca, SC 29672

o 864.873.3274
f 864.873.4208
Scott.Batson@duke-energy.com

ONS-2016-082

September 8, 2016

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, Maryland 20852

Subject: Duke Energy Carolinas, LLC
Oconee Nuclear Station
Docket Numbers 50-269, 50-270, and 50-287
Technical Specification (TS) Bases Change

The attached change to the Oconee Nuclear Station (ONS) TS Bases was processed in accordance with the provisions of Technical Specification 5.5.15, "Technical Specifications (TS) Bases Control Program."

TS Bases 3.4.16, Steam Generator (SG) Tube Integrity, was revised to reflect the changes approved by Amendment Nos. 396, 398, and 397, which clarified and relaxed aspects of the SG tube inspection TS requirements per TSTF-510, "Revision to Steam Generator Program Inspection Frequencies and Tube Sample Selection."

Any questions regarding this information should be directed to David Haile, ONS Regulatory Affairs, at (864) 873-4742.

Sincerely,

Scott L. Batson
Vice President
Oconee Nuclear Station

Attachment

A001
NRR

U. S. Nuclear Regulatory Commission
September 8, 2016
Page 2

cc: Ms. Catherine Haney
Administrator, Region II
U.S. Nuclear Regulatory Commission, Region II
Marquis One Tower
245 Peachtree Center Ave., NE, Suite 1200
Atlanta, GA 30303-1257

Mr. James R. Hall, Senior Project Manager (ONS)
(By electronic mail only)
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
11555 Rockville Pike
Mail Stop O-8G9A
Rockville, MD 20852

Mr. Eddy L. Crowe
Senior Resident Inspector
Oconee Nuclear Station

Attachment

TSB List of Effective Pages (LOEPs), Rev. 011	LOEP 1 - 4
TSB 3.4.16 - Steam Generator Integrity, Rev. 001	3.4.16 1 -6

OCONEE NUCLEAR STATION
 TECHNICAL SPECIFICATIONS-BASES REVISED 08/23/16
 LIST OF EFFECTIVE PAGES

<u>SECTION/PAGES</u>	<u>REVISION NUMBER</u>	<u>IMPLEMENTATION DATE</u>
TOC	000	09/03/14
B 2.1.1	000	05/31/12
B 2.1.2	000	02/06/14
B 3.0	000	10/20/11
B 3.1.1	000	05/16/12
B 3.1.2	000	05/16/12
B 3.1.3	000	06/02/99
B 3.1.4	000	07/23/12
B 3.1.5	000	05/16/12
B 3.1.6	000	07/23/12
B 3.1.7	000	07/23/12
B 3.1.8	000	05/16/12
B 3.2.1	000	05/16/12
B 3.2.2	000	05/16/12
B 3.2.3	000	05/16/12
B 3.3.1	002	07/14/16
B 3.3.2	000	12/14/04
B 3.3.3	000	12/10/14
B 3.3.4	000	12/10/14
B 3.3.5	000	12/10/14
B 3.3.6	000	12/10/14
B 3.3.7	000	12/10/14
B 3.3.8	000	05/16/12
B 3.3.9	000	05/16/12
B 3.3.10	000	05/16/12
B 3.3.11	000	05/16/12
B 3.3.12	000	05/16/12

OCONEE NUCLEAR STATION
 TECHNICAL SPECIFICATIONS-BASES REVISED 08/23/16
 LIST OF EFFECTIVE PAGES

<u>SECTION/PAGES</u>	<u>REVISION NUMBER</u>	<u>BASES REVISION DATE</u>
B 3.3.13	000	05/16/12
B 3.3.14	000	05/16/12
B 3.3.15	000	05/16/12
B 3.3.16	000	05/16/12
B 3.3.17	000	05/16/12
B 3.3.18	000	05/16/12
B 3.3.19	000	05/16/12
B 3.3.20	000	05/16/12
B 3.3.21	000	05/16/12
B 3.3.22	000	05/16/12
B 3.3.23	000	05/16/12
B 3.3.24	000	09/26/01
B 3.3.25	000	11/05/03
B 3.3.26	000	11/05/03
B 3.3.27	000	12/10/14
B 3.3.28	000	05/16/12
B 3.4.1	000	05/16/12
B 3.4.2	000	12/16/98
B 3.4.3	000	03/04/15
B 3.4.4	001	07/14/16
B 3.4.5	000	05/16/12
B 3.4.6	000	05/16/12
B 3.4.7	000	05/16/12
B 3.4.8	000	05/16/12
B 3.4.9	000	05/16/12
B 3.4.10	001	09/21/15
B 3.4.11	000	10/12/12
B 3.4.12	000	06/13/14

OCONEE NUCLEAR STATION
 TECHNICAL SPECIFICATIONS-BASES REVISED 08/23/16
 LIST OF EFFECTIVE PAGES

<u>SECTION/PAGES</u>	<u>REVISION NUMBER</u>	<u>BASES REVISION DATE</u>
B 3.4.13	000	05/16/12
B 3.4.14	001	09/21/15
B 3.4.15	001	11/24/15
B 3.4.16	001	08/23/16
B 3.5.1	000	05/16/12
B 3.5.2	002	01/19/16
B 3.5.3	001	09/21/15
B 3.5.4	000	05/16/12
B 3.6.1	000	10/20/11
B 3.6.2	000	05/16/12
B 3.6.3	000	05/16/12
B 3.6.4	000	05/16/12
B 3.6.5	001	09/21/15
B 3.7.1	001	09/21/15
B 3.7.2	000	11/13/12
B 3.7.3	001	09/21/15
B 3.7.4	001	01/19/16
B 3.7.5	001	09/21/15
B 3.7.6	000	05/16/12
B 3.7.7	000	12/10/14
B 3.7.8	000	05/16/12
B 3.7.9	000	08/28/14
B 3.7.10	002	06/14/16
B 3.7.10a	000	09/03/14
B 3.7.11	000	05/16/12
B 3.7.12	000	05/16/12
B 3.7.13	000	08/19/10
B 3.7.14	000	05/16/12

OCONEE NUCLEAR STATION
TECHNICAL SPECIFICATIONS-BASES REVISED 08/23/16
LIST OF EFFECTIVE PAGES

<u>SECTION/PAGES</u>	<u>REVISION NUMBER</u>	<u>BASES REVISION DATE</u>
B 3.7.15	000	10/24/07
B 3.7.16	000	05/16/12
B 3.7.17	000	04/12/06
B 3.7.18	000	06/15/06
B 3.7.19	001	03/10/16
B 3.8.1	001	07/14/16
B 3.8.2	000	04/07/11
B 3.8.3	000	04/28/15
B 3.8.4	000	12/18/07
B 3.8.5	000	05/16/12
B 3.8.6	000	05/16/12
B 3.8.7	000	05/16/12
B 3.8.8	000	05/16/12
B 3.8.9	000	05/16/12
B 3.9.1	000	05/16/12
B 3.9.2	000	05/16/12
B 3.9.3	000	05/16/12
B 3.9.4	000	05/16/12
B 3.9.5	000	05/16/12
B 3.9.6	000	05/16/12
B 3.9.7	000	05/16/12
B 3.9.8	000	06/25/14
B 3.10.1	000	11/05/14
B 3.10.2	000	11/05/14

Note: With the introduction of Fusion in June 2015, all controlled documents require a three-digit revision number. Thus, the revision numbers were set to "000" in the summer of 2015. As such, the revision dates for Revision 000 are based on the implementation dates for revisions in effect prior to this change.

B 3.4 REACTOR COOLANT SYSTEM (RCS)

B 3.4.16 Steam Generator (SG) Tube Integrity

BASES

BACKGROUND

Steam generator (SG) tubes are small diameter, thin walled tubes that carry primary coolant through the primary to secondary heat exchangers. The SG tubes have a number of important safety functions. Steam generator tubes are an integral part of the reactor coolant pressure boundary (RCPB) and, as such, are relied on to maintain the primary system's pressure and inventory. The SG tubes isolate the radioactive fission products in the primary coolant from the secondary system. In addition, as part of the RCPB, the SG tubes are unique in that they act as the heat transfer surface between the primary and secondary systems to remove heat from the primary system. This Specification addresses only the RCPB integrity function of the SG. The SG heat removal function is addressed by LCO 3.4.4, "RCS Loops - MODES 1 and 2," LCO 3.4.5, "RCS Loops - MODE 3," LCO 3.4.6, "RCS Loops - MODE 4," and LCO 3.4.7, "RCS Loops - MODE 5, Loops Filled."

SG tube integrity means that the tubes are capable of performing their intended RCPB safety function consistent with the licensing basis, including applicable regulatory requirements.

Steam generator tubing is subject to a variety of degradation mechanisms. Steam generator tubes may experience tube degradation related to corrosion phenomena, such as wastage, pitting, intergranular attack, and stress corrosion cracking, along with other mechanically induced phenomena such as denting and wear. These degradation mechanisms can impair tube integrity if they are not managed effectively. The SG performance criteria are used to manage SG tube degradation.

Specification 5.5.10, "Steam Generator (SG) Program," requires that a program be established and implemented to ensure that SG tube integrity is maintained. Pursuant to Specification 5.5.10, tube integrity is maintained when the SG performance criteria are met. There are three SG performance criteria: structural integrity, accident induced leakage, and operational LEAKAGE. The SG performance criteria are described in Specification 5.5.10. Meeting the SG performance criteria provides reasonable assurance of maintaining tube integrity at normal and accident conditions.

The processes used to meet the SG performance criteria are defined by the Steam Generator Program Guidelines (Ref. 1).

BASES

APPLICABLE
SAFETY
ANALYSES

The steam generator tube rupture (SGTR) accident is the limiting design basis event for SG tubes and avoiding an SGTR is the basis for this Specification. The analysis of a SGTR event assumes a bounding primary to secondary LEAKAGE rate equal to the operational LEAKAGE rate limits in LCO 3.4.13, "RCS Operational LEAKAGE," plus the leakage rate associated with a double-ended rupture of a single tube. The accident analysis for a SGTR assumes cooldown via the main steam atmosphere dump valves.

The analysis for design basis accidents and transients other than a SGTR assume the SG tubes retain their structural integrity (i.e., they are assumed not to rupture.) In these analyses, the steam discharge to the atmosphere bounds the primary to secondary LEAKAGE of 150 gallons per day per SG. For accidents that do not involve fuel damage, the primary coolant activity level of DOSE EQUIVALENT I-131 is assumed to be equal to the LCO 3.4.16, "RCS Specific Activity," limits. For accidents that assume fuel damage, the primary coolant activity is a function of the amount of activity released from the damaged fuel. The dose consequences of these events are within the limits of GDC 19 (Ref. 2), 10 CFR 100 (Ref. 3) or the NRC approved licensing basis (e.g., a small fraction of these limits).

Steam generator tube integrity satisfies Criterion 2 of 10 CFR 50.36(c)(2)(ii).

LCO

The LCO requires that SG tube integrity be maintained. The LCO also requires that all SG tubes that satisfy the plugging criteria be plugged in accordance with the Steam Generator Program.

During an SG inspection, any inspected tube that satisfies the Steam Generator Program plugging criteria is removed from service by plugging. If a tube was determined to satisfy the plugging criteria but was not plugged, the tube may still have tube integrity.

In the context of this Specification, a SG tube is defined as the entire length of the tube, including the tube wall, between the tube-to-tubesheet weld at the tube inlet and the tube-to-tubesheet weld at the tube outlet. The tube-to-tubesheet weld is not considered part of the tube.

A SG tube has tube integrity when it satisfies the SG performance criteria. The SG performance criteria are defined in Specification 5.5.10, "Steam Generator Program," and describe acceptable SG tube performance. The Steam Generator Program also provides the evaluation process for determining conformance with the SG performance criteria.

There are three SG performance criteria: structural integrity, accident induced leakage, and operational LEAKAGE. Failure to meet any one of these criteria is considered failure to meet the LCO.

BASES

LCO (continued)

The structural integrity performance criterion provides a margin of safety against tube burst or collapse under normal and accident conditions, and ensures structural integrity of the SG tubes under all anticipated transients included in the design specification. Tube burst is defined as, "The gross structural failure of the tube wall. The condition typically corresponds to an unstable opening displacement (e.g., opening area increased in response to constant pressure) accompanied by ductile (plastic) tearing of the tube material at the ends of the degradation." Tube collapse is defined as, "For the load displacement curve for a given structure, collapse occurs at the top of the load versus displacement curve where the slope of the curve becomes zero." The structural integrity performance criterion provides guidance on assessing loads that have a significant effect on burst or collapse. In that context, the term "significant" is defined as "An accident loading condition other than differential pressure is considered significant when the addition of such loads in the assessment of the structural integrity performance criterion could cause a lower structural limit or limiting burst/collapse condition to be established." For tube integrity evaluations, except for circumferential degradation, axial thermal loads are classified as secondary loads. For circumferential degradation, the classification of axial thermal loads as primary or secondary loads will be evaluated on a case-by-case basis. The division between primary and secondary classifications will be based on detailed analysis and/or testing.

Structural integrity requires that the primary membrane stress intensity in a tube not exceed the yield strength for all ASME Code, Section III, Service Level A (normal operating conditions) and Service Level B (upset or abnormal conditions) transients included in the design specification. This includes safety factors and applicable design basis loads based on ASME Code, Section III, Subsection NB (Ref. 4) and Draft Regulatory Guide 1.121 (Ref. 5).

The accident induced leakage performance criterion ensures that the primary to secondary LEAKAGE caused by a design basis accident, other than a SGTR, is within the accident analysis assumptions. The accident analysis assumes that accident induced leakage does not exceed 150 gallons per day per SG. The accident induced leakage rate includes any primary to secondary LEAKAGE existing prior to the accident in addition to primary to secondary LEAKAGE induced during the accident.

The operational LEAKAGE performance criterion provides an observable indication of SG tube conditions during plant operation. The limit on operational LEAKAGE is contained in LCO 3.4.13, "RCS Operational LEAKAGE," and limits primary to secondary LEAKAGE through any one SG to 150 gallons per day. This limit is based on the assumption that a single crack leaking this amount would not propagate to a SGTR under the stress conditions of a LOCA or a main steam line break. If this amount of LEAKAGE is due to more than one crack, the cracks are very small, and the above assumption is conservative.

BASES

APPLICABILITY Steam generator tube integrity is challenged when the pressure differential across the tubes is large. Large differential pressures across SG tubes can only be experienced in MODE 1, 2, 3, or 4.

RCS conditions are far less challenging in MODES 5 and 6 than during MODES 1, 2, 3, and 4. In MODES 5 and 6, primary to secondary differential pressure is low, resulting in lower stresses and reduced potential for LEAKAGE.

ACTIONS

The ACTIONS are modified by a Note clarifying that the Conditions may be entered independently for each SG tube. This is acceptable because the Required Actions provide appropriate compensatory actions for each affected SG tube. Complying with the Required Actions may allow for continued operation, and subsequent affected SG tubes are governed by subsequent Condition entry and application of associated Required Actions.

A.1 and A.2

Condition A applies if it is discovered that one or more SG tubes examined in an inservice inspection satisfy the tube plugging criteria but were not plugged in accordance with the Steam Generator Program as required by SR 3.4.16.2. An evaluation of SG tube integrity of the affected tube(s) must be made. Steam generator tube integrity is based on meeting the SG performance criteria described in the Steam Generator Program. The SG plugging criteria define limits on SG tube degradation that allow for flaw growth between inspections while still providing assurance that the SG performance criteria will continue to be met. In order to determine if a SG tube that should have been plugged has tube integrity, an evaluation must be completed that demonstrates that the SG performance criteria will continue to be met until the next refueling outage or SG tube inspection, whichever is shorter. The tube integrity determination is based on the estimated condition of the tube at the time the situation is discovered and the estimated growth of the degradation prior to the next SG tube inspection. If it is determined that tube integrity is not being maintained, Condition B applies.

A Completion Time of 7 days is sufficient to complete the evaluation while minimizing the risk of plant operation with a SG tube that may not have tube integrity.

If the evaluation determines that the affected tube(s) have tube integrity, Required Action A.2 allows plant operation to continue until the next refueling outage or SG inspection provided the inspection interval continues to be supported by an operational assessment that reflects the affected tubes. However, the affected tube(s) must be plugged prior to entering MODE 4 following the next refueling outage or SG inspection. This Completion Time is acceptable since operation until the next inspection is supported by the operational assessment.

BASES

ACTIONS
(continued)

B.1 and B.2

If the Required Actions and associated Completion Times of Condition A are not met or if SG tube integrity is not being maintained, the reactor must be brought to MODE 3 within 12 hours and MODE 5 within 36 hours.

The allowed Completion Times are reasonable, based on operating experience, to reach the desired plant conditions from full power conditions in an orderly manner and without challenging plant systems.

SURVEILLANCE
REQUIREMENTS

SR 3.4.16.1

During shutdown periods the SGs are inspected as required by this SR and the Steam Generator Program. NEI 97-06, Steam Generator Program Guidelines (Ref. 1), and its referenced EPRI Guidelines, establish the content of the Steam Generator Program. Use of the Steam Generator Program ensures that the inspection is appropriate and consistent with accepted industry practices.

During SG inspections a condition monitoring assessment of the SG tubes is performed. The condition monitoring assessment determines the "as found" condition of the SG tubes. The purpose of the condition monitoring assessment is to ensure that the SG performance criteria have been met for the previous operating period.

The Steam Generator Program determines the scope of the inspection and the methods used to determine whether the tubes contain flaws satisfying the tube plugging criteria. Inspection scope (i.e., which tubes or areas of tubing within the SG are to be inspected) is a function of existing and potential degradation locations. The Steam Generator Program also specifies the inspection methods to be used to find potential degradation. Inspection methods are a function of degradation morphology, non-destructive examination (NDE) technique capabilities, and inspection locations.

The Steam Generator Program defines the Frequency of SR 3.4.16.1. The Frequency is determined by the operational assessment and other limits in the SG examination guidelines (Ref. 6). The Steam Generator Program uses information on existing degradations and growth rates to determine an inspection Frequency that provides reasonable assurance that the tubing will meet the SG performance criteria at the next scheduled inspection. In addition, Specification 5.5.10 contains prescriptive requirements concerning inspection intervals to provide added assurance that the SG performance criteria will be met between scheduled inspections. If crack indications are found in any SG tube, the maximum inspection interval for all affected, and potentially affected, SGs is restricted by Technical Specification 5.5.10, until subsequent inspection results support extending the inspection interval.

BASES

SURVEILLANCE
REQUIREMENTS (continued)

SR 3.4.16.2

During an SG inspection, any inspected tube that satisfies the Steam Generator Program plugging criteria is removed from service by plugging. The tube plugging criteria delineated in Specification 5.5.10 are intended to ensure that tubes accepted for continued service satisfy the SG performance criteria with allowance for error in the flaw size measurement and for future flaw growth. In addition, the tube plugging criteria, in conjunction with other elements of the Steam Generator Program, ensure that the SG performance criteria will continue to be met until the next inspection of the subject tube(s). Reference 1 provides guidance for performing operational assessments to verify that the tubes remaining in service will continue to meet the SG performance criteria.

The Frequency of prior to entering MODE 4 following a SG inspection ensures that the Surveillance has been completed and all tubes meeting the plugging criteria are plugged prior to subjecting the SG tubes to significant primary to secondary pressure differential.

REFERENCES

1. NEI 97-06, "Steam Generator Program Guidelines."
 2. 10 CFR 50 Appendix A, GDC 19.
 3. 10 CFR 100.
 4. ASME Boiler and Pressure Vessel Code, Section III, Subsection NB.
 5. Draft Regulatory Guide 1.121, "Basis for Plugging Degraded Steam Generator Tubes," August 1976.
 6. EPRI, "Pressurized Water Reactor Steam Generator Examination Guidelines."
-