

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8308260006 DOC. DATE: 83/08/22 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H.B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director
 STOLZ, J.F. Operating Reactors Branch 4

SUBJECT: Forwards updated schedule re installation of replacement
 Limitorgue motor-operated valves. Target date for Unit 1
 extended to Mar 1985, due to shipping delays. Dates for Units
 2 & 3 remain as previously committed.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein:1cy. 05000269
 AEOD/Ornstein:1cy. 05000270
 AEOD/Ornstein:1cy. 05000287

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	NRR	ORB4 BC 01	7	7					
INTERNAL:	ELD/HDS4		1	0	NRR/DE/MTEB		1	1	
	NRR/DL DIR		1	1	NRR/DL/ORAB		1	0	
	NRR/DSI/METB		1	1	NRR/DSI/RAB		1	1	
	<u>REG FILE</u>	04	1	1	RGN2		1	1	
EXTERNAL:	ACRS	09	6	6	LPDR	03	1	1	
	NRC PDR	02	1	1	NSIC	05	1	1	
	NTIS		1	1					
NOTES:			1	1					

TOTAL NUMBER OF COPIES REQUIRED: LTTR 26 ENCL 24

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

August 22, 1983

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Sir:

The purpose of this letter is to revise a previously made commitment, contained in Duke letter dated February 25, 1982 concerning the replacement Limitorque motor-operated valves. Due to shipping delays and the earlier than originally planned refueling outage for Unit 1, the committed date of first refueling outage after January 1, 1983 was not met. The new commitment date is March 1985 during the next refueling outage of Oconee 1. With regard to the other Oconee units, the intended installation dates remain as previously committed.

For the information of the NRC Staff, attached is an updated version of Table 1 of Duke letter dated May 19, 1983.

Very truly yours,

Hal B Tucker by WAH
Hal B. Tucker

RLG/php

Attachment

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Mr. J. C. Bryant
NRC Resident Inspector
Oconee Nuclear Station

Mr. John F. Suermann
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8308260004 830822
PDR ADOCK 05000269
P PDR

*Acc 1
1/1*

TABLE 1
 OCONEE NUCLEAR STATION - UNITS 1, 2, AND 3
 RESOLUTION OF NRC/FRC TECHNICAL EVALUATION REPORT ITEMS
 TER CATEGORY I.B ITEMS - REPLACEMENT SCHEDULE*

TER			PLANT ID	SCHEDULED OUTAGE DATE FOR REPLACEMENT		
UNIT 1	UNIT 2	UNIT 3		UNIT 1	UNIT 2	UNIT 3
52, 54, 55 70 71 72, 73	5, 7 17, 18, 69 19 58, 60 66 67 68, 70	6 18, 19, 20, 64 20 58, 59 66 20 65	LP-17, 18 SV-75, 76, 31, 4, 34, 3, 16 SV-33 SV-32 PT-4, 5, 6, 7** SV-90, 95 SV-5 SV-36, 37, 38	3/85 complete complete complete complete complete complete complete	10/83 complete complete complete 10/83 complete complete complete	2/84 complete complete complete complete complete complete complete

* Justifications for Continued Operation (JCO's) have previously been submitted for these items. Refer to Duke Power Company letter, W. O. Parker to H. R. Denton dated February 25, 1982.

** Transmitter PT-7 has been determined not to be required to perform a safety function in a harsh environment; therefore, environmental qualification is not required.

Qualification References

1. LP-17, 18: Limitorque Valve Motor Operators; Limitorque Report 600456
2. All SV designations: ASCO Solenoid Valve Operators; ASCO Report AQS21678/TR
3. PT-4, 5, 6: Barton Pressure Transmitters (764); Barton Report R3-764-9