



THE CONTAINMENT ATMOSPHERE SAMPLE IS TAKEN DIRECTLY FROM THE CONTAINMENT ATMOSPHERE AND NOT A HVAC DUCT. AN ISOKINETIC NOZZLE IS NOT REQUIRED.

Waterford Steam Electric Station #3

PLANT VENT STACK PARTICULATE, IODINE & GAS RADIATION MONITOR

Revision 11 (05/01)

Figure 11.5-1