



ANP-3013NP, Revision 0, *Brunswick Unit 1 Cycle 19*
Fuel Cycle Design MELLLA+ Operating Domain,
May 2013



ANP-3013(NP)
Revision 0

Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain

May 2013

AREVA NP Inc.



AREVA NP Inc.

ANP-3013(NP)
Revision 0

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

sja

AREVA NP Inc.

ANP-3013(NP)
Revision 0

Copyright © 2013

AREVA NP Inc.
All Rights Reserved

Nature of Changes

Item	Page	Description and Justification
1.	All	This is the initial release.

Contents

1.0	Introduction	1-1
2.0	Summary.....	2-1
3.0	Cycle 19 Fuel Cycle Design.....	3-1
3.1	General Description	3-1
3.2	Control Rod Patterns and Thermal Limits	3-1
3.3	Hot Excess Reactivity and Cold Shutdown Margin.....	3-2
4.0	Special Analyses	4-1
4.1	Hot Standby Boron Worth (HSBW)	4-1
4.2	Voiding in the Channel Bypass Region	4-1
5.0	References.....	5-1
Appendix A	Brunswick Unit 1 Cycle 19 Step-Through Depletion Summary, Control Rod Patterns and Core Average Axial Power and Exposure Distributions.....	A-1
Appendix B	Elevation Views of the Brunswick Unit 1 Cycle 19 Fresh Reload Batch Fuel Assemblies	B-1
Appendix C	Brunswick Unit 1 Cycle 19 Fresh Fuel Locations	C-1
Appendix D	Brunswick Unit 1 Cycle 19 Radial Exposure and Power Distributions.....	D-1

Tables

2.1	Brunswick Unit 1 Cycle 19 Energy and Key Results Summary	2-2
2.2	Brunswick Unit 1 Cycle 19 Fuel Cycle Design Assembly ID Range by Nuclear Fuel Type	2-3
2.3	Assumed MCPR Operating Limits	2-3
2.4	Assumed ATRIUM 10XM LHGR Limits.....	2-3
3.1	Cycle 19 Core Composition and Design Parameters	3-3
3.2	Brunswick Unit 1 Cycle 19 Hot Operating Target k-eff versus Cycle Exposure	3-4
3.3	Brunswick Unit 1 Cycle 19 Cold Critical Target k-eff versus Cycle Exposure	3-4
3.4	Brunswick Unit 1 Cycle 19 Reactivity Margin Summary.....	3-5
4.1	Hot Standby Boron Worth Minimum Shutdown Margin	4-2
4.2	Maximum Bypass Voiding at LPRM Level D.....	4-2

Figures

2.1	Brunswick Unit 1 Cycle 19 Design Step-Through k-eff versus Cycle Exposure	2-4
2.2	Brunswick Unit 1 Cycle 19 Design Margin to Thermal Limits versus Cycle Exposure	2-4
3.1	Brunswick Unit 1 Cycle 19 Reference Loading Pattern.....	3-6
3.2	Brunswick Unit 1 Cycle 19 Upper Left Quarter Core Layout by Fuel Type	3-7
3.3	Brunswick Unit 1 Cycle 19 Upper Right Quarter Core Layout by Fuel Type.....	3-8
3.4	Brunswick Unit 1 Cycle 19 Lower Left Quarter Core Layout by Fuel Type	3-9
3.5	Brunswick Unit 1 Cycle 19 Lower Right Quarter Core Layout by Fuel Type.....	3-10

Nomenclature

ACE	AREVA NP's advanced critical power correlation []
APLHGR	average planar linear heat generation rate
BOC	beginning of cycle
BOL	beginning of life
BWR	boiling water reactor
CSDM	cold shutdown margin
EOC	end of cycle
EOF	end of full power capability
EFW	extended flow window operating domain (e.g. MELLLA+)
FFTR	final feedwater temperature reduction
GWd/MTU	gigawatt days per metric ton of initial uranium
HEXR	hot excess reactivity
LHGR	linear heat generation rate
MCPR	minimum critical power ratio
MICROBURN-B2	AREVA NP advanced BWR core simulator methodology with PPR capability
MWd/MTU	megawatt days per metric ton of initial uranium
NRC	Nuclear Regulatory Commission, U.S.
PLFR	part length fuel rod
PPR	Pin Power Reconstruction. The PPR methodology accounts for variation in local rod power distributions due to neighboring assemblies and control state. The local rod power distributions are reconstructed based on the actual flux solution for each statepoint.
R Value	the larger of zero or the shutdown margin at BOC minus the minimum calculated shutdown margin in the cycle
SLC	standby liquid control
SPCB	AREVA NP (formerly Siemens Power Corporation) critical power correlation

1.0 Introduction

MELLLA+ is an EFW operating domain that allows the use of lower flow rates when compared to the MELLLA domain. Specifically, at rated conditions the MELLLA+ domain allows for operation at flows greater than or equal to 85% of the rated core flow.

AREVA NP Inc. (AREVA) has performed a fuel cycle design and fuel management calculations for the Cycle 19 operation of the Brunswick Unit 1 in the MELLLA+ operating domain. These analyses have been performed with the approved AREVA neutronics methodology (Reference 1). The CASMO-4 lattice depletion code was used to generate nuclear data including cross sections and local power peaking factors. The MICROBURN-B2 three dimensional core simulator code, combined with the application of the applicable critical power correlation, was used to model the core. The MICROBURN-B2 pin power reconstruction (PPR) model was used to determine the thermal margins presented in this report. The ACE critical power correlation (Reference 3) was utilized for the ATRIUM™ 10XM* fuel assemblies while the co-resident ATRIUM-10 fuel assemblies will continue to be monitored with the SPCB correlation (Reference 2). The following MICROBURN-B2 modeling features are included in this analysis:

- Control blade B-10 depletion
- Explicit neutronic treatment of the spacer grids
- Explicit modeling of the PLFR plenums
- Explicit modeling of the water rod flow

Design results for the Cycle 19 reactor core loading including projected control rod patterns and evaluations of thermal and reactivity margins are presented. The Cycle 19 results are based on Cycle 18 core operational history as summarized in Table 2.1

* ATRIUM is a trademark of AREVA NP.

2.0 Summary

The Cycle 19 fresh batch size (234 assemblies) and batch average enrichment [] were determined to meet the energy requirements provided by Progress Energy (References 5 through 8). For a complete description of the fresh reload assemblies, see Reference 4. The loading of the Cycle 19 fuel as described in this report results in a projected Cycle 19 full power energy capability (including FFTR) of $1,891 \pm 30$ GWd ($18,788 \pm 300$ MWd/MTU). Beyond the full power capability, the cycle has been designed to achieve 38 GWd additional energy via Constant Pressure Power Coastdown operation.

In order to obtain optimum operating flexibility, the projected control rod patterns for Cycle 19 were developed to be consistent with a conservative margin to thermal limits. The cycle design calculations also demonstrate adequate hot excess reactivity and cold shutdown margin throughout the cycle. Key results from the design analysis are summarized in Table 2.1. Table 2.2 summarizes the assembly identification range by nuclear fuel type batch for the Cycle 19 design. Figures 2.1 and 2.2 provide a summary of the cycle design step-through projection.

Table 2.1 Brunswick Unit 1 Cycle 19 Energy and Key Results Summary

Cycle Energy, GWd (Cycle Exposure, MWd/MTU)	
Cycle 18	
• Core follow through April 19, 2011	1,020 (10,205)
• Best estimate depletion to Nominal EOC 18	1,903 (19,030)
• Short window EOC 18	1,859 (18,592)
• Long window EOC 18	1,953 (19,527)
Cycle 19	
• EOFP Energy (including FFTR)	1,891±30 (18,788±300)
• Constant Pressure Power Coastdown Energy	38 (378)
• EOC Energy	1,929±30 (19,166±300)
Key Results	
BOC CSDM, %Δk/k (based on short EOC 18)	1.29
Minimum CSDM, %Δk/k (based on short EOC 18)	1.29
Cycle Exposure of Minimum CSDM, MWd/MTU (short basis)	0
Cycle R Value, %Δk/k (short basis)	0.00
Minimum SLC SDM, %Δk/k (based on short EOC 18)	2.67
Cycle Exposure of Minimum SLC SDM, MWd/MTU (short basis)	0
BOC HEXR, %Δk/k (based on nominal EOC 18)	1.65
Maximum HEXR, %Δk/k (based on nominal EOC 18)	1.93
Cycle Exposure of Maximum HEXR, MWd/MTU (nominal basis)	14,000
Minimum MAPLHGR Margin, %	15.1
Exposure of Minimum MAPLHGR Margin, MWd/MTU	9,000
Minimum LHGR Margin, %	10.4
Exposure of Minimum LHGR Margin, MWd/MTU	9,300
Minimum CPR Margin, %	8.1
Exposure of Minimum CPR Margin, MWd/MTU	7,000

Table 2.2 Brunswick Unit 1 Cycle 19 Fuel Cycle Design Assembly ID Range by Nuclear Fuel Type

Nuclear Fuel Type	Number of Assemblies	Assembly ID Range
30	38	A17001-A17152
31	46	A17153-A17248
32	80	A18301-A18380
33	162	A18381-A18542
34	96	A19601-A19696
35	138	A19697-A19834

Table 2.3 Assumed MCPR Operating Limits

Cycle Exposure (GWd/MTU)	ATRIUM 10XM OLMCPR	ATRIUM-10 OLMCPR
0.0	1.39	1.48
16.7	1.41	1.54
18.225	1.42	1.55

Table 2.4 Assumed ATRIUM 10XM LHGR Limits

Peak Pellet Exposure (GWd/MTU)	LHGR kW/ft
0.0	14.1
18.9	14.1
74.4	7.4




Figure 2.1 Brunswick Unit 1 Cycle 19 Design Step-Through k_{eff} versus Cycle Exposure




Figure 2.2 Brunswick Unit 1 Cycle 19 Design Margin to Thermal Limits versus Cycle Exposure

3.0 **Cycle 19 Fuel Cycle Design**

3.1 ***General Description***

The assembly design for the Cycle 19 fresh reload fuel for Brunswick Unit 1 is described in detail in Reference 4. Elevation views of the fresh reload fuel design axial enrichment and gadolinia distributions are shown in Appendix B, Figures B.1 and B.2. The loading pattern maintains full symmetry within a scatter load fuel management scheme. This loading in conjunction with the control rod patterns presented in Appendix A shows acceptable power peaking and associated margins to limits for projected Cycle 19 operation. The analyses supporting this fuel cycle design were based on the core parameters shown in Table 3.1. Figures 3.1 through 3.5, along with Table 3.1 define the reference loading pattern used in the fuel cycle design. The specific core location of the fresh assemblies in Cycle 19 is provided in Appendix C. Key results for the cycle are summarized in Table 2.1.

Exposure limits have been checked on the long Cycle 18 energy window and the Cycle 19 operation to 703 EFPD. It has been confirmed that no full-length rod average exposure exceeds 60 GWd/MTU.

3.2 ***Control Rod Patterns and Thermal Limits***

Projected control rod patterns for Cycle 19 and resultant key operating parameters including thermal margins are shown in Appendix A. The thermal margins presented in this report were determined using the MICROBURN-B2 3D core simulator PPR model to provide adequate margin to thermal limits. The thermal limit margins presented in this report are based on assumed thermal limits (See Table 2.3 and 2.4) and are subject to change pending the completion of the thermal-mechanical and safety analyses. A detailed summary of the core parameters resulting from the step-through projection analysis is provided in Tables A.1 and A.2. Limiting results from the step-through are summarized in Table 2.1 and in Figure 2.2. The hot operating target k-eff versus cycle exposure which was determined to be appropriate for Cycle 19 is shown in Table 3.2 (Reference 9). The k-eff and margin to limits results from the design cycle depletion are presented graphically in Figures 2.1 and 2.2. The k-eff values presented in Figure 2.1 and in Appendix A are not bias corrected. Selected exposure and radial power distributions from the design step-through are presented in Appendix D. The maximum core exit void for the design step-through was determined to be 88.8%.

3.3 ***Hot Excess Reactivity and Cold Shutdown Margin***

The cycle design calculations demonstrate adequate hot excess reactivity, SLC shutdown margin, and cold shutdown margin throughout the cycle. Key shutdown margin and R-Value results are presented in Table 2.1. The shutdown margin for Cycle 19 is in conformance with the Technical Specification limit of $R + 0.38 \% \Delta k/k$ at BOC. The cold target k-eff versus exposure determined to be appropriate for calculation of cold shutdown margin in Cycle 19 is shown in Table 3.3 (Reference 9). The core hot excess reactivity was calculated at full power with all rods out, 77.0 Mlb/hr core flow, with equilibrium xenon. Table 3.4 summarizes the Cycle 19 reactivity margins versus cycle exposure, including the SLC shutdown margin for the cycle. The results in this table meet all applicable Reference 5 acceptance criteria.

BOC cold shutdown margin was evaluated to be $1.29 \% \Delta k/k$ at a cold temperature of 55 °F. Calculations have been performed at temperatures above 68 °F to determine the shutdown margin at the most reactive temperature.

Table 3.1 Cycle 19 Core Composition and Design Parameters

Fuel Description	Cycle Loaded	Nuclear Fuel Type	Number of Assemblies
ATRIUM-10 []	17	30	38
ATRIUM-10 []	17	31	46
ATRIUM-10 []	18	32	80
ATRIUM-10 []	18	33	162
ATRIUM 10XM []	19	34	96
ATRIUM 10XM []	19	35	138

Number of Fuel Assemblies in Core	560
Total Number of Fresh Assemblies	234
Total Core Mass, MTU	100.66
Rated Thermal Power Level, MW _t	2,923
Rated Core Flow, Mlb/hr	77.0
Reference Pressure, psia	1,045*
Reference Inlet Subcooling, Btu/lbm	22.0†

* Value is representative of MICROBURN-B2 input for dome pressure at rated conditions and varies depending on core state point.

† Value is typically determined by MICROBURN-B2 using a heat balance method based on nominal feedwater temperature and other parameters identified in the cycle specific plant parameters document.

Table 3.2 Brunswick Unit 1 Cycle 19 Hot Operating Target k-eff versus Cycle Exposure

Cycle Exposure (MWd/MTU)	Hot Operating k-eff*
0.0	0.9995
8,000.0	0.9975
14,000.0	0.9975
18,000.0	1.0000
22,000.0	1.0000

Table 3.3 Brunswick Unit 1 Cycle 19 Cold Critical Target k-eff versus Cycle Exposure

Cycle Exposure (MWd/MTU)	Cold Critical k-eff*
0.0	0.9940
6,000.0	0.9900
22,000.0	0.9900

* Values are linearly interpolated between cycle exposure points.

Table 3.4 Brunswick Unit 1 Cycle 19 Reactivity Margin Summary

Cycle Exposure (MWd/MTU)	Cold Shutdown Margin* (% Δk/k)	SLC Cold Shutdown Margin† (% Δk/k)	Hot Excess Reactivity‡ (% Δk/k)
0	1.29§	2.67	1.65
200	1.58	2.92	1.61
1,000	1.92	3.20	1.42
2,300	2.18	3.44	1.41
3,600	2.28	3.61	1.40
5,500	2.34	3.75	1.44
7,500	2.36	3.87	1.59
9,000	2.41	3.92	1.69
10,000	2.42	3.95	1.75
11,000	2.34	3.98	1.80
12,200	2.16	3.94	1.87
13,000	2.03	3.92	1.92
14,000	1.84	3.92	1.93
15,400	1.55	4.12	1.65
16,700	1.38	4.57	1.03
18,225	1.39	5.27	-0.11
18,788	1.42	5.52	--
19,166	1.49	5.71	--
20,414	1.79	6.44	--

NOTE: Values are shown in **bold** if the most reactive temperature is greater than 68 °F.

* Based on short window EOC 18 and 68 °F.

† Based on short window EOC 18, calculated at 360.8 °F ARO conditions.

‡ Based on nominal EOC 18.

§ Evaluated at 55 °F which bounds values at 68 °F.

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

	1	3	5	7	9	11	13	15	17	19	21	23	25
52									A17167	A17179	A17007	A17043	A17162
50								A17126	A18373	A18318	A18342	A18366	A18326
48								A18358	A18310	A19634	A18496	A19610	A19602
46								A19658	A19650	A19642	A19626	A19618	A18488
44								A19666	A19831	A18456	A19819	A18408	A19791
42								A19682	A19674	A18440	A19815	A18512	A19787
40								A19827	A18463	A19811	A18495	A19783	A18400
38								A19848	A19807	A18504	A19779	A18381	A19751
36	A17025	A18377	A18309	A19649	A19823	A18439	A19803	A18503	A19775	A18464	A19747	A18392	A19727
34	A17161	A18341	A19633	A19641	A18455	A19799	A18511	A19771	A18480	A19743	A18447	A19723	A18416
32	A17054	A18317	A18535	A19625	A19795	A18479	A19767	A18471	A19739	A18523	A19719	A18531	A19707
30	A17001	A18365	A19609	A19617	A18407	A19763	A18399	A19735	A18391	A19715	A18527	A19703	A18519
28	A17083	A18325	A19601	A18487	A19759	A18431	A19731	A18423	A19711	A18415	A19699	A18384	A18472
26	A17235	A18332	A19608	A18494	A19762	A18438	A19734	A18430	A19714	A18422	A19702	A18526	A19697
24	A17149	A18372	A19616	A19624	A18414	A19766	A18406	A19738	A18398	A19718	A18530	A19706	A18522
22	A17094	A18324	A18538	A19632	A19798	A18486	A19770	A18478	A19742	A18542	A19722	A18453	A19710
20	A17243	A18348	A19640	A19648	A18462	A19802	A18405	A19774	A18454	A19746	A18534	A19726	A18421
18	A17125	A18380	A18316	A19656	A19826	A18446	A19806	A18510	A19778	A18485	A19750	A18518	A19730
16		A17244	A18364	A19664	A19672	A19680	A18470	A19810	A18509	A19782	A18413	A19754	A18429
14			A17129	A18308	A18477	A19688	A19830	A18502	A19814	A18445	A19786	A18389	A19758
12				A17061	A18340	A19696	A18355	A19687	A19679	A18469	A19818	A18517	A19790
10				A17202	A17245	A18356	A19695	A18390	A19671	A19834	A18461	A19822	A18397
8					A17211	A17150	A18339	A18307	A19663	A19655	A19647	A19631	A19623
6						A17232	A17140	A17237	A18363	A18315	A19639	A18501	A19615
4								A17216	A18376	A18323	A18347	A18371	A18331
2									A17212	A17215	A17236	A17101	A17139
	27	29	31	33	35	37	39	41	43	45	47	49	51
52	A17024	A17052	A17013	A17186	A17189								
50	A18327	A18367	A18343	A18319	A18374	A17157							
48	A19603	A19611	A18497	A19635	A18311	A18359	A17204	A17014	A17169				
46	A18489	A19619	A19627	A19643	A19651	A19659	A18303	A18335	A17004	A17190			
44	A19792	A18532	A19820	A18457	A19832	A19667	A18473	A19691	A18352	A17003	A17199		
42	A18433	A19788	A18514	A19816	A18441	A19675	A19683	A18351	A19692	A18336	A17156		
40	A19756	A18401	A19784	A18465	A19812	A18498	A19828	A19684	A18386	A18304	A17158		
38	A18425	A19752	A18513	A19780	A18505	A19808	A18449	A19676	A19668	A19660	A18360	A17178	
36	A19728	A18393	A19748	A18466	A19776	A18506	A19804	A18442	A19824	A19652	A18312	A18378	A17028
34	A18417	A19724	A18450	A19744	A18385	A19772	A18540	A19800	A18458	A19644	A19636	A18320	A17165
32	A19708	A18528	A19720	A18481	A19740	A18474	A19768	A18482	A19796	A19628	A18536	A18344	A17059
30	A18520	A19704	A18409	A19716	A18394	A19736	A18402	A19764	A18410	A19620	A19612	A18368	A17166
28	A19698	A18524	A19700	A18418	A19712	A18426	A19732	A18434	A19760	A18490	A19604	A18328	A17092
26	A18476	A18525	A19701	A18419	A19713	A18427	A19733	A18435	A19761	A18491	A19605	A18329	A17070
24	A18521	A19705	A18529	A19717	A18395	A19737	A18403	A19765	A18411	A19621	A19613	A18369	A17240
22	A19709	A18452	A19721	A18541	A19741	A18475	A19769	A18483	A19797	A19629	A18537	A18345	A17099
20	A18420	A19725	A18533	A19745	A18451	A19773	A18388	A19801	A18459	A19645	A19637	A18321	A17248
18	A19729	A18428	A19749	A18484	A19777	A18507	A19805	A18443	A19825	A19653	A18313	A18379	A17200
16	A18396	A19753	A18382	A19781	A18508	A19809	A18467	A19677	A19669	A19661	A18361		
14	A19757	A18404	A19785	A18468	A19813	A18499	A19829	A19685	A18387	A18305	A17213		
12	A18436	A19789	A18516	A19817	A18444	A19678	A19686	A18354	A19693	A18337	A17128		
10	A19793	A18412	A19821	A18460	A19833	A19670	A18515	A19694	A18353	A17152	A17233		
8	A18492	A19622	A19630	A19646	A19654	A19662	A18306	A18338	A17151	A17214			
6	A19606	A19614	A18500	A19638	A18314	A18362	A17246	A17145	A17203				
4	A18330	A18370	A18346	A18322	A18375	A17247							
2	A17239	A17110	A17146	A17222	A17134								

Figure 3.1 Brunswick Unit 1 Cycle 19 Reference Loading Pattern

Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLIA+ Operating Domain

	1	3	5	7	9	11	13	15	17	19	21	23	25
52									31	31	30	30	31
									33.6	33.3	31.1	32.3	33.0
50	Nuclear Fuel Type							30	32	32	32	32	32
	BOC Exposure (Gwd/MTU)							33.9	22.4	20.6	19.9	19.5	19.7
48					31	30	31	32	32	34	33	34	34
					36.8	33.9	32.3	23.0	21.1	0.0	23.7	0.0	0.0
46			31	31	32	32	34	34	34	34	34	34	33
			36.3	32.9	21.3	21.2	0.0	0.0	0.0	0.0	0.0	0.0	21.8
44		31	30	32	34	33	34	35	33	35	33	35	35
		38.8	30.9	17.9	0.0	23.8	0.0	0.0	23.0	0.0	23.2	0.0	0.0
42		30	32	34	32	34	34	34	33	35	33	35	33
		34.2	21.0	0.0	18.1	0.0	0.0	22.6	0.0	23.3	0.0	23.4	
40		30	32	33	34	35	33	35	33	35	33	35	35
		32.5	20.7	23.3	0.0	0.0	22.4	0.0	22.2	0.0	23.4	0.0	0.0
38		31	32	34	34	34	33	35	33	35	33	35	33
		34.9	22.9	0.0	0.0	0.0	22.3	0.0	22.5	0.0	23.1	0.0	22.9
36		30	32	32	34	35	33	35	33	35	33	35	35
		33.8	22.1	20.7	0.0	0.0	22.1	0.0	22.0	0.0	22.9	0.0	23.1
34		31	32	34	34	33	35	33	35	33	35	33	33
		30.2	19.7	0.0	0.0	22.2	0.0	23.0	0.0	23.1	0.0	22.6	0.0
32		30	32	33	34	35	33	35	33	35	33	35	35
		32.6	20.3	23.5	0.0	0.0	22.5	0.0	22.0	0.0	23.2	0.0	22.6
30		30	32	34	34	33	35	33	35	33	35	35	33
		31.7	19.4	0.0	0.0	22.5	0.0	21.7	0.0	22.6	0.0	22.6	0.0
28		30	32	34	33	35	33	35	33	35	33	35	33
		32.8	19.5	0.0	21.4	0.0	22.6	0.0	22.2	0.0	23.1	0.0	23.4

Fuel Type	Description	Cycle Loaded	No. Per Quarter core
30	[]	17	11
31	[]	17	10
32	[]	18	20
33	[]	18	41
34	[]	19	24
35	[]	19	34

Figure 3.2 Brunswick Unit 1 Cycle 19 Upper Left Quarter Core Layout by Fuel Type

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLRA+ Operating Domain**

	27	29	31	33	35	37	39	41	43	45	47	49	51
52	30 31.9	30 31.4	30 32.5	31 32.3	31 33.0								
50	32 20.0	32 19.8	32 20.2	32 20.8	32 22.7	31 34.7							
48	34 0.0	34 0.0	33 24.0	34 0.0	32 21.2	32 23.3	31 32.4	30 31.7	31 39.0				
46	33 22.0	34 0.0	34 0.0	34 0.0	34 0.0	34 0.0	32 21.3	32 21.6	30 31.7	31 38.6			
44	35 0.0	33 23.0	35 0.0	33 23.3	35 0.0	34 0.0	33 23.8	34 0.0	32 18.2	30 31.1	31 39.2		
42	33 23.6	35 0.0	33 23.4	35 0.0	33 22.8	34 0.0	34 0.0	32 18.3	34 0.0	32 21.5	31 34.6		
40	35 0.0	33 23.5	35 0.0	33 23.1	35 0.0	33 22.7	35 0.0	34 0.0	33 24.0	32 21.1	31 32.6		
38	33 23.0	35 0.0	33 23.6	35 0.0	33 22.7	35 0.0	33 22.6	34 0.0	34 0.0	32 0.0	31 23.3	31 35.3	
36	35 0.0	33 23.2	35 0.0	33 22.9	35 0.0	33 22.5	35 0.0	33 22.6	35 0.0	34 0.0	32 21.2	32 22.5	30 33.2
34	33 22.7	35 0.0	33 22.9	35 0.0	33 23.8	35 0.0	33 23.7	35 0.0	33 22.6	34 0.0	34 0.0	32 20.8	31 32.5
32	35 0.0	33 22.9	35 0.0	33 23.4	35 0.0	33 22.4	35 0.0	33 22.9	35 0.0	34 0.0	33 23.9	32 20.1	30 31.6
30	33 23.7	35 0.0	33 23.2	35 0.0	33 23.0	35 0.0	33 22.2	35 0.0	33 22.9	34 0.0	34 0.0	32 19.7	31 29.6
28	35 0.0	33 23.5	35 0.0	33 23.2	35 0.0	33 22.5	35 0.0	33 23.1	35 0.0	33 21.9	34 0.0	32 20.0	30 32.3

Fuel Type	Description	Cycle Loaded	No. Per Quarter core
30	[]	17	9
31	[]	17	12
32	[]	18	20
33	[]	18	40
34	[]	19	24
35	[]	19	35

Figure 3.3 Brunswick Unit 1 Cycle 19 Upper Right Quarter Core Layout by Fuel Type

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLIA+ Operating Domain**

	1	3	5	7	9	11	13	15	17	19	21	23	25		
26	31 32.1	32 19.7	34 0.0	33 21.5	35 0.0	33 22.6	35 0.0	33 22.0	35 0.0	33 22.8	35 0.0	33 23.2	35 0.0		
24	30 31.6	32 19.4	34 0.0	34 0.0	33 22.5	35 0.0	33 21.7	35 0.0	33 22.6	35 0.0	33 22.5	35 0.0	33 23.5		
22	30 32.5	32 20.4	33 23.5	34 0.0	35 0.0	33 22.4	35 0.0	33 22.0	35 0.0	33 23.2	35 0.0	33 22.3	35 0.0		
20	31 32.7	32 19.8	34 0.0	34 0.0	33 22.1	35 0.0	33 23.4	35 0.0	33 22.4	35 0.0	33 22.6	35 0.0	33 22.6		
18	30 33.4	32 22.2	32 20.7	34 0.0	35 0.0	33 22.1	35 0.0	33 22.0	35 0.0	33 23.1	35 0.0	33 23.0	35 0.0		
16		31 34.6	32 22.9	34 0.0	34 0.0	34 0.0	33 22.4	35 0.0	33 22.4	35 0.0	33 23.3	35 0.0	33 22.9		
14			30 32.3	32 20.7	33 23.5	34 0.0	35 0.0	33 22.2	35 0.0	33 22.7	35 0.0	33 23.8	35 0.0		
12				30 33.0	32 21.2	34 0.0	32 17.9	34 0.0	34 0.0	33 22.9	35 0.0	33 23.2	35 0.0	33 23.4	
10					31 39.8	31 32.4	32 18.0	34 0.0	33 23.7	34 0.0	35 0.0	33 23.1	35 0.0	33 23.1	35 0.0
8						31 39.1	30 30.9	32 21.2	32 21.4	34 0.0	34 0.0	34 0.0	34 0.0	34 0.0	33 21.7
6							31 38.9	30 33.8	31 34.5	32 22.9	32 21.2	34 0.0	33 23.7	34 0.0	34 0.0
4	Nuclear Fuel Type BOC Exposure (GWd/MTU)							31 36.8	32 22.3	32 20.6	32 19.8	32 19.4	32 19.7		
2									31 33.6	31 32.7	31 32.7	30 32.1	30 30.8		

Fuel Type	Description	Cycle Loaded	No. Per Quarter core
30	[]	1	9
31	[]	17	12
32	[]	18	20
33	[]	18	40
34	[]	19	24
35	[]	19	35

Figure 3.4 Brunswick Unit 1 Cycle 19 Lower Left Quarter Core Layout by Fuel Type

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLRA+ Operating Domain**

	27	29	31	33	35	37	39	41	43	45	47	49	51
26	33 23.9	33 23.5	35 0.0	33 23.3	35 0.0	33 22.6	35 0.0	33 23.0	35 0.0	33 21.7	34 0.0	32 19.8	30 32.1
24	33 23.7	35 0.0	33 22.9	35 0.0	33 23.0	35 0.0	33 22.2	35 0.0	33 22.9	34 0.0	34 0.0	32 19.7	31 29.8
22	35 0.0	33 22.7	35 0.0	33 23.6	35 0.0	33 22.4	35 0.0	33 22.8	35 0.0	34 0.0	33 23.9	32 19.9	30 31.6
20	33 22.8	35 0.0	33 23.0	35 0.0	33 23.0	35 0.0	33 23.8	35 0.0	33 22.6	34 0.0	34 0.0	32 20.6	31 32.5
18	35 0.0	33 23.1	35 0.0	33 23.5	35 0.0	33 22.3	35 0.0	33 22.5	35 0.0	34 0.0	32 21.1	32 22.4	31 34.4
16	33 23.2	35 0.0	33 23.2	35 0.0	33 22.8	35 0.0	33 22.8	34 0.0	34 0.0	34 0.0	32 23.2	31 35.6	
14	35 0.0	33 23.5	35 0.0	33 23.2	35 0.0	33 22.6	35 0.0	34 0.0	33 24.0	32 21.1	31 33.1		
12	33 23.6	35 0.0	33 23.7	35 0.0	33 22.8	34 0.0	34 0.0	32 18.3	34 0.0	32 21.3	30 33.6		
10	35 0.0	33 23.3	35 0.0	33 23.4	35 0.0	34 0.0	33 23.3	34 0.0	32 18.1	30 31.5	31 38.8		
8	33 22.0	34 0.0	34 0.0	34 0.0	34 0.0	34 0.0	32 21.4	32 21.6	30 30.7	30 38.8	31 38.8		
6	34 0.0	34 0.0	33 24.1	34 0.0	32 21.2	32 23.3	31 32.2	30 33.4	31 39.2				
4	32 20.0	32 19.7	32 20.2	32 20.8	32 22.7	31 34.5							
2	31 32.5	30 31.7	30 30.7	31 32.6	30 32.3								

Fuel Type	Description	Cycle Loaded	No. Per Quarter core
30	[]	17	9
31	[]	17	12
32	[]	18	20
33	[]	18	41
34	[]	19	24
35	[]	19	34

Figure 3.5 Brunswick Unit 1 Cycle 19 Lower Right Quarter Core Layout by Fuel Type

4.0 Special Analyses

The following special analyses were performed at customer request.

4.1 *Hot Standby Boron Worth (HSBW)*

AREVA has calculated the Brunswick Unit 1 Equilibrium Cycle margin to criticality at hot standby conditions with the standby liquid control system engaged. The limiting result is presented in Table 4.1 for a moderator boron concentration of 522 ppm. The target k-eff is the average of the hot and cold target k-eff values. As shown, the shutdown margin is greater than 0.4 % $\Delta k/k$ limit.

4.2 *Voiding in the Channel Bypass Region*

To demonstrate compliance with the NRC's requirement that there be less than 5% bypass voiding around the LPRMs (see Section 5.1.1.5.1 of Reference 10), the bypass void level has been evaluated throughout the equilibrium cycle. The maximum bypass void value applicable to the Cycle 19 design [

]

* []

[]

[]

Table 4.1 Hot Standby Boron Worth Minimum Shutdown Margin

Operating Domain	Boron Concentration (ppm)	Cycle Exposure* (MWd/MTU)	k-eff	Target k-eff	Shutdown Margin (% Δk/k)
MELLLA+	522	14900	0.98868	0.99403	0.53
MELLLA	522	16700	0.99459	0.98581	0.88

Table 4.2 Maximum Bypass Voiding at LPRM Level D

Power (%), Flow (%) Condition	Cycle Exposure (GWd/MTU)	Bypass Void (%)
[]		[]

NOTE: There is no bypass voiding at LPRM levels A, B, or C.

* Cycle exposure at minimum SDM.

5.0 References

1. EMF-2158(P)(A) Revision 0, *Siemens Power Corporation Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/MICROBURN-B2*, Siemens Power Corporation, October 1999.
2. EMF-2209(P)(A) Revision 3, *SPCB Critical Power Correlation*, AREVA NP, September 2009.
3. ANP-10298(P)(A) Revision 0, *ACE/ATRIUM-10XM Critical Power Correlation*, AREVA NP, March 2010.
4. ANP-3006(P) Revision 0, *Nuclear Fuel Design Report Brunswick Unit 1 Cycle 19 ATRIUM 10XM Fuel*, AREVA NP, June 2011.
5. Letter, E. J. Geyer (Progress Energy) to R. J. DeSteese (AREVA), "BRK1-19 Energy Utilization Plan Revision 1," NF11-016, January 25, 2011. (38-9153944-000)
6. Letter, E. J. Geyer (Progress Energy) to R. J. DeSteese (AREVA), "BRK1-19 Energy Utilization Plan Revision 3 (Control Blade Replacement)," NF11-129, May 4, 2011. (38-9161259-000)
7. Letter, E. J. Geyer (Progress Energy) to R. J. DeSteese (AREVA), "BRK1-19 Energy Utilization Plan Revision 4 (Conservative SIL320 Implementation)," NF11-137, May 17, 2011. (38-9161750-000)
8. 51-9152200-001, "Brunswick Unit 1 Cycle 19 Nuclear Design Basis Plan," AREVA NP, February 3, 2011.
9. 12-9151855-000, "Brunswick Unit 1 Cycle 19 Target K-effective Selection," AREVA NP, January 19, 2011.
10. Safety Evaluation by the Office of Nuclear Reactor Regulation Licensing Topical Report NEDC-33006P, *General Electric Boiling Water Reactor Maximum Extended Load Line Limit Analysis Plus*, General Electric Hitachi Nuclear Energy America, LLC, October 2008. (ADAMS Accession Number ML 081130008).

Appendix A Brunswick Unit 1 Cycle 19 Step-Through Depletion Summary, Control Rod Patterns and Core Average Axial Power and Exposure Distributions

Table A.1 Brunswick Unit 1 Cycle 19 Design Depletion Summary

Cycle Exposure (GWd/MT)	Calculated K-eff	Control Rod Density	Total Core Power Mw	Total Core Flow (Mlb/hr)	Ref. Pressure (psia)	Inlet Sub-Cooling (Btu/lb)	Void Fraction	Core Minimum CPR	Core Maximum LHGR (kW/ft)	Core Maximum APLHGR (kW/ft)
0.000	0.99937	6.42	2923.0	68.14	1044.53	24.46	0.538	1.614	12.43	9.64
0.200	0.99930	6.42	2923.0	68.53	1044.53	24.31	0.533	1.618	12.10	9.41
0.500	0.99922	6.42	2923.0	72.76	1044.59	22.74	0.517	1.656	11.69	9.09
1.000	0.99913	6.42	2923.0	73.92	1044.61	22.33	0.513	1.651	11.64	9.12
1.500	0.99903	6.42	2923.0	73.15	1044.60	22.59	0.512	1.643	11.47	9.06
2.000	0.99891	6.42	2923.0	72.50	1044.59	22.83	0.510	1.635	11.29	8.98
2.300	0.99884	6.42	2923.0	72.19	1044.58	22.94	0.509	1.632	11.19	8.94
2.600	0.99874	6.42	2923.0	71.88	1044.58	23.05	0.508	1.629	11.09	8.91
2.601	0.99881	5.66	2923.0	71.61	1044.58	23.14	0.522	1.583	12.58	9.95
3.100	0.99871	5.66	2923.0	70.84	1044.57	23.43	0.520	1.579	12.26	9.78
3.600	0.99856	5.66	2923.0	70.07	1044.55	23.71	0.519	1.576	12.08	9.72
4.100	0.99840	5.66	2923.0	69.30	1044.54	24.01	0.518	1.569	11.92	9.67
4.600	0.99830	5.66	2923.0	68.53	1044.53	24.31	0.517	1.560	11.78	9.67
4.601	0.99833	6.20	2923.0	75.27	1044.62	21.89	0.503	1.557	11.94	9.90
5.000	0.99824	6.20	2923.0	74.50	1044.62	22.13	0.504	1.555	11.88	9.90
5.500	0.99811	6.20	2923.0	73.34	1044.60	22.53	0.504	1.551	11.80	9.92
6.000	0.99800	6.20	2923.0	72.00	1044.58	23.00	0.505	1.544	11.76	9.97
6.500	0.99787	6.20	2923.0	70.46	1044.56	23.57	0.508	1.529	11.75	10.05
7.000	0.99778	6.20	2923.0	68.92	1044.54	24.16	0.510	1.516	11.77	10.17
7.001	0.99778	6.57	2923.0	76.23	1044.64	21.58	0.500	1.667	12.20	10.40
7.500	0.99768	6.57	2923.0	74.50	1044.62	22.13	0.503	1.646	12.24	10.53
8.000	0.99755	6.57	2923.0	72.96	1044.59	22.66	0.506	1.625	12.33	10.69
8.500	0.99755	6.57	2923.0	71.61	1044.58	23.14	0.509	1.607	12.40	10.78
9.000	0.99755	6.57	2923.0	70.26	1044.56	23.64	0.511	1.591	12.42	10.77
9.300	0.99756	6.57	2923.0	69.42	1044.55	23.97	0.512	1.578	12.38	10.77
9.600	0.99756	6.57	2923.0	68.65	1044.53	24.27	0.512	1.567	12.29	10.71
9.601	0.99750	8.12	2923.0	76.23	1044.64	21.58	0.481	1.689	11.18	9.94
10.000	0.99755	8.12	2923.0	75.00	1044.62	21.97	0.482	1.676	10.96	9.80
10.500	0.99751	8.12	2923.0	73.34	1044.60	22.53	0.482	1.656	10.58	9.51
11.000	0.99752	8.12	2923.0	71.61	1044.58	23.14	0.481	1.633	10.24	9.15
11.350	0.99752	8.12	2923.0	70.19	1044.56	23.67	0.481	1.614	10.21	9.13
11.700	0.99750	8.12	2923.0	68.72	1044.54	24.24	0.480	1.594	10.37	9.31
11.701	0.99750	7.30	2923.0	73.23	1044.60	22.58	0.494	1.652	11.34	9.97
12.200	0.99748	7.30	2923.0	71.69	1044.58	23.11	0.489	1.622	10.64	9.36
12.700	0.99748	7.30	2923.0	70.30	1044.56	23.63	0.484	1.595	10.17	9.01
13.000	0.99748	7.30	2923.0	69.49	1044.55	23.94	0.480	1.580	10.08	8.97
13.500	0.99751	7.30	2923.0	68.72	1044.54	24.24	0.473	1.564	9.91	9.00
14.000	0.99752	7.30	2923.0	68.26	1044.53	24.42	0.464	1.545	10.04	9.23
14.400	0.99776	7.30	2923.0	68.92	1044.54	24.16	0.455	1.541	10.25	9.37
14.401	0.99776	5.47	2923.0	68.14	1044.53	24.47	0.481	1.538	9.50	8.45
14.900	0.99805	5.47	2923.0	70.46	1044.56	23.58	0.464	1.575	9.90	8.74
15.400	0.99839	5.47	2923.0	73.92	1044.61	22.34	0.446	1.613	10.22	8.99
15.900	0.99867	5.47	2923.0	78.54	1044.67	20.86	0.426	1.634	10.49	9.22
15.901	0.99865	4.81	2923.0	69.30	1044.54	24.01	0.437	1.561	10.17	8.95
16.300	0.99895	4.81	2923.0	73.73	1044.60	22.40	0.419	1.585	10.31	9.07
16.700	0.99907	4.81	2923.0	79.12	1044.68	20.68	0.401	1.604	10.48	9.24
16.701	0.99914	3.59	2923.0	71.22	1044.57	23.27	0.424	1.560	10.39	9.14
17.200	0.99950	3.59	2923.0	79.69	1044.69	20.51	0.396	1.603	10.61	9.31
17.201	0.99950	3.41	2923.0	76.23	1044.64	21.56	0.401	1.588	10.82	9.91
17.450	0.99963	3.41	2923.0	80.31	1044.70	20.33	0.388	1.601	10.99	10.06
17.451	0.99972	2.19	2923.0	73.65	1044.61	22.41	0.408	1.555	10.50	9.63
17.750	0.99976	2.19	2923.0	79.89	1044.69	20.46	0.390	1.605	10.67	9.76
17.751	0.99988	1.03	2923.0	74.31	1044.61	22.19	0.408	1.568	10.54	9.66
18.025	1.00000	1.03	2923.0	80.08	1044.69	20.40	0.391	1.610	10.67	9.75
18.026	0.99998	0.00	2923.0	75.85	1044.64	21.68	0.408	1.602	10.08	9.22
18.225	1.00008	0.00	2923.0	80.46	1044.70	20.29	0.395	1.637	10.21	9.23
18.226	1.00007	0.00	2923.0	77.00	1044.30	24.32	0.392	1.633	10.03	9.10
18.375	1.00009	0.00	2923.0	80.39	1044.30	23.17	0.383	1.656	10.12	9.12
18.376	1.00004	0.00	2923.0	77.00	1044.30	27.11	0.380	1.652	9.96	8.99
18.525	1.00010	0.00	2923.0	80.46	1044.30	25.83	0.370	1.674	10.07	9.03

Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLRA+ Operating Domain

18.526	1.00010	0.00	2923.0	77.08	1044.30	29.70	0.368	1.669	9.91	8.92
18.650	1.00011	0.00	2923.0	80.27	1044.30	28.40	0.360	1.690	10.00	8.95
18.651	1.00011	0.00	2923.0	77.19	1044.30	32.10	0.358	1.686	9.86	8.85
18.661	1.00012	0.00	2923.0	77.46	1044.30	31.98	0.358	1.688	9.86	8.85
18.730	1.00012	0.00	2923.0	79.04	1044.30	31.28	0.353	1.698	9.91	8.87
18.788	1.00016	0.00	2923.0	80.46	1044.30	30.68	0.349	1.706	9.96	8.89
19.166	1.00015	0.00	2722.7	80.46	1044.30	28.43	0.330	1.822	9.55	8.41
19.600	1.00018	0.00	2492.5	80.46	1044.30	25.83	0.308	1.958	9.02	7.94
20.000	1.00022	0.00	2266.5	80.46	1044.30	23.29	0.287	2.110	8.57	7.51
20.414	1.00025	0.00	2046.4	80.46	1044.30	20.81	0.265	2.286	8.16	7.11

Table A.2 Brunswick Unit 1 Cycle 19 Design Depletion Thermal Margin Summary

Cycle Exposure (GWd/MT)	Calculated K-eff	Control Rod Density	Core Limiting CPR	Fraction of Limiting CPR	Core Limiting LHGR (kW/ft)	Fraction of Limiting LHGR	Core Limiting APLHGR (kW/ft)	Fraction of Limiting APLHGR
0.000	0.99937	6.417	1.639	0.903	12.43	0.882	8.92	0.774
0.200	0.99930	6.417	1.641	0.902	12.10	0.858	8.75	0.761
0.500	0.99922	6.417	1.693	0.874	11.69	0.829	8.43	0.738
1.000	0.99913	6.417	1.701	0.870	11.64	0.825	8.37	0.738
1.500	0.99903	6.417	1.701	0.870	11.47	0.813	8.11	0.732
2.000	0.99891	6.417	1.700	0.870	11.29	0.801	8.02	0.730
2.300	0.99884	6.417	1.702	0.869	11.19	0.794	7.95	0.727
2.600	0.99874	6.417	1.704	0.869	11.09	0.787	7.90	0.726
2.601	0.99881	5.657	1.660	0.892	12.58	0.892	8.78	0.800
3.100	0.99871	5.657	1.657	0.893	12.26	0.870	8.56	0.788
3.600	0.99856	5.657	1.655	0.894	12.08	0.857	8.43	0.782
4.100	0.99840	5.657	1.633	0.906	11.92	0.845	8.32	0.778
4.600	0.99830	5.657	1.621	0.913	11.78	0.836	8.22	0.776
4.601	0.99833	6.204	1.557	0.893	11.94	0.847	8.32	0.785
5.000	0.99824	6.204	1.649	0.897	11.88	0.842	8.25	0.784
5.500	0.99811	6.204	1.642	0.901	11.80	0.837	8.18	0.784
6.000	0.99800	6.204	1.632	0.907	11.76	0.834	8.14	0.787
6.500	0.99787	6.204	1.620	0.913	11.75	0.833	8.11	0.791
7.000	0.99778	6.204	1.610	0.919	11.77	0.835	8.09	0.796
7.001	0.99778	6.569	1.722	0.859	12.20	0.865	8.64	0.824
7.500	0.99768	6.569	1.704	0.868	12.24	0.868	8.61	0.829
8.000	0.99755	6.569	1.686	0.878	12.33	0.874	8.64	0.839
8.500	0.99755	6.569	1.672	0.885	12.40	0.882	8.64	0.846
9.000	0.99755	6.569	1.658	0.892	12.42	0.893	8.58	0.849
9.300	0.99756	6.569	1.646	0.899	12.38	0.896	8.51	0.847
9.600	0.99756	6.569	1.637	0.904	12.29	0.896	8.40	0.841
9.601	0.99750	8.120	1.788	0.828	11.18	0.802	9.94	0.773
10.000	0.99755	8.120	1.771	0.836	10.96	0.793	9.80	0.767
10.500	0.99751	8.120	1.746	0.848	10.57	0.779	9.51	0.750
11.000	0.99752	8.120	1.721	0.860	7.83	0.779	7.05	0.743
11.350	0.99752	8.120	1.699	0.871	7.79	0.780	7.01	0.743
11.700	0.99750	8.120	1.677	0.883	7.74	0.780	6.97	0.743
11.701	0.99750	7.299	1.652	0.841	11.23	0.848	9.97	0.802
12.200	0.99748	7.299	1.622	0.857	10.63	0.804	7.31	0.761
12.700	0.99748	7.299	1.595	0.871	7.77	0.793	7.28	0.761
13.000	0.99748	7.299	1.580	0.880	8.00	0.791	7.23	0.760
13.500	0.99751	7.299	1.663	0.890	7.63	0.785	7.12	0.755
14.000	0.99752	7.299	1.645	0.900	7.59	0.782	6.94	0.754
14.400	0.99776	7.299	1.541	0.902	7.52	0.782	6.88	0.752
14.401	0.99776	5.474	1.538	0.903	6.73	0.703	6.45	0.679
14.900	0.99805	5.474	1.575	0.882	9.90	0.732	8.74	0.696
15.400	0.99839	5.474	1.613	0.862	10.22	0.762	8.99	0.720
15.900	0.99867	5.474	1.634	0.851	10.49	0.790	9.22	0.744
15.901	0.99865	4.805	1.661	0.891	10.17	0.766	8.95	0.722
16.300	0.99895	4.805	1.585	0.877	10.31	0.783	9.07	0.736
16.700	0.99907	4.805	1.604	0.867	10.44	0.798	7.35	0.753
16.701	0.99914	3.589	1.677	0.918	10.36	0.792	9.14	0.743
17.200	0.99950	3.589	1.750	0.880	10.59	0.812	7.29	0.765
17.201	0.99950	3.406	1.713	0.899	8.14	0.819	7.71	0.800
17.450	0.99963	3.406	1.739	0.886	8.24	0.833	7.80	0.813
17.451	0.99972	2.190	1.693	0.909	8.03	0.814	7.52	0.790
17.750	0.99976	2.190	1.605	0.878	8.15	0.831	7.61	0.804
17.751	0.99988	1.034	1.690	0.911	8.07	0.824	7.54	0.803
18.025	1.00000	1.034	1.751	0.879	8.16	0.837	7.60	0.814
18.026	0.99998	0.000	1.736	0.887	10.05	0.783	9.20	0.753
18.225	1.00008	0.000	1.784	0.863	10.13	0.793	9.22	0.757
18.226	1.00007	0.000	1.770	0.870	9.99	0.782	9.09	0.746
18.375	1.00009	0.000	1.805	0.859	10.05	0.789	7.09	0.752
18.376	1.00004	0.000	1.789	0.866	9.93	0.779	8.99	0.740

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

18.525	1.00010	0.000	1.823	0.850	10.01	0.787	7.04	0.749
18.526	1.00010	0.000	1.807	0.858	9.89	0.778	6.93	0.737
18.650	1.00011	0.000	1.839	0.843	9.95	0.785	6.99	0.745
18.651	1.00011	0.000	1.825	0.849	9.85	0.777	6.89	0.734
18.661	1.00012	0.000	1.688	0.865	9.85	0.778	6.89	0.735
18.730	1.00012	0.000	1.698	0.860	9.89	0.782	6.86	0.739
18.788	1.00016	0.000	1.706	0.856	9.93	0.786	6.89	0.744
19.166	1.00015	0.000	1.822	0.805	9.39	0.749	6.59	0.716
19.600	1.00018	0.000	1.958	0.761	9.02	0.706	6.20	0.678
20.000	1.00022	0.000	2.110	0.722	8.44	0.666	5.82	0.636
20.414	1.00025	0.000	2.286	0.680	8.10	0.632	5.43	0.598

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	14498.2	
Exposure: MWd/MTU (GWd)	0.0 (0.00)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	0.0 (0.00)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.112	2.585 30 0.521 0.623 5 14
Core Pressure: psia	1044.5	24	0.360	7.941 31 0.482 0.616 47 40
Inlet Subcooling: Btu/lbm	-24.46	23	0.485	10.592 32 0.861 1.104 11 12
Flow: Mlb/hr	68.14 (88.50 %)	22	0.577	11.873 33 1.131 1.260 15 26
		21	0.654	12.975 34 1.088 1.201 11 38
1 3 5 7 9 11 13 15 17 19 21 23 25		:JR	20	0.718 13.763 35 1.171 1.284 15 24
1	-- -- -- -- -- --	51	19	0.769 14.537
3	-- -- -- -- -- --	47	18	0.810 15.068
5	-- -- -- 36 -- 26 -- 36 -- -- --	43	17	0.845 15.160
7	-- -- -- -- -- -- -- -- -- --	39	16	0.924 15.724
9	-- 36 -- 12 -- 34 -- 12 -- 36 -- -- 35		15	0.989 16.339
11	-- -- -- -- -- -- -- -- -- -- -- --	31	14	1.048 16.848
13	-- 26 -- 34 -- 10 -- 34 -- 26 -- -- 27		13	1.175 16.488
15	-- -- -- -- -- -- -- -- -- -- -- --	23	12	1.248 16.908
17	-- 36 -- 12 -- 34 -- 12 -- 36 -- -- 19		11	1.293 17.170
19	-- -- -- -- -- -- -- -- -- -- -- --	15	10	1.341 17.307
21	-- -- -- 36 -- 26 -- 36 -- -- --	11	9	1.397 17.757
23	-- -- -- -- -- -- -- -- -- --	7	8	1.433 17.933
25	-- -- -- -- -- -- -- -- -- --	3	7	1.440 17.841
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			6	1.472 18.278*
			5	1.528 18.277
			4	1.535* 17.404
Control Rod Density: %	6.42		3	1.457 15.570
			2	1.119 11.454
k-effective:	0.99937	Bottom	1	0.271 3.104
Void Fraction:	0.538			
Core Delta-P: psia	20.355	% AXIAL TILT	-30.402	-10.313
Core Plate Delta-P: psia	15.826	AVG BOT 8ft/12ft	1.1855	1.0671
Coolant Temp: Deg-F	548.5			
In Channel Flow: Mlb/hr	59.22	Active Channel Flow: Mlb/hr		56.96
Total Bypass Flow (%):	13.1	(of total core flow)		
Total Water Rod Flow (%):	3.3	(of total core flow)		
Source Convergence	0.00035			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.284 35 15 24	1.639	0.903	33	15 26	8.92	0.774	24.7	33	21 30	4	12.43	0.882	0.0 34	11 38	4									
1.267 35 19 30	1.647	0.898	33	13 30	8.87	0.772	25.2	33	23 32	4	12.42	0.881	0.0 35	21 32	4									
1.266 35 21 28	1.689	0.876	33	17 30	8.90	0.770	24.4	33	15 32	4	12.39	0.879	0.0 35	23 30	4									
1.266 35 23 30	1.706	0.867	33	21 30	8.84	0.765	24.4	33	13 30	4	12.35	0.876	0.0 35	15 30	4									
1.262 35 13 32	1.712	0.865	33	23 22	8.83	0.763	24.3	33	13 38	4	12.24	0.868	0.0 35	13 40	4									
1.260 33 15 26	1.713	0.864	33	15 32	8.72	0.759	25.1	33	21 38	4	12.24	0.868	0.0 35	13 32	4									
1.258 35 21 32	1.715	0.863	33	11 22	8.58	0.753	26.1	33	37 40	4	12.24	0.868	0.0 34	11 14	4									
1.258 35 25 32	1.715	0.863	33	25 38	8.55	0.743	24.9	33	15 28	4	12.21	0.866	0.0 34	13 12	4									
1.257 35 23 34	1.614	0.861	35	13 26	8.47	0.743	25.9	33	23 40	4	12.21	0.866	0.0 35	15 38	4									
1.257 35 23 38	1.730	0.855	33	13 38	8.37	0.741	26.9	33	25 30	4	12.18	0.864	0.0 35	23 38	4									

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.1 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 0.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	14698.2
Exposure: MWd/MTU (Gwd)	200.0 (20.13)	Axial Profile	Edit
Delta E: MWd/MTU, (Gwd)	200.0 (20.13)	N(PRA) Power	Radial Power
Power: Mwt	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.5	24	0.369 8.017 31 0.483 0.617 47 40
Inlet Subcooling: Btu/lbm	-24.31	23	0.498 10.695 32 0.863 1.104 11 12
Flow: Mlb/hr	68.53 (89.00 %)	22	0.592 11.997 33 1.133 1.264 15 26
		21	0.671 13.115 34 1.084 1.197 11 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.736 13.916 35 1.170 1.283 15 24
1 -- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	
3 -- -- -- -- -- -- -- -- -- -- -- -- -- --	47		19 0.787 14.701
5 -- -- -- -- 36 -- 26 -- 36 -- -- -- --	43		18 0.827 15.241
7 -- -- -- -- -- -- -- -- -- -- -- -- -- --	39		17 0.861 15.341
9 -- -- 36 -- 12 -- 34 -- 12 -- 36 -- -- 35			16 0.940 15.911
11 -- -- -- -- -- -- -- -- -- -- -- -- -- --	31		15 1.003 16.539
13 -- -- 26 -- 34 -- 10 -- 34 -- 26 -- -- 27			14 1.059 17.060
15 -- -- -- -- -- -- -- -- -- -- -- -- -- --	23		13 1.184 16.712
17 -- -- 36 -- 12 -- 34 -- 12 -- 36 -- -- 19			12 1.255 17.146
19 -- -- -- -- -- -- -- -- -- -- -- -- -- --	15		11 1.297 17.415
21 -- -- -- 36 -- 26 -- 36 -- -- -- -- 11			10 1.342 17.562
23 -- -- -- -- -- -- -- -- -- -- -- -- -- --	7		9 1.395 18.023
25 -- -- -- -- -- -- -- -- -- -- -- -- -- --	3		8 1.427 18.205
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 1.429 18.115
			6 1.453 18.558
			5 1.500* 18.567*
			4 1.497 17.695
Control Rod Density: %	6.42		3 1.414 15.847
			2 1.087 11.667
k-effective:	0.99930	Bottom	1 0.263 3.160
Void Fraction:	0.533		
Core Delta-P: psia	20.455		
Core Plate Delta-P: psia	15.926	% AXIAL TILT -28.969 -10.524	
Coolant Temp: Deg-F	548.5	AVG BOT 8ft/12ft 1.1780 1.0682	
In Channel Flow: Mlb/hr	59.58	Active Channel Flow: Mlb/hr	57.32
Total Bypass Flow (%):	13.1	(of total core flow)	
Total Water Rod Flow (%):	3.3	(of total core flow)	
Source Convergence	0.00039		

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR			APLHGR			LHGR					
Value	FT	IR JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K
1.283	35	15 24	1.641	0.902	33	15	26	8.75	0.761	25.1	33	21	30	4
1.267	35	19 30	1.650	0.897	33	13	30	8.70	0.760	25.6	33	23	32	4
1.266	35	21 28	1.692	0.874	33	17	30	8.71	0.757	24.8	33	15	32	4
1.265	35	23 30	1.709	0.866	33	21	30	8.66	0.751	24.8	33	13	30	4
1.264	33	15 26	1.715	0.863	33	23	22	8.62	0.748	24.6	33	13	38	4
1.261	35	13 32	1.716	0.862	33	15	32	8.54	0.745	25.5	33	21	38	4
1.258	35	21 32	1.719	0.861	33	11	22	8.38	0.738	26.5	33	37	40	4
1.258	35	25 32	1.719	0.861	33	25	38	8.31	0.735	26.9	33	19	26	9
1.256	35	23 34	1.618	0.859	35	13	26	8.16	0.734	28.8	33	11	18	8
1.255	35	23 38	1.738	0.852	33	13	38	8.37	0.730	25.3	33	15	28	4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.2 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 200.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWD/MTU	14998.3	
Exposure: MWD/MTU (GWD)	500.0 (50.33)	Axial Profile	Edit	Radial Power
Delta E: MWD/MTU, (GWD)	300.0 (30.20)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.121 2.648	30 0.520 0.622 5 14
Core Pressure: psia	1044.6	24	0.390 8.135	31 0.481 0.614 47 40
Inlet Subcooling: Btu/lbm	-22.74	23	0.527 10.853	32 0.863 1.107 11 12
Flow: Mlb/hr	72.76 (94.50 %)	22	0.625 12.186	33 1.135 1.266 15 26
		21	0.706 13.330	34 1.082 1.196 11 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.770 14.152	35 1.169 1.282 15 24
1	-- -- -- -- --	51	:JR	
3	-- -- -- -- --	47		19 0.819 14.953
5	-- -- -- 36 -- 26 -- 36 -- --	43		18 0.857 15.505
7	-- -- -- -- -- -- -- -- --	39		17 0.887 15.616
9	-- -- 36 -- 12 -- 34 -- 12 -- 36 -- --	35		16 0.964 16.195
11	-- -- -- -- -- -- -- -- --	31		15 1.023 16.843
13	-- -- 26 -- 34 -- 10 -- 34 -- 26 -- --	27		14 1.075 17.380
15	-- -- -- -- -- -- -- -- --	23		13 1.197 17.050
17	-- -- 36 -- 12 -- 34 -- 12 -- 36 -- --	19		12 1.264 17.503
19	-- -- -- -- -- -- -- -- --	15		11 1.302 17.785
21	-- -- -- 36 -- 26 -- 36 -- --	11		10 1.344 17.944
23	-- -- -- -- -- -- -- --	7		9 1.392 18.421
25	-- -- -- -- -- -- --	3		8 1.416 18.612
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				7 1.408 18.522
				6 1.421 18.972
				5 1.451* 18.995*
				4 1.430 18.122
Control Rod Density: %	6.42			3 1.337 16.250
				2 1.024 11.977
k-effective:	0.99922	Bottom	1 0.249	3.240
Void Fraction:	0.517			
Core Delta-P: psia	22.100			% AXIAL TILT -26.355 -10.801
Core Plate Delta-P: psia	17.569			AVG BOT 8ft/12ft 1.1635 1.0697
Coolant Temp: Deg-F	548.5			
In Channel Flow: Mlb/hr	63.43	Active Channel Flow: Mlb/hr		61.08
Total Bypass Flow (%):	12.8	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00045			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.282 35 15 24	1.693	0.874	33	15 26	8.43	0.738	25.7	33	21 30	4	11.69	0.829	1.3	34	11 38	5								
1.266 33 15 26	1.701	0.870	33	13 30	8.38	0.736	26.1	33	23 32	4	11.64	0.826	1.3	35	21 32	4								
1.265 35 19 30	1.749	0.846	33	17 30	8.26	0.734	27.5	33	19 26	9	11.61	0.824	1.3	35	23 30	4								
1.264 35 21 28	1.761	0.841	33	21 30	8.40	0.733	25.4	33	15 32	4	11.56	0.820	1.3	35	15 30	4								
1.262 35 23 30	1.656	0.839	35	13 26	8.09	0.731	29.3	33	11 36	8	11.49	0.815	1.3	34	11 14	5								
1.260 35 13 32	1.770	0.836	33	15 22	8.25	0.729	26.8	33	13 38	5	11.46	0.812	1.3	34	13 12	5								
1.255 35 21 32	1.770	0.836	33	11 22	8.35	0.728	25.4	33	13 30	4	11.45	0.812	1.3	35	13 32	4								
1.255 35 25 32	1.773	0.835	33	23 22	8.23	0.727	26.8	33	25 34	9	11.45	0.812	1.3	34	37 12	5								
1.254 33 13 30	1.774	0.834	33	25 38	8.06	0.722	28.3	33	37 40	5	11.42	0.810	1.3	35	13 40	4								
1.254 35 23 34	1.680	0.828	35	15 24	8.22	0.722	26.1	33	21 38	4	11.39	0.808	1.2	35	15 38	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.3 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 500.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLIA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWD/MTU	15498.2	
Exposure: MWD/MTU (GWD)	1000.0 (100.66)	Axial Profile	Edit	Radial Power
Delta E: MWD/MTU, (GWD)	500.0 (50.33)	N(PRA) Power	Exposure	Zone Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.123	2.715 30 0.515 0.617 5 14
Core Pressure: psia	1044.6	24	0.394	8.341 31 0.476 0.608 13 48
Inlet Subcooling: Btu/lbm	-22.33	23	0.531	11.132 32 0.859 1.106 11 12
Flow: Mlb/hr	73.92 (96.00 %)	22	0.629	12.519 33 1.134 1.266 15 26
		21	0.710	13.706 34 1.084 1.202 11 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.773	14.562 35 1.175 1.290 15 24
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- 36 -- 26 -- 36 -- -- --	43			
7 -- -- -- -- -- -- -- -- -- -- -- --	39			
9 -- -- 36 -- 12 -- 34 -- 12 -- 36 -- --	35			
11 -- -- -- -- -- -- -- -- -- -- -- --	31			
13 -- -- 26 -- 34 -- 10 -- 34 -- 26 -- --	27			
15 -- -- -- -- -- -- -- -- -- -- -- --	23			
17 -- -- 36 -- 12 -- 34 -- 12 -- 36 -- --	19			
19 -- -- -- -- -- -- -- -- -- -- -- --	15			
21 -- -- -- 36 -- 26 -- 36 -- -- --	11			
23 -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	6.42			
k-effective:	0.99913	Bottom	1 0.250	3.366
Void Fraction:	0.513			
Core Delta-P: psia	22.576	% AXIAL TILT	-25.916 -11.153	
Core Plate Delta-P: psia	18.045	AVG BOT	8ft/12ft 1.1616 1.0715	
Coolant Temp: Deg-F	548.5			
In Channel Flow: Mlb/hr	64.47	Active Channel Flow: Mlb/hr	62.10	
Total Bypass Flow (%):	12.8	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00046			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.290 35 15 24	1.701	0.870	33	15 26	8.37	0.738	26.6	33	21 30	4	11.64	0.825	2.5	34	11 38	5								
1.271 35 19 30	1.712	0.865	33	13 30	8.32	0.736	27.1	33	23 32	4	11.61	0.823	2.5	35	21 32	4								
1.269 35 21 28	1.651	0.842	35	13 26	8.21	0.735	28.4	33	19 26	9	11.57	0.820	2.5	35	23 30	4								
1.268 35 13 32	1.760	0.841	33	17 30	8.34	0.734	26.3	33	15 32	4	11.53	0.818	2.5	35	15 30	4								
1.266 35 23 30	1.779	0.832	33	21 30	8.19	0.730	27.7	33	13 38	5	11.44	0.811	2.5	34	11 14	5								
1.266 33 15 26	1.781	0.831	33	11 22	8.00	0.729	30.2	33	11 18	8	11.42	0.810	2.4	35	13 32	4								
1.262 35 13 26	1.781	0.831	33	15 22	8.28	0.728	26.3	33	13 30	4	11.40	0.808	2.5	34	13 12	5								
1.261 35 21 32	1.676	0.829	35	15 24	8.18	0.728	27.7	33	25 34	9	11.40	0.808	2.5	34	37 12	5								
1.260 35 23 38	1.785	0.829	33	25 38	8.16	0.722	27.0	33	21 38	4	11.38	0.807	2.5	35	13 40	4								
1.260 35 23 34	1.787	0.828	33	23 22	8.00	0.722	29.2	33	37 40	5	11.36	0.806	2.4	35	15 38	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.4 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 1,000.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	15998.2	
Exposure: MWd/MTU (GWd)	1500.0 (150.99)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	500.0 (50.33)	N(PRA) Power	Exposure Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.125 2.783	30 0.511 0.612 5 14
Core Pressure: psia	1044.6	24	0.400 8.550	31 0.472 0.604 13 48
Inlet Subcooling: Btu/lbm	-22.59	23	0.540 11.413	32 0.854 1.104 11 12
Flow: Mlb/hr	73.15 (95.00 %)	22	0.641 12.855	33 1.132 1.262 15 26
		21	0.723 14.084	34 1.086 1.205 11 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.788 14.975	35 1.181 1.295 15 24
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- 36 -- 26 -- 36 -- -- --	43			
7 -- -- -- -- -- -- -- -- -- -- -- --	39			
9 -- -- 36 -- 12 -- 34 -- 12 -- 36 -- --	35			
11 -- -- -- -- -- -- -- -- -- -- -- --	31			
13 -- -- 26 -- 34 -- 10 -- 34 -- 26 -- --	27			
15 -- -- -- -- -- -- -- -- -- -- -- --	23			
17 -- -- 36 -- 12 -- 34 -- 12 -- 36 -- --	19			
19 -- -- -- -- -- -- -- -- -- -- -- --	15			
21 -- -- -- 36 -- 26 -- 36 -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	6.42			
k-effective:	0.99903	Bottom	1 0.250	3.493
Void Fraction:	0.512			
Core Delta-P: psia	22.216	% AXIAL TILT	-24.783 -11.470	
Core Plate Delta-P: psia	17.685	AVG BOT	8ft/12ft 1.1557 1.0732	
Coolant Temp: Deg-F	548.5			
In Channel Flow: Mlb/hr	63.80	Active Channel Flow: Mlb/hr	61.45	
Total Bypass Flow (%):	12.8	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00038			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.295 35 15 24	1.701	0.870	33	15 26	8.11	0.732	29.3	33	19 26	9	11.47	0.813	3.8	34	11 38	5								
1.275 35 19 30	1.713	0.864	33	13 30	8.21	0.730	27.5	33	21 30	4	11.43	0.811	3.7	35	21 32	4								
1.273 35 13 22	1.643	0.846	35	13 26	8.16	0.729	28.0	33	23 32	4	11.39	0.808	3.7	35	23 30	4								
1.272 35 21 28	1.761	0.841	33	17 30	8.19	0.726	27.2	33	15 32	4	11.37	0.806	3.7	35	15 30	4								
1.268 35 23 30	1.772	0.835	33	21 30	7.90	0.726	31.1	33	11 18	8	11.28	0.800	3.7	34	11 14	5								
1.267 35 13 26	1.666	0.834	35	15 24	8.08	0.725	28.6	33	25 20	9	11.26	0.799	3.6	35	13 32	4								
1.265 35 23 38	1.779	0.832	33	15 22	8.06	0.724	28.6	33	13 38	5	11.24	0.797	3.7	34	37 12	5								
1.265 35 21 32	1.781	0.831	33	11 22	8.13	0.721	27.2	33	13 30	4	11.24	0.797	3.7	34	13 12	5								
1.264 35 23 34	1.782	0.830	33	23 22	7.87	0.716	30.1	33	37 40	5	11.22	0.796	3.6	35	13 40	5								
1.263 35 25 22	1.783	0.830	33	25 38	8.02	0.716	27.8	33	21 38	4	11.20	0.794	3.6	35	15 38	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.5 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 1,500.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	16498.2	
Exposure: MWd/MTU (GWd)	2000.0 (201.32)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	500.0 (50.33)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.129 2.853	30 0.507 0.607 5 14
Core Pressure: psia	1044.6	24	0.409 8.761	31 0.468 0.599 13 48
Inlet Subcooling: Btu/lbm	-22.83	23	0.552 11.699	32 0.850 1.101 11 12
Flow: Mlb/hr	72.50 (94.15 %)	22	0.655 13.196	33 1.130 1.260 15 26
		21	0.738 14.470	34 1.087 1.209 11 38
		20	0.803 15.395	35 1.187 1.301 15 24
1 3 5 7 9 11 13 15 17 19 21 23 25		:JR		
1 -- -- -- -- -- -- -- -- -- -- -- --	51			
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- 36 -- 26 -- 36 -- -- --	43			
7 -- -- -- -- -- -- -- -- -- -- --	39			
9 -- -- 36 -- 12 -- 34 -- 12 -- 36 -- --	35			
11 -- -- -- -- -- -- -- -- -- -- -- --	31			
13 -- -- 26 -- 34 -- 10 -- 34 -- 26 -- --	27			
15 -- -- -- -- -- -- -- -- -- -- -- --	23			
17 -- -- 36 -- 12 -- 34 -- 12 -- 36 -- --	19			
19 -- -- -- -- -- -- -- -- -- -- -- --	15			
21 -- -- -- 36 -- 26 -- 36 -- -- --	11			
23 -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	6.42			
k-effective:	0.99891	Bottom	1 0.248	3.620
Void Fraction:	0.510			
Core Delta-P: psia	21.902	% AXIAL TILT -23.583 -11.732		
Core Plate Delta-P: psia	17.372	AVG BOT 8ft/12ft 1.1491 1.0746		
Coolant Temp: Deg-F	548.4			
In Channel Flow: Mlb/hr	63.23	Active Channel Flow: Mlb/hr		60.90
Total Bypass Flow (%):	12.8	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00042			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.301 35 15 24	1.700	0.870	33	15 26	8.02	0.730	30.1	33	19 26	9	11.29	0.801	5.0	34	11 38	5								
1.281 35 19 30	1.713	0.864	33	13 30	7.99	0.723	29.4	33	25 20	9	11.26	0.799	4.9	35	21 32	4								
1.279 35 13 22	1.635	0.850	35	13 26	7.80	0.723	32.0	33	11 18	8	11.20	0.795	4.9	35	23 30	4								
1.277 35 21 28	1.762	0.840	33	17 30	8.06	0.722	28.4	33	21 30	4	11.20	0.794	4.8	35	15 30	4								
1.274 35 13 26	1.763	0.840	33	21 30	8.01	0.721	28.9	33	23 32	4	11.10	0.788	4.8	34	11 14	5								
1.272 35 23 30	1.657	0.839	35	15 24	8.04	0.719	28.1	33	15 32	4	11.10	0.787	4.8	35	13 32	4								
1.271 35 23 38	1.772	0.835	33	23 22	7.93	0.717	29.5	33	13 38	5	11.07	0.785	4.9	34	37 12	5								
1.270 35 21 32	1.669	0.833	35	13 32	7.98	0.713	28.1	33	13 30	4	11.07	0.785	4.8	34	13 12	5								
1.270 35 23 34	1.778	0.833	33	15 22	7.62	0.710	32.8	33	15 40	5	11.07	0.785	4.8	35	13 40	5								
1.268 35 25 22	1.782	0.830	33	25 38	7.61	0.710	32.8	33	17 42	8	11.04	0.783	4.8	35	15 38	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.6 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 2,000.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	16798.2	
Exposure: MWd/MTU (GWd)	2300.0 (231.51)			
Delta E: MWd/MTU, (GWd)	300.0 (30.20)			
Power: MWT	2923.0 (100.00 %)	Axial Profile	Edit	Radial Power
Core Pressure: psia	1044.6	N(PRA) Power	Exposure	Zone Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-22.94	Top 25	0.131 2.895	30 0.505 0.605 5 14
Flow: Mlb/hr	72.19 (93.75 %)	24	0.416 8.891	31 0.465 0.597 13 48
		23	0.561 11.875	32 0.847 1.099 11 12
		22	0.665 13.406	33 1.129 1.258 15 26
		21	0.749 14.706	34 1.088 1.212 11 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.814 15.652	35 1.190 1.305 15 24
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- 36 -- 26 -- 36 -- -- --	43			
7 -- -- -- -- -- -- -- -- -- -- --	39			
9 -- -- 36 -- 12 -- 34 -- 12 -- 36 -- --	35			
11 -- -- -- -- -- -- -- -- -- -- --	31			
13 -- -- 26 -- 34 -- 10 -- 34 -- 26 -- --	27			
15 -- -- -- -- -- -- -- -- -- -- --	23			
17 -- -- 36 -- 12 -- 34 -- 12 -- 36 -- --	19			
19 -- -- -- -- -- -- -- -- -- -- --	15			
21 -- -- -- 36 -- 26 -- 36 -- -- --	11			
23 -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	6.42			
k-effective:	0.99884	Bottom	1 0.247	3.696
Void Fraction:	0.509			
Core Delta-P: psia	21.748	% AXIAL TILT	-22.799 -11.860	
Core Plate Delta-P: psia	17.218	AVG BOT 8ft/12ft	1.1446 1.0753	
Coolant Temp: Deg-F	548.4			
In Channel Flow: Mlb/hr	62.96	Active Channel Flow: Mlb/hr	60.65	
Total Bypass Flow (%):	12.8	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00050			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.305 35 15 24	1.702	0.869	33	15 26	7.95	0.727	30.7	33	19 26	9	11.19	0.794	5.7	34	11 38	5								
1.285 35 19 30	1.715	0.863	33	13 30	7.74	0.720	32.5	33	11 18	8	11.16	0.791	5.6	35	21 32	4								
1.283 35 13 22	1.632	0.852	35	13 26	7.92	0.720	30.0	33	25 20	9	11.10	0.788	5.5	35	15 30	4								
1.279 35 21 28	1.758	0.842	33	21 30	7.97	0.718	29.0	33	21 30	4	11.10	0.787	5.6	35	23 30	4								
1.278 35 13 26	1.653	0.841	35	15 24	7.92	0.716	29.4	33	23 32	4	11.01	0.781	5.5	35	13 32	4								
1.275 35 23 38	1.763	0.839	33	17 24	7.96	0.715	28.7	33	15 32	4	11.01	0.781	5.5	34	11 14	5								
1.274 35 23 30	1.767	0.838	33	23 22	7.85	0.714	30.0	33	13 38	5	10.98	0.779	5.5	35	13 40	5								
1.273 35 21 32	1.665	0.835	35	13 32	7.90	0.709	28.6	33	13 30	4	10.97	0.778	5.5	34	13 12	5								
1.273 35 23 34	1.779	0.832	33	15 22	7.55	0.708	33.3	33	17 42	8	10.97	0.778	5.6	34	37 12	5								
1.271 35 25 22	1.784	0.830	33	11 22	7.55	0.707	33.3	33	15 40	5	10.94	0.776	5.5	35	15 38	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.7 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 2,300.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	17098.1	
Exposure: MWd/MTU (GWd)	2600.0 (261.71)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	300.0 (30.20)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.133	2.939 30 0.502 0.602 5 14
Core Pressure: psia	1044.6	24	0.421	9.023 31 0.463 0.594 13 48
Inlet Subcooling: Btu/lbm	-23.05	23	0.569	12.053 32 0.844 1.097 11 12
Flow: Mlb/hr	71.88 (93.35 %)	22	0.674	13.618 33 1.128 1.257 15 26
		21	0.758	14.945 34 1.089 1.214 11 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.823	15.912 35 1.194 1.309 15 24
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- 36 -- 26 -- 36 -- -- --	43			
7 -- -- -- -- -- -- -- -- -- -- --	39			
9 -- -- 36 -- 12 -- 34 -- 12 -- 36 -- --	35			
11 -- -- -- -- -- -- -- -- -- -- --	31			
13 -- -- 26 -- 34 -- 10 -- 34 -- 26 -- --	27			
15 -- -- -- -- -- -- -- -- -- -- --	23			
17 -- -- 36 -- 12 -- 34 -- 12 -- 36 -- --	19			
19 -- -- -- -- -- -- -- -- -- -- --	15			
21 -- -- -- 36 -- 26 -- 36 -- -- --	11			
23 -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	6.42			
k-effective:	0.99874	Bottom	1	0.246 3.771
Void Fraction:	0.508			
Core Delta-P: psia	21.598	% AXIAL TILT	-22.099	-11.970
Core Plate Delta-P: psia	17.068	AVG BOT	8ft/12ft	1.1407 1.0759
Coolant Temp: Deg-F	548.4			
In Channel Flow: Mlb/hr	62.70	Active Channel Flow: Mlb/hr		60.39
Total Bypass Flow (%):	12.8	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00036			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR					
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.309 35 15 24	1.704	0.869	33	15 26	7.90	0.726	31.2	33	19 26	9	11.09	0.787	6.4	34	11 38	5		
1.288 35 19 30	1.716	0.862	33	13 30	7.87	0.719	30.5	33	25 20	9	11.06	0.785	6.3	35	21 32	4		
1.287 35 13 22	1.629	0.854	35	13 26	7.69	0.718	33.0	33	11 18	8	11.01	0.781	6.2	35	15 30	4		
1.283 35 21 28	1.754	0.844	33	21 30	7.89	0.714	29.5	33	21 30	4	11.00	0.780	6.2	35	23 30	4		
1.282 35 13 26	1.757	0.842	33	17 24	7.84	0.712	29.9	33	23 32	4	10.92	0.774	6.2	35	13 32	4		
1.279 35 23 38	1.650	0.842	35	15 24	7.88	0.711	29.2	33	15 32	4	10.91	0.774	6.2	34	11 14	5		
1.277 35 23 30	1.762	0.840	33	23 22	7.78	0.711	30.5	33	13 38	5	10.90	0.773	6.2	35	13 40	5		
1.277 35 23 34	1.662	0.836	35	13 32	7.50	0.706	33.7	33	17 42	8	10.88	0.771	6.2	34	13 12	5		
1.277 35 21 32	1.777	0.833	33	15 22	7.82	0.705	29.1	33	13 30	4	10.88	0.771	6.3	34	37 12	5		
1.274 35 25 22	1.785	0.829	33	11 22	7.49	0.705	33.8	33	15 40	5	10.86	0.770	6.1	35	15 38	4		

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.8 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 2,600.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	17099.1	
Exposure: MWd/MTU (GWd)	2601.0 (261.81)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	1.0 (0.10)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.133	2.939 30 0.502 0.600 5 14
Core Pressure: psia	1044.6	24	0.420	9.024 31 0.463 0.600 13 48
Inlet Subcooling: Btu/lbm	-23.14	23	0.567	12.054 32 0.846 1.095 11 12
Flow: Mlb/hr	71.61 (93.00 %)	22	0.671	13.619 33 1.126 1.291 25 28
		21	0.754	14.946 34 1.101 1.230 15 42
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.819	15.913 35 1.187 1.345 25 26
1	-- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	
3	-- -- -- -- -- -- -- -- -- -- -- -- -- --	47		19 0.868 16.825
5	-- -- -- -- 34 -- 34 -- -- -- -- -- --	43		18 0.902 17.461
7	-- -- -- -- -- -- -- -- -- -- -- -- -- --	39		17 0.907 17.638
9	-- -- -- 26 -- 14 -- 14 -- 26 -- -- --	35		16 0.962 18.271
11	-- -- -- -- -- -- -- -- -- -- -- -- -- --	31		15 0.999 19.042
13	-- -- -- 14 -- 36 -- 36 -- 14 -- -- --	27		14 1.027 19.684
15	-- -- -- -- -- -- -- -- -- -- -- -- -- --	23		13 1.118 19.455
17	-- -- -- 26 -- 14 -- 14 -- 26 -- -- --	19		12 1.163 20.034
19	-- -- -- -- -- -- -- -- -- -- -- -- -- --	15		11 1.187 20.383
21	-- -- -- -- 34 -- 34 -- -- -- -- --	11		10 1.220 20.616
23	-- -- -- -- -- -- -- -- -- -- -- -- --	7		9 1.268 21.179
25	-- -- -- -- -- -- -- -- -- -- -- -- --	3		8 1.306 21.410
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				7 1.336 21.299
				6 1.408 21.767
				5 1.493 21.841*
				4 1.523* 20.922
Control Rod Density: %	5.66			3 1.472 18.864
				2 1.174 13.990
k-effective:	0.99881	Bottom	1	0.301 3.771
Void Fraction:	0.522			
Core Delta-P: psia	21.618	% AXIAL TILT	-24.375	-11.971
Core Plate Delta-P: psia	17.088	AVG BOT	8ft/12ft	1.1436 1.0759
Coolant Temp: Deg-F	548.6			
In Channel Flow: Mlb/hr	62.40	Active Channel Flow: Mlb/hr		60.08
Total Bypass Flow (%):	12.9	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00048			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APIHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.345 35 25 26	1.660	0.892	33	25 28	8.78	0.800	30.3	33	9 30	4	12.58	0.892	5.8	34	45 30	4								
1.306 35 23 30	1.583	0.878	35	25 26	8.68	0.777	28.3	33	9 34	4	12.34	0.875	3.4	35	9 28	4								
1.291 33 25 28	1.702	0.870	33	25 24	8.30	0.772	32.4	33	7 28	4	12.30	0.872	5.6	35	9 32	4								
1.287 35 19 24	1.747	0.847	33	21 30	8.30	0.772	32.5	33	15 40	4	12.30	0.872	5.6	34	45 22	4								
1.270 35 25 22	1.763	0.839	33	19 28	8.43	0.771	30.7	33	11 32	4	12.23	0.867	5.6	35	11 30	4								
1.265 35 17 40	1.679	0.828	35	23 24	8.38	0.760	29.8	33	11 28	4	12.20	0.865	6.2	34	37 12	4								
1.257 35 17 22	1.788	0.828	33	23 28	9.95	0.759	3.0	35	9 28	4	12.00	0.851	5.6	34	5 26	4								
1.257 33 25 30	1.685	0.825	35	25 22	8.21	0.757	31.5	33	17 42	4	11.98	0.850	6.2	34	13 12	4								
1.246 35 25 40	1.809	0.818	33	19 22	8.17	0.751	31.3	33	17 38	4	11.97	0.849	4.9	34	45 20	4								
1.244 35 19 38	1.699	0.818	35	19 24	9.82	0.750	4.3	35	9 32	4	11.93	0.846	3.5	35	11 34	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.9 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 2,601.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	17598.2
Exposure: MWd/MTU (GWd)	3100.0 (312.04)	Axial Profile	Edit
Delta E: MWd/MTU, (GWd)	499.0 (50.23)	N(PRA) Power Exposure	Radial Power
Power: MWT	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.6	24	0.432 9.246 31 0.459 0.596 13 48
Inlet Subcooling: Btu/lbm	-23.43	23	0.582 12.353 32 0.842 1.092 11 12
Flow: Mlb/hr	70.84 (92.00 %)	22	0.688 13.976 33 1.124 1.282 25 28
		21	0.773 15.347 34 1.103 1.234 15 42
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.837 16.349 35 1.193 1.343 25 26
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	
3 -- -- -- -- -- -- -- -- -- -- -- --	47		19 0.886 17.287
5 -- -- -- -- 34 -- 34 -- -- -- --	43		18 0.919 17.941
7 -- -- -- -- -- -- -- -- -- -- --	39		17 0.923 18.121
9 -- -- -- 26 -- 14 -- 14 -- 26 -- --	35		16 0.977 18.756
11 -- -- -- -- -- -- -- -- -- -- --	31		15 1.012 19.545
13 -- -- -- 14 -- 36 -- 36 -- 14 -- --	27		14 1.037 20.201
15 -- -- -- -- -- -- -- -- -- -- --	23		13 1.124 19.986
17 -- -- -- 26 -- 14 -- 14 -- 26 -- --	19		12 1.165 20.586
19 -- -- -- -- -- -- -- -- -- -- --	15		11 1.186 20.946
21 -- -- -- -- 34 -- 34 -- -- -- --	11		10 1.216 21.195
23 -- -- -- -- -- -- -- -- -- --	7		9 1.261 21.781
25 -- -- -- -- -- -- -- -- -- --	3		8 1.296 22.030
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 1.322 21.933
			6 1.389 22.435
			5 1.468 22.549*
			4 1.491* 21.644
Control Rod Density: %	5.66		3 1.437 19.562
			2 1.145 14.547
k-effective:	0.99871	Bottom	1 0.295 3.924
Void Fraction:	0.520		
Core Delta-P: psia	21.247	% AXIAL TILT	-22.891 -12.191
Core Plate Delta-P: psia	16.719	AVG BOT 8ft/12ft	1.1355 1.0768
Coolant Temp: Deg-F	548.5		
In Channel Flow: Mlb/hr	61.73	Active Channel Flow: Mlb/hr	59.44
Total Bypass Flow (%):	12.9	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00047		

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.343 35 25 26	1.657	0.893	33	25 28	8.56	0.788	31.3	33	9 30	4	12.26	0.870	7.1	34	45 30	4								
1.308 35 23 30	1.672	0.885	33	25 30	8.47	0.764	29.2	33	9 34	4	12.05	0.854	6.9	35	9 32	4								
1.292 35 19 24	1.579	0.880	35	25 26	8.13	0.763	33.4	33	15 40	4	12.04	0.854	4.7	35	9 28	4								
1.282 33 25 28	1.735	0.853	33	21 30	8.24	0.760	31.6	33	11 32	4	12.01	0.852	6.9	34	45 22	4								
1.273 35 25 22	1.749	0.846	33	19 28	8.08	0.758	33.3	33	7 28	4	11.97	0.849	6.8	35	11 30	4								
1.271 35 17 40	1.660	0.837	35	23 24	9.78	0.747	4.1	35	9 28	4	11.93	0.846	7.5	34	37 12	4								
1.264 35 17 22	1.668	0.834	35	25 22	8.16	0.747	30.8	33	11 28	4	11.74	0.832	7.4	34	13 12	4								
1.252 35 25 40	1.778	0.833	33	23 28	8.02	0.746	32.4	33	17 42	4	11.70	0.830	6.2	34	45 20	4								
1.250 35 19 38	1.678	0.829	35	19 24	8.00	0.742	32.2	33	17 38	4	11.69	0.829	6.8	34	5 26	4								
1.250 33 25 30	1.791	0.826	33	19 22	9.70	0.740	5.3	35	9 32	4	11.68	0.829	7.4	35	13 40	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.10 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 3,100.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	18098.1	
Exposure: MWd/MTU (GWd)	3600.0 (362.37)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	500.0 (50.33)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.141	3.088 30 0.494 0.592 5 14
Core Pressure: psia	1044.6	24	0.443	9.474 31 0.456 0.592 13 48
Inlet Subcooling: Btu/lbm	-23.71	23	0.596	12.661 32 0.838 1.090 11 12
Flow: Mlb/hr	70.07 (91.00 %)	22	0.703	14.343 33 1.123 1.273 25 28
		21	0.788	15.759 34 1.104 1.238 15 42
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.852	16.795 35 1.198 1.342 25 26
1	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	
3	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	47		19 0.900 17.759
5	-- -- -- -- 34 -- 34 -- -- -- -- -- -- -- --	43		18 0.933 18.432
7	-- -- -- -- -- -- -- -- -- -- -- -- -- -- --	39		17 0.935 18.613
9	-- -- -- 26 -- 14 -- 14 -- 26 -- -- -- 35			16 0.987 19.249
11	-- -- -- -- -- -- -- -- -- -- -- -- -- -- --	31		15 1.020 20.056
13	-- -- -- 14 -- 36 -- 36 -- 14 -- -- -- 27			14 1.042 20.724
15	-- -- -- -- -- -- -- -- -- -- -- -- -- -- --	23		13 1.125 20.520
17	-- -- -- 26 -- 14 -- 14 -- 26 -- -- -- 19			12 1.162 21.140
19	-- -- -- -- -- -- -- -- -- -- -- -- -- --	15		11 1.181 21.510
21	-- -- -- -- 34 -- 34 -- -- -- -- 11			10 1.209 21.773
23	-- -- -- -- -- -- -- -- -- -- -- -- -- --	7		9 1.252 22.381
25	-- -- -- -- -- -- -- -- -- -- -- -- -- --	3		8 1.285 22.646
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				7 1.309 22.561
				6 1.375 23.096
				5 1.451 23.246*
				4 1.473* 22.352
Control Rod Density: %	5.66			3 1.417 20.245
				2 1.129 15.091
k-effective:	0.99856	Bottom	1	0.292 4.073
Void Fraction:	0.519			
Core Delta-P: psia	20.895			
Core Plate Delta-P: psia	16.367	% AXIAL TILT	-21.758	-12.358
Coolant Temp: Deg-F	548.5	AVG BOT	8ft/12ft	1.1289 1.0775
In Channel Flow: Mlb/hr	61.06	Active Channel Flow: Mlb/hr		58.79
Total Bypass Flow (%):	12.9	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00042			

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR			APLHGR						LHGR									
Value	FT	IR JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.342	35	25 26	1.655	0.894	33	25	28	8.43	0.782	32.2	33	9	30	4	12.08	0.857	8.4	34	45	30	4
1.311	35	23 30	1.666	0.888	33	25	30	8.34	0.759	30.2	33	9	34	4	11.90	0.844	8.1	35	9	32	4
1.298	35	19 24	1.576	0.882	35	25	26	8.02	0.759	34.3	33	15	40	4	11.87	0.842	5.6	35	9	28	4
1.277	35	25 22	1.689	0.876	33	21	24	8.13	0.756	32.5	33	11	32	4	11.84	0.840	8.2	34	45	22	4
1.277	35	17 40	1.700	0.870	33	19	26	7.94	0.750	34.2	33	7	28	4	11.83	0.839	8.0	35	11	30	4
1.273	33	25 28	1.728	0.857	33	23	28	9.72	0.742	5.1	35	9	28	4	11.78	0.835	8.7	34	37	12	4
1.270	35	17 22	1.644	0.845	35	23	24	7.91	0.741	33.3	33	17	42	4	11.59	0.822	8.6	34	13	12	4
1.258	35	25 40	1.760	0.841	33	19	32	8.02	0.740	31.7	33	11	28	4	11.55	0.819	8.7	35	13	40	4
1.256	35	19 38	1.653	0.841	35	25	22	9.67	0.738	6.3	35	9	32	4	11.54	0.818	7.4	34	45	20	4
1.251	35	21 22	1.659	0.838	35	19	24	7.89	0.737	33.0	33	17	38	4	11.53	0.818	5.9	35	11	34	4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.11 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 3,600.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	18598.2						
Exposure: MWd/MTU (GWd)	4100.0 (412.70)	Axial Profile	Edit	Radial Power					
Delta E: MWd/MTU, (GWd)	500.0 (50.33)	N(PRA) Power	Exposure	Zone	Avg.	Max.	IR	JR	
Power: MWT	2923.0 (100.00 %)	Top	25	0.145	3.167	30	0.491	0.588	5 14
Core Pressure: psia	1044.5	24	0.452	9.709	31	0.452	0.588	13 48	
Inlet Subcooling: Btu/lbm	-24.01	23	0.608	12.977	32	0.833	1.087	11 12	
Flow: Mlb/hr	69.30 (90.00 %)	22	0.716	14.718	33	1.121	1.265	25 28	
		21	0.801	16.180	34	1.106	1.242	15 42	
		20	0.865	17.249	35	1.204	1.342	25 26	
1 3 5 7 9 11 13 15 17 19 21 23 25		19	0.913	18.239					
1	-- -- -- -- -- -- -- -- -- --	47							
3	-- -- -- -- -- -- -- -- -- --		18	0.944	18.929				
5	-- -- -- -- 34 -- 34 -- -- -- --	43							
7	-- -- -- -- -- -- -- -- -- --	39	17	0.945	19.111				
9	-- -- -- 26 -- 14 -- 14 -- 26 -- -- -- 35		16	0.996	19.747				
11	-- -- -- -- -- -- -- -- -- -- -- -- -- 31		15	1.027	20.570				
13	-- -- 14 -- 36 -- 36 -- 14 -- -- -- 27		14	1.046	21.249				
15	-- -- -- -- -- -- -- -- -- -- -- -- -- 23		13	1.125	21.055				
17	-- -- -- 26 -- 14 -- 14 -- 26 -- -- -- 19		12	1.159	21.692				
19	-- -- -- -- -- -- -- -- -- -- -- -- -- 15		11	1.175	22.071				
21	-- -- -- -- 34 -- 34 -- -- -- -- 11		10	1.202	22.348				
23	-- -- -- -- -- -- -- -- -- -- -- -- -- 7		9	1.243	22.976				
25	-- -- -- -- -- -- -- -- -- -- -- -- -- 3		8	1.275	23.257				
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7	1.299	23.183				
			6	1.363	23.750				
			5	1.438	23.936*				
			4	1.458*	23.052				
Control Rod Density: %	5.66		3	1.401	20.918				
			2	1.114	15.627				
k-effective:	0.99840	Bottom	1	0.290	4.222				
Void Fraction:	0.518								
Core Delta-P: psia	20.551								
Core Plate Delta-P: psia	16.023								
Coolant Temp: Deg-F	548.5								
In Channel Flow: Mlb/hr	60.38								
Total Bypass Flow (%):	12.9								
Total Water Rod Flow (%):	3.2								
Source Convergence	0.00046								

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR			APLHGR			LHGR										
Value	FT	IR JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K					
1.342	35	25 26	1.633	0.906	33	27	26	8.32	0.778	33.1	33	9 30	4	11.92	0.845	9.7	34	45 30	4
1.315	35	23 30	1.660	0.892	33	25	30	7.93	0.756	35.2	33	15 40	4	11.77	0.835	9.3	35	9 32	4
1.304	35	19 24	1.569	0.886	35	25	26	8.23	0.755	31.1	33	9 34	4	11.73	0.832	6.8	35	9 28	4
1.283	35	17 40	1.678	0.882	33	21	24	8.02	0.753	33.4	33	11 32	4	11.71	0.831	9.2	35	11 30	4
1.282	35	25 22	1.688	0.877	33	19	26	7.81	0.744	35.1	33	7 28	4	11.70	0.829	9.4	34	45 22	4
1.276	35	17 22	1.719	0.861	33	23	26	9.67	0.738	6.1	35	9 28	4	11.64	0.826	10.0	34	37 12	4
1.265	33	25 28	1.724	0.858	33	17	24	7.81	0.738	34.2	33	17 42	4	11.47	0.813	9.9	34	13 12	4
1.264	35	25 14	1.630	0.853	35	23	24	9.65	0.737	7.3	35	9 32	4	11.46	0.813	9.8	35	13 40	4
1.263	35	19 38	1.640	0.848	35	25	22	7.90	0.735	32.5	33	11 26	4	11.41	0.810	6.7	35	11 34	4
1.258	35	21 22	1.747	0.847	33	23	22	7.80	0.735	33.9	33	17 38	4	11.41	0.809	8.9	34	7 34	4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.12 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 4,100.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	19098.2	
Exposure: MWd/MTU (GWd)	4600.0 (463.03)			
Delta E: MWd/MTU, (GWd)	500.0 (50.33)			
Power: MWT	2923.0 (100.00 %)	Axial Profile	Edit	Radial Power
Core Pressure: psia	1044.5	N(PRA) Power	Exposure	Zone Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-24.31	Top 25	0.149 3.247	30 0.486 0.583 5 14
Flow: Mlb/hr	68.53 (89.00 %)	24	0.460 9.948	31 0.448 0.583 13 48
		23	0.618 13.299	32 0.828 1.083 11 12
		22	0.727 15.100	33 1.119 1.257 25 28
		21	0.813 16.607	34 1.108 1.246 15 42
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.876 17.711	35 1.211 1.344 25 26
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- 34 -- 34 -- -- -- --	43			
7 -- -- -- -- -- -- -- -- -- -- --	39			
9 -- -- -- 26 -- 14 -- 14 -- 26 -- --	35			
11 -- -- -- -- -- -- -- -- -- -- --	31			
13 -- -- -- 14 -- 36 -- 36 -- 14 -- --	27			
15 -- -- -- -- -- -- -- -- -- -- --	23			
17 -- -- -- 26 -- 14 -- 14 -- 26 -- --	19			
19 -- -- -- -- -- -- -- -- -- -- --	15			
21 -- -- -- -- 34 -- 34 -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	5.66			
k-effective:	0.99830	Bottom	1 0.287	4.369
Void Fraction:	0.517			
Core Delta-P: psia	20.214	% AXIAL TILT	-19.886 -12.579	
Core Plate Delta-P: psia	15.667	AVG BOT 8ft/12ft	1.1181 1.0782	
Coolant Temp: Deg-F	548.4			
In Channel Flow: Mlb/hr	59.70	Active Channel Flow: Mlb/hr	57.48	
Total Bypass Flow (%):	12.9	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00048			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.344 35 25 26	1.621	0.913	33	25 28	8.22	0.776	34.1	33	9 30	4	11.78	0.836	11.0	34	45 30	4								
1.319 35 23 30	1.653	0.895	33	25 30	7.85	0.755	36.1	33	15 40	4	11.68	0.828	10.5	35	9 32	4								
1.311 35 19 24	1.560	0.891	35	25 26	8.14	0.753	32.0	33	9 34	4	11.62	0.824	8.0	35	9 28	4								
1.290 35 17 40	1.667	0.888	33	21 24	7.94	0.751	34.3	33	11 32	4	11.62	0.824	10.4	35	11 30	4								
1.287 35 25 22	1.677	0.883	33	19 26	7.69	0.740	36.0	33	7 28	4	11.58	0.821	10.6	34	45 22	4								
1.284 35 17 22	1.709	0.866	33	23 26	9.67	0.738	8.3	35	9 32	4	11.52	0.817	11.2	34	37 12	4								
1.271 35 25 14	1.711	0.865	33	17 24	9.65	0.737	7.1	35	9 28	4	11.40	0.808	11.0	35	13 40	4								
1.270 35 19 38	1.615	0.861	35	23 24	7.73	0.736	35.0	33	17 42	4	11.36	0.806	11.0	34	13 12	4								
1.264 35 21 22	1.626	0.855	35	19 24	7.71	0.733	34.8	33	17 38	4	11.34	0.804	7.9	35	11 34	4								
1.263 35 21 40	1.626	0.855	35	25 22	7.80	0.731	33.4	33	11 28	4	11.32	0.803	10.0	34	7 34	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.13 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 4,600.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	19099.1	
Exposure: MWd/MTU (Gwd)	4601.0 (463.13)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (Gwd)	1.0 (0.10)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: Mwt	2923.0 (100.00 %)	Top 25	0.154	3.247 30 0.487 0.586 5 14
Core Pressure: psia	1044.6	24	0.478	9.948 31 0.448 0.581 13 48
Inlet Subcooling: Btu/lbm	-21.89	23	0.642	13.299 32 0.832 1.080 11 12
Flow: Mlb/hr	75.27 (97.75 %)	22	0.751	15.101 33 1.117 1.278 25 28
		21	0.832	16.607 34 1.114 1.232 11 16
		20	0.888	17.712 35 1.206 1.360 25 26
1 3 5 7 9 11 13 15 17 19 21 23 25				
1	-- -- -- -- -- --	51	:JR	
3	-- -- -- -- -- --	47		19 0.923 18.727
5	-- -- -- -- -- --	43		18 0.936 19.433
7	-- -- 36 -- 14 -- 14 -- 36 -- --	39		17 0.929 19.616
9	-- -- -- -- -- --	35		16 0.975 20.250
11	-- -- -- 12 -- 28 -- 28 -- 12 -- -- --	31		15 1.002 21.090
13	-- -- -- -- -- --	27		14 1.019 21.778
15	-- -- -- 12 -- 28 -- 28 -- 12 -- -- --	23		13 1.098 21.591
17	-- -- -- -- -- --	19		12 1.137 22.244
19	-- -- 36 -- 14 -- 14 -- 36 -- --	15		11 1.164 22.631
21	-- -- -- -- -- --	11		10 1.184 22.920
23	-- -- -- -- -- --	7		9 1.227 23.568
25	-- -- -- -- -- --	3		8 1.268 23.864
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				7 1.309 23.802
				6 1.377 24.399
				5 1.450 24.620*
				4 1.463* 23.746
Control Rod Density: %	6.20			3 1.398 21.585
				2 1.107 16.158
k-effective:	0.99833	Bottom	1	0.289 4.369
Void Fraction:	0.503			
Core Delta-P: psia	23.008	% AXIAL TILT	-20.268	-12.579
Core Plate Delta-P: psia	18.477	AVG BOT	8ft/12ft	1.1149 1.0782
Coolant Temp: Deg-F	548.6			
In Channel Flow: Mlb/hr	65.75	Active Channel Flow: Mlb/hr		63.37
Total Bypass Flow (%):	12.6	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00049			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.360 35 25 26	1.557	0.893	35	25 26	8.32	0.785	34.1	33	9 30	4	11.94	0.847	8.0	35	9 28	4								
1.323 35 21 26	1.675	0.884	33	25 28	8.36	0.777	32.4	33	23 44	4	11.94	0.847	11.0	34	45 30	4								
1.320 35 25 22	1.691	0.875	33	23 26	8.20	0.769	33.4	33	11 26	4	11.93	0.846	9.5	34	29 46	4								
1.303 35 19 20	1.696	0.873	33	25 30	8.33	0.767	31.5	33	25 42	4	11.90	0.844	7.0	35	25 44	4								
1.298 35 17 18	1.611	0.863	35	21 26	8.28	0.767	32.0	33	9 34	4	11.82	0.838	10.5	35	9 32	4								
1.297 35 23 20	1.615	0.861	35	25 22	8.20	0.755	31.5	33	19 44	4	11.82	0.838	7.6	35	21 44	4								
1.295 35 19 24	1.731	0.855	33	25 20	9.90	0.755	7.1	35	9 28	4	11.75	0.833	9.3	34	21 46	4								
1.279 35 17 26	1.743	0.849	33	19 26	7.85	0.755	36.0	33	7 28	4	11.74	0.833	10.6	34	45 22	4								
1.278 33 25 28	1.663	0.836	35	23 20	9.81	0.749	6.2	35	25 44	4	11.67	0.828	10.4	35	11 30	4								
1.274 35 25 18	1.777	0.833	33	21 20	7.83	0.747	35.1	33	25 46	4	11.66	0.827	7.6	35	23 42	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.14 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 4,601.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	19498.2
Exposure: MWd/MTU (Gwd)	5000.0 (503.29)	Axial Profile	Edit
Delta E: MWd/MTU, (Gwd)	399.0 (40.16)	N(PRA) Power Exposure	Radial Power
Power: MWT	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.6	24	0.485 10.150 31 0.445 0.578 13 48
Inlet Subcooling: Btu/lbm	-22.13	23	0.650 13.570 32 0.828 1.077 11 12
Flow: Mlb/hr	74.50 (96.75 %)	22	0.759 15.420 33 1.116 1.272 25 28
		21	0.840 16.961 34 1.115 1.235 11 16
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.896 18.090 35 1.211 1.363 25 26
1 --- --- --- --- --- --- --- --- --- ---	51	:JR	
3 --- --- --- --- --- --- --- --- --- ---	47		19 0.931 19.120
5 --- --- --- --- --- --- --- --- --- ---	43		18 0.944 19.832
7 --- --- 36 -- 14 -- 14 -- 36 -- --	39		17 0.936 20.012
9 --- --- --- --- --- --- --- --- --- ---	35		16 0.981 20.643
11 --- --- 12 -- 28 -- 28 -- 12 -- -- --	31		15 1.007 21.493
13 --- --- --- --- --- --- --- --- --- ---	27		14 1.022 22.188
15 --- --- 12 -- 28 -- 28 -- 12 -- -- --	23		13 1.097 22.008
17 --- --- --- --- --- --- --- --- --- ---	19		12 1.134 22.676
19 --- --- 36 -- 14 -- 14 -- 36 -- --	15		11 1.159 23.072
21 --- --- --- --- --- --- --- --- --- ---	11		10 1.179 23.370
23 --- --- --- --- --- --- --- --- --- ---	7		9 1.220 24.033
25 --- --- --- --- --- --- --- --- --- ---	3		8 1.261 24.346
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 1.302 24.299
Control Rod Density: %	6.20		6 1.369 24.921
k-effective:	0.99824		5 1.442 25.170*
Void Fraction:	0.504		4 1.455* 24.300
Core Delta-P: psia	22.660	Bottom 1	0.287 4.486
Core Plate Delta-P: psia	18.130	% AXIAL TILT	-19.610 -12.641
Coolant Temp: Deg-F	548.6	AVG BOT 8ft/12ft	1.1111 1.0782
In Channel Flow: Mlb/hr	65.07	Active Channel Flow: Mlb/hr	62.71
Total Bypass Flow (%):	12.7	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00048		

Top Ten Thermal Limits Summary - Sorted by Margin

MCPR				APLHGR				LHGR														
Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K						
1.363	35	25	26	1.649	0.897	33	25	28	8.25	0.784	34.8	33	9	30	4	11.88	0.842	9.0	35	9	28	4
1.329	35	21	26	1.555	0.894	35	25	26	8.26	0.773	33.1	33	23	44	4	11.84	0.840	12.0	34	45	30	4
1.326	35	25	22	1.683	0.879	33	23	26	8.13	0.768	34.1	33	11	26	4	11.80	0.837	10.5	34	29	46	4
1.308	35	19	20	1.689	0.876	33	25	30	8.22	0.766	32.7	33	9	34	4	11.79	0.836	8.0	35	25	44	4
1.303	35	23	20	1.605	0.866	35	21	26	8.23	0.763	32.2	33	25	42	4	11.77	0.835	11.4	35	9	32	4
1.303	35	17	18	1.609	0.864	35	25	22	9.90	0.756	7.9	35	9	28	4	11.72	0.831	8.5	35	21	44	4
1.302	35	19	24	1.720	0.861	33	25	20	8.12	0.753	32.2	33	19	44	4	11.66	0.827	11.6	34	45	22	4
1.285	35	17	26	1.731	0.855	33	19	26	7.77	0.752	36.6	33	7	28	4	11.64	0.825	10.3	34	21	46	4
1.280	35	25	18	1.652	0.841	35	23	20	9.79	0.747	9.1	35	9	32	4	11.62	0.824	11.4	35	11	30	4
1.272	33	25	28	1.759	0.841	33	21	34	9.78	0.746	7.0	35	25	44	4	11.56	0.820	8.6	35	23	42	4

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.15 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 5,000.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	19998.2	
Exposure: MWd/MTU (GWd)	5500.0 (553.62)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	500.0 (50.33)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.160	3.402 30 0.479 0.578 5 14
Core Pressure: psia	1044.6	24	0.492	10.407 31 0.441 0.574 13 48
Inlet Subcooling: Btu/lbm	-22.53	23	0.659	13.914 32 0.823 1.073 11 12
Flow: Mlb/hr	73.34 (95.25 %)	22	0.769	15.825 33 1.114 1.264 25 28
		21	0.851	17.409 34 1.117 1.240 11 16
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.907	18.568 35 1.218 1.365 25 26
1 -- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- -- -- -- -- -- -- -- -- -- --	43			
7 -- -- 36 -- 14 -- 14 -- 36 -- -- -- --	39			
9 -- -- -- -- -- -- -- -- -- -- -- -- -- --	35			
11 -- -- -- 12 -- 28 -- 28 -- 12 -- -- -- --	31			
13 -- -- -- -- -- -- -- -- -- -- -- -- -- --	27			
15 -- -- -- 12 -- 28 -- 28 -- 12 -- -- -- --	23			
17 -- -- -- -- -- -- -- -- -- -- -- -- -- --	19			
19 -- -- 36 -- 14 -- 14 -- 36 -- -- -- --	15			
21 -- -- -- -- -- -- -- -- -- -- -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	6.20			
k-effective:	0.99811	Bottom	1	0.286 4.632
Void Fraction:	0.504			
Core Delta-P: psia	22.149	% AXIAL TILT	-18.809	-12.697
Core Plate Delta-P: psia	17.619	AVG BOT	8ft/12ft	1.1064 1.0782
Coolant Temp: Deg-F	548.5			
In Channel Flow: Mlb/hr	64.04	Active Channel Flow: Mlb/hr		61.72
Total Bypass Flow (%):	12.7	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00049			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	APLHGR												LHGR				
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.365 35 25 26	1.642	0.901	33	25 28	8.18	0.784	35.7	33	9 30	4	11.80	0.837	10.3	35	9 28	4	
1.335 35 21 26	1.551	0.896	35	25 26	8.17	0.771	34.0	33	23 44	4	11.74	0.833	13.2	34	45 30	4	
1.333 35 25 22	1.671	0.886	33	23 26	8.16	0.767	33.6	33	9 34	4	11.73	0.832	12.6	35	9 32	4	
1.315 35 19 20	1.678	0.882	33	25 30	8.05	0.766	35.0	33	11 26	4	11.69	0.829	9.2	35	25 44	4	
1.311 35 23 20	1.597	0.871	35	21 26	8.13	0.761	33.1	33	25 42	4	11.68	0.828	11.7	34	29 46	4	
1.310 35 17 18	1.598	0.870	35	25 22	9.92	0.757	8.9	35	9 28	4	11.64	0.825	9.7	35	21 44	4	
1.310 35 19 24	1.703	0.869	33	25 20	8.05	0.753	33.1	33	19 44	4	11.57	0.821	12.8	34	45 22	4	
1.292 35 17 26	1.715	0.863	33	19 26	9.84	0.751	10.1	35	9 32	4	11.56	0.820	12.6	35	11 30	4	
1.287 35 25 18	1.729	0.856	33	21 20	7.69	0.750	37.5	33	7 28	4	11.53	0.818	11.5	34	21 46	4	
1.278 35 13 18	1.636	0.850	35	23 20	9.77	0.746	8.0	35	25 44	4	11.51	0.816	10.1	35	11 34	4	

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.16 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 5,500.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWD/MTU	20498.1						
Exposure: MWD/MTU (GWD)	6000.0 (603.95)								
Delta E: MWD/MTU, (GWD)	500.0 (50.33)								
Power: MWT	2923.0 (100.00 %)	Axial Profile	Edit	Radial Power					
Core Pressure: psia	1044.6	N(PRA) Power	Exposure	Zone	Avg.	Max.	IR	JR	
Inlet Subcooling: Btu/lbm	-23.00	Top 25	0.163	3.491	30	0.475	0.573	5	14
Flow: Mlb/hr	72.00 (93.50 %)	24	0.499	10.668	31	0.437	0.569	13	48
		23	0.668	14.263	32	0.818	1.069	11	12
		22	0.778	16.235	33	1.112	1.257	25	28
		21	0.860	17.863	34	1.118	1.244	11	16
		20	0.916	19.051	35	1.224	1.369	25	26
1 3 5 7 9 11 13 15 17 19 21 23 25		:JR							
1	-- -- -- -- --	51							
3	-- -- -- -- --	47							
5	-- -- -- -- --	43							
7	-- -- 36 -- 14 -- 14 -- 36 -- --	39							
9	-- -- -- -- -- -- -- -- -- -- --	35							
11	-- -- -- 12 -- 28 -- 28 -- 12 -- -- --	31							
13	-- -- -- -- -- -- -- -- -- -- --	27							
15	-- -- -- 12 -- 28 -- 28 -- 12 -- -- --	23							
17	-- -- -- -- -- -- -- -- -- -- --	19							
19	-- -- 36 -- 14 -- 14 -- 36 -- --	15							
21	-- -- -- -- -- -- -- -- --	11							
23	-- -- -- -- -- -- -- -- --	7							
25	-- -- -- -- -- -- -- --	3							
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50									
Control Rod Density: %	6.20								
k-effective:	0.99800	Bottom	1	0.286	4.777				
Void Fraction:	0.505								
Core Delta-P: psia	21.568	% AXIAL TILT -18.111 -12.731							
Core Plate Delta-P: psia	17.039	AVG BOT 8ft/12ft 1.1023 1.0780							
Coolant Temp: Deg-F	548.5								
In Channel Flow: Mlb/hr	62.84	Active Channel Flow: Mlb/hr			60.55				
Total Bypass Flow (%):	12.7	(of total core flow)							
Total Water Rod Flow (%):	3.2	(of total core flow)							
Source Convergence	0.00048								

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.369 35 25 26	1.632	0.907	33	25 28	8.14	0.787	36.6	33	9 30	4	11.76	0.834	11.5	35	9 28	4								
1.342 35 21 26	1.544	0.900	35	25 26	8.10	0.771	34.9	33	23 44	4	11.72	0.831	13.9	35	9 32	4								
1.340 35 25 22	1.656	0.894	33	23 26	8.12	0.769	34.5	33	9 34	4	11.66	0.827	14.4	34	45 30	4								
1.323 35 19 20	1.663	0.890	33	25 24	7.99	0.768	35.9	33	11 26	4	11.64	0.825	10.5	35	25 44	4								
1.318 35 23 20	1.581	0.879	35	21 26	9.97	0.761	10.0	35	9 28	4	11.59	0.822	10.9	35	21 44	4								
1.318 35 19 24	1.684	0.879	33	25 20	8.06	0.761	34.0	33	25 42	4	11.58	0.822	12.9	34	29 46	4								
1.317 35 17 18	1.582	0.879	35	25 22	9.93	0.758	11.1	35	9 32	4	11.55	0.819	13.7	35	11 30	4								
1.299 35 17 26	1.696	0.873	33	19 26	8.00	0.755	34.0	33	19 44	4	11.51	0.816	14.0	34	45 22	4								
1.295 35 25 18	1.710	0.865	33	21 20	7.62	0.750	38.3	33	7 28	4	11.49	0.815	11.3	35	11 34	4								
1.284 35 13 18	1.617	0.859	35	23 20	9.80	0.748	9.1	35	25 44	4	8.92	0.813	40.3	33	9 24	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.17 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 6,000.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	20998.2							
Exposure: MWd/MTU (GWd)	6500.0 (654.28)									
Delta E: MWd/MTU, (GWd)	500.0 (50.33)	Axial Profile	Edit	Radial Power						
Power: MWT	2923.0 (100.00 %)	N(PRA)	Power	Exposure	Zone	Avg.	Max.	IR	JR	
Core Pressure: psia	1044.6	Top	25	0.166	3.581	30	0.471	0.569	5	14
Inlet Subcooling: Btu/lbm	-23.57		24	0.506	10.932	31	0.433	0.565	13	48
Flow: Mlb/hr	70.46 (91.50 %)		23	0.676	14.617	32	0.812	1.065	11	12
			22	0.786	16.650	33	1.110	1.250	25	28
			21	0.868	18.321	34	1.120	1.248	11	16
			20	0.924	19.539	35	1.231	1.372	25	26
1 3 5 7 9 11 13 15 17 19 21 23 25		:JR								
1 -- -- -- -- -- -- -- -- -- -- -- 51			19	0.958	20.624					
3 -- -- -- -- -- -- -- -- -- -- -- 47			18	0.969	21.356					
5 -- -- -- -- -- -- -- -- -- -- -- 43			17	0.960	21.523					
7 -- -- 36 -- 14 -- 14 -- 36 -- 39			16	1.002	22.139					
9 -- -- -- -- -- -- -- -- -- -- -- 35			15	1.022	23.025					
11 -- -- 12 -- 28 -- 28 -- 12 -- -- 31			14	1.028	23.738					
13 -- -- -- -- -- -- -- -- -- -- -- 27			13	1.090	23.571					
15 -- -- 12 -- 28 -- 28 -- 12 -- -- 23			12	1.117	24.287					
17 -- -- -- -- -- -- -- -- -- -- -- 19			11	1.134	24.715					
19 -- -- 36 -- 14 -- 14 -- 36 -- 15			10	1.149	25.038					
21 -- -- -- -- -- -- -- -- -- -- -- 11			9	1.187	25.759					
23 -- -- -- -- -- -- -- -- -- -- -- 7			8	1.227	26.129					
25 -- -- -- -- -- -- -- -- -- -- -- 3			7	1.270	26.141					
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			6	1.341	26.860					
Control Rod Density: %	6.20		5	1.421	27.213*					
			4	1.442*	26.364					
k-effective:	0.99787		3	1.381	24.085					
Void Fraction:	0.508		2	1.090	18.135					
Core Delta-P: psia	20.920		Bottom	1	0.288	4.923				
Core Plate Delta-P: psia	16.393						% AXIAL TILT	-17.501	-12.746	
Coolant Temp: Deg-F	548.4						AVG BOT	8ft/12ft	1.0986	1.0778
In Channel Flow: Mlb/hr	61.47									
Total Bypass Flow (%):	12.8						Active Channel Flow: Mlb/hr		59.21	
Total Water Rod Flow (%):	3.2						(of total core flow)			
Source Convergence	0.00050						(of total core flow)			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.372 35	25	26			1.620	0.913	33	25	28	8.11	0.791	37.5	33	9	30	4	11.75	0.833	12.7	35	9	28	4	
1.350 35	21	26			1.529	0.909	35	25	26	8.06	0.774	35.8	33	23	44	4	11.74	0.833	15.1	35	9	32	4	
1.348 35	25	22			1.639	0.903	33	23	26	8.09	0.774	35.4	33	9	34	4	11.62	0.824	15.7	34	45	30	4	
1.331 35	19	20			1.645	0.899	33	25	24	7.95	0.770	36.8	33	11	26	4	11.61	0.823	11.7	35	25	44	4	
1.326 35	19	24			1.663	0.890	33	25	20	10.05	0.768	11.0	35	9	28	4	11.58	0.821	12.1	35	21	44	4	
1.326 35	23	20			1.563	0.890	35	21	26	10.04	0.766	12.2	35	9	32	4	11.56	0.820	14.9	35	11	30	4	
1.324 35	17	18			1.563	0.889	35	25	22	8.02	0.763	34.9	33	25	42	4	8.88	0.817	41.2	33	9	24	4	
1.307 35	17	26			1.675	0.883	33	19	26	7.97	0.758	34.8	33	19	44	4	11.52	0.817	14.2	34	29	46	4	
1.303 35	25	18			1.689	0.876	33	21	20	9.86	0.753	10.1	35	25	44	4	11.50	0.816	12.4	35	11	34	4	
1.291 35	13	18			1.596	0.871	35	23	20	7.58	0.752	39.2	33	7	28	4	11.48	0.814	15.2	34	45	22	4	

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.18 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 6,500.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	21498.1						
Exposure: MWd/MTU (Gwd)	7000.0 (704.61)	Axial Profile	Edit	Radial Power					
Delta E: MWd/MTU, (Gwd)	500.0 (50.33)	N(PRA) Power	Exposure	Zone	Avg.	Max.	IR	JR	
Power: MWT	2923.0 (100.00 %)	Top	25	0.168	3.673	30	0.466	0.564	5 14
Core Pressure: psia	1044.5		24	0.510	11.200	31	0.429	0.561	13 48
Inlet Subcooling: Btu/lbm	-24.16		23	0.680	14.974	32	0.807	1.060	11 12
Flow: Mlb/hr	68.92 (89.50 %)		22	0.791	17.069	33	1.107	1.243	25 28
			21	0.873	18.784	34	1.122	1.253	11 16
1 3 5 7 9 11 13 15 17 19 21 23 25			20	0.929	20.032	35	1.238	1.376	25 26
1 --- --- --- --- --- --- ---	51	:JR							
3 --- --- --- --- --- --- ---	47								
5 --- --- --- --- --- --- ---	43								
7 --- 36 --- 14 --- 14 --- 36 ---	39								
9 --- --- --- --- --- --- ---	35								
11 --- --- 12 --- 28 --- 28 --- 12 ---	31								
13 --- --- --- --- --- --- ---	27								
15 --- --- 12 --- 28 --- 28 --- 12 ---	23								
17 --- --- --- --- --- --- ---	19								
19 --- 36 --- 14 --- 14 --- 36 ---	15								
21 --- --- --- --- --- --- ---	11								
23 --- --- --- --- --- --- ---	7								
25 --- --- --- --- --- --- ---	3								
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50									
Control Rod Density: %	6.20								
k-effective:	0.99778	Bottom	1	0.290	5.069				
Void Fraction:	0.510								
Core Delta-P: psia	20.289								
Core Plate Delta-P: psia	15.763								
Coolant Temp: Deg-F	548.4								
In Channel Flow: Mlb/hr	60.09	Active Channel Flow: Mlb/hr							
Total Bypass Flow (%):	12.8	(of total core flow)							
Total Water Rod Flow (%):	3.2	(of total core flow)							
Source Convergence	0.00045								

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.376 35 25 26	1.610	0.919	33	25 28	8.09	0.796	38.4	33	9 30	4	11.77	0.835	13.9	35	9 28	4								
1.356 35 21 26	1.516	0.917	35	25 26	8.09	0.780	36.3	33	9 34	4	11.77	0.835	16.3	35	9 32	4								
1.355 35 25 22	1.624	0.911	33	23 26	8.04	0.778	36.7	33	23 44	4	11.61	0.824	12.9	35	25 44	4								
1.339 35 19 20	1.630	0.908	33	25 24	10.17	0.776	13.2	35	9 32	4	8.86	0.823	42.2	33	9 24	4								
1.334 35 19 24	1.644	0.900	33	25 20	10.16	0.776	12.0	35	9 28	4	11.61	0.823	13.3	35	21 44	4								
1.334 35 23 20	1.545	0.899	35	21 26	7.94	0.775	37.6	33	11 26	4	11.60	0.823	16.9	34	45 30	4								
1.331 35 17 18	1.546	0.899	35	25 22	7.99	0.767	35.8	33	25 42	4	11.59	0.822	16.1	35	11 30	4								
1.314 35 17 26	1.657	0.893	33	19 26	7.97	0.764	35.7	33	19 44	4	11.54	0.818	13.6	35	11 34	4								
1.311 35 25 18	1.669	0.887	33	21 20	9.95	0.760	11.1	35	25 44	4	11.49	0.815	15.4	34	29 46	4								
1.297 35 13 18	1.576	0.882	35	23 20	7.55	0.755	40.0	33	7 28	4	11.48	0.814	16.4	34	45 22	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.19 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 7,000.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	21499.2	
Exposure: MWd/MTU (GWD)	7001.0 (704.71)			
Delta E: MWd/MTU, (GWD)	1.0 (0.10)	Axial Profile	Edit	Radial Power
Power: MWT	2923.0 (100.00 %)	N(PRA) Power	Exposure Zone	Avg. Max. IR JR
Core Pressure: psia	1044.6	Top 25	0.167 3.673	30 0.471 0.579 5 14
Inlet Subcooling: Btu/lbm	-21.58	24	0.509 11.200	31 0.431 0.569 47 40
Flow: Mlb/hr	76.23 (99.00 %)	23	0.678 14.975	32 0.817 1.077 11 12
		22	0.783 17.070	33 1.100 1.251 13 24
		21	0.854 18.785	34 1.136 1.304 11 16
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.895 20.033	35 1.229 1.387 13 26
1	-- -- -- -- --	:JR		
3	-- -- -- -- --		19 0.917 21.136	
5	-- -- -- -- --		18 0.920 21.873	
7	-- -- -- 14 -- 8 -- 14 -- --		17 0.905 22.036	
9	-- -- -- -- -- -- -- -- --		16 0.943 22.645	
11	-- 36 -- 12 -- 36 -- 12 -- 36 -- --		15 0.962 23.542	
13	-- -- -- -- -- -- -- -- --		14 0.971 24.257	
15	-- 36 -- 12 -- 36 -- 12 -- 36 -- --		13 1.039 24.090	
17	-- -- -- -- -- -- -- -- --		12 1.079 24.819	
19	-- -- -- 14 -- 8 -- 14 -- --		11 1.119 25.255	
21	-- -- -- -- -- -- -- --		10 1.168 25.585	
23	-- -- -- -- -- -- --		9 1.231 26.324	
25	-- -- -- -- -- --		8 1.286 26.714	
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 1.335 26.746	
			6 1.402 27.498	
			5 1.482 27.889*	
			4 1.499* 27.050	
Control Rod Density: %	6.57		3 1.431 24.742	
			2 1.127 18.654	
k-effective:	0.99778 .	Bottom	1 0.298 5.069	
Void Fraction:	0.500			
Core Delta-P: psia	23.447	% AXIAL TILT	-20.666 -12.746	
Core Plate Delta-P: psia	18.915	AVG BOT 8ft/12ft	1.1097 1.0775	
Coolant Temp: Deg-F	548.6			
In Channel Flow: Mlb/hr	66.62	Active Channel Flow: Mlb/hr	64.22	
Total Bypass Flow (%):	12.6	(of total core flow)		
Total Water Rod Flow (%):	3.1	(of total core flow)		
Source Convergence	0.00047			

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K
1.387	35	13	26	1.722	0.859	33	13	24	8.64	0.824	35.1	33	13	38	4
1.364	35	13	22	1.765	0.838	33	25	28	8.30	0.804	36.7	33	23	44	4
1.364	35	25	26	1.768	0.837	33	23	26	8.10	0.800	38.8	33	11	36	4
1.353	35	11	20	1.770	0.836	33	11	28	10.40	0.794	11.5	35	13	36	4
1.351	35	13	18	1.667	0.834	35	13	26	8.03	0.786	37.8	33	15	36	4
1.351	35	23	24	1.667	0.834	35	25	26	8.18	0.785	35.7	33	19	44	4
1.347	35	9	26	1.783	0.830	33	15	26	8.06	0.783	37.0	33	13	20	4
1.329	35	21	26	1.676	0.829	35	9	26	10.23	0.781	11.6	35	13	40	4
1.327	35	15	20	1.791	0.826	33	23	22	10.20	0.779	11.3	35	21	44	4
1.322	35	15	24	1.792	0.826	33	13	20	10.14	0.774	11.1	35	25	44	4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.20 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 7,001.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWD/MTU	21998.1	
Exposure: MWD/MTU (GWD)	7500.0 (754.94)			
Delta E: MWD/MTU, (GWD)	499.0 (50.23)			
Power: MWT	2923.0 (100.00 %)	Axial Profile	Edit	Radial Power
Core Pressure: psia	1044.6	N(PRA) Power	Exposure Zone	Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-22.13	Top 25 0.169 3.765 30 0.467 0.574 5 14		
Flow: Mlb/hr	74.50 (96.75 %)	24 0.514 11.469 31 0.427 0.564 47 40		
		23 0.684 15.333 32 0.812 1.072 11 12		
		22 0.789 17.487 33 1.098 1.246 13 24		
		21 0.860 19.239 34 1.139 1.309 11 16		
		20 0.901 20.509 35 1.236 1.392 13 26		
1 3 5 7 9 11 13 15 17 19 21 23 25	51	:JR		
1 -- -- -- -- -- -- -- -- -- -- -- --	47			
3 -- -- -- -- -- -- -- -- -- -- -- --	43			
5 -- -- -- -- -- -- -- -- -- -- -- --	39			
7 -- -- -- 14 -- 8 -- 14 -- -- --	35			
9 -- -- -- -- -- -- -- -- -- -- -- --	31			
11 -- -- 36 -- 12 -- 36 -- 12 -- 36 -- -- --	31			
13 -- -- -- -- -- -- -- -- -- -- -- --	27			
15 -- -- 36 -- 12 -- 36 -- 12 -- 36 -- -- --	23			
17 -- -- -- -- -- -- -- -- -- -- -- --	19			
19 -- -- -- 14 -- 8 -- 14 -- -- --	15			
21 -- -- -- -- -- -- -- -- -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	6.57			
k-effective:	0.99768	Bottom	1 0.301 5.221	
Void Fraction:	0.503			
Core Delta-P: psia	22.699			
Core Plate Delta-P: psia	18.168		% AXIAL TILT -20.229 -12.820	
Coolant Temp: Deg-F	548.6		AVG BOT 8ft/12ft 1.1069 1.0774	
In Channel Flow: Mlb/hr	65.07			
Total Bypass Flow (%):	12.7		Active Channel Flow: Mlb/hr 62.71	
Total Water Rod Flow (%):	3.2		(of total core flow)	
Source Convergence	0.00038			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.392 35 13 26	1.704	0.868	33	13 24	8.61	0.829	36.1	33	13 38	4	12.24	0.868	14.9	35	13 40	4								
1.370 35 13 22	1.751	0.845	33	23 26	8.30	0.811	37.6	33	23 44	4	12.19	0.864	16.7	34	11 38	4								
1.365 35 25 26	1.753	0.844	33	25 28	8.10	0.807	39.7	33	11 36	4	12.10	0.858	15.9	35	13 18	4								
1.359 35 11 20	1.646	0.844	35	13 26	10.53	0.804	12.6	35	13 36	4	12.07	0.856	14.5	35	21 44	4								
1.358 35 13 18	1.755	0.844	33	11 28	8.20	0.793	36.6	33	19 44	4	9.48	0.852	38.9	33	13 38	4								
1.355 35 23 24	1.653	0.841	35	25 26	8.02	0.792	38.7	33	15 36	4	12.00	0.851	14.5	35	15 38	4								
1.351 35 9 26	1.763	0.839	33	15 26	10.37	0.791	12.7	35	13 40	4	11.96	0.848	16.6	34	11 40	4								
1.334 35 15 20	1.771	0.836	33	23 22	10.36	0.791	12.3	35	21 44	4	11.93	0.846	14.5	35	23 42	4								
1.334 35 21 26	1.663	0.836	35	9 26	8.05	0.788	37.9	33	13 20	4	11.92	0.846	14.6	35	9 36	4								
1.328 35 15 24	1.771	0.836	33	13 20	10.28	0.784	12.1	35	25 44	4	8.94	0.842	43.4	33	11 18	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.21 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 7,500.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	22498.1	
Exposure: MWd/MTU (GWd)	8000.0 (805.27)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	500.0 (50.33)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.172	3.859 30 0.462 0.570 5 14
Core Pressure: psia	1044.6	24	0.520	11.741 31 0.423 0.560 47 40
Inlet Subcooling: Btu/lbm	-22.66	23	0.691	15.695 32 0.806 1.069 11 12
Flow: Mlb/hr	72.96 (94.75 %)	22	0.796	17.907 33 1.095 1.242 13 24
		21	0.867	19.698 34 1.141 1.315 11 16
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.908	20.990 35 1.242 1.398 13 26
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- -- -- -- -- -- -- -- --	43			
7 -- -- -- 14 -- 8 -- 14 -- -- --	39			
9 -- -- -- -- -- -- -- -- -- -- -- --	35			
11 -- -- 36 -- 12 -- 36 -- 12 -- 36 -- -- --	31			
13 -- -- -- -- -- -- -- -- -- -- -- --	27			
15 -- -- 36 -- 12 -- 36 -- 12 -- 36 -- -- --	23			
17 -- -- -- -- -- -- -- -- -- -- -- --	19			
19 -- -- -- 14 -- 8 -- 14 -- -- --	15			
21 -- -- -- -- -- -- -- -- -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	6.57			
k-effective:	0.99755	Bottom	1	0.306 5.373
Void Fraction:	0.506			
Core Delta-P: psia	22.045	% AXIAL TILT	-19.856	-12.880
Core Plate Delta-P: psia	17.515	AVG BOT	8ft/12ft	1.1040 1.0773
Coolant Temp: Deg-F	548.5			
In Channel Flow: Mlb/hr	63.68	Active Channel Flow: Mlb/hr		61.36
Total Bypass Flow (%):	12.7	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00044			

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR										
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.398	35	13	26	1.686	0.878	33	13	24	8.64	0.839	37.0	33	13	38	4	12.33	0.874	16.1	35	13	40	4
1.376	35	13	22	1.625	0.855	35	13	26	8.32	0.820	38.5	33	23	44	4	12.31	0.873	17.9	34	11	38	4
1.367	35	25	26	1.736	0.852	33	23	26	8.13	0.818	40.6	33	11	36	4	12.20	0.865	17.1	35	13	18	4
1.366	35	11	20	1.736	0.852	33	11	26	10.69	0.816	13.7	35	13	36	4	9.51	0.864	40.0	33	13	38	4
1.366	35	13	18	1.742	0.849	33	25	28	10.55	0.805	13.8	35	13	40	4	12.16	0.862	15.8	35	21	44	4
1.360	35	23	24	1.744	0.849	33	15	26	10.54	0.805	13.4	35	21	44	4	12.08	0.857	15.8	35	15	38	4
1.356	35	9	26	1.641	0.847	35	25	26	8.25	0.805	37.5	33	19	44	4	12.06	0.856	17.8	34	11	40	4
1.341	35	15	20	1.751	0.845	33	13	20	8.04	0.800	39.6	33	15	36	4	12.03	0.853	15.8	35	9	36	4
1.339	35	21	26	1.752	0.845	33	23	22	8.06	0.796	38.8	33	13	20	4	8.96	0.853	44.4	33	11	18	4
1.335	35	15	24	1.650	0.842	35	9	26	10.43	0.796	13.2	35	25	44	4	11.99	0.851	15.8	35	23	42	4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.22 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 8,000.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	22998.1	
Exposure: MWd/MTU (GWd)	8500.0 (855.60)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	500.0 (50.33)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: Mwt	2923.0 (100.00 %)	Top 25	0.174	3.954 30 0.458 0.566 5 14
Core Pressure: psia	1044.6	24	0.526	12.016 31 0.420 0.556 47 40
Inlet Subcooling: Btu/lbm	-23.14	23	0.698	16.061 32 0.802 1.065 11 12
Flow: Mlb/hr	71.61 (93.00 %)	22	0.802	18.331 33 1.093 1.237 13 24
		21	0.873	20.160 34 1.145 1.322 11 16
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.914	21.474 35 1.248 1.403 13 26
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- -- -- -- -- -- -- -- --	43			
7 -- -- -- 14 -- 8 -- 14 -- -- --	39			
9 -- -- -- -- -- -- -- -- -- -- -- --	35			
11 -- -- 36 -- 12 -- 36 -- 12 -- 36 -- -- --	31			
13 -- -- -- -- -- -- -- -- -- -- -- --	27			
15 -- -- 36 -- 12 -- 36 -- 12 -- 36 -- -- --	23			
17 -- -- -- -- -- -- -- -- -- -- -- --	19			
19 -- -- -- 14 -- 8 -- 14 -- -- --	15			
21 -- -- -- -- -- -- -- -- -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	6.57			
k-effective:	0.99755	Bottom	1	0.310 5.529
Void Fraction:	0.509			
Core Delta-P: psia	21.478			
Core Plate Delta-P: psia	16.950	% AXIAL TILT	-19.486	-12.929
Coolant Temp: Deg-F	548.5	AVG BOT	8ft/12ft	1.1012 1.0771
In Channel Flow: Mlb/hr	62.48	Active Channel Flow: Mlb/hr		60.19
Total Bypass Flow (%):	12.8	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00048			

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APIHGR				LHGR										
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.403	35	13	26	1.672	0.885	33	13	24	8.64	0.846	38.0	33	13	38	4	12.40	0.882	19.2	34	11	38	4
1.382	35	13	22	1.607	0.865	35	13	26	8.32	0.828	39.4	33	23	44	4	12.38	0.878	17.4	35	13	40	4
1.373	35	11	20	1.723	0.859	33	11	26	8.14	0.826	41.5	33	11	36	4	9.51	0.873	41.0	33	13	38	4
1.372	35	13	18	1.725	0.858	33	23	26	10.78	0.823	14.8	35	13	36	4	12.23	0.867	18.4	35	13	18	4
1.368	35	25	26	1.729	0.856	33	15	26	10.69	0.816	14.5	35	21	44	4	12.22	0.866	17.0	35	21	44	4
1.363	35	23	24	1.735	0.853	33	13	20	10.69	0.816	14.8	35	13	40	4	12.14	0.862	19.0	34	11	40	4
1.360	35	9	26	1.735	0.853	33	25	28	8.28	0.815	38.4	33	19	44	4	8.96	0.861	45.4	33	11	18	4
1.348	35	15	20	1.631	0.852	35	25	26	10.53	0.808	15.6	34	11	38	4	12.10	0.858	17.0	35	15	38	4
1.343	35	21	26	1.738	0.852	33	23	22	8.01	0.805	40.4	33	15	36	4	12.10	0.858	17.0	35	9	36	4
1.340	35	15	24	1.634	0.850	35	13	22	10.54	0.805	14.3	35	25	44	4	12.03	0.853	18.6	34	29	46	4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.23 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 8,500.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	23498.1						
Exposure: MWd/MTU (GWd)	9000.0 (905.93)	Axial Profile	Edit	Radial Power					
Delta E: MWd/MTU, (GWd)	500.0 (50.33)	N(PRA) Power	Exposure	Zone	Avg.	Max.	IR	JR	
Power: MWT	2923.0 (100.00 %)	Top	25	0.176	4.050	30	0.455	0.562	5 14
Core Pressure: psia	1044.6	24	0.529	12.295	31	0.416	0.552	47 40	
Inlet Subcooling: Btu/lbm	-23.64	23	0.702	16.431	32	0.797	1.062	11 12	
Flow: Mlb/hr	70.26 (91.25 %)	22	0.806	18.759	33	1.090	1.232	13 24	
		21	0.876	20.626	34	1.149	1.328	11 16	
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.917	21.961	35	1.253	1.406	13 26	
1 --- --- --- --- --- ---	51	:JR							
3 --- --- --- --- --- ---	47								
5 --- --- --- --- --- ---	43								
7 --- --- 14 --- 8 --- 14 --- ---	39								
9 --- --- --- --- --- --- --- ---	35								
11 --- 36 --- 12 --- 36 --- 12 --- 36 --- 31									
13 --- --- --- --- --- ---	27								
15 --- 36 --- 12 --- 36 --- 12 --- 36 --- 23									
17 --- --- --- --- --- --- --- ---	19								
19 --- --- 14 --- 8 --- 14 --- ---	15								
21 --- --- --- --- --- ---	11								
23 --- --- --- --- --- ---	7								
25 --- --- --- --- --- ---	3								
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50									
Control Rod Density: %	6.57								
k-effective:	0.99755	Bottom	1	0.312	5.686				
Void Fraction:	0.511								
Core Delta-P: psia	20.919								
Core Plate Delta-P: psia	16.391								
Coolant Temp: Deg-F	548.5								
In Channel Flow: Mlb/hr	61.27	Active Channel Flow: Mlb/hr							
Total Bypass Flow (%):	12.8	(of total core flow)							
Total Water Rod Flow (%):	3.2	(of total core flow)							
Source Convergence	0.00029								

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR			APLHGR			LHGR					
Value	FT	IR JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K
1.406	35	13 26	1.658	0.892	33	13	24	8.58	0.849	38.9	33	13	38	4
1.386	35	13 22	1.591	0.874	35	13	26	8.29	0.831	40.4	33	23	44	4
1.379	35	11 20	1.711	0.865	33	11	26	8.10	0.830	42.4	33	11	36	4
1.378	35	13 18	1.715	0.863	33	23	26	10.77	0.828	15.9	35	13	36	4
1.369	35	25 26	1.717	0.862	33	15	26	10.75	0.827	15.9	35	13	40	4
1.367	35	23 24	1.720	0.861	33	13	20	10.76	0.825	15.6	35	21	44	4
1.364	35	9 26	1.618	0.859	35	13	22	10.63	0.822	16.7	34	11	38	4
1.353	35	15 20	1.725	0.858	33	23	22	8.27	0.822	39.3	33	19	44	4
1.347	35	21 26	1.621	0.857	35	25	26	10.58	0.810	15.4	35	25	44	4
1.345	35	15 24	1.729	0.856	33	25	28	7.93	0.804	41.3	33	15	36	4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.24 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 9,000.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
 MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	23798.2	
Exposure: MWd/MTU (GWd)	9300.0 (936.12)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	300.0 (30.20)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: Mwt	2923.0 (100.00 %)	Top 25	0.179	4.109 30 0.453 0.560 5 14
Core Pressure: psia	1044.5	24	0.536	12.463 31 0.414 0.550 47 40
Inlet Subcooling: Btu/lbm	-23.97	23	0.710	16.654 32 0.795 1.060 11 12
Flow: Mlb/hr	69.42 (90.15 %)	22	0.814	19.017 33 1.088 1.230 13 24
		21	0.885	20.906 34 1.151 1.332 11 16
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.925	22.254 35 1.256 1.408 13 26
1	-- -- -- -- -- -- -- -- -- --	51	:JR	
3	-- -- -- -- -- -- -- -- -- --	47		19 0.946 23.410
5	-- -- -- -- -- -- -- -- -- --	43		18 0.946 24.151
7	-- -- -- 14 -- 8 -- 14 -- --	39		17 0.927 24.274
9	-- -- -- -- -- -- -- -- -- --	35		16 0.959 24.845
11	-- 36 -- 12 -- 36 -- 12 -- 36 --	31		15 0.970 25.778
13	-- -- -- -- -- -- -- -- -- --	27		14 0.965 26.502
15	-- 36 -- 12 -- 36 -- 12 -- 36 --	23		13 1.013 26.336
17	-- -- -- -- -- -- -- -- -- --	19		12 1.038 27.139
19	-- -- -- 14 -- 8 -- 14 -- --	15		11 1.067 27.652
21	-- -- -- -- -- -- -- -- -- --	11		10 1.110 28.083
23	-- -- -- -- -- -- -- -- -- --	7		9 1.170 28.957
25	-- -- -- -- -- -- -- -- -- --	3		8 1.230 29.472
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				7 1.289 29.621
				6 1.373 30.539
				5 1.475 31.129*
				4 1.520* 30.358
Control Rod Density: %	6.57			3 1.476 27.922
				2 1.168 21.161
k-effective:	0.99756	Bottom	1	0.311 5.781
Void Fraction:	0.512			
Core Delta-P: psia	20.556			
Core Plate Delta-P: psia	16.029	% AXIAL TILT	-18.611	-12.988
Coolant Temp: Deg-F	548.4	AVG BOT	8ft/12ft	1.0958 1.0768
In Channel Flow: Mlb/hr	60.52	Active Channel Flow: Mlb/hr		58.29
Total Bypass Flow (%):	12.8	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00048			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.408 35	13	26	1.646	0.899	33	13	24	8.51	0.847	39.5	33	13	38	4	12.38	0.896	21.3	34	11	38	4			
1.388 35	13	22	1.578	0.881	35	13	26	8.22	0.829	40.9	33	23	44	4	12.14	0.876	21.0	34	41	40	4			
1.382 35	11	20	1.700	0.870	33	11	26	10.71	0.828	16.6	35	13	40	4	9.38	0.876	42.6	33	13	38	4			
1.381 35	13	18	1.704	0.869	33	23	26	8.04	0.828	42.9	33	11	36	4	12.25	0.873	19.5	35	13	40	4			
1.370 35	25	26	1.705	0.868	33	15	26	10.64	0.827	17.3	34	11	38	4	12.06	0.868	20.6	34	29	46	4			
1.369 35	23	24	1.707	0.867	33	13	20	10.72	0.827	16.3	35	21	44	4	12.06	0.866	20.4	35	39	36	4			
1.367 35	9	26	1.604	0.866	35	13	22	10.69	0.826	16.6	35	13	36	4	8.84	0.865	46.9	33	11	18	4			
1.355 35	15	20	1.712	0.865	33	23	22	8.23	0.822	39.9	33	19	44	4	12.19	0.864	18.2	35	21	44	3			
1.349 35	21	26	1.611	0.863	35	25	26	10.53	0.811	16.0	35	25	44	4	11.99	0.864	20.8	34	9	38	4			
1.347 35	15	24	1.612	0.862	35	15	24	7.83	0.798	41.8	33	15	36	4	11.97	0.858	20.1	34	21	46	4			

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.25 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 9,300.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLAA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	24098.2						
Exposure: MWd/MTU (GWd)	9600.0 (966.32)								
Delta E: MWd/MTU, (GWd)	300.0 (30.20)								
Power: MWT	2923.0 (100.00 %)	Axial Profile	Edit	Radial Power					
Core Pressure: psia	1044.5	N(PRA) Power	Exposure	Zone	Avg.	Max.	IR	JR	
Inlet Subcooling: Btu/lbm	-24.27	Top 25	0.180	4.168	30	0.451	0.559	5	14
Flow: Mlb/hr	68.65 (89.15 %)	24	0.539	12.633	31	0.413	0.549	47	40
		23	0.714	16.879	32	0.793	1.058	11	12
		22	0.818	19.278	33	1.087	1.227	13	24
		21	0.889	21.189	34	1.154	1.335	11	16
		20	0.930	22.550	35	1.259	1.410	13	26
1 3 5 7 9 11 13 15 17 19 21 23 25									
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR							
3 -- -- -- -- -- -- -- -- -- -- -- --	47								
5 -- -- -- -- -- -- -- -- -- -- -- --	43								
7 -- -- -- 14 -- 8 -- 14 -- -- -- --	39								
9 -- -- -- -- -- -- -- -- -- -- -- --	35								
11 -- -- 36 -- 12 -- 36 -- 12 -- 36 -- --	31								
13 -- -- -- -- -- -- -- -- -- -- -- --	27								
15 -- -- 36 -- 12 -- 36 -- 12 -- 36 -- --	23								
17 -- -- -- -- -- -- -- -- -- -- -- --	19								
19 -- -- -- 14 -- 8 -- 14 -- -- -- --	15								
21 -- -- -- -- -- -- -- -- -- -- -- --	11								
23 -- -- -- -- -- -- -- -- -- -- -- --	7								
25 -- -- -- -- -- -- -- -- -- -- -- --	3								
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50									
Control Rod Density: %	6.57								
k-effective:	0.99756	Bottom	1	0.310	5.876				
Void Fraction:	0.512								
Core Delta-P: psia	20.229	% AXIAL TILT	-18.168	-12.999					
Core Plate Delta-P: psia	15.703	AVG BOT 8ft/12ft	1.0935	1.0766					
Coolant Temp: Deg-F	548.4								
In Channel Flow: Mlb/hr	59.84	Active Channel Flow: Mlb/hr		57.63					
Total Bypass Flow (%):	12.8	(of total core flow)							
Total Water Rod Flow (%):	3.2	(of total core flow)							
Source Convergence	0.00041								

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APIHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.410 35	13	26	1.637	0.904	33	13	24	8.40	0.841	40.1	33	13	38	4	12.29	0.896	22.1	34	11	38	4			
1.390 35	13	22	1.567	0.887	35	13	26	10.61	0.829	18.0	34	11	38	4	12.07	0.877	21.7	34	41	40	4			
1.385 35	11	20	1.691	0.875	33	11	26	10.65	0.828	17.2	35	39	40	4	9.27	0.871	43.2	33	13	38	4			
1.383 35	13	18	1.695	0.873	33	23	26	10.65	0.826	16.9	35	21	44	4	12.00	0.869	21.4	34	29	46	4			
1.371 35	23	24	1.696	0.873	33	15	26	8.13	0.825	41.4	33	23	44	4	12.11	0.869	20.2	35	13	40	4			
1.370 35	25	26	1.594	0.872	35	13	22	7.95	0.823	43.4	33	11	36	4	11.94	0.865	21.4	34	43	38	4			
1.370 35	9	26	1.697	0.872	33	13	20	10.56	0.821	17.2	35	13	36	4	8.75	0.861	47.5	33	11	18	4			
1.357 35	15	20	1.702	0.870	33	23	22	8.17	0.820	40.4	33	19	44	4	11.91	0.861	21.1	35	39	36	4			
1.351 35	21	26	1.602	0.868	35	15	24	10.44	0.808	16.7	35	25	44	4	11.92	0.859	20.8	34	21	46	4			
1.349 35	15	24	1.604	0.867	35	25	26	10.35	0.799	16.4	35	17	44	4	12.00	0.857	19.8	35	21	44	4			

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.26 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 9,600.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	24099.1	
Exposure: MWd/MTU (GWd)	9601.0 (966.42)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	1.0 (0.10)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.179 4.168	30 0.464 0.566 5 14
Core Pressure: psia	1044.6	24	0.540 12.633	31 0.426 0.560 13 48
Inlet Subcooling: Btu/lbm	-21.58	23	0.715 16.880	32 0.817 1.104 11 12
Flow: Mlb/hr	76.23 (99.00 %)	22	0.813 19.278	33 1.073 1.202 13 24
		21	0.872 21.190	34 1.179 1.342 11 16
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.911 22.551	35 1.235 1.376 13 22
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47		19 0.949 23.714	
5 -- -- -- 36 -- 26 -- 36 -- -- --	43		18 0.986 24.455	
7 -- -- -- -- -- -- -- -- -- -- --	39		17 1.008 24.572	
9 -- -- 36 -- 6 -- 8 -- 6 -- 36 -- --	35		16 1.074 25.136	
11 -- -- -- -- -- -- -- -- -- -- --	31		15 1.106 26.072	
13 -- -- 26 -- 8 -- 26 -- 8 -- 26 -- --	27		14 1.107 26.795	
15 -- -- -- -- -- -- -- -- -- -- --	23		13 1.155 26.626	
17 -- -- 36 -- 6 -- 8 -- 6 -- 36 -- --	19		12 1.163 27.436	
19 -- -- -- -- -- -- -- -- -- -- --	15		11 1.156 27.957	
21 -- -- -- 36 -- 26 -- 36 -- -- --	11		10 1.168 28.401	
23 -- -- -- -- -- -- -- -- -- --	7		9 1.202 29.292	
25 -- -- -- -- -- -- -- -- --	3		8 1.231 29.824	
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 1.252 29.989	
Control Rod Density: %	8.12		6 1.290 30.932	
k-effective:	0.99750		5 1.340* 31.551*	
Void Fraction:	0.481		4 1.330 30.792	
Core Delta-P: psia	23.195	Bottom 1	0.251 5.876	
Core Plate Delta-P: psia	18.663			
Coolant Temp: Deg-F	548.4			
In Channel Flow: Mlb/hr	66.72	% AXIAL TILT	-13.945 -12.999	
Total Bypass Flow (%):	12.5	AVG BOT 8ft/12ft	1.0894 1.0766	
Total Water Rod Flow (%):	3.1	Active Channel Flow: Mlb/hr	64.36	
Source Convergence	0.00046	(of total core flow)		

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR												APLHGR												LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K													
1.376 35	13	22	1.788	0.828	33	13	24	9.94	0.773	17.3	35	13	40	4	11.18	0.802	20.2	35	13	40	4															
1.364 35	13	18	1.689	0.823	35	9	22	7.55	0.765	41.4	33	13	38	5	8.50	0.798	43.1	33	13	38	5															
1.359 35	11	24	1.695	0.820	35	11	24	7.30	0.762	44.1	33	15	40	5	8.11	0.795	47.1	33	15	40	5															
1.355 35	13	14	1.821	0.813	33	11	22	9.66	0.749	17.0	35	15	38	4	10.96	0.793	21.2	34	11	14	4															
1.354 35	15	16	1.831	0.808	33	15	14	7.16	0.737	42.9	33	11	18	8	10.88	0.793	22.1	34	11	38	4															
1.353 35	17	14	1.721	0.807	35	13	32	7.31	0.729	39.7	33	15	32	4	10.95	0.792	21.1	34	13	12	4															
1.346 35	9	22	1.833	0.807	33	19	40	9.40	0.729	16.9	35	13	32	4	10.95	0.782	19.6	35	15	38	4															
1.345 35	21	14	1.722	0.807	35	13	14	9.38	0.727	16.9	35	15	30	4	10.66	0.773	21.5	34	37	12	4															
1.342 34	11	16	1.838	0.805	33	13	38	7.27	0.726	39.8	33	13	30	4	7.96	0.772	46.1	33	11	18	8															
1.336 35	13	26	1.840	0.804	33	13	20	7.00	0.723	43.2	33	17	42	8	7.79	0.758	46.5	33	17	42	8															

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.27 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 9,601.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	24498.1	
Exposure: MWd/MTU (GWd)	10000.0 (1006.60)			
Delta E: MWd/MTU, (GWd)	399.0 (40.16)			
Power: MWT	2923.0 (100.00 %)	Axial Profile	Edit	Radial Power
Core Pressure: psia	1044.6	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-21.97	Top 25	0.181	4.248 30 0.461 0.563 5 14
Flow: Mlb/hr	75.00 (97.40 %)	24	0.545	12.861 31 0.423 0.557 13 48
		23	0.721	17.182 32 0.814 1.101 11 12
		22	0.819	19.624 33 1.071 1.198 13 24
		21	0.879	21.561 34 1.183 1.347 11 16
		20	0.918	22.939 35 1.238 1.378 13 22
1 3 5 7 9 11 13 15 17 19 21 23 25				
1	-- -- -- -- -- -- -- -- -- --	51	:JR	
3	-- -- -- -- -- -- -- -- -- --	47		19 0.956 24.117
5	-- -- -- 36 -- 26 -- 36 -- --	43		18 0.994 24.875
7	-- -- -- -- -- -- -- -- -- --	39		17 1.017 25.001
9	-- -- 36 -- 6 -- 8 -- 6 -- 36 -- --	35		16 1.083 25.569
11	-- -- -- -- -- -- -- -- -- --	31		15 1.114 26.517
13	-- -- 26 -- 8 -- 26 -- 8 -- 26 --	27		14 1.113 27.241
15	-- -- -- -- -- -- -- -- -- --	23		13 1.159 27.064
17	-- -- 36 -- 6 -- 8 -- 6 -- 36 -- --	19		12 1.164 27.877
19	-- -- -- -- -- -- -- -- -- --	15		11 1.156 28.396
21	-- -- -- 36 -- 26 -- 36 -- -- --	11		10 1.167 28.844
23	-- -- -- -- -- -- -- -- -- --	7		9 1.200 29.748
25	-- -- -- -- -- -- -- -- -- --	3		8 1.228 30.291
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				7 1.248 30.464
				6 1.283 31.421
				5 1.326* 32.059*
				4 1.311 31.296
Control Rod Density: %	8.12			3 1.226 28.816
				2 0.944 21.858
k-effective:	0.99755	Bottom	1	0.248 5.978
Void Fraction:	0.482			
Core Delta-P: psia	22.646	% AXIAL TILT	-13.263	-12.936
Core Plate Delta-P: psia	18.115	AVG BOT	8ft/12ft	1.0861 1.0762
Coolant Temp: Deg-F	548.4			
In Channel Flow: Mlb/hr	65.62	Active Channel Flow: Mlb/hr		63.29
Total Bypass Flow (%):	12.5	(of total core flow)		
Total Water Rod Flow (%):	3.1	(of total core flow)		
Source Convergence	0.00042			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.378 35	13	22	1.771	0.836	33	13	24	9.80	0.767	18.1	35	13	40	4	10.96	0.793	21.2	35	13	40	4			
1.368 35	13	18	1.676	0.829	35	9	22	7.44	0.759	42.0	33	13	38	5	8.37	0.792	43.8	33	13	38	5			
1.363 35	11	24	1.683	0.826	35	11	24	7.19	0.755	44.8	33	15	40	5	10.84	0.791	22.1	34	11	14	4			
1.359 35	13	14	1.805	0.820	33	11	22	7.13	0.739	43.5	33	11	18	8	10.84	0.790	22.0	34	13	12	4			
1.357 35	15	16	1.813	0.816	33	15	14	9.45	0.738	17.8	35	15	38	4	7.98	0.789	47.8	33	15	40	5			
1.356 35	17	14	1.818	0.814	33	19	40	6.96	0.724	43.8	33	17	42	8	10.73	0.789	23.0	34	11	38	4			
1.351 35	9	22	1.708	0.814	35	13	14	7.09	0.721	41.7	33	9	20	8	7.92	0.774	46.7	33	11	18	8			
1.348 35	21	14	1.710	0.813	35	13	32	9.19	0.721	18.4	34	11	40	4	10.56	0.772	22.4	34	37	12	4			
1.347 34	11	16	1.821	0.813	33	13	38	9.15	0.717	18.3	34	13	42	4	10.69	0.769	20.5	35	15	38	4			
1.338 35	13	26	1.822	0.812	33	13	20	9.17	0.715	17.7	35	13	32	4	7.74	0.760	47.1	33	17	42	8			

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.28 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 10,000.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWD/MTU	24998.1	
Exposure: MWD/MTU (GWD)	10500.0 (1056.90)	Axial Profile	Edit	Radial Power
Delta E: MWD/MTU, (GWD)	500.0 (50.33)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.185 4.348	30 0.458 0.560 5 14
Core Pressure: psia	1044.6	24	0.554 13.150	31 0.421 0.554 13 48
Inlet Subcooling: Btu/lbm	-22.53	23	0.732 17.564	32 0.610 1.098 11 12
Flow: Mlb/hr	73.34 (95.25 %)	22	0.830 20.061	33 1.068 1.194 13 24
		21	0.890 22.030	34 1.188 1.352 11 16
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.931 23.428	35 1.242 1.380 13 22
1	-- -- -- -- -- -- -- -- -- --	51	:JR	
3	-- -- -- -- -- -- -- -- -- --	47		19 0.970 24.627
5	-- -- -- 36 -- 26 -- 36 -- --	43		18 1.009 25.405
7	-- -- -- -- -- -- -- -- -- --	39		17 1.032 25.543
9	-- -- 36 -- 6 -- 8 -- 6 -- 36 -- --	35		16 1.099 26.115
11	-- -- -- -- -- -- -- -- -- --	31		15 1.129 27.079
13	-- -- 26 -- 8 -- 26 -- 8 -- 26 -- --	27		14 1.126 27.802
15	-- -- -- -- -- -- -- -- -- --	23		13 1.167 27.615
17	-- -- 36 -- 6 -- 8 -- 6 -- 36 -- --	19		12 1.169 28.430
19	-- -- -- -- -- -- -- -- -- --	15		11 1.158 28.945
21	-- -- -- 36 -- 26 -- 36 -- -- --	11		10 1.168 29.399
23	-- -- -- -- -- -- -- -- -- --	7		9 1.200 30.319
25	-- -- -- -- -- -- -- -- -- --	3		8 1.225 30.875
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				7 1.241 31.058
				6 1.269 32.031
				5 1.298* 32.689*
				4 1.274 31.919
Control Rod Density: %	8.12			3 1.188 29.398
				2 0.916 22.306
k-effective:	0.99751	Bottom	1 0.241	6.104
Void Fraction:	0.482			
Core Delta-P: psia	21.904			
Core Plate Delta-P: psia	17.374			
Coolant Temp: Deg-F	548.3			
In Channel Flow: Mlb/hr	64.15			
Total Bypass Flow (%):	12.5			
Total Water Rod Flow (%):	3.1			
Source Convergence	.0.00045			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.380 35	13 22	1.746	0.848	33	13 24	9.51	0.750	19.1	35	39 40	4	10.57	0.779	23.3	34	11 14	4							
1.371 35	13 18	1.656	0.839	35	9 22	7.24	0.745	42.8	33	13 38	5	10.58	0.778	23.1	34	13 12	4							
1.367 35	11 24	1.664	0.835	35	11 24	7.00	0.742	45.6	33	15 40	5	8.14	0.778	44.7	33	13 38	5							
1.362 35	13 14	1.781	0.831	33	11 22	7.08	0.741	44.3	33	11 18	8	7.87	0.776	47.6	33	11 18	8							
1.359 35	15 16	1.787	0.828	33	13 16	6.92	0.725	44.6	33	17 42	8	7.77	0.775	48.7	33	15 40	5							
1.359 35	17 14	1.788	0.828	33	15 14	7.05	0.723	42.5	33	9 20	8	10.45	0.774	23.8	34	11 38	5							
1.356 35	9 22	1.791	0.826	33	13 34	9.09	0.715	18.8	35	15 38	4	10.57	0.772	22.3	35	13 40	4							
1.352 34	11 16	1.794	0.825	33	19 40	9.00	0.712	19.3	34	41 40	4	10.34	0.762	23.3	34	37 12	5							
1.350 35	21 14	1.687	0.824	35	13 32	8.97	0.709	19.3	34	13 42	4	7.69	0.762	48.0	33	17 42	8							
1.342 35	13 26	1.688	0.824	35	13 14	6.82	0.702	42.9	33	19 44	8	7.79	0.747	45.1	33	9 34	8							

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.29 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 10,500.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	25498.2	
Exposure: MWd/MTU (GWD)	11000.0 (1107.20)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWD)	500.0 (50.33)	N(PRA) Power	Exposure	Zone Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.188 4.450	30 0.456 0.558 5 14
Core Pressure: psia	1044.6	24	0.562 13.443	31 0.418 0.552 13 48
Inlet Subcooling: Btu/lbm	-23.14	23	0.742 17.951	32 0.807 1.094 11 12
Flow: Mlb/hr	71.61 (93.00 %)	22	0.841 20.504	33 1.065 1.190 13 24
		21	0.902 22.504	34 1.192 1.357 11 16
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.944 23.924	35 1.245 1.382 13 22
1	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	
3	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	47		19 0.985 25.144
5	-- -- -- 36 -- 26 -- 36 -- -- -- -- -- -- -- --	43		18 1.026 25.942
7	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	39		17 1.051 26.093
9	-- -- 36 -- 6 -- 8 -- 6 -- 36 -- -- 35			16 1.120 26.670
11	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	31		15 1.150 27.649
13	-- -- 26 -- 8 -- 26 -- 8 -- 26 -- -- 27			14 1.144 28.370
15	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	23		13 1.181 28.170
17	-- -- 36 -- 6 -- 8 -- 6 -- 36 -- -- 19			12 1.180 28.986
19	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	15		11 1.166 29.496
21	-- -- -- 36 -- 26 -- 36 -- -- -- 11			10 1.174 29.954
23	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	7		9 1.202 30.889
25	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	3		8 1.224 31.457
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				7 1.233 31.648
				6 1.251 32.634
				5 1.263* 33.306*
				4 1.227 32.524
Control Rod Density: %	8.12			3 1.138 29.963
				2 0.879 22.741
k-effective:	0.99752	Bottom	1	0.231 6.226
Void Fraction:	0.481			
Core Delta-P: psia	21.135			
Core Plate Delta-P: psia	16.607			
Coolant Temp: Deg-F	548.2			
In Channel Flow: Mlb/hr	62.62			
Total Bypass Flow (%):	12.6			
Total Water Rod Flow (%):	3.1			
Source Convergence	0.00049			

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K
1.382	35	13	22	1.721	0.860	33	13	24	7.05	0.743	45.1	33	11	18	8
1.374	35	13	18	1.633	0.851	35	9	22	6.89	0.728	45.4	33	17	42	8
1.371	35	11	24	1.642	0.846	35	11	24	9.15	0.727	20.0	35	39	40	4
1.365	35	13	14	1.751	0.845	33	13	16	7.00	0.726	43.6	33	13	38	5
1.362	35	17	14	1.755	0.843	33	11	22	7.01	0.725	43.3	33	9	20	8
1.362	35	9	22	1.759	0.841	33	13	34	6.90	0.724	44.7	33	37	40	5
1.361	35	15	16	1.760	0.841	33	15	14	6.79	0.705	43.6	33	19	44	8
1.357	34	11	16	1.768	0.837	33	19	40	8.78	0.698	20.0	34	41	40	5
1.353	35	21	14	1.663	0.836	35	13	32	8.75	0.695	19.9	34	13	42	5
1.345	35	13	26	1.665	0.835	35	13	14	8.77	0.693	19.4	35	15	38	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.30 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 11,000.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	25848.1
Exposure: MWd/MTU (Gwd)	11350.0 (1142.50)	Axial Profile	Edit
Delta E: MWd/MTU, (Gwd)	350.0 (35.23)	N(PRA) Power Exposure	Radial Power
Power: MWT	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.6	24	0.190 4.523 30 0.454 0.557 5 14
Inlet Subcooling: Btu/lbm	-23.67	23	0.567 13.651 31 0.417 0.551 13 48
Flow: Mlb/hr	70.19 (91.15 %)	22	0.749 18.226 32 0.805 1.092 11 12
		21	0.849 20.818 33 1.064 1.187 13 24
		20	0.911 22.841 34 1.195 1.359 11 16
1 3 5 7 9 11 13 15 17 19 21 23 25		19	0.955 24.277 35 1.247 1.384 13 22
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	
3 -- -- -- -- -- -- -- -- -- -- -- --	47		
5 -- -- -- 36 -- 26 -- 36 -- -- --	43		
7 -- -- -- -- -- -- -- -- -- -- -- --	39		
9 -- -- 36 -- 6 -- 8 -- 6 -- 36 -- --	35		
11 -- -- -- -- -- -- -- -- -- -- -- --	31		
13 -- -- 26 -- 8 -- 26 -- 8 -- 26 -- --	27		
15 -- -- -- -- -- -- -- -- -- -- -- --	23		
17 -- -- 36 -- 6 -- 8 -- 6 -- 36 -- --	19		
19 -- -- -- -- -- -- -- -- -- -- -- --	15		
21 -- -- -- 36 -- 26 -- 36 -- -- --	11		
23 -- -- -- -- -- -- -- -- -- -- -- --	7		
25 -- -- -- -- -- -- -- -- -- -- -- --	3		
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			
Control Rod Density: %	8.12		
k-effective:	0.99752	Bottom	1 0.223 6.308
Void Fraction:	0.481		
Core Delta-P: psia	20.515	% AXIAL TILT	-9.379 -12.640
Core Plate Delta-P: psia	15.987	AVG BOT 8ft/12ft	1.0686 1.0747
Coolant Temp: Deg-F	548.1		
In Channel Flow: Mlb/hr	61.36	Active Channel Flow: Mlb/hr	59.15
Total Bypass Flow (%):	12.6	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00048		

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.384 35 13 22	1.699	0.871	33	13 24	7.01	0.743	45.7	33	11 18	8	7.79	0.780	49.0	33	11 18	8								
1.375 35 13 18	1.614	0.861	35	9 22	6.87	0.730	45.9	33	17 42	8	7.63	0.767	49.4	33	17 42	8								
1.374 35 11 24	1.622	0.857	35	11 24	6.97	0.725	43.8	33	9 20	8	7.69	0.750	46.5	33	9 34	8								
1.366 35 13 14	1.729	0.856	33	13 16	8.93	0.712	20.3	35	39 40	5	9.99	0.746	24.8	34	11 14	5								
1.365 35 9 22	1.731	0.855	33	9 24	6.81	0.711	44.2	33	13 38	5	10.00	0.746	24.6	34	13 12	5								
1.364 35 17 14	1.735	0.853	33	11 22	6.66	0.710	46.2	33	15 40	6	9.89	0.744	25.6	34	11 38	5								
1.362 35 15 16	1.736	0.852	33	13 34	6.77	0.706	44.1	33	19 44	8	7.55	0.744	47.6	33	13 38	5								
1.359 34 11 16	1.738	0.852	33	15 14	9.13	0.703	16.0	35	9 26	15	7.31	0.742	50.1	33	15 40	5								
1.355 35 21 14	1.639	0.848	34	11 38	7.07	0.703	39.3	33	11 26	14	7.56	0.738	46.6	33	19 44	8								
1.347 35 13 26	1.745	0.848	33	19 14	8.60	0.688	20.7	34	41 40	5	9.84	0.737	25.1	34	37 12	5								

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.31 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 11,350.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	26198.1
Exposure: MWd/MTU (GWd)	11700.0 (1177.70)	Axial Profile	Edit
Delta E: MWd/MTU, (GWd)	350.0 (35.23)	N(PRA) Power Exposure	Radial Power
Power: MWT	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.5	24	0.453 0.555 5 14
Inlet Subcooling: Btu/lbm	-24.24	23	0.416 0.549 13 48
Flow: Mlb/hr	68.72 (89.25 %)	22	0.803 1.089 11 12
		21	1.062 1.185 11 22
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.197 1.361 11 16
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	20 0.922 23.181 34 1.250 1.385 13 22
3 -- -- -- -- -- -- -- -- -- -- -- --	47		20 0.966 24.633 35 1.011 25.884
5 -- -- -- 36 -- 26 -- 36 -- -- --	43		19 1.056 26.713
7 -- -- -- -- -- -- -- -- -- -- --	39		18 1.084 26.883
9 -- -- 36 -- 6 -- 8 -- 6 -- 36 -- --	35		17 1.156 27.466
11 -- -- -- -- -- -- -- -- -- -- --	31		16 1.186 28.467
13 -- -- 26 -- 8 -- 26 -- 8 -- 26 -- --	27		15 1.176 29.183
15 -- -- -- -- -- -- -- -- -- -- --	23		14 1.207 28.960
17 -- -- 36 -- 6 -- 8 -- 6 -- 36 -- --	19		13 1.200 29.775
19 -- -- -- -- -- -- -- -- -- -- --	15		12 1.182 30.275
21 -- -- -- 36 -- 26 -- 36 -- -- --	11		10 1.184 30.737
23 -- -- -- -- -- -- -- -- -- --	7		9 1.207 31.690
25 -- -- -- -- -- -- -- -- -- --	3		8 1.219* 32.271
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 1.216 32.466
			6 1.216 33.461
			5 1.202 34.136*
			4 1.147 33.327
Control Rod Density: %	8.12		3 1.055 30.706
			2 0.816 23.316
k-effective:	0.99750	Bottom 1	0.214 6.388
Void Fraction:	0.480		
Core Delta-P: psia	19.886	% AXIAL TILT	-8.079 -12.532
Core Plate Delta-P: psia	15.359	AVG BOT 8ft/12ft	1.0631 1.0742
Coolant Temp: Deg-F	548.0		
In Channel Flow: Mlb/hr	60.07	Active Channel Flow: Mlb/hr	57.90
Total Bypass Flow (%):	12.6	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00033		

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.385 35 13 22	1.677	0.883	33	13 24	6.97	0.743	46.2	33	11 18	8	7.74	0.780	49.6	33	11 18	8								
1.377 35 13 18	1.594	0.872	35	9 22	6.83	0.730	46.4	33	17 42	8	7.59	0.768	49.9	33	17 42	8								
1.376 35 11 24	1.600	0.869	35	11 24	6.93	0.724	44.3	33	9 20	8	7.64	0.749	47.1	33	9 34	8								
1.368 35 9 22	1.705	0.868	33	9 24	9.31	0.720	16.6	35	9 26	15	10.37	0.738	19.4	35	9 26	15								
1.367 35 13 14	1.706	0.868	33	13 16	7.15	0.714	39.9	33	11 26	14	7.52	0.738	47.2	33	19 44	8								
1.366 35 17 14	1.713	0.864	33	11 22	6.74	0.707	44.6	33	19 44	8	7.74	0.732	43.8	33	11 28	13								
1.363 35 15 16	1.713	0.864	33	13 34	6.52	0.700	46.9	33	13 16	6	7.41	0.732	47.7	33	13 38	6								
1.361 34 11 16	1.715	0.863	33	15 14	6.53	0.700	46.7	33	15 40	6	9.74	0.731	25.3	34	13 12	5								
1.358 35 21 14	1.612	0.862	34	11 38	8.69	0.696	21.0	35	39 40	5	9.72	0.731	25.5	34	11 14	5								
1.349 35 13 26	1.720	0.860	33	19 14	8.88	0.682	15.8	35	25 10	15	7.22	0.730	49.9	33	15 40	6								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.32 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 11,700.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLIA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	26199.1	
Exposure: MWd/MTU (Gwd)	11701.0 (1177.80)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (Gwd)	1.0 (0.10)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.175	4.597 30 0.443 0.532 5 14
Core Pressure: psia	1044.6	24	0.522	13.862 31 0.407 0.551 13 48
Inlet Subcooling: Btu/lbm	-22.58	23	0.690	18.505 32 0.793 1.067 11 12
Flow: Mlb/hr	73.23 (95.10 %)	22	0.784	21.135 33 1.065 1.194 25 12
		21	0.846	23.182 34 1.196 1.370 15 12
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.894	24.634 35 1.258 1.408 19 12
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- 36 -- 36 -- -- -- --	43			
7 -- -- -- -- -- -- -- -- -- -- -- --	39			
9 -- -- -- 12 -- 6 -- 6 -- 12 -- -- --	35			
11 -- -- -- -- -- -- -- -- -- -- -- --	31			
13 -- -- -- 0 -- 36 -- 36 -- 0 -- -- --	27			
15 -- -- -- -- -- -- -- -- -- -- -- --	23			
17 -- -- -- 12 -- 6 -- 6 -- 12 -- -- --	19			
19 -- -- -- -- -- -- -- -- -- -- -- --	15			
21 -- -- -- -- 36 -- 36 -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	7.30			
k-effective:	0.99750	Bottom	1	0.282 6.388
Void Fraction:	0.494			
Core Delta-P: psia	22.062	% AXIAL TILT	-17.320	-12.531
Core Plate Delta-P: psia	17.532	AVG BOT 8ft/12ft	1.1020	1.0742
Coolant Temp: Deg-F	548.4			
In Channel Flow: Mlb/hr	63.97	Active Channel Flow: Mlb/hr		61.66
Total Bypass Flow (%):	12.6	(of total core flow)		
Total Water Rod Flow (%):	3.2	(of total core flow)		
Source Convergence	0.00035			

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K
1.408	35	19	12	1.652	0.841	35	25	10	9.97	0.802	21.4	34	37	42	4
1.400	35	17	14	1.771	0.836	33	19	40	9.97	0.794	20.2	35	43	22	4
1.394	35	25	14	1.684	0.826	35	17	14	7.71	0.794	42.8	33	43	20	4
1.388	35	25	10	1.797	0.824	33	25	12	7.46	0.786	45.1	33	17	12	5
1.384	35	21	14	1.688	0.824	35	23	12	9.97	0.786	19.0	35	43	36	4
1.370	34	15	12	1.797	0.824	33	23	14	9.74	0.783	21.3	35	39	40	4
1.358	35	25	26	1.688	0.823	35	19	12	9.78	0.782	20.6	34	45	22	4
1.354	35	23	24	1.698	0.819	35	25	14	9.90	0.779	18.8	35	17	10	4
1.349	35	17	10	1.704	0.816	35	17	10	7.47	0.779	44.1	33	43	24	4
1.349	35	19	16	1.818	0.814	33	17	12	7.43	0.778	44.6	33	37	40	4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.33 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 11,701 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	26698.1
Exposure: MWd/MTU (GWd)	12200.0 (1228.00)	Axial Profile	Edit
Delta E: MWd/MTU, (GWd)	499.0 (50.23)	N(PRA) Power Exposure	Radial Power
Power: MWT	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.6	24	0.442 0.531 5 14
Inlet Subcooling: Btu/lbm	-23.11	23	0.406 0.550 13 48
Flow: Mlb/hr	71.69 (93.10 %)	22	0.792 1.065 11 12
		21	1.063 1.192 25 12
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.198 1.371 15 12
1 --- --- --- --- --- --- --- --- --- ---	51	:JR	35 1.261 1.411 19 12
3 --- --- --- --- --- --- --- --- --- ---	47		
5 --- --- --- 36 --- 36 --- --- ---	43		
7 --- --- --- --- --- --- --- --- ---	39		
9 --- --- 12 --- 6 --- 12 --- --- ---	35		
11 --- --- --- --- --- --- --- --- ---	31		
13 --- --- 0 --- 36 --- 36 --- 0 --- ---	27		
15 --- --- --- --- --- --- --- --- ---	23		
17 --- --- 12 --- 6 --- 12 --- --- ---	19		
19 --- --- --- --- --- --- --- --- ---	15		
21 --- --- --- 36 --- 36 --- --- ---	11		
23 --- --- --- --- --- --- --- ---	7		
25 --- --- --- --- --- --- --- ---	3		
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			
Control Rod Density: %	7.30		
k-effective:	0.99748	Bottom	1 0.261 6.531
Void Fraction:	0.489		
Core Delta-P: psia	21.309	% AXIAL TILT	-14.412 -12.532
Core Plate Delta-P: psia	16.781	AVG BOT 8ft/12ft	1.0886 1.0741
Coolant Temp: Deg-F	548.3		
In Channel Flow: Mlb/hr	62.64	Active Channel Flow: Mlb/hr	60.37
Total Bypass Flow (%):	12.6	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00041		

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR					
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.411 35 19 12	1.622	0.857	35	25 10	7.31	0.761	44.0	33	23 10	8	10.63	0.804	26.2	34	37 12	4		
1.401 35 17 14	1.736	0.853	33	19 14	7.12	0.761	46.5	33	21 42	8	10.64	0.804	26.0	34	45 20	4		
1.398 35 25 14	1.651	0.842	35	23 12	9.36	0.759	22.4	34	37 42	4	10.51	0.798	26.6	34	45 30	4		
1.394 35 25 10	1.760	0.841	33	23 14	7.09	0.754	45.9	33	17 12	5	10.51	0.793	26.0	34	45 22	4		
1.388 35 21 14	1.654	0.841	35	17 14	9.31	0.748	21.3	35	43 22	4	7.85	0.793	49.8	33	21 12	8		
1.371 34 15 12	1.763	0.840	33	25 12	7.20	0.748	43.7	33	43 20	4	8.13	0.792	46.4	33	29 44	8		
1.356 35 25 26	1.657	0.839	35	19 12	9.36	0.744	20.0	35	43 18	4	10.45	0.791	26.3	34	15 10	4		
1.354 35 23 24	1.666	0.834	35	25 14	6.94	0.743	46.6	33	37 40	5	10.38	0.789	26.8	34	13 12	4		
1.353 35 17 10	1.780	0.831	33	19 10	9.34	0.741	19.8	35	17 10	4	7.63	0.784	51.2	33	35 12	5		
1.352 35 19 16	1.673	0.831	35	17 10	9.20	0.741	21.6	34	45 22	4	10.48	0.783	24.8	34	45 36	4		

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.34 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 12,200.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	27198.1	
Exposure: MWd/MTU (Gwd)	12700.0 (1278.40)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (Gwd)	500.0 (50.33)	N(PRA) Power	Exposure Zone	Avg. Max. IR JR
Power: Mwt	2923.0 (100.00 %)	Top 25	0.186 4.793	30 0.441 0.530 5 14
Core Pressure: psia	1044.6	24	0.552 14.423	31 0.405 0.549 13 48
Inlet Subcooling: Btu/lbm	-23.63	23	0.729 19.245	32 0.790 1.063 11 12
Flow: Mlb/hr	70.30 (91.30 %)	22	0.829 21.983	33 1.061 1.191 25 12
		21	0.897 24.098	34 1.201 1.373 15 12
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.952 25.602	35 1.263 1.414 19 12
1 -- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- 36 -- 36 -- -- -- -- -- --	43			
7 -- -- -- -- -- -- -- -- -- -- -- -- -- --	39			
9 -- -- -- 12 -- 6 -- 6 -- 12 -- -- -- 35				
11 -- -- -- -- -- -- -- -- -- -- -- -- -- --	31			
13 -- -- -- 0 -- 36 -- 36 -- 0 -- -- -- 27				
15 -- -- -- -- -- -- -- -- -- -- -- -- -- --	23			
17 -- -- -- 12 -- 6 -- 6 -- 12 -- -- -- 19				
19 -- -- -- -- -- -- -- -- -- -- -- -- -- --	15			
21 -- -- -- -- 36 -- 36 -- -- -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	7.30			
k-effective:	0.99748	Bottom	1 0.241	6.663
Void Fraction:	0.484			
Core Delta-P: psia	20.639			
Core Plate Delta-P: psia	16.112		% AXIAL TILT -11.595 -12.478	
Coolant Temp: Deg-F	548.2		AVG BOT 8ft/12ft 1.0759 1.0737	
In Channel Flow: Mlb/hr	61.44		Active Channel Flow: Mlb/hr	59.22
Total Bypass Flow (%):	12.6		(of total core flow)	
Total Water Rod Flow (%):	3.2		(of total core flow)	
Source Convergence	0.00043			

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR										
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.414	35	19	12	1.595	0.871	35	25	10	7.28	0.761	44.3	33	29	44	8	7.77	0.793	50.6	33	21	12	8
1.402	35	17	14	1.704	0.868	33	19	14	7.05	0.760	47.3	33	21	42	8	8.06	0.792	47.3	33	29	44	8
1.402	35	25	14	1.618	0.859	35	23	12	6.93	0.728	44.8	33	27	42	8	9.99	0.763	27.3	34	37	12	5
1.400	35	25	10	1.728	0.856	33	23	14	6.74	0.722	46.7	33	17	12	5	9.95	0.759	27.1	34	45	20	4
1.393	35	21	14	1.626	0.855	35	19	12	8.76	0.716	23.4	34	37	42	4	7.25	0.752	52.0	33	35	12	5
1.373	34	15	12	1.732	0.855	33	25	12	6.68	0.710	45.9	33	43	34	5	9.79	0.751	27.7	34	45	30	4
1.359	35	23	12	1.627	0.854	35	17	14	6.58	0.710	47.3	33	37	40	5	9.88	0.749	26.3	34	37	44	4
1.356	35	17	10	1.636	0.849	35	25	14	9.01	0.710	18.9	35	23	42	8	9.81	0.748	27.1	34	45	22	4
1.354	35	19	16	1.745	0.848	33	19	10	6.76	0.709	44.7	33	23	26	9	10.17	0.745	22.7	35	23	42	8
1.352	35	25	26	1.751	0.845	33	17	12	8.92	0.707	19.7	35	21	10	8	9.69	0.744	27.9	34	13	12	4

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.35 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 12,700.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	27498.1	
Exposure: MWd/MTU (GWd)	13000.0 (1308.60)			
Delta E: MWd/MTU, (GWd)	300.0 (30.20)			
Power: MWT	2923.0 (100.00 %)	Axial Profile	Edit	Radial Power
Core Pressure: psia	1044.5	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-23.94	Top 25	0.189 4.855	30 0.440 0.529 5 14
Flow: Mlb/hr	69.49 (90.25 %)	24	0.561 14.598	31 0.405 0.548 13 48
		23	0.740 19.477	32 0.790 1.062 11 12
		22	0.843 22.249	33 1.060 1.190 25 12
		21	0.914 24.385	34 1.202 1.373 15 12
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.971 25.907	35 1.264 1.415 19 12
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47		19 1.014 27.211	
5 -- -- -- -- 36 -- 36 -- -- -- --	43		18 1.044 28.076	
7 -- -- -- -- -- -- -- -- -- -- -- --	39		17 1.062 28.266	
9 -- -- -- 12 -- 6 -- 6 -- 12 -- -- --	35		16 1.124 28.853	
11 -- -- -- -- -- -- -- -- -- -- -- --	31		15 1.148 29.886	
13 -- -- -- 0 -- 36 -- 36 -- 0 -- -- --	27		14 1.136 30.594	
15 -- -- -- -- -- -- -- -- -- -- -- --	23		13 1.167 30.339	
17 -- -- -- 12 -- 6 -- 6 -- 12 -- -- --	19		12 1.174 31.174	
19 -- -- -- -- -- -- -- -- -- -- -- --	15		11 1.185 31.699	
21 -- -- -- -- 36 -- 36 -- -- -- --	11		10 1.207 32.203	
23 -- -- -- -- -- -- -- -- -- -- -- --	7		9 1.239 33.215	
25 -- -- -- -- -- -- -- -- -- -- -- --	3		8 1.254* 33.841	
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 1.249 34.062	
Control Rod Density: %	7.30		6 1.244 35.093	
k-effective:	0.99748		5 1.214 35.784*	
Void Fraction:	0.480	Bottom	4 1.157 34.943	
Core Delta-P: psia	20.250	1 0.229 6.737		
Core Plate Delta-P: psia	15.723			
Coolant Temp: Deg-F	548.1			
In Channel Flow: Mlb/hr	60.74	% AXIAL TILT	-9.817 -12.416	
Total Bypass Flow (%):	12.6	AVG BOT 8ft/12ft	1.0678 1.0734	
Total Water Rod Flow (%):	3.1	Active Channel Flow: Mlb/hr	58.55	
Source Convergence	0.00043	(of total core flow)		

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.415 35 19 12	1.580	0.880	35	25 10	7.23	0.760	44.8	33	29 44	8	8.00	0.791	47.8	33	29 44	8								
1.404 35 25 14	1.686	0.878	33	19 14	6.99	0.757	47.8	33	21 42	8	7.69	0.790	51.1	33	21 12	8								
1.403 35 25 10	1.598	0.870	35	23 12	6.89	0.727	45.2	33	27 42	8	10.08	0.743	23.3	35	23 42	8								
1.403 35 17 14	1.710	0.865	33	23 14	8.97	0.709	19.4	35	23 42	8	9.66	0.743	27.9	34	37 12	5								
1.395 35 21 14	1.607	0.865	35	19 12	6.71	0.707	45.1	33	23 26	9	7.47	0.743	48.4	33	27 12	8								
1.373 34 15 12	1.714	0.864	33	25 12	8.87	0.707	20.2	35	21 10	8	9.99	0.740	23.9	35	21 44	8								
1.364 35 23 12	1.611	0.863	35	17 14	6.58	0.705	46.5	33	19 44	8	7.26	0.735	49.9	33	19 44	8								
1.357 35 17 10	1.619	0.859	35	25 14	6.44	0.703	48.4	33	17 42	6	7.33	0.733	48.9	33	23 40	8								
1.356 35 19 16	1.725	0.858	33	19 10	6.67	0.702	45.0	33	23 40	8	7.38	0.732	48.1	33	23 26	9								
1.349 35 25 26	1.733	0.854	33	17 12	8.48	0.695	23.7	34	37 42	5	9.54	0.732	27.7	34	45 20	4								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.36 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 13,000.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	27998.1
Exposure: MWd/MTU (GWd)	13500.0 (1358.90)	Axial Profile	Edit
Delta E: MWd/MTU, (GWd)	500.0 (50.33)	N(PRA) Power Exposure	Radial Power
Power: MWT	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.5	24	0.439 0.528 5 14
Inlet Subcooling: Btu/lbm	-24.24	23	0.404 0.548 13 48
Flow: Mlb/hr	68.72 (89.25 %)	22	0.788 1.061 11 12
		21	1.057 1.188 25 12
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.205 1.375 15 12
1 --- --- --- --- --- --- --- --- --- ---	51	:JR	20 1.265 1.417 19 12
3 --- --- --- --- --- --- --- --- --- ---	47		19 1.051 27.751
5 --- --- --- 36 --- 36 --- --- ---	43		18 1.083 28.633
7 --- --- --- --- --- --- --- --- ---	39		17 1.101 28.832
9 --- --- 12 -- 6 -- 6 -- 12 -- ---	35		16 1.165 29.420
11 --- --- --- --- --- --- --- --- ---	31		15 1.187 30.465
13 --- --- 0 -- 36 -- 36 -- 0 -- ---	27		14 1.170 31.167
15 --- --- --- --- --- --- --- --- ---	23		13 1.197 30.894
17 --- --- 12 -- 6 -- 6 -- 12 -- ---	19		12 1.198 31.732
19 --- --- --- --- --- --- --- ---	15		11 1.202 32.262
21 --- --- --- 36 -- 36 -- --- ---	11		10 1.216 32.776
23 --- --- --- --- --- --- --- ---	7		9 1.238 33.804
25 --- --- --- --- --- --- --- ---	3		8 1.240* 34.437
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 1.220 34.656
Control Rod Density: %	7.30		6 1.194 35.685
k-effective:	0.99751	Bottom	5 1.143 36.361*
Void Fraction:	0.473	1	4 1.069 35.492
Core Delta-P: psia	19.835		3 0.985 32.751
Core Plate Delta-P: psia	15.309	% AXIAL TILT	2 0.781 24.943
Coolant Temp: Deg-F	547.9	AVG BOT 8ft/12ft	
In Channel Flow: Mlb/hr	60.09	1.0530	1.0727
Total Bypass Flow (%):	12.6	Active Channel Flow: Mlb/hr	57.94
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00027	(of total core flow)	

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.417 35 19 12	1.663	0.890	33	19 14	7.12	0.755	45.6	33	29 44	8	7.63	0.785	51.4	33	23 44	8								
1.408 35 25 10	1.564	0.889	35	25 10	6.92	0.751	47.9	33	21 42	9	7.55	0.783	52.0	33	21 12	8								
1.407 35 25 14	1.568	0.886	35	23 12	6.84	0.728	45.9	33	27 42	9	7.43	0.745	49.0	33	27 12	9								
1.404 35 17 14	1.585	0.877	35	19 12	9.00	0.707	18.5	35	23 12	15	9.91	0.738	24.4	35	23 42	8								
1.398 35 21 14	1.688	0.877	33	23 14	8.77	0.703	21.1	35	21 44	8	9.83	0.735	24.9	35	21 44	8								
1.375 34 15 12	1.692	0.875	33	25 12	6.66	0.702	45.2	33	23 40	9	7.37	0.734	48.5	33	23 14	9								
1.372 35 23 12	1.593	0.873	35	17 14	6.60	0.702	45.9	33	23 26	9	7.16	0.731	50.7	33	19 44	8								
1.361 35 17 10	1.697	0.872	33	19 10	6.50	0.701	47.3	33	19 44	8	7.26	0.728	49.2	33	25 8	9								
1.357 35 19 16	1.599	0.869	35	25 14	8.74	0.688	18.8	35	25 10	15	9.71	0.728	25.2	34	29 46	8								
1.350 35 21 10	1.709	0.866	33	17 12	6.26	0.688	49.0	33	17 42	8	7.27	0.727	48.9	33	23 26	9								

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.37 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 13,500.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	28498.1	
Exposure: MWd/MTU (GWd)	14000.0 (1409.20)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	500.0 (50.33)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.202	5.068 30 0.439 0.527 5 14
Core Pressure: psia	1044.5	24	0.597	15.202 31 0.403 0.547 13 48
Inlet Subcooling: Btu/lbm	-24.42	23	0.787	20.272 32 0.788 1.061 11 12
Flow: Mlb/hr	68.26 (88.65 %)	22	0.899	23.162 33 1.055 1.185 25 12
		21	0.978	25.375 34 1.209 1.377 15 12
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.041	26.960 35 1.266 1.418 19 12
1 --- --- --- --- --- ---	51	:JR		
3 --- --- --- --- --- ---	47			
5 --- --- --- 36 --- 36 --- --- ---	43			
7 --- --- --- --- --- --- ---	39			
9 --- --- 12 --- 6 --- 6 --- 12 --- --- ---	35			
11 --- --- --- --- --- --- --- --- --- ---	31			
13 --- --- 0 --- 36 --- 36 --- 0 --- --- ---	27			
15 --- --- --- --- --- --- --- --- --- ---	23			
17 --- --- 12 --- 6 --- 6 --- 12 --- --- ---	19			
19 --- --- --- --- --- --- ---	15			
21 --- --- --- 36 --- 36 --- --- ---	11			
23 --- --- --- --- --- --- ---	7			
25 --- --- --- --- --- --- ---	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	7.30			
k-effective:	0.99752	Bottom	1	0.189 6.959
Void Fraction:	0.464			
Core Delta-P: psia	19.542	% AXIAL TILT	-3.341	-12.098
Core Plate Delta-P: psia	15.017	AVG BOT 8ft/12ft	1.0368	1.0717
Coolant Temp: Deg-F	547.8			
In Channel Flow: Mlb/hr	59.73	Active Channel Flow: Mlb/hr		57.60
Total Bypass Flow (%):	12.5	(of total core flow)		
Total Water Rod Flow (%):	3.1	(of total core flow)		
Source Convergence	0.00050			

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR			APIHGR			LHGR						
Value	FT	IR JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.418	35	19 12	1.645	0.900	33	19	14	6	6.94	0.754	47.9	33	23	44	9
1.410	35	25 10	1.545	0.900	35	23	12	6	6.85	0.750	48.6	33	21	42	9
1.408	35	25 14	1.548	0.898	35	25	10	9	9.23	0.730	19.4	35	23	12	15
1.405	35	17 14	1.567	0.887	35	19	12	6	6.79	0.728	46.7	33	27	42	9
1.399	35	21 14	1.672	0.885	33	23	14	9	9.15	0.721	19.0	35	21	10	15
1.378	35	23 12	1.675	0.884	33	25	12	8	8.96	0.710	19.7	35	25	10	15
1.377	34	15 12	1.676	0.883	33	19	10	6	6.61	0.702	45.9	33	23	40	9
1.363	35	17 10	1.579	0.880	35	17	14	6	6.49	0.700	47.4	33	19	44	9
1.358	35	19 16	1.581	0.879	35	27	14	8	8.87	0.699	18.9	35	19	12	15
1.357	35	21 10	1.583	0.878	34	37	12	6	6.47	0.693	46.6	33	23	26	9

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.38 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 14,000.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLIA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	28898.0	
Exposure: MWd/MTU (Gwd)	14400.0 (1449.50)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (Gwd)	400.0 (40.26)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.208 5.157	30 0.438 0.526 5 14
Core Pressure: psia	1044.5	24	0.615 15.455	31 0.402 0.547 13 48
Inlet Subcooling: Btu/lbm	-24.16	23	0.810 20.605	32 0.788 1.061 11 12
Flow: Mlb/hr	68.92 (89.50 %)	22	0.927 23.545	33 1.053 1.182 25 12
		21	1.008 25.792	34 1.213 1.379 15 12
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.074 27.404	35 1.266 1.417 19 12
1 -- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- -- -- --	47		19 1.124 28.777	
5 -- -- -- -- 36 -- 36 -- -- -- --	43		18 1.157 29.690	
7 -- -- -- -- -- -- -- -- -- -- -- -- -- --	39		17 1.174 29.906	
9 -- -- -- 12 -- 6 -- 6 -- 12 -- -- -- 35			16 1.237 30.493	
11 -- -- -- -- -- -- -- -- -- -- -- -- -- --	31		15 1.253* 31.558	
13 -- -- -- 0 -- 36 -- 36 -- 0 -- -- -- 27			14 1.227 32.242	
15 -- -- -- -- -- -- -- -- -- -- -- -- -- --	23		13 1.247 31.930	
17 -- -- -- 12 -- 6 -- 6 -- 12 -- -- -- 19			12 1.237 32.765	
19 -- -- -- -- -- -- -- -- -- -- -- -- -- --	15		11 1.228 33.297	
21 -- -- -- -- 36 -- 36 -- -- -- -- 11			10 1.226 33.819	
23 -- -- -- -- -- -- -- -- -- -- -- -- -- --	7		9 1.227 34.862	
25 -- -- -- -- -- -- -- -- -- -- -- -- -- --	3		8 1.204 35.491	
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 1.155 35.686	
Control Rod Density: %	7.30		6 1.095 36.686	
k-effective:	0.99776	Bottom	5 1.010 37.310*	
Void Fraction:	0.455	1	4 0.914 36.374	
Core Delta-P: psia	19.707	% AXIAL TILT	3 0.823 33.559	
Core Plate Delta-P: psia	15.182	AVG BOT 8ft/12ft	2 0.649 25.583	
Coolant Temp: Deg-F	547.7	1.0228 1.0708		
In Channel Flow: Mlb/hr	60.35	Active Channel Flow: Mlb/hr	58.22	
Total Bypass Flow (%):	12.4	(of total core flow)		
Total Water Rod Flow (%):	3.1	(of total core flow)		
Source Convergence	0.00047			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	APL/HGR												LHGR				
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.417 35 19 12	1.541	0.902	35	23 12	6.88	0.752	48.5	33	23 44	9	7.52	0.782	52.1	33	23 44	9	
1.410 35 25 10	1.643	0.901	33	19 14	6.78	0.747	49.2	33	21 42	9	7.43	0.777	52.7	33	21 12	9	
1.407 35 25 14	1.549	0.897	35	25 10	9.37	0.745	20.2	35	23 12	15	10.23	0.751	22.8	34	23 8	15	
1.405 35 17 14	1.565	0.888	35	19 12	9.33	0.740	19.7	35	21 10	15	10.18	0.749	23.0	35	23 12	15	
1.398 35 21 14	1.670	0.886	33	19 10	6.74	0.727	47.3	33	27 42	9	10.24	0.747	22.2	35	21 44	15	
1.380 35 23 12	1.571	0.885	34	37 12	9.10	0.726	20.5	35	25 10	15	10.23	0.747	22.2	34	21 8	15	
1.379 34 15 12	1.673	0.885	33	23 14	9.06	0.718	19.7	35	19 12	15	7.30	0.744	50.4	33	27 12	9	
1.366 35 17 10	1.675	0.884	33	25 12	8.97	0.706	18.9	35	25 14	15	7.20	0.734	50.4	33	23 40	9	
1.362 35 21 10	1.679	0.881	33	23 44	8.98	0.706	18.7	35	21 14	15	7.10	0.732	51.5	33	19 44	9	
1.358 35 19 16	1.578	0.881	35	27 14	8.88	0.702	19.2	34	23 8	15	7.17	0.731	50.6	33	25 8	9	

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.39 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 14,400.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	28899.1
Exposure: MWd/MTU (Gwd)	14401.0 (1449.60)	Axial Profile	Edit
Delta E: MWd/MTU, (Gwd)	1.0 (0.10)	N(PRA) Power Exposure	Radial Power
Power: MWT	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.5	24	0.177 5.158 30 0.424 0.524 5 14
Inlet Subcooling: Btu/lbm	-24.47	23	0.523 15.455 31 0.390 0.525 13 48
Flow: Mlb/hr	68.14 (88.50 %)	22	0.689 20.606 32 0.768 1.057 11 12
		21	0.794 23.546 33 1.064 1.210 23 22
1 3 5 7 9 11 13 15 17 19 21 23 25		20	0.871 25.793 34 1.191 1.356 11 16
1 --- --- --- --- --- --- --- --- --- ---	51	:JR	20 0.941 27.405 35 1.289 1.460 23 24
3 --- --- --- --- --- --- --- --- --- ---	47		19 1.005 28.778
5 --- --- --- --- --- --- --- --- --- ---	43		18 1.064 29.691
7 --- --- --- 6 --- --- --- --- --- ---	39		17 1.101 29.907
9 --- --- --- --- --- --- --- --- --- ---	35		16 1.177 30.495
11 --- --- 0 --- --- --- --- --- --- ---	31		15 1.205 31.559
13 --- --- --- --- --- --- --- --- --- ---	27		14 1.189 32.244
15 --- --- 0 --- --- --- --- --- --- ---	23		13 1.215 31.931
17 --- --- --- --- --- --- --- --- --- ---	19		12 1.210 32.766
19 --- --- 6 --- 6 --- --- --- --- ---	15		11 1.206 33.298
21 --- --- --- --- --- --- --- --- --- ---	11		10 1.210 33.821
23 --- --- --- --- --- --- --- --- --- ---	7		9 1.223* 34.863
25 --- --- --- --- --- --- --- --- --- ---	3		8 1.221 35.492
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 1.209 35.687
Control Rod Density: %	5.47		6 1.213 36.687
			5 1.189 37.311*
			4 1.144 36.375
k-effective:	0.99776	Bottom 1	0.244 7.036
Void Fraction:	0.481		
Core Delta-P: psia	19.748	% AXIAL TILT	-9.720 -11.909
Core Plate Delta-P: psia	15.223	AVG BOT 8ft/12ft	1.0777 1.0708
Coolant Temp: Deg-F	548.0		
In Channel Flow: Mlb/hr	59.52	Active Channel Flow: Mlb/hr	57.36
Total Bypass Flow (%):	12.7	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00040		

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.460 35 23 24	1.538	0.903	35	23 24	6.45	0.679	45.1	33	23 22	8	6.73	0.703	52.6	33	13 16	8								
1.452 35 25 22	1.549	0.897	35	27 22	8.45	0.679	21.3	35	23 24	15	6.86	0.702	50.8	33	19 22	8								
1.446 35 25 26	1.552	0.896	35	21 28	6.41	0.678	45.5	33	21 24	8	6.98	0.700	49.2	33	23 22	6								
1.445 35 21 22	1.553	0.895	35	25 26	8.43	0.676	21.2	35	21 26	15	7.08	0.700	47.8	33	21 30	8								
1.444 35 21 26	1.553	0.895	35	21 22	6.15	0.676	49.0	33	13 16	8	6.69	0.699	52.7	33	15 40	8								
1.430 35 23 20	1.655	0.894	33	21 24	8.44	0.675	20.7	35	25 22	15	6.85	0.699	50.5	33	29 28	5								
1.409 35 19 20	1.667	0.888	33	23 22	6.28	0.675	47.0	33	23 26	5	9.12	0.697	27.3	35	29 30	5								
1.407 35 19 24	1.673	0.885	33	21 20	6.13	0.674	49.1	33	15 40	8	6.78	0.697	51.1	33	27 30	6								
1.397 35 15 16	1.675	0.884	33	25 24	6.23	0.672	47.3	33	19 22	8	9.50	0.696	22.6	34	11 38	15								
1.395 35 17 18	1.681	0.880	33	25 20	8.45	0.672	20.1	35	21 22	15	6.60	0.694	53.1	33	11 18	8								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.40 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 14,401.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	29398.2	
Exposure: MWd/MTU (GWd)	14900.0 (1499.80)			
Delta E: MWd/MTU, (GWd)	499.0 (50.23)			
Power: MWT	2923.0 (100.00 %)	Axial Profile	Edit	Radial Power
Core Pressure: psia	1044.6	N(PRA) Power	Exposure Zone	Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-23.58	Top 25 0.186 5.256 30 0.424 0.523 5 14		
Flow: Mlb/hr	70.46 (91.50 %)	24 0.550 15.731 31 0.390 0.526 13 48		
		23 0.725 20.970 32 0.770 1.060 11 12		
		22 0.836 23.969 33 1.061 1.194 23 22		
		21 0.917 26.257 34 1.198 1.360 15 12		
		20 0.990 27.906 35 1.286 1.438 23 24		
1 3 5 7 9 11 13 15 17 19 21 23 25				
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- -- -- -- -- -- -- -- --	43			
7 -- -- -- -- 6 -- 6 -- -- -- --	39			
9 -- -- -- -- -- -- -- -- -- -- -- --	35			
11 -- -- -- 0 -- -- -- -- -- -- -- --	31			
13 -- -- -- -- -- -- -- -- -- -- -- --	27			
15 -- -- -- 0 -- -- -- -- -- -- -- --	23			
17 -- -- -- -- -- -- -- -- -- -- -- --	19			
19 -- -- -- -- 6 -- 6 -- -- -- --	15			
21 -- -- -- -- -- -- -- -- -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	5.47			
k-effective:	0.99805	Bottom	1 0.214	7.160
Void Fraction:	0.464			
Core Delta-P: psia	20.520	% AXIAL TILT	-5.483 -11.789	
Core Plate Delta-P: psia	15.993	AVG BOT 8ft/12ft	1.0565 1.0704	
Coolant Temp: Deg-F	547.9			
In Channel Flow: Mlb/hr	61.66	Active Channel Flow: Mlb/hr	59.47	
Total Bypass Flow (%):	12.5	(of total core flow)		
Total Water Rod Flow (%):	3.1	(of total core flow)		
Source Convergence	0.00042			

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR						APLHGR						LHGR						
Value	FT	IR JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.438	35	23 24	1.575	0.882	35	29	30	8.74	0.696	20.1	35	15	38	15	9.90	0.732	23.6	34	11	38	15
1.432	35	25 22	1.582	0.879	35	21	22	8.56	0.693	22.2	35	23	24	15	9.84	0.725	23.4	34	15	42	15
1.429	35	21 22	1.584	0.878	35	27	22	8.71	0.692	19.9	35	13	40	15	9.74	0.715	22.9	34	11	14	15
1.423	35	21 26	1.692	0.875	33	21	24	8.54	0.691	22.0	35	21	26	15	9.71	0.713	22.8	34	13	12	15
1.421	35	25 26	1.591	0.874	35	21	28	8.57	0.690	21.6	35	25	22	15	6.76	0.702	52.2	33	13	16	9
1.418	35	23 20	1.700	0.871	33	21	20	8.61	0.690	20.9	35	21	22	15	9.57	0.702	22.7	35	13	14	15
1.402	35	19 20	1.597	0.870	35	27	28	8.64	0.688	20.2	34	11	16	15	6.72	0.699	52.2	33	15	40	9
1.396	35	15 16	1.598	0.870	34	11	38	8.61	0.684	20.0	34	15	42	15	6.81	0.697	50.9	33	19	22	9
1.393	35	17 18	1.703	0.869	33	23	22	8.61	0.682	19.5	35	13	36	15	9.46	0.697	23.2	35	15	16	15
1.392	35	19 24	1.712	0.864	33	25	20	8.45	0.681	21.7	35	25	26	15	9.31	0.695	24.8	35	21	28	15

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.41 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 14,900.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	29898.2
Exposure: MWd/MTU (GWd)	15400.0 (1550.10)	Axial Profile	Edit
Delta E: MWd/MTU, (GWd)	500.0 (50.33)	N(PRA) Power Exposure	Radial Power
Power: MWT	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.6	24	0.424 0.523 5 14
Inlet Subcooling: Btu/lbm	-22.34	23	0.390 0.527 13 48
Flow: Mlb/hr	73.92 (96.00 %)	22	0.772 1.064 11 12
		21	1.057 1.177 23 22
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.206 1.365 15 42
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	1.283 1.414 23 24
3 -- -- -- -- -- -- -- -- -- -- -- --	47		
5 -- -- -- -- -- -- -- -- -- -- -- --	43		
7 -- -- -- -- 6 -- 6 -- -- -- --	39		
9 -- -- -- -- -- -- -- -- -- -- -- --	35		
11 -- -- -- 0 -- -- -- -- -- -- 0 -- -- --	31		
13 -- -- -- -- -- -- -- -- -- -- -- --	27		
15 -- -- -- 0 -- -- -- -- -- -- 0 -- -- --	23		
17 -- -- -- -- -- -- -- -- -- -- -- --	19		
19 -- -- -- -- 6 -- 6 -- -- -- --	15		
21 -- -- -- -- -- -- -- -- -- -- -- --	11		
23 -- -- -- -- -- -- -- -- -- -- -- --	7		
25 -- -- -- -- -- -- -- -- -- -- -- --	3		
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			
Control Rod Density: %	5.47		
k-effective:	0.99839	Bottom	1 0.188 7.269
Void Fraction:	0.446		
Core Delta-P: psia	21.783		
Core Plate Delta-P: psia	17.256	% AXIAL TILT	-1.428 -11.602
Coolant Temp: Deg-F	547.9	AVG BOT 8ft/12ft	1.0351 1.0696
In Channel Flow: Mlb/hr	64.83	Active Channel Flow: Mlb/hr	62.58
Total Bypass Flow (%):	12.3	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00050		

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR					
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.414 35 23 24	1.613	0.862	34	11 38	8.99	0.720	20.8	35	13 40 15	10.22	0.762	24.6	34	11 38	15			
1.412 35 21 22	1.624	0.856	35	29 30	8.97	0.719	21.1	35	15 38 15	10.17	0.757	24.4	34	15 42	15			
1.412 35 25 22	1.625	0.855	35	21 22	8.94	0.716	21.0	34	11 38 15	10.07	0.747	23.9	34	11 14	15			
1.405 35 23 20	1.629	0.853	35	27 22	8.91	0.714	20.8	34	15 42 15	10.05	0.745	23.8	34	13 12	15			
1.400 35 21 26	1.630	0.853	34	37 12	8.84	0.705	20.4	35	13 36 15	9.85	0.728	23.7	35	13 14	15			
1.395 35 25 26	1.743	0.849	33	21 20	8.82	0.702	20.2	35	17 40 15	9.72	0.721	24.0	35	15 38	15			
1.394 35 15 16	1.746	0.848	33	21 24	8.69	0.702	21.8	35	21 22 15	7.24	0.720	48.3	33	13 38	15			
1.393 35 19 20	1.749	0.846	33	13 16	6.77	0.701	43.4	33	13 38 14	9.73	0.717	23.2	34	9 38	15			
1.389 35 17 18	1.643	0.846	34	11 14	8.60	0.701	23.1	35	23 24 15	7.14	0.716	49.1	33	15 40	12			
1.376 35 19 24	1.643	0.846	35	21 28	6.79	0.701	43.1	33	15 40 14	9.63	0.715	24.2	34	7 32	15			

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.42 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 15,400.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	30398.1	
Exposure: MWd/MTU (Gwd)	15900.0 (1600.50)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (Gwd)	500.0 (50.33)	N(PRA) Power	Exposure Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.207 5.467	30 0.423 0.522 5 14
Core Pressure: psia	1044.7	24	0.615 16.329	31 0.390 0.527 39 6
Inlet Subcooling: Btu/lbm	-20.86	23	0.811 21.759	32 0.775 1.069 11 12
Flow: Mlb/hr	78.54 (102.00 %)	22	0.934 24.885	33 1.054 1.162 15 40
		21	1.021 27.260	34 1.216 1.371 15 42
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.094 28.987	35 1.279 1.393 21 22
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- -- -- -- -- -- -- -- --	43			
7 -- -- -- -- 6 -- 6 -- -- -- --	39			
9 -- -- -- -- -- -- -- -- -- -- -- --	35			
11 -- -- 0 -- -- -- -- -- -- 0 -- -- --	31			
13 -- -- -- -- -- -- -- -- -- -- -- --	27			
15 -- -- 0 -- -- -- -- -- -- 0 -- -- --	23			
17 -- -- -- -- -- -- -- -- -- -- -- --	19			
19 -- -- -- 6 -- 6 -- -- -- --	15			
21 -- -- -- -- -- -- -- -- -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	5.47			
k-effective:	0.99867	Bottom	1	0.166 7.364
Void Fraction:	0.426			
Core Delta-P: psia	23.568	% AXIAL TILT	2.778 -11.354	
Core Plate Delta-P: psia	19.038	AVG BOT 8ft/12ft	1.0115 1.0685	
Coolant Temp: Deg-F	547.9			
In Channel Flow: Mlb/hr	69.06	Active Channel Flow: Mlb/hr	66.73	
Total Bypass Flow (%):	12.1	(of total core flow)		
Total Water Rod Flow (%):	3.0	(of total core flow)		
Source Convergence	0.00049			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR					
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.393 35 21 22	1.634	0.851	34	11 38	9.22	0.744	21.8	35	13 40	15	10.49	0.790	25.7	34	11 38	15		
1.392 35 15 38	1.644	0.845	34	37 12	9.17	0.741	21.9	34	11 38	15	10.45	0.786	25.4	34	15 42	15		
1.391 35 27 32	1.657	0.839	34	11 14	9.15	0.739	22.0	35	15 38	15	10.36	0.775	25.0	34	11 14	15		
1.390 35 23 20	1.659	0.838	34	13 12	9.16	0.739	21.8	34	15 42	15	10.37	0.774	24.7	34	13 42	15		
1.390 35 23 24	1.780	0.831	33	13 16	9.02	0.725	21.4	35	13 36	15	10.06	0.751	24.7	35	13 14	15		
1.383 35 19 20	1.672	0.831	35	21 22	9.01	0.723	21.2	35	17 40	15	10.06	0.747	24.2	34	9 38	15		
1.383 35 17 18	1.676	0.829	35	29 30	8.98	0.721	21.2	34	11 40	15	7.42	0.744	49.1	33	13 38	15		
1.377 35 13 40	1.678	0.828	35	27 22	6.97	0.720	43.2	33	13 38	15	10.02	0.742	23.9	34	15 44	15		
1.377 35 31 28	1.793	0.825	33	17 16	7.00	0.720	42.7	33	15 40	15	9.90	0.742	25.2	34	7 32	15		
1.373 35 17 40	1.689	0.823	35	37 38	8.97	0.719	21.1	34	13 42	15	9.91	0.742	25.0	35	15 38	15		

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.43 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 15,900.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	30399.1	
Exposure: MWd/MTU (GWd)	15901.0 (1600.60)			
Delta E: MWd/MTU, (GWd)	1.0 (0.10)	Axial Profile	Edit	Radial Power
Power: MWT	2923.0 (100.00 %)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Core Pressure: psia	1044.5	Top 25	0.234	5.467 30 0.421 0.519 5 40
Inlet Subcooling: Btu/lbm	-24.01	24	0.692	16.330 31 0.387 0.522 39 6
Flow: Mlb/hr	69.30 (90.00 %)	23	0.907	21.760 32 0.765 1.048 11 42
		22	1.041	24.886 33 1.063 1.160 21 34
		21	1.129	27.262 34 1.194 1.349 11 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.172	28.989 35 1.291 1.393 21 22
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	19	1.200 30.464
3 -- -- -- -- -- -- -- -- -- -- -- --	47		18	1.227 31.472
5 -- -- -- -- -- -- -- -- -- -- -- --	43		17	1.232 31.744
7 -- -- -- -- 10 -- 8 -- -- -- --	39		16	1.281* 32.345
9 -- -- -- -- -- -- -- -- -- -- -- --	35		15	1.280 33.444
11 -- -- -- 8 -- -- -- -- -- -- 8 -- -- -- 31			14	1.239 34.097
13 -- -- -- -- -- -- -- -- -- -- -- --	27		13	1.250 33.711
15 -- -- -- 8 -- -- -- -- -- -- 8 -- -- -- 23			12	1.225 34.531
17 -- -- -- -- -- -- -- -- -- -- -- --	19		11	1.196 35.046
19 -- -- -- -- 8 -- 10 -- -- -- -- 15			10	1.168 35.559
21 -- -- -- -- -- -- -- -- -- -- -- --	11		9	1.144 36.600
23 -- -- -- -- -- -- -- -- -- -- -- --	7		8	1.101 37.203
25 -- -- -- -- -- -- -- -- -- -- -- --	3		7	1.043 37.355
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			6	0.992 38.329
			5	0.913 38.883*
			4	0.825 37.853
Control Rod Density: %	4.81		3	0.746 34.941
			2	0.600 26.708
k-effective:	0.99865	Bottom	1	0.164 7.364
Void Fraction:	0.437			
Core Delta-P: psia	19.653	% AXIAL TILT	6.393	-11.354
Core Plate Delta-P: psia	15.128	AVG BOT 8ft/12ft	0.9791	1.0685
Coolant Temp: Deg-F	547.5			
In Channel Flow: Mlb/hr	60.79	Active Channel Flow: Mlb/hr		58.68
Total Bypass Flow (%):	12.3	(of total core flow)		
Total Water Rod Flow (%):	3.0	(of total core flow)		
Source Convergence	0.00043			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.393 35 21 22	1.661	0.891	33	21 34	8.95	0.722	21.8	35	13 40 15	10.17	0.766	25.7	34	11 38	15									
1.391 35 19 34	1.661	0.891	33	15 36	8.91	0.720	22.0	35	15 38 15	10.13	0.761	25.5	34	15 42	15									
1.390 35 23 34	1.561	0.890	34	11 38	8.90	0.719	21.9	34	11 38 15	10.04	0.750	24.8	34	11 40	15									
1.389 35 17 36	1.562	0.890	35	21 22	8.89	0.717	21.8	34	15 42 15	10.03	0.749	24.7	34	13 42	15									
1.385 35 23 24	1.566	0.888	34	37 12	6.91	0.710	42.6	33	13 38 17	7.50	0.732	46.8	33	17 38	18									
1.385 35 27 32	1.668	0.887	33	17 38	6.94	0.709	42.1	33	15 40 17	7.33	0.729	48.3	33	13 38	17									
1.384 35 15 38	1.567	0.887	35	29 20	8.78	0.706	21.4	35	13 36 15	9.74	0.727	24.8	35	13 40	15									
1.379 35 21 26	1.672	0.885	33	23 22	6.88	0.705	42.4	33	17 38 18	7.10	0.727	50.9	33	27 30	18									
1.371 35 19 24	1.672	0.885	33	15 40	8.78	0.704	21.2	35	17 40 15	7.14	0.725	50.3	33	23 26	18									
1.369 35 13 36	1.571	0.885	35	27 22	6.73	0.704	44.4	33	23 22 18	7.51	0.725	45.7	33	15 40	18									

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.44 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 15,901.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	30798.0		
Exposure: MWd/MTU (GWd)	16300.0 (1640.70)				
Delta E: MWd/MTU, (GWd)	399.0 (40.16)				
Power: MWT	2923.0 (100.00 %)				
Core Pressure: psia	1044.6	N(PRA) Power Exposure			
Inlet Subcooling: Btu/lbm	-22.40	Top 25 0.243	5.571	Zone Avg.	IR JR
Flow: Mlb/hr	73.73 (95.75 %)	24 0.722	16.622	31 0.387	0.522 39 6
		23 0.946	22.143	32 0.767	1.053 11 42
		22 1.085	25.328	33 1.060	1.155 15 36
		21 1.174	27.742	34 1.202	1.353 11 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20 1.213	29.487	35 1.288	1.386 17 36
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR			
3 -- -- -- -- -- -- -- -- -- -- -- --	47				
5 -- -- -- -- -- -- -- -- -- -- -- --	43				
7 -- -- -- -- 10 -- 8 -- -- -- --	39				
9 -- -- -- -- -- -- -- -- -- -- -- --	35				
11 -- -- -- 8 -- -- -- -- -- -- 8 -- -- -- --	31				
13 -- -- -- -- -- -- -- -- -- -- -- --	27				
15 -- -- -- 8 -- -- -- -- -- -- 8 -- -- -- --	23				
17 -- -- -- -- -- -- -- -- -- -- -- --	19				
19 -- -- -- -- 8 -- 10 -- -- -- --	15				
21 -- -- -- -- -- -- -- -- -- -- -- --	11				
23 -- -- -- -- -- -- -- -- -- -- -- --	7				
25 -- -- -- -- -- -- -- -- -- -- -- --	3				
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50					
Control Rod Density: %	4.81				
k-effective:	0.99895	Bottom	1 0.148	7.431	
Void Fraction:	0.419				
Core Delta-P: psia	21.309	% AXIAL TILT	9.393 -11.059		
Core Plate Delta-P: psia	16.783	AVG BOT 8ft/12ft	0.9612 1.0669		
Coolant Temp: Deg-F	547.5				
In Channel Flow: Mlb/hr	64.82	Active Channel Flow: Mlb/hr	62.63		
Total Bypass Flow (%):	12.1	(of total core flow)			
Total Water Rod Flow (%):	3.0	(of total core flow)			
Source Convergence	0.00047				

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.386 35 17 36	1.585	0.877	34	11 38	9.07	0.736	22.5	35	13 40 15	10.31	0.783	26.5	34	11 38	15									
1.384 35 15 38	1.586	0.876	34	37 12	9.02	0.733	22.7	34	11 38 15	10.28	0.778	26.3	34	15 42	15									
1.384 35 19 34	1.701	0.870	33	15 36	9.02	0.732	22.5	34	15 42 15	10.21	0.768	25.6	34	11 40	15									
1.379 35 21 32	1.706	0.868	33	15 40	8.98	0.731	22.7	35	15 38 15	10.21	0.767	25.5	34	13 42	15									
1.378 35 23 34	1.709	0.866	33	17 38	7.12	0.730	42.4	33	15 40 18	7.65	0.753	47.4	33	17 38	18									
1.369 35 13 36	1.715	0.863	33	39 16	7.01	0.728	43.8	33	13 38 18	7.45	0.748	49.3	33	13 38	18									
1.368 35 27 32	1.715	0.863	33	21 34	7.14	0.726	41.7	33	21 38 21	7.69	0.748	46.4	33	15 40	18									
1.367 35 29 30	1.614	0.861	35	29 20	7.01	0.723	43.0	33	17 38 18	7.65	0.743	46.3	33	15 36	18									
1.365 35 17 40	1.616	0.860	35	15 38	7.19	0.721	40.3	33	23 40 21	9.92	0.742	25.0	34	9 38	15									
1.362 35 31 28	1.617	0.860	35	21 22	7.06	0.720	42.0	33	15 36 18	9.86	0.742	25.6	35	13 40	15									

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.45 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 16,300.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	31198.1
Exposure: MWd/MTU (Gwd)	16700.0 (1681.00)	Axial Profile	Edit
Delta E: MWd/MTU, (Gwd)	400.0 (40.26)	N(PRA) Power Exposure	Radial Power
Power: MWT	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.7	24	0.254 5.678 30 0.420 0.518 5 40
Inlet Subcooling: Btu/lbm	-20.68	23	0.756 16.928 31 0.386 0.522 39 6
Flow: Mlb/hr	79.12 (102.75 %)	22	0.992 22.544 32 0.769 1.058 11 42
		21	1.137 25.791 33 1.057 1.153 15 40
		20	1.225 28.243 34 1.210 1.360 37 12
1 3 5 7 9 11 13 15 17 19 21 23 25		19	1.260 30.005 35 1.285 1.383 37 16
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	
3 -- -- -- -- -- -- -- -- -- -- -- --	47		
5 -- -- -- -- -- -- -- -- -- -- -- --	43		
7 -- -- -- -- 10 -- 8 -- -- -- --	39		
9 -- -- -- -- -- -- -- -- -- -- -- --	35		
11 -- -- -- 8 -- -- -- -- -- -- 8 -- -- --	31		
13 -- -- -- -- -- -- -- -- -- -- -- --	27		
15 -- -- -- 8 -- -- -- -- -- -- 8 -- -- --	23		
17 -- -- -- -- -- -- -- -- -- -- -- --	19		
19 -- -- -- -- 8 -- 10 -- -- -- --	15		
21 -- -- -- -- -- -- -- -- -- -- -- --	11		
23 -- -- -- -- -- -- -- -- -- -- -- --	7		
25 -- -- -- -- -- -- -- -- -- -- -- --	3		
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			
Control Rod Density: %	4.81		
k-effective:	0.99907	Bottom	1 0.134 7.491
Void Fraction:	0.401		
Core Delta-P: psia	23.431	% AXIAL TILT	12.567 -10.733
Core Plate Delta-P: psia	18.902	AVG BOT 8ft/12ft	0.9414 1.0652
Coolant Temp: Deg-F	547.6		
In Channel Flow: Mlb/hr	69.73	Active Channel Flow: Mlb/hr	67.43
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00020		

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.383 35 37 16	1.604	0.867	34	37 12	7.35	0.753	42.4	33	21 38 21	10.44	0.798	27.4	34	11 38	15									
1.380 35 17 36	1.605	0.866	34	11 38	7.30	0.753	43.0	33	15 40 18	10.41	0.794	27.2	34	15 42	15									
1.374 35 19 34	1.746	0.848	33	15 40	7.19	0.752	44.4	33	13 38 18	10.36	0.786	26.5	34	11 40	15									
1.368 35 39 18	1.641	0.847	34	11 14	7.43	0.750	41.0	33	23 40 21	10.36	0.785	26.4	34	13 42	15									
1.366 35 39 14	1.750	0.846	33	15 36	9.16	0.749	23.3	35	13 40 15	7.80	0.773	48.1	33	17 38	18									
1.365 35 23 34	1.644	0.846	35	23 38	9.13	0.746	23.4	34	11 38 15	7.88	0.772	47.0	33	15 40	18									
1.365 35 31 32	1.644	0.846	35	35 14	9.13	0.746	23.3	34	15 42 15	7.61	0.772	50.1	33	13 38	18									
1.365 35 17 40	1.644	0.845	34	13 12	9.16	0.742	22.2	35	15 38 17	7.99	0.769	45.4	33	21 38	21									
1.360 34 37 12	1.644	0.845	35	13 36	7.14	0.741	43.6	33	17 38 18	7.80	0.764	47.1	33	17 42	18									
1.359 34 41 16	1.645	0.845	35	21 40	7.19	0.738	42.6	33	15 36 18	7.80	0.764	47.0	33	15 36	18									

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.46 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 16,700.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	31199.1	
Exposure: MWd/MTU (GWd)	16701.0 (1681.10)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	1.0 (0.10)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.239	5.679 30 0.419 0.516 5 40
Core Pressure: psia	1044.6	24	0.707	16.929 31 0.385 0.520 47 40
Inlet Subcooling: Btu/lbm	-23.27	23	0.928	22.545 32 0.766 1.044 11 12
Flow: Mlb/hr	71.22 (92.50 %)	22	1.070	25.793 33 1.057 1.158 15 36
		21	1.164	28.244 34 1.209 1.357 41 16
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.215	30.006 35 1.288 1.393 39 36
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- -- -- -- -- -- -- -- --	43			
7 -- -- -- -- -- 10 -- -- -- -- --	39			
9 -- -- -- -- -- -- -- -- -- -- -- --	35			
11 -- -- -- -- 8 -- -- -- 8 -- -- --	31			
13 -- -- -- -- -- -- -- -- -- -- -- --	27			
15 -- -- -- -- 8 -- -- -- 8 -- -- --	23			
17 -- -- -- -- -- -- -- -- -- -- -- --	19			
19 -- -- -- -- -- 10 -- -- -- -- --	15			
21 -- -- -- -- -- -- -- -- -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	3.59			
k-effective:	0.99914	Bottom	1	0.149 7.491
Void Fraction:	0.424			
Core Delta-P: psia	20.314	% AXIAL TILT	9.450	-10.732
Core Plate Delta-P: psia	15.789	AVG BOT 8ft/12ft	0.9630	1.0652
Coolant Temp: Deg-F	547.4			
In Channel Flow: Mlb/hr	62.57	Active Channel Flow: Mlb/hr	60.43	
Total Bypass Flow (%):	12.2	(of total core flow)		
Total Water Rod Flow (%):	3.0	(of total core flow)		
Source Convergence	0.00048			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR					
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.393 35 39 36	1.677	0.918	33	15 36	9.14	0.743	22.7	34	41 38 15	10.36	0.792	27.4	34	11 38	15			
1.388 35 37 38	1.679	0.917	33	17 38	9.12	0.743	22.9	35	37 38 15	10.31	0.787	27.2	34	15 42	15			
1.388 35 35 40	1.681	0.916	33	15 40	9.12	0.741	22.6	35	39 40 15	10.17	0.771	26.5	34	11 40	15			
1.380 35 33 38	1.683	0.915	33	13 16	9.14	0.740	22.2	35	35 40 15	10.16	0.770	26.4	34	13 42	15			
1.376 35 41 34	1.684	0.914	33	19 40	9.06	0.740	23.3	34	15 42 15	10.12	0.764	26.0	34	45 22	15			
1.374 35 35 36	1.686	0.913	33	13 34	9.13	0.739	22.2	35	39 36 15	7.53	0.760	49.6	33	13 38	17			
1.374 35 39 32	1.700	0.906	33	13 24	7.08	0.737	43.9	33	13 38 17	9.98	0.757	26.6	34	45 30	15			
1.371 35 41 30	1.702	0.905	33	9 30	7.04	0.735	44.2	33	37 40 17	7.63	0.756	48.1	33	17 38	18			
1.365 35 39 28	1.560	0.904	34	11 38	8.99	0.732	22.9	35	41 34 15	7.71	0.755	47.0	33	15 40	18			
1.362 35 33 42	1.563	0.902	34	37 12	7.04	0.731	43.6	33	17 38 18	10.07	0.754	25.1	34	43 38	15			

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.47 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 16,701.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	31698.1	
Exposure: MWd/MTU (Gwd)	17200.0 (1731.30)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (Gwd)	499.0 (50.23)	N(PRA) Power	Exposure	Zone Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.253 5.811	30 0.418 0.515 5 40
Core Pressure: psia	1044.7	24	0.752 17.302	31 0.384 0.520 47 40
Inlet Subcooling: Btu/lbm	-20.51	23	0.987 23.035	32 0.768 1.052 41 12
Flow: Mlb/hr	79.69 (103.50 %)	22	1.137 26.362	33 1.054 1.156 35 38
		21	1.230 28.864	34 1.218 1.366 41 16
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.274 30.653	35 1.285 1.395 39 36
1	-- -- -- -- --	51	:JR	
3	-- -- -- -- --	47		19 1.294 32.166
5	-- -- -- -- --	43		18 1.309 33.208
7	-- -- -- -- 10	39		17 1.297 33.480
9	-- -- -- -- --	35		16 1.333* 34.047
11	-- -- -- 8	31		15 1.321 35.141
13	-- -- -- -- --	27		14 1.272 35.737
15	-- -- -- 8	23		13 1.285 35.272
17	-- -- -- -- --	19		12 1.252 36.058
19	-- -- -- -- 10	15		11 1.207 36.530
21	-- -- -- -- --	11		10 1.161 37.002
23	-- -- -- -- --	7		9 1.115 38.004
25	-- -- -- -- --	3		8 1.044 38.544
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				7 0.955 38.612
				6 0.874 39.511
				5 0.772 39.956*
				4 0.673 38.812
Control Rod Density: %	3.59			3 0.595 35.802
				2 0.477 27.400
k-effective:	0.99950	Bottom	1	0.131 7.567
Void Fraction:	0.396			
Core Delta-P: psia	23.650	% AXIAL TILT	13.505 -10.336	
Core Plate Delta-P: psia	19.120	AVG BOT 8ft/12ft	0.9375 1.0631	
Coolant Temp: Deg-F	547.5			
In Channel Flow: Mlb/hr	70.27	Active Channel Flow: Mlb/hr	67.96	
Total Bypass Flow (%):	11.8	(of total core flow)		
Total Water Rod Flow (%):	2.9	(of total core flow)		
Source Convergence	0.00045			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.395 35 39 36	1.750	0.880	33	15 40	7.29	0.765	44.7	33	37 40 18	10.59	0.812	27.6	34	41 38	15									
1.389 35 37 38	1.603	0.880	34	11 38	7.25	0.764	45.1	33	13 38 18	10.55	0.809	27.7	34	37 42	15									
1.388 35 35 40	1.751	0.879	33	39 16	9.31	0.763	23.7	34	41 38 15	10.47	0.796	26.8	34	41 40	15									
1.380 35 41 34	1.603	0.879	34	37 12	9.27	0.760	23.6	35	39 40 15	10.44	0.794	26.8	34	39 42	15									
1.376 35 33 38	1.755	0.878	33	35 38	9.25	0.758	23.7	34	37 42 15	10.35	0.789	27.0	34	45 22	15									
1.374 35 39 32	1.756	0.877	33	15 36	9.22	0.757	23.8	35	37 38 15	7.70	0.789	51.0	33	13 38	18									
1.372 35 41 30	1.761	0.875	33	11 36	7.22	0.755	44.3	33	35 38 18	7.94	0.786	47.9	33	15 40	18									
1.371 35 35 36	1.764	0.873	33	19 40	9.24	0.754	23.2	35	35 40 15	7.91	0.785	48.2	33	35 42	18									
1.366 34 41 16	1.765	0.873	33	39 34	7.35	0.754	42.6	33	11 36 18	7.82	0.783	48.9	33	17 38	18									
1.366 35 39 40	1.623	0.869	35	37 38	9.24	0.754	23.1	35	39 36 15	10.34	0.782	26.2	34	43 38	15									

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.48 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 17,200.0 MWd/MTU

Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain

Cycle:	19	Core Average Exposure: MWD/MTU	31699.0	
Exposure: MWD/MTU (GWD)	17201.0 (1731.40)	Axial Profile	Edit	Radial Power
Delta E: MWD/MTU, (GWD)	1.0 (0.10)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.255	5.811 30 0.416 0.512 5 40
Core Pressure: psia	1044.6	24	0.758	17.303 31 0.382 0.517 47 40
Inlet Subcooling: Btu/lbm	-21.56	23	0.996	23.036 32 0.763 1.043 41 12
Flow: Mlb/hr	76.23 (99.00 %)	22	1.151	26.363 33 1.059 1.155 37 36
		21	1.254	28.865 34 1.208 1.356 41 16
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.311	30.654 35 1.291 1.389 39 36
1 -- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- -- -- -- -- -- -- -- -- -- --	43			
7 -- -- -- -- -- -- 12 -- -- -- -- -- --	39			
9 -- -- -- -- -- -- -- -- -- -- -- -- -- --	35			
11 -- -- -- -- 10 -- -- -- -- -- -- -- --	31			
13 -- -- -- -- -- -- -- -- -- -- -- -- -- --	27			
15 -- -- -- -- 10 -- -- -- -- -- -- -- --	23			
17 -- -- -- -- -- -- -- -- -- -- -- -- -- --	19			
19 -- -- -- -- -- -- 12 -- -- -- -- -- --	15			
21 -- -- -- -- -- -- -- -- -- -- -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	3.41			
k-effective:	0.99950	Bottom	1	0.130 7.567
Void Fraction:	0.401			
Core Delta-P: psia	22.163	% AXIAL TILT	14.555 -10.335	
Core Plate Delta-P: psia	17.635	AVG BOT 8ft/12ft	0.9286 1.0631	
Coolant Temp: Deg-F	547.4			
In Channel Flow: Mlb/hr	67.15	Active Channel Flow: Mlb/hr	64.92	
Total Bypass Flow (%):	11.9	(of total core flow)		
Total Water Rod Flow (%):	2.9	(of total core flow)		
Source Convergence	0.00046			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.389 35 39 36	1.713	0.899	33	15 36	7.71	0.800	43.5	33	27 38 20	8.14	0.819	49.4	33	27 38	20									
1.383 35 37 38	1.716	0.898	33	35 38	9.91	0.791	20.5	35	27 40 20	10.49	0.804	27.6	34	41 38	15									
1.383 35 35 40	1.718	0.896	33	15 40	7.70	0.768	39.8	33	19 22 21	10.45	0.801	27.7	34	37 42	15									
1.376 35 33 38	1.720	0.895	33	39 16	7.30	0.766	44.7	33	37 40 18	10.82	0.797	23.2	35	27 40	20									
1.374 35 39 32	1.722	0.894	33	19 40	7.26	0.765	45.1	33	13 38 18	7.74	0.791	50.7	33	13 38	18									
1.373 35 35 36	1.722	0.894	33	39 34	7.41	0.764	43.1	33	17 24 21	7.89	0.790	48.9	33	17 38	18									
1.372 35 41 34	1.730	0.890	33	39 30	7.30	0.764	44.3	33	35 38 18	7.97	0.788	47.9	33	15 40	18									
1.368 35 41 30	1.734	0.888	33	11 36	7.27	0.762	44.6	33	33 40 18	7.94	0.787	48.2	33	35 42	18									
1.366 35 39 28	1.588	0.888	34	11 38	7.33	0.759	43.4	33	15 36 18	10.35	0.787	26.8	34	41 40	15									
1.358 35 31 40	1.588	0.888	34	37 12	7.28	0.758	43.9	33	39 34 18	8.33	0.787	43.7	33	19 22	21									

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.49 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 17,201.0 MWD/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	31948.0	
Exposure: MWd/MTU (Gwd)	17450.0 (1756.50)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (Gwd)	249.0 (25.06)	N(PRA) Power Exposure.	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.263 5.881	30 0.415 0.511 5 40
Core Pressure: psia	1044.7	24	0.782 17.503	31 0.382 0.517 47 40
Inlet Subcooling: Btu/lbm	-20.33	23	1.027 23.299	32 0.764 1.047 41 12
Flow: Mlb/hr	80.31 (104.30 %)	22	1.186 26.669	33 1.057 1.155 37 36
		21	1.287 29.198	34 1.214 1.361 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.341 31.002	35 1.288 1.390 39 36
1 --- --- --- --- --- ---	51	:JR		
3 --- --- --- --- --- ---	47		19 1.350*	32.519
5 --- --- --- --- --- ---	43		18 1.346	33.561
7 --- --- --- --- 12 --- --- ---	39		17 1.318	33.828
9 --- --- --- --- --- ---	35		16 1.343	34.383
11 --- --- --- 10 --- --- ---	31		15 1.321	35.472
13 --- --- --- --- --- ---	27		14 1.266	36.056
15 --- --- --- 10 --- --- ---	23		13 1.276	35.574
17 --- --- --- --- --- ---	19		12 1.238	36.352
19 --- --- --- 12 --- --- ---	15		11 1.190	36.813
21 --- --- --- --- --- ---	11		10 1.139	37.274
23 --- --- --- --- --- ---	7		9 1.088	38.265
25 --- --- --- --- ---	3		8 1.012	38.789
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 0.919	38.836
			6 0.833	39.716
			5 0.729	40.138*
			4 0.629	38.971
Control Rod Density: %	3.41		3 0.554	35.943
			2 0.443	27.513
k-effective:	0.99963	Bottom 1	0.122	7.600
Void Fraction:	0.388			
Core Delta-P: psia	23.802	% AXIAL TILT	16.579	-10.102
Core Plate Delta-P: psia	19.272	AVG BOT 8ft/12ft	0.9157	1.0618
Coolant Temp: Deg-F	547.5			
In Channel Flow: Mlb/hr	70.87	Active Channel Flow: Mlb/hr		68.56
Total Bypass Flow (%):	11.8	(of total core flow)		
Total Water Rod Flow (%):	2.9	(of total core flow)		
Source Convergence	0.00043			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR					
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.390 35 39 36	1.739	0.886	33	35 38	7.80	0.813	44.0	33	27 38 20	8.24	0.833	49.8	33	27 38	20			
1.384 35 37 38	1.741	0.885	33	37 36	10.06	0.807	21.0	35	27 40 20	10.58	0.815	28.2	34	41 38	15			
1.383 35 35 40	1.749	0.880	33	39 16	7.42	0.782	45.1	33	37 40 18	10.98	0.812	23.8	35	27 40	20			
1.374 35 41 34	1.601	0.880	34	37 12	7.79	0.780	40.2	33	19 22 21	10.54	0.812	28.2	34	37 42	15			
1.374 35 33 38	1.750	0.880	33	15 40	7.37	0.780	45.5	33	13 38 18	7.83	0.806	51.4	33	13 38	18			
1.374 35 39 32	1.603	0.880	34	11 38	7.51	0.778	43.5	33	17 24 21	7.93	0.804	50.0	33	37 40	18			
1.371 35 35 36	1.752	0.879	33	11 36	7.39	0.776	44.7	33	35 38 18	8.06	0.803	48.6	33	35 42	18			
1.369 35 41 30	1.755	0.878	33	19 14	7.36	0.774	45.0	33	33 40 18	7.98	0.802	49.3	33	17 38	18			
1.366 35 39 28	1.756	0.877	33	39 34	7.38	0.771	44.3	33	39 34 18	8.43	0.801	44.2	33	19 22	21			
1.361 34 41 38	1.614	0.874	35	35 32	7.40	0.771	44.0	33	37 36 18	10.46	0.800	27.4	34	41 40	15			

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.50 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 17,450.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWD/MTU	31949.1	
Exposure: MWD/MTU (GWD)	17451.0 (1756.60)	Axial Profile	Edit	Radial Power
Delta E: MWD/MTU, (GWD)	1.0 (0.10)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.247	5.882 30 0.407 0.499 5 40
Core Pressure: psia	1044.6	24	0.731	17.503 31 0.374 0.505 39 48
Inlet Subcooling: Btu/lbm	-22.41	23	0.961	23.300 32 0.749 1.021 41 12
Flow: Mlb/hr	73.65 (95.65 %)	22	1.115	26.670 33 1.067 1.162 31 38
		21	1.221	29.199 34 1.190 1.332 37 42
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.288	31.004 35 1.307 1.412 29 38
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47		19	1.320 32.521
5 -- -- -- -- -- -- -- -- -- -- -- --	43		18	1.325 33.563
7 -- -- -- -- -- -- -- -- -- -- -- --	39		17	1.305 33.829
9 -- -- -- -- -- -- -- -- -- -- -- --	35		16	1.336* 34.385
11 -- -- -- -- 12 -- -- -- -- -- --	31		15	1.319 35.474
13 -- -- -- -- -- -- -- -- -- -- -- --	27		14	1.268 36.057
15 -- -- -- -- 12 -- -- -- -- -- --	23		13	1.281 35.575
17 -- -- -- -- -- -- -- -- -- -- -- --	19		12	1.246 36.353
19 -- -- -- -- -- -- -- -- -- -- -- --	15		11	1.201 36.815
21 -- -- -- -- -- -- -- -- -- -- -- --	11		10	1.153 37.275
23 -- -- -- -- -- -- -- -- -- -- -- --	7		9	1.106 38.266
25 -- -- -- -- -- -- -- -- -- -- -- --	3		8	1.038 38.790
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7	0.953 38.837
Control Rod Density: %	2.19		6	0.877 39.717
k-effective:	0.99972		5	0.781 40.139*
Void Fraction:	0.408		4	0.687 38.971
Core Delta-P: psia	21.171	Bottom	1	0.612 35.943
Core Plate Delta-P: psia	16.646		2	0.494 27.513
Coolant Temp: Deg-F	547.3			
In Channel Flow: Mlb/hr	64.80	Active Channel Flow: Mlb/hr		
Total Bypass Flow (%):	12.0	(of total core flow)		
Total Water Rod Flow (%):	3.0	(of total core flow)		
Source Convergence	0.00048			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR												APLHGR												LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K													
1.412 35 29 38	1.693	0.909	33	29 40	7.52	0.790	44.8	33	35 30 20	8.03	0.814	50.0	33	35	30	20																				
1.403 35 31 40	1.694	0.909	33	19 40	7.68	0.785	42.1	33	19 22 20	8.27	0.805	46.4	33	19	22	20																				
1.402 35 27 40	1.555	0.907	35	29 38	9.62	0.779	22.2	35	17 32 20	10.27	0.791	28.2	34	37	42	15																				
1.387 35 33 38	1.698	0.907	33	31 38	9.57	0.776	22.4	35	33 30 20	10.25	0.789	28.2	34	41	38	15																				
1.384 35 27 36	1.702	0.905	33	23 18	7.26	0.758	44.2	33	31 38 18	7.60	0.781	51.2	33	13	38	18																				
1.383 35 31 36	1.704	0.904	33	25 38	7.21	0.757	44.7	33	35 38 18	10.50	0.781	24.3	35	35	22	20																				
1.372 35 35 40	1.709	0.901	33	33 36	7.23	0.756	44.3	33	39 34 18	10.43	0.780	25.0	35	19	30	20																				
1.372 35 29 42	1.715	0.898	33	15 36	7.25	0.755	44.0	33	37 36 18	7.76	0.780	49.3	33	17	38	18																				
1.366 35 35 36	1.716	0.898	33	35 38	7.17	0.755	45.1	33	37 40 18	7.75	0.777	49.1	33	37	36	18																				
1.363 35 37 38	1.577	0.894	35	27 14	7.17	0.755	45.0	33	33 40 18	7.67	0.777	50.0	33	37	40	18																				

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.51 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 17,451.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	32248.1
Exposure: MWd/MTU (Gwd)	17750.0 (1786.70)	Axial Profile	Edit
Delta E: MWd/MTU, (Gwd)	299.0 (30.10)	N(PRA) Power Exposure	Radial Power
Power: MWT	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.7	24	0.256 5.963 30 0.406 0.498 5 40
Inlet Subcooling: Btu/lbm	-20.46	23	0.760 17.735 31 0.373 0.505 47 40
Flow: Mlb/hr	79.89 (103.75 %)	22	0.999 23.604 32 0.750 1.027 41 42
		21	1.157 27.026 33 1.065 1.158 31 38
		20	1.261 29.588 34 1.197 1.338 37 42
1 3 5 7 9 11 13 15 17 19 21 23 25		19	1.322 31.414 35 1.304 1.405 29 38
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	
3 -- -- -- -- -- -- -- -- -- -- -- --	47		
5 -- -- -- -- -- -- -- -- -- -- -- --	43		
7 -- -- -- -- -- -- -- -- -- -- -- --	39		
9 -- -- -- -- -- -- -- -- -- -- -- --	35		
11 -- -- -- -- 12 -- -- -- -- -- --	31		
13 -- -- -- -- -- -- -- -- -- -- -- --	27		
15 -- -- -- -- 12 -- -- -- -- -- --	23		
17 -- -- -- -- -- -- -- -- -- -- -- --	19		
19 -- -- -- -- -- -- -- -- -- -- -- --	15		
21 -- -- -- -- -- -- -- -- -- -- -- --	11		
23 -- -- -- -- -- -- -- -- -- -- -- --	7		
25 -- -- -- -- -- -- -- -- -- -- -- --	3		
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			
Control Rod Density: %	2.19		
k-effective:	0.99976	Bottom	1 0.127 7.641
Void Fraction:	0.390		
Core Delta-P: psia	23.674	% AXIAL TILT	15.592 -9.838
Core Plate Delta-P: psia	19.145	AVG BOT 8ft/12ft	0.9235 1.0604
Coolant Temp: Deg-F	547.5		
In Channel Flow: Mlb/hr	70.47	Active Channel Flow: Mlb/hr	68.17
Total Bypass Flow (%):	11.8	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00027		

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.405 35 29 38	1.605	0.878	35	29 38	7.61	0.804	45.3	33	35 30 20	8.15	0.831	50.5	33	35	30	20								
1.399 35 31 40	1.755	0.878	33	19 40	7.65	0.797	43.9	33	33 32 20	8.36	0.818	46.9	33	19	22	20								
1.397 35 27 40	1.757	0.877	33	31 38	9.76	0.792	22.5	35	35 32 20	10.36	0.803	28.8	34	37	42	15								
1.383 35 33 38	1.760	0.875	33	29 40	9.67	0.788	23.0	35	33 30 20	10.47	0.803	27.7	34	11	38	17								
1.376 35 31 36	1.762	0.874	33	35 38	7.30	0.773	45.5	33	37 40 18	7.71	0.798	51.9	33	13	38	18								
1.375 35 27 36	1.614	0.874	35	35 32	7.27	0.771	45.8	33	39 38 18	10.66	0.796	24.8	35	17	32	20								
1.373 35 35 40	1.764	0.873	33	37 36	7.34	0.771	44.7	33	39 34 18	7.81	0.795	50.5	33	37	40	18								
1.369 35 29 42	1.773	0.868	33	33 36	7.31	0.771	45.2	33	35 38 18	7.87	0.795	49.7	33	35	38	18								
1.364 35 39 36	1.773	0.868	33	25 38	7.34	0.769	44.5	33	37 36 18	7.93	0.795	49.1	33	41	36	18								
1.364 35 37 38	1.774	0.868	33	23 18	7.27	0.769	45.5	33	33 40 18	7.92	0.794	49.1	33	35	42	18								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.52 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 17,750.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWD/MTU	32249.1	
Exposure: MWD/MTU (Gwd)	17751.0 (1786.80)	Axial Profile	Edit	Radial Power
Delta E: MWD/MTU, (Gwd)	1.0 (0.10)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.240	5.964 30 0.398 0.490 5 14
Core Pressure: psia	1044.6	24	0.710	17.736 31 0.366 0.497 47 40
Inlet Subcooling: Btu/lbm	-22.19	23	0.935	23.605 32 0.735 1.009 41 42
Flow: Mlb/hr	74.31 (96.50 %)	22	1.087	27.027 33 1.075 1.171 37 32
		21	1.192	29.590 34 1.173 1.322 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.261	31.416 35 1.322 1.411 35 36
1	-- -- -- -- -- -- -- -- -- --	47	1.302	32.943
3	-- -- -- -- -- -- -- -- -- --	43	1.325	33.987
5	-- -- -- -- -- -- -- -- -- --	39	1.309	34.247
7	-- -- -- -- -- -- -- -- -- --	35	1.342*	34.789
9	-- -- -- -- -- -- -- -- -- --	31	1.327	35.873
11	-- -- -- -- 14 -- -- -- -- -- --	27	1.279	36.441
13	-- -- -- -- -- -- -- -- -- --	23	1.295	35.941
15	-- -- -- -- -- -- -- -- -- --	19	1.261	36.709
17	-- -- -- -- -- -- -- -- -- --	15	1.215	37.157
19	-- -- -- -- -- -- -- -- -- --	11	1.165	37.604
21	-- -- -- -- -- -- -- -- -- --	7	1.115	38.581
23	-- -- -- -- -- -- -- -- -- --	3	1.046	39.086
25	-- -- -- -- -- -- -- -- -- --		0.960	39.109
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			0.884	39.967
			0.789	40.361*
			0.695	39.167
Control Rod Density: %	1.03		0.622	36.118
			0.503	27.654
k-effective:	0.99988	Bottom 1	0.140	7.642
Void Fraction:	0.408			
Core Delta-P: psia	21.486	% AXIAL TILT	12.297	-9.837
Core Plate Delta-P: psia	16.960	AVG BOT 8ft/12ft	0.9474	1.0604
Coolant Temp: Deg-F	547.3			
In Channel Flow: Mlb/hr	65.37	Active Channel Flow: Mlb/hr	63.17	
Total Bypass Flow (%):	12.0	(of total core flow)		
Total Water Rod Flow (%):	3.0	(of total core flow)		
Source Convergence	0.00048			

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR				APLHGR						LHGR								
Value	FT	IR JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.411	35	35 36	1.690	0.911	33	33	36	7.54	0.803	46.1	33	35	24	19	8.07	0.824	50.6	33	35	24	19
1.410	35	31 36	1.695	0.908	33	37	32	7.66	0.800	44.4	33	33	22	19	8.11	0.817	49.5	33	19	32	19
1.407	35	33 34	1.707	0.902	33	37	36	9.64	0.786	23.0	35	17	32	19	7.81	0.792	50.1	33	37	22	19
1.405	35	37 34	1.709	0.901	33	39	30	9.44	0.771	23.2	35	33	24	19	10.22	0.792	28.8	34	41	38	15
1.403	35	29 38	1.568	0.899	35	35	36	9.36	0.762	22.9	35	35	36	15	7.73	0.789	50.7	33	35	20	19
1.401	35	35 32	1.713	0.899	33	31	38	7.27	0.759	44.2	33	15	32	19	10.53	0.788	25.1	35	35	22	19
1.400	35	37 30	1.717	0.897	33	17	20	9.26	0.758	23.5	35	37	34	15	10.16	0.787	28.8	34	37	42	15
1.399	35	39 32	1.719	0.896	33	39	34	9.25	0.758	23.5	35	33	38	15	7.52	0.777	51.7	33	13	38	18
1.395	35	33 38	1.721	0.895	33	35	38	7.21	0.757	44.7	33	39	34	18	7.51	0.776	51.6	33	39	20	18
1.389	35	31 40	1.578	0.894	35	37	30	7.21	0.755	44.5	33	37	36	18	7.67	0.775	49.8	33	17	38	18

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.53 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 17,751.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	32523.1	
Exposure: MWd/MTU (GWd)	18025.0 (1814.40)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	274.0 (27.58)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.249 6.036	30 0.398 0.489 5 14
Core Pressure: psia	1044.7	24	0.739 17.942	31 0.365 0.498 47 40
Inlet Subcooling: Btu/lbm	-20.40	23	0.972 23.876	32 0.737 1.014 41 42
Flow: Mlb/hr	80.08 (104.00 %)	22	1.128 27.345	33 1.073 1.167 37 32
		21	1.231 29.938	34 1.179 1.328 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.295 31.784	35 1.319 1.406 35 36
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47		19 1.330 33.323	
5 -- -- -- -- -- -- -- -- -- -- -- --	43		18 1.346 34.374	
7 -- -- -- -- -- -- -- -- -- -- -- --	39		17 1.323 34.629	
9 -- -- -- -- -- -- -- -- -- -- -- --	35		16 1.352* 35.160	
11 -- -- -- -- 14 -- -- -- -- -- --	31		15 1.334 36.239	
13 -- -- -- -- -- -- -- -- -- -- -- --	27		14 1.283 36.794	
15 -- -- -- -- -- -- -- -- -- -- -- --	23		13 1.299 36.278	
17 -- -- -- -- -- -- -- -- -- -- -- --	19		12 1.263 37.037	
19 -- -- -- -- -- -- -- -- -- -- -- --	15		11 1.212 37.474	
21 -- -- -- -- -- -- -- -- -- -- -- --	11		10 1.158 37.907	
23 -- -- -- -- -- -- -- -- -- -- -- --	7		9 1.105 38.872	
25 -- -- -- -- -- -- -- -- -- -- -- --	3		8 1.027 39.358	
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 0.933 39.359	
			6 0.849 40.198	
			5 0.748 40.567*	
			4 0.651 39.348	
Control Rod Density: %	1.03		3 0.577 36.280	
			2 0.466 27.785	
k-effective:	1.00000	Bottom	1 0.129 7.680	
Void Fraction:	0.391			
Core Delta-P: psia	23.810	% AXIAL TILT	14.605 -9.608	
Core Plate Delta-P: psia	19.281	AVG BOT 8ft/12ft	0.9326 1.0592	
Coolant Temp: Deg-F	547.5			
In Channel Flow: Mlb/hr	70.62	Active Channel Flow: Mlb/hr	68.31	
Total Bypass Flow (%):	11.8	(of total core flow)		
Total Water Rod Flow (%):	2.9	(of total core flow)		
Source Convergence	0.00044			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.406 35 35 36	1.751	0.879	33	33 36	7.60	0.814	46.6	33	35 24 19	8.16	0.837	51.1	33	35 24	19									
1.403 35 31 36	1.753	0.878	33	37 32	7.71	0.810	44.8	33	33 22 19	8.31	0.828	48.5	33	33 22	19									
1.402 35 37 34	1.610	0.876	35	35 36	9.75	0.796	23.2	35	35 22 19	7.90	0.806	50.6	33	37 22	19									
1.400 35 33 34	1.761	0.875	33	37 36	9.50	0.779	23.8	35	33 24 19	10.32	0.804	29.4	34	41 38	15									
1.397 35 39 32	1.766	0.872	33	39 30	7.36	0.772	44.7	33	15 32 19	7.82	0.803	51.2	33	35 20	19									
1.397 35 29 38	1.620	0.870	35	37 30	7.32	0.772	45.2	33	39 34 18	10.67	0.801	25.4	35	35 22	19									
1.395 35 37 30	1.771	0.869	33	39 34	7.31	0.769	45.0	33	37 36 18	10.26	0.800	29.4	34	37 42	15									
1.394 35 35 32	1.772	0.869	33	31 38	9.39	0.768	23.5	35	35 36 15	7.62	0.794	52.3	33	13 38	18									
1.391 35 33 38	1.774	0.868	33	35 38	7.27	0.768	45.2	33	17 34 19	7.62	0.791	52.1	33	39 20	18									
1.385 35 31 40	1.626	0.867	35	39 32	7.30	0.766	44.7	33	39 30 18	7.78	0.790	50.3	33	17 38	18									

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.54 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,025.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: Mwd/MTU	32524.0
Exposure: Mwd/MTU (Gwd)	18026.0 (1814.50)	Axial Profile	Edit
Delta E: Mwd/MTU, (Gwd)	1.0 (0.10)	N(PRA) Power Exposure	Radial Power
Power: Mwt	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.6	24	0.693 17.942 31 0.359 0.488 47 40
Inlet Subcooling: Btu/lbm	-21.68	23	0.911 23.877 32 0.724 0.994 41 42
Flow: Mlb/hr	75.85 (98.50 %)	22	1.060 27.346 33 1.081 1.161 37 32
		21	1.161 29.939 34 1.160 1.302 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.229 31.786 35 1.335 1.403 37 30
1 --- --- --- --- --- --- --- --- --- ---	51	:JR	
3 --- --- --- --- --- --- --- --- --- ---	47		
5 --- --- --- --- --- --- --- --- --- ---	43		
7 --- --- --- --- --- --- --- --- --- ---	39		
9 --- --- --- --- --- --- --- --- --- ---	35		
11 --- --- --- --- --- --- --- --- --- ---	31		
13 --- --- --- --- --- --- --- --- --- ---	27		
15 --- --- --- --- --- --- --- --- --- ---	23		
17 --- --- --- --- --- --- --- --- --- ---	19		
19 --- --- --- --- --- --- --- --- --- ---	15		
21 --- --- --- --- --- --- --- --- --- ---	11		
23 --- --- --- --- --- --- --- --- --- ---	7		
25 --- --- --- --- --- --- --- --- --- ---	3		
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			
Control Rod Density: %	0.00		
k-effective:	0.99998	Bottom 1	0.144 7.681
Void Fraction:	0.408		
Core Delta-F: psia	22.182	% AXIAL TILT	10.710 -9.607
Core Plate Delta-P: psia	17.656	AVG BOT 8ft/12ft	0.9598 1.0592
Coolant Temp: Deg-F	547.4		
In Channel Flow: Mlb/hr	66.74	Active Channel Flow: Mlb/hr	64.50
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00039		

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR			APLHGR						LHGR			
Value	FT	IR JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.403	35	37 30	1.736	0.887	33	37	26		9.20	0.753	23.5	35	35	36	15
1.392	35	35 32	1.740	0.885	33	37	32		9.22	0.751	23.0	35	37	30	15
1.391	35	39 28	1.745	0.883	33	39	30		9.13	0.750	24.0	35	37	34	15
1.389	35	33 34	1.750	0.880	33	33	36		9.16	0.749	23.4	35	35	32	15
1.388	35	31 36	1.602	0.880	35	37	30		9.15	0.749	23.4	35	39	32	15
1.387	35	35 36	1.762	0.874	33	37	18		9.08	0.747	24.1	35	33	38	15
1.386	35	37 34	1.615	0.873	35	35	36		9.13	0.746	23.3	35	33	34	15
1.386	35	39 32	1.766	0.872	33	35	20		7.06	0.745	45.2	33	39	34	18
1.380	35	29 38	1.618	0.872	35	35	22		9.13	0.745	23.0	35	31	36	15
1.379	35	35 28	1.770	0.870	33	39	34		9.09	0.744	23.5	35	39	28	15

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.55 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,026.0 Mwd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	32723.2	
Exposure: MWd/MTU (GWd)	18225.0 (1834.50)			
Delta E: MWd/MTU, (GWd)	199.0 (20.03)			
Power: MWT	2923.0 (100.00 %)	Axial Profile	Edit	Radial Power
Core Pressure: psia	1044.7	N(PRA) Power	Exposure	Zone Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-20.29	Top 25	0.240 6.088	30 0.391 0.481 5 40
Flow: Mlb/hr	80.46 (104.50 %)	24	0.714 18.088	31 0.359 0.488 47 40
		23	0.939 24.069	32 0.726 0.998 41 42
		22	1.091 27.571	33 1.080 1.159 37 32
		21	1.190 30.186	34 1.165 1.307 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.254 32.046	35 1.332 1.399 37 30
1 --- --- --- --- --- --- ---	51	:JR		
3 --- --- --- --- --- --- ---	47			
5 --- --- --- --- --- --- ---	43			
7 --- --- --- --- --- --- ---	39			
9 --- --- --- --- --- --- ---	35			
11 --- --- --- --- --- --- ---	31			
13 --- --- --- --- --- --- ---	27			
15 --- --- --- --- --- --- ---	23			
17 --- --- --- --- --- --- ---	19			
19 --- --- --- --- --- --- ---	15			
21 --- --- --- --- --- --- ---	11			
23 --- --- --- --- --- --- ---	7			
25 --- --- --- --- --- --- ---	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	0.00			
k-effective:	1.00008	Bottom	1 0.136	7.710
Void Fraction:	0.395			
Core Delta-P: psia	24.068	% AXIAL TILT	12.424 -9.454	
Core Plate Delta-P: psia	19.539	AVG BOT 8ft/12ft	0.9488 1.0584	
Coolant Temp: Deg-F	547.5			
In Channel Flow: Mlb/hr	70.94	Active Channel Flow: Mlb/hr	68.61	
Total Bypass Flow (%):	11.8	(of total core flow)		
Total Water Rod Flow (%):	2.9	(of total core flow)		
Source Convergence	0.00046			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.399 35 37 30	1.784	0.863	33	37 26	9.22	0.757	23.8	35	35 36 15	10.13	0.793	29.8	34	41	38	15								
1.389 35 39 28	1.637	0.862	35	37 30	7.15	0.756	45.5	33	39 34 18	10.06	0.787	29.8	34	37	42	15								
1.388 35 35 22	1.788	0.861	33	37 32	9.23	0.755	23.3	35	37 30 15	7.68	0.777	49.9	33	41	36	18								
1.384 35 39 32	1.791	0.860	33	39 30	9.15	0.755	24.4	35	37 34 15	7.44	0.776	52.4	33	13	38	18								
1.384 35 35 36	1.798	0.856	33	33 36	7.14	0.754	45.3	33	37 36 18	7.60	0.775	50.5	33	35	38	18								
1.384 35 33 34	1.647	0.856	35	35 36	9.18	0.753	23.8	35	39 32 15	7.53	0.774	51.2	33	37	40	18								
1.383 35 37 34	1.805	0.853	33	37 36	9.17	0.752	23.8	35	35 32 15	7.42	0.773	52.4	33	39	20	18								
1.383 35 31 36	1.654	0.853	35	39 28	7.05	0.752	46.3	33	37 40 18	7.53	0.773	51.1	33	41	32	18								
1.376 35 29 38	1.654	0.852	35	35 22	7.03	0.752	46.5	33	39 38 18	9.95	0.773	29.0	34	41	40	15								
1.373 35 35 28	1.656	0.852	35	37 20	9.10	0.751	24.4	35	33 38 15	7.59	0.773	50.4	33	37	36	18								

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.56 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,225.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	32724.2
Exposure: MWd/MTU (GWd)	18226.0 (1834.60)	Axial Profile	Edit
Delta E: MWd/MTU, (GWd)	1.0 (0.10)	N(PRA) Power Exposure	Radial Power
Power: MWT	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.3	24	0.700 18.089 31 0.360 0.489 47 40
Inlet Subcooling: Btu/lbm	-24.32	23	0.920 24.070 32 0.730 1.000 41 42
Flow: Mlb/hr	77.00 (100.00 %)	22	1.069 27.572 33 1.079 1.155 37 32
		21	1.168 30.187 34 1.166 1.305 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.232 32.048 35 1.329 1.394 37 30
1 -- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	
3 -- -- -- -- -- -- -- -- -- -- -- -- -- --	47		1.269 33.596
5 -- -- -- -- -- -- -- -- -- -- -- -- -- --	43		1.294 34.652
7 -- -- -- -- -- -- -- -- -- -- -- -- -- --	39		1.289 34.907
9 -- -- -- -- -- -- -- -- -- -- -- -- -- --	35		1.331* 35.431
11 -- -- -- -- -- -- -- -- -- -- -- -- -- --	31		1.325 36.509
13 -- -- -- -- -- -- -- -- -- -- -- -- -- --	27		1.286 37.056
15 -- -- -- -- -- -- -- -- -- -- -- -- -- --	23		1.312 36.529
17 -- -- -- -- -- -- -- -- -- -- -- -- -- --	19		1.284 37.282
19 -- -- -- -- -- -- -- -- -- -- -- -- -- --	15		1.241 37.710
21 -- -- -- -- -- -- -- -- -- -- -- -- -- --	11		1.193 38.133
23 -- -- -- -- -- -- -- -- -- -- -- -- -- --	7		1.144 39.088
25 -- -- -- -- -- -- -- -- -- -- -- -- -- --	3		1.071 39.561
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			0.981 39.546
			0.899 40.369
			0.797 40.720*
			0.697 39.484
Control Rod Density: %	0.00		3 0.620 36.401
			2 0.502 27.884
k-effective:	1.00007	Bottom	1 0.140 7.710
Void Fraction:	0.392		
Core Delta-P: psia	22.395	% AXIAL TILT	10.762 -9.453
Core Plate Delta-P: psia	17.857	AVG BOT 8ft/12ft	0.9584 1.0584
Coolant Temp: Deg-F	546.8		
In Channel Flow: Mlb/hr	67.87	Active Channel Flow: Mlb/hr	65.64
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00046		

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR												APIHGR												LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K													
1.394 35 37 30	1.770	0.870	33	37 26	9.09	0.746	23.8	35	35 36 15	9.99	0.782	29.8	34	41	38	15																				
1.384 35 39 28	1.774	0.868	33	37 32	9.02	0.744	24.4	35	37 34 15	9.93	0.777	29.9	34	37	42	15																				
1.383 35 35 22	1.778	0.866	33	39 30	9.10	0.744	23.3	35	37 30 15	7.54	0.763	49.9	33	41	36	18																				
1.380 35 39 32	1.633	0.863	35	37 30	7.02	0.743	45.5	33	39 34 18	9.83	0.763	29.0	34	41	40	15																				
1.380 35 35 36	1.785	0.863	33	33 36	9.05	0.743	23.8	35	39 32 15	7.31	0.763	52.4	33	13	38	18																				
1.379 35 33 34	1.792	0.859	33	37 18	9.04	0.741	23.8	35	35 32 15	7.46	0.761	50.5	33	35	38	18																				
1.379 35 37 34	1.644	0.858	35	35 36	8.98	0.741	24.4	35	33 38 15	9.80	0.761	29.0	34	39	42	15																				
1.379 35 31 36	1.799	0.856	33	39 34	7.01	0.740	45.3	33	37 36 18	7.40	0.760	51.2	33	37	40	18																				
1.371 35 29 38	1.802	0.854	33	35 20	8.85	0.739	25.8	35	37 38 15	7.40	0.759	51.1	33	41	32	18																				
1.368 35 35 28	1.650	0.854	35	35 22	8.91	0.739	25.1	35	39 36 15	7.29	0.759	52.4	33	39	20	18																				

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.57 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,226.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	32873.1	
Exposure: MWd/MTU (GWd)	18375.0 (1849.60)			
Delta E: MWd/MTU, (GWd)	149.0 (15.00)			
Power: Mwt	2923.0 (100.00 %)	Axial Profile	Edit	Radial Power
Core Pressure: psia	1044.3	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-23.17	Top 25	0.241	6.127 30 0.392 0.482 5 40
Flow: Mlb/hr	80.39 (104.40 %)	24	0.716	18.199 31 0.360 0.490 47 40
		23	0.942	24.215 32 0.731 1.003 41 42
		22	1.093	27.742 33 1.078 1.154 37 32
		21	1.190	30.373 34 1.170 1.309 41 38
		20	1.251	32.243 35 1.328 1.392 37 30
1 3 5 7 9 11 13 15 17 19 21 23 25				
1	-- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	
3	-- -- -- -- -- -- -- -- -- -- -- -- -- --	47		19 1.285 33.797
5	-- -- -- -- -- -- -- -- -- -- -- -- -- --	43		18 1.306 34.858
7	-- -- -- -- -- -- -- -- -- -- -- -- -- --	39		17 1.297 35.112
9	-- -- -- -- -- -- -- -- -- -- -- -- -- --	35		16 1.337* 35.632
11	-- -- -- -- -- -- -- -- -- -- -- -- -- --	31		15 1.329 36.709
13	-- -- -- -- -- -- -- -- -- -- -- -- -- --	27		14 1.288 37.249
15	-- -- -- -- -- -- -- -- -- -- -- -- -- --	23		13 1.314 36.715
17	-- -- -- -- -- -- -- -- -- -- -- -- -- --	19		12 1.285 37.464
19	-- -- -- -- -- -- -- -- -- -- -- -- -- --	15		11 1.239 37.885
21	-- -- -- -- -- -- -- -- -- -- -- -- -- --	11		10 1.189 38.302
23	-- -- -- -- -- -- -- -- -- -- -- -- -- --	7		9 1.137 39.250
25	-- -- -- -- -- -- -- -- -- -- -- -- -- --	3		8 1.060 39.713
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	0.00			
k-effective:	1.00009	Bottom	1	0.134 7.731
Void Fraction:	0.383			
Core Delta-P: psia	23.770	% AXIAL TILT	12.102	-9.339
Core Plate Delta-P: psia	19.230	AVG BOT 8ft/12ft	0.9498	1.0578
Coolant Temp: Deg-F	546.9			
In Channel Flow: Mlb/hr	70.95	Active Channel Flow: Mlb/hr		68.65
Total Bypass Flow (%):	11.7	(of total core flow)		
Total Water Rod Flow (%):	2.9	(of total core flow)		
Source Convergence	0.00048			

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K
1.392	35	37	30	1.805	0.859	33	37	26	7.09	0.752	45.7	33	39	34	18
1.383	35	39	28	1.807	0.858	33	37	32	9.11	0.750	24.1	35	35	36	15
1.379	35	39	32	1.656	0.857	35	37	30	6.98	0.748	46.7	33	39	38	18
1.379	35	35	32	1.810	0.856	33	39	30	7.00	0.748	46.5	33	37	40	18
1.378	35	35	36	1.666	0.852	35	35	36	7.07	0.748	45.5	33	37	36	18
1.377	35	37	34	1.819	0.852	33	33	36	9.04	0.748	24.7	35	37	34	15
1.376	35	33	34	1.823	0.850	33	37	18	9.12	0.747	23.6	35	37	30	15
1.376	35	31	36	1.672	0.849	35	39	28	9.08	0.747	24.1	35	39	32	15
1.369	35	29	38	1.675	0.848	35	37	20	6.99	0.745	46.2	33	35	38	18
1.364	35	35	28	1.675	0.848	35	39	32	9.00	0.744	24.7	35	33	38	15

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.58 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,375.0 MWd/MTU

Brunswick Unit 1 Cycle 19 Fuel Cycle Design MELLA+ Operating Domain

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR						APLHGR						LHGR						
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.387	35	37	30	1.789	0.866	33	37	26	8.99	0.740	24.1	35	35	36	15	9.93	0.779	30.1	34	41	38	15
1.378	35	39	28	1.792	0.865	33	37	32	6.97	0.739	45.7	33	39	34	18	9.86	0.774	30.2	34	37	42	15
1.375	35	39	32	1.795	0.863	33	39	30	8.93	0.738	24.7	35	37	34	15	9.78	0.761	29.3	34	41	40	15
1.375	35	35	22	1.652	0.860	35	37	30	8.96	0.737	24.1	35	39	32	15	7.50	0.761	50.1	33	41	36	18
1.374	35	35	36	1.804	0.859	33	33	36	8.99	0.737	23.6	35	37	30	15	7.25	0.760	52.9	33	13	38	18
1.373	35	37	34	1.808	0.857	33	37	18	6.89	0.737	46.5	33	37	40	18	9.75	0.759	29.3	34	39	42	15
1.372	35	33	34	1.662	0.854	35	35	36	6.87	0.737	46.7	33	39	38	18	7.35	0.758	51.5	33	37	40	18
1.371	35	31	36	1.814	0.854	33	39	34	6.96	0.736	45.5	33	37	36	18	7.41	0.758	50.8	33	35	38	18
1.365	35	29	38	1.668	0.851	35	39	28	8.88	0.735	24.7	35	33	38	15	9.71	0.757	29.5	34	45	22	15
1.360	35	35	28	1.670	0.850	35	37	20	8.78	0.735	26.1	35	37	38	15	7.46	0.757	50.1	33	35	42	18

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.59 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,376.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	33023.0
Exposure: MWd/MTU (GWd)	18525.0 (1864.70)	Axial Profile	Edit
Delta E: MWd/MTU, (GWd)	149.0 (15.00)	N(PRA) Power Exposure	Radial Power
Power: MWT	2923.0 (100.00 %)	Top 25	Zone Avg. Max. IR JR
Core Pressure: psia	1044.3	24	0.242 6.167 30 0.393 0.483 5 40
Inlet Subcooling: Btu/lbm	-25.83	23	0.721 18.311 31 0.360 0.491 47 40
Flow: Mlb/hr	80.46 (104.50 %)	22	0.948 24.362 32 0.737 1.007 41 42
		21	1.099 27.914 33 1.075 1.150 37 32
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.194 30.560 34 1.174 1.311 41 38
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	20 1.252 32.440 35 1.323 1.385 37 30
3 -- -- -- -- -- -- -- -- -- -- -- --	47		19 1.283 34.000
5 -- -- -- -- -- -- -- -- -- -- -- --	43		18 1.302 35.064
7 -- -- -- -- -- -- -- -- -- -- -- --	39		17 1.292 35.317
9 -- -- -- -- -- -- -- -- -- -- -- --	35		16 1.332* 35.832
11 -- -- -- -- -- -- -- -- -- -- -- --	31		15 1.325 36.908
13 -- -- -- -- -- -- -- -- -- -- -- --	27		14 1.285 37.443
15 -- -- -- -- -- -- -- -- -- -- -- --	23		13 1.315 36.902
17 -- -- -- -- -- -- -- -- -- -- -- --	19		12 1.289 37.647
19 -- -- -- -- -- -- -- -- -- -- -- --	15		11 1.245 38.063
21 -- -- -- -- -- -- -- -- -- -- -- --	11		10 1.198 38.474
23 -- -- -- -- -- -- -- -- -- -- -- --	7		9 1.148 39.415
25 -- -- -- -- -- -- -- -- -- -- -- --	3		8 1.069 39.867
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7 0.970 39.826
			6 0.879 40.625
			5 0.766 40.946*
			4 0.661 39.680
Control Rod Density: %	0.00		3 0.583 36.576
			2 0.471 28.025
k-effective:	1.00010	Bottom	1 0.131 7.752
Void Fraction:	0.370		
Core Delta-P: psia	23.549	% AXIAL TILT	12.094 -9.226
Core Plate Delta-P: psia	18.999	AVG BOT 8ft/12ft	0.9492 1.0573
Coolant Temp: Deg-F	546.2		
In Channel Flow: Mlb/hr	71.11	Active Channel Flow: Mlb/hr	68.83
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	2.8	(of total core flow)	
Source Convergence	0.00040		

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.385 35 37 30	1.823	0.850	33	37 26	7.04	0.749	46.0	33	39 34 18	10.01	0.787	30.4	34	41	38	15								
1.378 35 39 28	1.825	0.849	33	37 32	6.95	0.747	47.0	33	39 38 18	9.94	0.782	30.5	34	37	42	15								
1.375 35 39 32	1.674	0.848	35	37 30	6.97	0.747	46.7	33	37 40 18	7.59	0.772	50.4	33	41	36	18								
1.373 35 35 36	1.828	0.848	33	39 30	7.02	0.745	45.7	33	37 36 18	7.33	0.771	53.1	33	13	38	18								
1.372 35 37 34	1.683	0.844	35	35 36	9.03	0.744	24.4	35	35 36 15	9.87	0.770	29.6	34	41	40	15								
1.372 35 35 32	1.839	0.843	33	37 36	8.96	0.742	24.9	35	37 34 15	7.44	0.769	51.7	33	37	40	18								
1.369 35 33 34	1.839	0.843	33	33 36	9.00	0.742	24.4	35	39 32 15	9.84	0.768	29.6	34	39	42	15								
1.369 35 31 36	1.689	0.841	35	39 28	6.94	0.742	46.4	33	35 38 18	7.54	0.768	50.4	33	35	42	18								
1.362 35 29 38	1.845	0.840	33	39 34	6.91	0.741	46.8	33	41 32 18	7.49	0.768	51.0	33	35	38	18								
1.356 35 35 28	1.690	0.840	35	39 32	9.02	0.741	23.9	35	37 30 15	7.43	0.767	51.7	33	41	32	18								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.60 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,525.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: Mwd/MTU	33024.0	
Exposure: Mwd/MTU (Gwd)	18526.0 (1864.80)			
Delta E: Mwd/MTU, (Gwd)	1.0 (0.10)	Axial Profile	Edit	Radial Power
Power: Mwt	2923.0 (100.00 %)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Core Pressure: psia	1044.3	Top 25	0.238	6.167 30 0.395 0.484 5 40
Inlet Subcooling: Btu/lbm	-29.70	24	0.708	18.312 31 0.362 0.492 47 40
Flow: Mlb/hr	77.08 (100.10 %)	23	0.931	24.363 32 0.741 1.009 41 42
		22	1.080	27.915 33 1.074 1.147 37 32
		21	1.175	30.561 34 1.175 1.309 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.233	32.442 35 1.320 1.381 37 30
1	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	47	1.265	34.001
3	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --		1.286	35.065
5	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	43	1.278	35.318
7	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	39	1.320*	35.833
9	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	35	1.317	36.910
11	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	31	1.281	37.444
13	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	27	1.314	36.903
15	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	23	1.293	37.649
17	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	19	1.254	38.064
19	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	15	1.211	38.475
21	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	11	0.992	39.827
23	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	7	0.900	40.626
25	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	3	0.784	40.946*
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50		4	0.675	39.681
Control Rod Density: %	0.00		3	0.595
			2	0.481
k-effective:	1.00010	Bottom	1	0.133
Void Fraction:	0.368			7.752
Core Delta-P: psia	21.964	% AXIAL TILT	10.715	-9.225
Core Plate Delta-P: psia	17.404	AVG BOT 8ft/12ft	0.9575	1.0573
Coolant Temp: Deg-F	545.5			
In Channel Flow: Mlb/hr	68.10	Active Channel Flow: Mlb/hr		65.92
Total Bypass Flow (%):	11.6	(of total core flow)		
Total Water Rod Flow (%):	2.8	(of total core flow)		
Source Convergence	0.00049			

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR			APLHGR			LHGR					
Value	FT	IR JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K
1.381	35	37 30	1.807	0.858	33	37	26	6.93	0.737	46.0	33	39	34	18
1.374	35	39 28	1.808	0.857	33	37	32	6.85	0.736	47.0	33	39	38	18
1.371	35	39 32	1.812	0.855	33	39	30	6.86	0.736	46.7	33	37	40	18
1.369	35	35 36	1.669	0.851	35	37	30	8.92	0.736	24.4	35	35	36	15
1.369	35	37 34	1.823	0.850	33	37	18	8.85	0.734	24.9	35	37	34	15
1.368	35	35 32	1.823	0.850	33	33	36	6.91	0.733	45.7	33	37	36	18
1.365	35	33 34	1.828	0.848	33	39	34	8.89	0.733	24.4	35	39	32	15
1.365	35	31 36	1.678	0.846	35	35	36	8.91	0.732	23.9	35	37	30	15
1.359	35	29 38	1.684	0.843	35	39	28	8.73	0.732	26.3	35	37	38	15
1.352	35	35 28	1.839	0.843	33	35	38	8.78	0.732	25.6	35	39	36	15

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.61 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,526.0 Mwd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	33148.0	
Exposure: MWd/MTU (Gwd)	18650.0 (1877.30)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (Gwd)	124.0 (12.48)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: Mwt	2923.0 (100.00 %)	Top 25	0.242	6.200 30 0.394 0.484 5 40
Core Pressure: psia	1044.3	24	0.722	18.405 31 0.361 0.492 47 40
Inlet Subcooling: Btu/lbm	-28.40	23	0.950	24.485 32 0.741 1.011 41 42
Flow: Mlb/hr	80.27 (104.25 %)	22	1.100	28.058 33 1.074 1.146 37 32
		21	1.193	30.717 34 1.178 1.312 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.249	32.605 35 1.319 1.380 37 30
1	-- -- -- -- -- -- -- -- -- --	51	:JR	
3	-- -- -- -- -- -- -- -- -- --	47		19 1.279 34.169
5	-- -- -- -- -- -- -- -- -- --	43		18 1.296 35.235
7	-- -- -- -- -- -- -- -- -- --	39		17 1.285 35.487
9	-- -- -- -- -- -- -- -- -- --	35		16 1.326* 35.998
11	-- -- -- -- -- -- -- -- -- --	31		15 1.321 37.074
13	-- -- -- -- -- -- -- -- -- --	27		14 1.283 37.605
15	-- -- -- -- -- -- -- -- -- --	23		13 1.316 37.058
17	-- -- -- -- -- -- -- -- -- --	19		12 1.293 37.801
19	-- -- -- -- -- -- -- -- -- --	15		11 1.253 38.212
21	-- -- -- -- -- -- -- -- -- --	11		10 1.208 38.618
23	-- -- -- -- -- -- -- -- -- --	7		9 1.160 39.554
25	-- -- -- -- -- -- -- -- -- --	3		8 1.079 39.997
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				7 0.977 39.944
				6 0.881 40.732
				5 0.763 41.039*
				4 0.654 39.760
Control Rod Density: %	0.00			3 0.575 36.647
				2 0.464 28.082
k-effective:	1.00011	Bottom	1	0.129 7.769
Void Fraction:	0.360			
Core Delta-P: psia	23.244	% AXIAL TILT	11.862	-9.132
Core Plate Delta-P: psia	18.685	AVG BOT 8ft/12ft	0.9502	1.0568
Coolant Temp: Deg-F	545.6			
In Channel Flow: Mlb/hr	71.01	Active Channel Flow: Mlb/hr		68.76
Total Bypass Flow (%):	11.5	(of total core flow)		
Total Water Rod Flow (%):	2.8	(of total core flow)		
Source Convergence	0.00049			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR												APLHGR												LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K													
1.380 35 37 30	1.839	0.843	33	37 26	6.99	0.745	46.1	33	39 34 18	9.95	0.785	30.7	34	41	38	15																				
1.373 35 39 28	1.840	0.842	33	37 32	6.91	0.744	47.2	33	39 38 18	9.89	0.780	30.7	34	37	42	15																				
1.371 35 39 32	1.843	0.841	33	39 30	6.93	0.744	46.9	33	37 40 18	7.55	0.770	50.6	33	41	36	18																				
1.368 35 35 36	1.690	0.840	35	37 30	6.97	0.740	45.9	33	37 36 18	9.83	0.769	29.8	34	41	40	15																				
1.368 35 37 34	1.852	0.837	33	37 18	8.95	0.739	24.6	35	35 36 15	7.29	0.768	53.3	33	13	38	18																				
1.366 35 35 32	1.698	0.836	35	35 36	7.01	0.738	45.1	33	41 36 18	9.80	0.767	29.8	34	39	42	15																				
1.363 35 33 34	1.856	0.835	33	33 36	6.86	0.738	47.0	33	41 32 18	7.39	0.766	51.9	33	37	40	18																				
1.362 35 31 36	1.858	0.834	33	39 34	8.88	0.737	25.2	35	37 34 15	7.50	0.765	50.6	33	35	42	18																				
1.357 35 29 38	1.704	0.833	35	39 28	6.89	0.737	46.6	33	35 38 18	9.75	0.765	30.0	34	45	22	15																				
1.351 35 33 38	1.704	0.833	35	39 32	8.92	0.737	24.6	35	39 32 15	7.38	0.764	51.9	33	41	32	18																				

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.62 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,650.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWD/MTU	33149.0							
Exposure: MWD/MTU (GWD)	18651.0 (1877.40)	Axial Profile	Edit	Radial Power						
Delta E: MWD/MTU, (GWD)	1.0 (0.10)	N(PRA)	Power	Exposure	Zone	Avg.	Max.	IR	JR	
Power: MWT	2923.0 (100.00 %)	Top	25	0.238	6.200	30	0.396	0.485	5	40
Core Pressure: psia	1044.3	24	0.710	18.406	31	0.362	0.493	47	40	
Inlet Subcooling: Btu/lbm	-32.10	23	0.934	24.486	32	0.745	1.013	41	42	
Flow: Mlb/hr	77.19 (100.25 %)	22	1.082	28.059	33	1.073	1.144	37	32	
		21	1.175	30.718	34	1.179	1.310	41	38	
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.231	32.606	35	1.317	1.376	37	30	
1	-- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR							
3	-- -- -- -- -- -- -- -- -- -- -- -- -- --	47								
.5	-- -- -- -- -- -- -- -- -- -- -- -- -- --	43								
7	-- -- -- -- -- -- -- -- -- -- -- -- -- --	39								
9	-- -- -- -- -- -- -- -- -- -- -- -- -- --	35								
11	-- -- -- -- -- -- -- -- -- -- -- -- -- --	31								
13	-- -- -- -- -- -- -- -- -- -- -- -- -- --	27								
15	-- -- -- -- -- -- -- -- -- -- -- -- -- --	23								
17	-- -- -- -- -- -- -- -- -- -- -- -- -- --	19								
19	-- -- -- -- -- -- -- -- -- -- -- -- -- --	15								
21	-- -- -- -- -- -- -- -- -- -- -- -- -- --	11								
23	-- -- -- -- -- -- -- -- -- -- -- -- -- --	7								
25	-- -- -- -- -- -- -- -- -- -- -- -- -- --	3								
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50										
Control Rod Density: %	0.00									
k-effective:	1.00011	Bottom	1	0.132	7.769					
Void Fraction:	0.358									
Core Delta-P: psia	21.811	% AXIAL TILT	10.558	-9.131						
Core Plate Delta-P: psia	17.243	AVG BOT 8ft/12ft	0.9581	1.0568						
Coolant Temp: Deg-F	544.8									
In Channel Flow: Mlb/hr	68.28	Active Channel Flow: Mlb/hr		66.11						
Total Bypass Flow (%):	11.5	(of total core flow)								
Total Water Rod Flow (%):	2.8	(of total core flow)								
Source Convergence	0.00050									

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR				APLHGR				LHGR								
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.376 35 37 30	1.825	0.849	33	37 26	6.89	0.734	46.1	33	39 34	18	9.85	0.777	30.7	34	41	38	15
1.369 35 39 28	1.826	0.849	33	37 32	6.81	0.734	47.2	33	39 38	18	9.79	0.772	30.7	34	37	42	15
1.367 35 39 32	1.829	0.847	33	39 30	6.83	0.734	46.9	33	37 40	18	9.73	0.762	29.8	34	41	40	15
1.364 35 35 36	1.838	0.843	33	37 18	8.85	0.731	24.6	35	35 36	15	9.71	0.759	29.8	34	39	42	15
1.364 35 37 34	1.686	0.842	35	37 30	6.87	0.730	45.9	33	37 36	18	7.44	0.759	50.6	33	41	36	18
1.362 35 35 32	1.842	0.842	33	33 36	8.83	0.729	24.6	35	39 32	15	7.19	0.757	53.4	33	13	38	18
1.359 35 31 36	1.844	0.841	33	39 34	8.78	0.729	25.2	35	37 34	15	9.66	0.757	30.0	34	45	22	15
1.359 35 33 34	1.695	0.838	35	35 36	8.67	0.729	26.6	35	37 38	15	7.29	0.755	51.9	33	37	40	18
1.353 35 29 38	1.854	0.836	33	35 38	8.72	0.729	25.8	35	39 36	15	7.39	0.754	50.6	33	35	42	18
1.347 35 33 38	1.700	0.835	35	39 28	6.91	0.728	45.1	33	41 36	18	7.27	0.753	51.9	33	41	32	18

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.63 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,651.0 MWD/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	33158.6	
Exposure: MWd/MTU (GWd)	18660.6 (1878.30)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	9.6 (0.97)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.238	6.202 30 0.396 0.485 5 40
Core Pressure: psia	1044.3	24	0.711	18.413 31 0.362 0.493 47 40
Inlet Subcooling: Btu/lbm	-31.98	23	0.935	24.496 32 0.745 1.013 41 42
Flow: Mlb/hr	77.46 (100.60 %)	22	1.084	28.070 33 1.073 1.144 37 32
		21	1.177	30.730 34 1.179 1.310 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.233	32.619 35 1.317 1.376 37 30
1	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	47	1.263	34.183
3	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	43	1.282	35.250
5	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	39	1.273	35.502
7	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	35	1.316	36.013
9	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	31	1.314	37.088
11	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	27	1.280	37.618
13	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	23	1.317*	37.072
15	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	19	1.297	37.814
17	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	15	1.261	38.225
19	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	11	1.221	38.630
21	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	7	1.176	39.566
23	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --	3	1.098	40.008
25	-- -- -- -- -- -- -- -- -- -- -- -- -- -- -- --		0.996	39.954
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			0.898	40.741
Control Rod Density: %	0.00		0.777	41.047*
k-effective:	1.00012	Bottom	0.472	28.087
Void Fraction:	0.358		0.585	36.653
Core Delta-P: psia	21.917		0.472	28.087
Core Plate Delta-P: psia	17.349	% AXIAL TILT	10.657	-9.124
Coolant Temp: Deg-F	544.8	AVG BOT 8ft/12ft	0.9575	1.0567
In Channel Flow: Mlb/hr	68.52	Active Channel Flow: Mlb/hr		66.35
Total Bypass Flow (%):	11.5	(of total core flow)		
Total Water Rod Flow (%):	2.8	(of total core flow)		
Source Convergence	0.00046			

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR			APLHGR			LHGR												
Value	FT	IR JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K							
1.376	35	37 30	1.688	0.865	35	37 30		6.89	0.735	46.2	33	39	34	18	9.85	0.778	30.7	34	41	38	15
1.369	35	39 28	1.696	0.861	35	35 36		6.82	0.735	47.2	33	39	38	18	9.79	0.773	30.8	34	37	42	15
1.367	35	39 32	1.828	0.859	33	37 26		6.84	0.735	46.9	33	37	40	18	9.74	0.762	29.9	34	41	40	15
1.364	35	35 36	1.829	0.858	33	37 32		8.85	0.732	24.7	35	35	36	15	9.71	0.760	29.8	34	39	42	15
1.364	35	37 34	1.702	0.858	35	39 28		6.87	0.730	45.9	33	37	36	18	7.45	0.759	50.6	33	41	36	18
1.362	35	35 32	1.703	0.858	35	39 32		8.83	0.730	24.6	35	39	32	15	7.19	0.758	53.4	33	13	38	18
1.359	35	31 36	1.832	0.857	33	39 30		8.79	0.730	25.2	35	37	34	15	9.66	0.758	30.1	34	45	22	15
1.359	35	33 34	1.704	0.857	35	37 20		8.68	0.729	26.6	35	37	38	15	7.29	0.756	51.9	33	37	40	18
1.353	35	29 38	1.711	0.853	35	35 22		8.73	0.729	25.9	35	39	36	15	7.40	0.755	50.6	33	35	42	18
1.347	35	33 38	1.841	0.853	33	37 18		6.92	0.729	45.1	33	41	36	18	7.28	0.754	51.9	33	41	32	18

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.64 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,660.6 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWD/MTU	33228.1							
Exposure: MWD/MTU (GWD)	18730.0 (1885.30)	Axial Profile	Edit	Radial Power						
Delta E: MWD/MTU, (GWD)	69.4 (6.99)	N(PRA)	Power	Exposure	Zone	Avg.	Max.	IR	JR	
Power: MWT	2923.0 (100.00 %)	Top	25	0.241	6.221	30	0.396	0.485	5	40
Core Pressure: psia	1044.3		24	0.719	18.465	31	0.362	0.493	47	40
Inlet Subcooling: Btu/lbm	-31.28		23	0.946	24.565	32	0.745	1.014	41	42
Flow: Mlb/hr	79.04 (102.65 %)		22	1.095	28.150	33	1.072	1.143	37	32
1 3 5 7 9 11 13 15 17 19 21 23 25			21	1.188	30.817	34	1.181	1.312	41	38
1 -- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR	20	1.242	32.710	35	1.316	1.375	37	30
3 -- -- -- -- -- -- -- -- -- -- -- -- -- --	47		19	1.271	34.276					
5 -- -- -- -- -- -- -- -- -- -- -- -- -- --	43		18	1.288	35.345					
7 -- -- -- -- -- -- -- -- -- -- -- -- -- --	39		17	1.277	35.596					
9 -- -- -- -- -- -- -- -- -- -- -- -- -- --	35		16	1.320*	36.105					
11 -- -- -- -- -- -- -- -- -- -- -- -- -- --	31		15	1.317	37.180					
13 -- -- -- -- -- -- -- -- -- -- -- -- -- --	27		14	1.282	37.708					
15 -- -- -- -- -- -- -- -- -- -- -- -- -- --	23		13	1.318	37.159					
17 -- -- -- -- -- -- -- -- -- -- -- -- -- --	19		12	1.299	37.900					
19 -- -- -- -- -- -- -- -- -- -- -- -- -- --	15		11	1.262	38.308					
21 -- -- -- -- -- -- -- -- -- -- -- -- -- --	11		10	1.220	38.711					
23 -- -- -- -- -- -- -- -- -- -- -- -- -- --	7		9	1.173	39.643					
25 -- -- -- -- -- -- -- -- -- -- -- -- -- --	3		8	1.092	40.080					
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7	0.987	40.019					
Control Rod Density: %	0.00		6	0.886	40.801					
k-effective:	1.00012		5	0.764	41.098*					
Void Fraction:	0.353		4	0.652	39.811					
Core Delta-P: psia	22.539	% AXIAL TILT	11.356	-9.073						
Core Plate Delta-P: psia	17.970	AVG BOT 8ft/12ft	0.9531	1.0565						
Coolant Temp: Deg-F	544.9									
In Channel Flow: Mlb/hr	69.96	Active Channel Flow: Mlb/hr		67.76						
Total Bypass Flow (%):	11.5	(of total core flow)								
Total Water Rod Flow (%):	2.8	(of total core flow)								
Source Convergence	0.00041									

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.375 35	37	30	1.698	0.860	35	37	30	6.86	0.739	47.3	33	39	38	18	9.89	0.782	30.9	34	41	38	15			
1.369 35	39	28	1.706	0.856	35	35	36	6.87	0.739	47.0	33	37	40	18	9.83	0.777	30.9	34	37	42	15			
1.367 35	39	32	1.712	0.853	35	39	32	6.93	0.739	46.3	33	39	34	18	9.78	0.766	30.0	34	41	40	15			
1.363 35	37	34	1.712	0.853	35	39	28	6.90	0.734	46.0	33	37	36	18	7.49	0.765	50.7	33	41	36	18			
1.363 35	35	36	1.714	0.852	35	37	20	8.87	0.734	24.8	35	35	36	15	9.75	0.764	30.0	34	39	42	15			
1.361 35	35	32	1.843	0.852	33	37	26	6.96	0.734	45.2	33	41	36	18	7.23	0.763	53.5	33	13	38	18			
1.358 35	31	36	1.844	0.851	33	37	32	6.81	0.733	47.1	33	41	32	18	9.70	0.762	30.2	34	45	22	15			
1.357 35	33	34	1.847	0.850	33	39	30	8.85	0.732	24.7	35	39	32	15	7.33	0.761	52.1	33	37	40	18			
1.352 35	29	38	1.722	0.848	35	35	22	8.81	0.732	25.3	35	37	34	15	7.44	0.760	50.7	33	35	42	18			
1.347 35	33	38	1.723	0.847	34	37	12	8.70	0.732	26.7	35	37	38	15	7.32	0.759	52.0	33	41	32	18			

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.65 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,730.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	33286.3	
Exposure: MWd/MTU (GWd)	18788.1 (1891.20)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (GWd)	58.1 (5.85)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2923.0 (100.00 %)	Top 25	0.243	6.236 30 0.395 0.485 5 40
Core Pressure: psia	1044.3	24	0.727	18.510 31 0.362 0.493 47 40
Inlet Subcooling: Btu/lbm	-30.68	23	0.956	24.623 32 0.745 1.015 41 42
Flow: Mlb/hr	80.46 (104.50 %)	22	1.106	28.218 33 1.072 1.142 37 32
		21	1.198	30.891 34 1.182 1.313 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.251	32.787 35 1.316 1.374 37 30
1 -- -- -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- -- -- --	47		19	1.278 34.355
5 -- -- -- -- -- -- -- -- -- -- -- -- -- --	43		18	1.294 35.425
7 -- -- -- -- -- -- -- -- -- -- -- -- -- --	39		17	1.282 35.675
9 -- -- -- -- -- -- -- -- -- -- -- -- -- --	35		16	1.324* 36.182
11 -- -- -- -- -- -- -- -- -- -- -- -- -- --	31		15	1.320 37.258
13 -- -- -- -- -- -- -- -- -- -- -- -- -- --	27		14	1.284 37.783
15 -- -- -- -- -- -- -- -- -- -- -- -- -- --	23		13	1.320 37.231
17 -- -- -- -- -- -- -- -- -- -- -- -- -- --	19		12	1.300 37.972
19 -- -- -- -- -- -- -- -- -- -- -- -- -- --	15		11	1.262 38.378
21 -- -- -- -- -- -- -- -- -- -- -- -- -- --	11		10	1.218 38.778
23 -- -- -- -- -- -- -- -- -- -- -- -- -- --	7		9	1.169 39.708
25 -- -- -- -- -- -- -- -- -- -- -- -- -- --	3		8	1.085 40.141
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7	0.978 40.074
Control Rod Density: %	0.00		6	0.875 40.849
k-effective:	1.00016	Bottom	5	0.751 41.140*
Void Fraction:	0.349		4	0.640 39.847
Core Delta-P: psia	23.107	% AXIAL TILT	3	0.561 36.723
Core Plate Delta-P: psia	18.538	AVG BOT 8ft/12ft	2	0.452 28.143
Coolant Temp: Deg-F	544.9			
In Channel Flow: Mlb/hr	71.26	Active Channel Flow: Mlb/hr		
Total Bypass Flow (%):	11.4			69.03
Total Water Rod Flow (%):	2.8			(of total core flow)
Source Convergence	0.00049			

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR			APLHGR			LHGR						
Value	FT	IR JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.374	35	37 30	1.706	0.856	35	37	30	18	6.89	0.744	47.4	33	39	38	18
1.369	35	39 28	1.713	0.852	35	35	36		6.91	0.744	47.1	33	37	40	18
1.367	35	39 32	1.719	0.849	35	39	32		6.96	0.743	46.4	33	39	34	18
1.363	35	37 34	1.719	0.849	35	39	28		7.00	0.739	45.3	33	41	36	18
1.363	35	35 36	1.722	0.848	35	37	20		6.93	0.738	46.1	33	37	36	18
1.360	35	35 32	1.856	0.846	33	37	26		6.84	0.737	47.2	33	41	32	18
1.357	35	31 36	1.857	0.845	33	37	32		8.89	0.737	24.9	35	35	36	15
1.356	35	33 34	1.727	0.845	34	37	12		6.85	0.735	46.8	33	35	38	18
1.351	35	29 38	1.728	0.845	34	11	38		8.87	0.735	24.8	35	39	32	15
1.346	35	33 38	1.860	0.844	33	39	30		8.72	0.735	26.8	35	37	38	15

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.66 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 18,788.1 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	33663.8	
Exposure: MWd/MTU (Gwd)	19165.6 (1929.20)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (Gwd)	377.5 (38.00)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2722.7 (93.15 %)	Top 25	0.257	6.341 30 0.396 0.486 5 40
Core Pressure: psia	1044.3	24	0.772	18.809 31 0.362 0.495 47 40
Inlet Subcooling: Btu/lbm	-28.43	23	1.014	25.017 32 0.747 1.022 41 42
Flow: Mlb/hr	80.46 (104.50 %)	22	1.168	28.676 33 1.069 1.138 39 30
		21	1.256	31.385 34 1.189 1.321 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.301	33.301 35 1.312 1.370 37 30
1 --- --- --- --- --- --- --- --- --- ---	51	:JR		
3 --- --- --- --- --- --- --- --- --- ---	47		19	1.318 34.878
5 --- --- --- --- --- --- --- --- --- ---	43		18	1.324 35.952
7 --- --- --- --- --- --- --- --- --- ---	39		17	1.303 36.196
9 --- --- --- --- --- --- --- --- --- ---	35		16	1.339* 36.689
11 --- --- --- --- --- --- --- --- --- ---	31		15	1.330 37.762
13 --- --- --- --- --- --- --- --- --- ---	27		14	1.289 38.273
15 --- --- --- --- --- --- --- --- --- ---	23		13	1.322 37.706
17 --- --- --- --- --- --- --- --- --- ---	19		12	1.297 38.438
19 --- --- --- --- --- --- --- --- --- ---	15		11	1.253 38.829
21 --- --- --- --- --- --- --- --- --- ---	11		10	1.202 39.212
23 --- --- --- --- --- --- --- --- --- ---	7		9	1.141 40.123
25 --- --- --- --- --- --- --- --- --- ---	3		8	1.046 40.523
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7	0.928 40.416
Control Rod Density: %	0.00		6	0.817 41.153
			5	0.693 41.399*
			4	0.586 40.067
k-effective:	1.00015	Bottom	1	0.115 7.833
Void Fraction:	0.330			
Core Delta-P: psia	22.641	% AXIAL TILT	15.482	-8.717
Core Plate Delta-P: psia	18.082	AVG BOT 8ft/12ft	0.9267	1.0546
Coolant Temp: Deg-F	545.1			
In Channel Flow: Mlb/hr	71.47	Active Channel Flow: Mlb/hr		69.31
Total Bypass Flow (%):	11.2	(of total core flow)		
Total Water Rod Flow (%):	2.7	(of total core flow)		
Source Convergence	0.00045			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR					
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.370 35 37 30	1.822	0.805	35	37 30	6.59	0.716	47.9	33	39 38 18	9.39	0.749	31.8	34	41	38	15		
1.367 35 39 28	1.972	0.803	33	37 36	6.60	0.715	47.7	33	37 40 18	9.33	0.744	31.8	34	37	42	15		
1.365 35 39 32	1.828	0.803	34	37 12	6.63	0.713	46.9	33	39 34 18	7.20	0.741	51.4	33	41	36	18		
1.360 35 37 34	1.828	0.803	35	35 36	6.70	0.711	45.9	33	41 36 18	6.94	0.739	54.2	33	13	38	18		
1.359 35 35 36	1.975	0.802	33	37 32	6.53	0.708	47.8	33	41 32 18	7.04	0.737	52.7	33	37	40	18		
1.353 35 35 32	1.829	0.802	34	11 38	6.60	0.707	46.7	33	37 36 18	7.15	0.736	51.4	33	35	42	18		
1.349 35 31 36	1.976	0.802	33	37 26	6.63	0.705	45.9	33	35 42 18	7.03	0.735	52.7	33	41	32	18		
1.349 35 33 34	1.830	0.802	35	39 32	6.52	0.704	47.4	33	35 38 18	9.30	0.735	30.9	34	41	40	15		
1.346 35 39 36	1.978	0.801	33	39 30	6.56	0.704	46.9	33	43 34 18	9.27	0.733	30.9	34	39	42	15		
1.345 35 29 38	1.832	0.800	34	45 30	6.52	0.702	47.2	33	43 30 18	7.14	0.732	51.1	33	39	34	18		

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.67 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 19,165.6 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	34098.2	
Exposure: MWd/MTU (GWd)	19600.0 (1972.90)			
Delta E: MWd/MTU, (GWd)	434.4 (43.72)			
Power: MWT	2492.5 (85.27 %)	Axial Profile	Edit	Radial Power
Core Pressure: psia	1044.3	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-25.83	Top 25	0.274	6.469 30 0.396 0.487 5 40
Flow: Mlb/hr	80.46 (104.50 %)	24	0.827	19.177 31 0.363 0.497 47 40
		23	1.085	25.499 32 0.750 1.030 41 42
		22	1.243	29.235 33 1.066 1.135 39 30
		21	1.324	31.982 34 1.199 1.331 41 38
		20	1.358	33.917 35 1.308 1.363 39 28
1 3 5 7 9 11 13 15 17 19 21 23 25	51	:JR		
1	-- -- -- -- -- -- -- -- -- --	47		
3	-- -- -- -- -- -- -- -- -- --	43		
5	-- -- -- -- -- -- -- -- -- --	39		
7	-- -- -- -- -- -- -- -- -- --	35		
9	-- -- -- -- -- -- -- -- -- --	31		
11	-- -- -- -- -- -- -- -- -- --	27		
13	-- -- -- -- -- -- -- -- -- --	23		
15	-- -- -- -- -- -- -- -- -- --	19		
17	-- -- -- -- -- -- -- -- -- --	15		
19	-- -- -- -- -- -- -- -- -- --	11		
21	-- -- -- -- -- -- -- -- -- --	7		
23	-- -- -- -- -- -- -- -- -- --	3		
25	-- -- -- -- -- -- -- -- -- --			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	0.00			
k-effective:	1.00018	Bottom	1	0.104 7.882
Void Fraction:	0.308			
Core Delta-P: psia	22.132	% AXIAL TILT	19.427	-8.321
Core Plate Delta-P: psia	17.584	AVG BOT 8ft/12ft	0.9006	1.0524
Coolant Temp: Deg-F	545.3			
In Channel Flow: Mlb/hr	71.70	Active Channel Flow: Mlb/hr		69.61
Total Bypass Flow (%):	10.9	(of total core flow)		
Total Water Rod Flow (%):	2.6	(of total core flow)		
Source Convergence	0.00044			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	APLHGR												LHGR				
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.363 35 39 28	1.958	0.761	34	43 38	6.20	0.678	48.6	33	39 38	18	9.02	0.706	29.8	34	41 38	18	
1.363 35 39 32	1.965	0.758	34	45 22	6.21	0.678	48.4	33	37 40	18	6.78	0.704	52.1	33	41 36	18	
1.363 35 37 30	2.104	0.758	33	41 36	6.31	0.675	46.6	33	41 36	18	8.95	0.702	30.1	34	37 42	18	
1.355 35 37 34	1.966	0.758	34	37 12	6.22	0.673	47.6	33	39 34	18	6.61	0.701	53.8	33	39 38	18	
1.353 35 35 36	1.966	0.758	34	45 30	6.14	0.670	48.5	33	41 32	18	6.62	0.699	53.5	33	37 40	18	
1.347 35 39 36	1.969	0.757	34	11 38	6.19	0.670	47.5	33	43 34	18	6.72	0.698	52.1	33	35 42	18	
1.344 35 35 32	1.975	0.754	34	11 14	6.24	0.668	46.6	33	35 42	18	6.62	0.698	53.4	33	41 32	18	
1.340 35 31 36	2.114	0.754	33	37 36	6.18	0.667	47.4	33	37 36	18	6.70	0.694	51.8	33	39 34	18	
1.339 35 33 34	1.977	0.754	34	37 44	6.13	0.666	47.9	33	43 30	18	6.64	0.692	52.5	33	43 34	18	
1.337 35 33 38	1.979	0.753	35	37 30	6.10	0.664	48.0	33	35 38	18	8.95	0.692	28.6	34	45 22	18	

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.68 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 19,600.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	34498.2	
Exposure: MWd/MTU (Gwd)	20000.0 (2013.20)	Axial Profile	Edit	Radial Power
Delta E: MWd/MTU, (Gwd)	400.0 (40.26)	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Power: MWT	2266.5 (77.54 %)	Top 25	0.291 6.594	30 0.397 0.489 5 40
Core Pressure: psia	1044.3	24	0.883 19.539	31 0.363 0.500 47 40
Inlet Subcooling: Btu/lbm	-23.29	23	1.157 25.974	32 0.752 1.038 41 42
Flow: Mlb/hr	80.46 (104.50 %)	22	1.317 29.781	33 1.063 1.131 39 30
		21	1.388 32.561	34 1.208 1.341 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25		20	1.409* 34.507	35 1.304 1.360 39 32
1 -- -- -- -- -- -- -- -- -- -- -- --	51	:JR		
3 -- -- -- -- -- -- -- -- -- -- -- --	47			
5 -- -- -- -- -- -- -- -- -- -- -- --	43			
7 -- -- -- -- -- -- -- -- -- -- -- --	39			
9 -- -- -- -- -- -- -- -- -- -- -- --	35			
11 -- -- -- -- -- -- -- -- -- -- -- --	31			
13 -- -- -- -- -- -- -- -- -- -- -- --	27			
15 -- -- -- -- -- -- -- -- -- -- -- --	23			
17 -- -- -- -- -- -- -- -- -- -- -- --	19			
19 -- -- -- -- -- -- -- -- -- -- -- --	15			
21 -- -- -- -- -- -- -- -- -- -- -- --	11			
23 -- -- -- -- -- -- -- -- -- -- -- --	7			
25 -- -- -- -- -- -- -- -- -- -- -- --	3			
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50				
Control Rod Density: %	0.00			
k-effective:	1.00022	Bottom	1 0.098	7.923
Void Fraction:	0.287			
Core Delta-P: psia	21.666	% AXIAL TILT	22.931 -7.921	
Core Plate Delta-P: psia	17.129	AVG EOT 8ft/12ft	0.8761 1.0502	
Coolant Temp: Deg-F	545.6			
In Channel Flow: Mlb/hr	71.92	Active Channel Flow: Mlb/hr	69.90	
Total Bypass Flow (%):	10.6	(of total core flow)		
Total Water Rod Flow (%):	2.5	(of total core flow)		
Source Convergence	0.00046			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	APLHGR												LHGR				
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.360 35 39 32	2.110	0.722	34	43 38	5.82	0.636	48.5	33	39 38 19	8.44	0.666	30.7	34	41 38	18		
1.359 35 39 28	2.123	0.717	34	45 22	5.88	0.636	47.5	33	37 40 19	8.37	0.662	31.0	34	37 42	18		
1.356 35 37 30	2.129	0.715	34	45 30	5.99	0.634	45.6	33	41 36 19	6.32	0.661	52.7	33	41 36	18		
1.350 35 37 34	2.132	0.714	34	37 12	5.88	0.631	46.8	33	43 34 19	6.19	0.659	54.2	33	13 38	19		
1.349 35 39 36	2.132	0.714	34	11 38	5.80	0.628	47.7	33	41 32 19	6.33	0.656	52.0	33	37 40	19		
1.348 35 35 36	2.132	0.714	34	37 44	5.85	0.628	46.9	33	43 30 19	6.40	0.656	50.9	33	35 42	19		
1.341 34 41 38	2.135	0.713	34	41 40	5.76	0.628	48.3	33	39 34 18	8.40	0.655	29.5	34	45 22	18		
1.339 35 41 34	2.139	0.712	35	43 22	5.93	0.628	45.6	33	35 42 19	6.27	0.655	52.6	33	41 32	19		
1.335 35 37 38	2.139	0.712	34	45 20	7.42	0.622	26.3	34	41 38 18	6.34	0.654	51.5	33	43 34	19		
1.335 35 41 30	2.141	0.711	34	45 36	5.72	0.622	48.0	33	37 36 18	6.29	0.652	51.9	33	43 30	19		

* LHGR calculated with pin-power reconstruction
 * CPR calculated with pin-power reconstruction & CPR limit type 3
 * Thermal limit file:

Figure A.69 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 20,000.0 MWd/MTU

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain**

Cycle:	19	Core Average Exposure: MWd/MTU	34912.4	
Exposure: MWd/MTU (GWd)	20414.3 (2054.90)			
Delta E: MWd/MTU, (GWd)	414.3 (41.70)			
Power: MWT	2046.4 (70.01 %)	Axial Profile	Edit	Radial Power
Core Pressure: psia	1044.3	N(PRA) Power Exposure	Zone	Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-20.81	Top 25	0.310	6.731 30 0.397 0.491 5 40
Flow: Mlb/hr	80.46 (104.50 %)	24	0.947	19.940 31 0.364 0.502 47 40
		23	1.238	26.499 32 0.756 1.047 41 42
		22	1.399	30.380 33 1.059 1.127 39 30
		21	1.460	33.190 34 1.218 1.351 41 38
1 3 5 7 9 11 13 15 17 19 21 23 25			20	1.466* 35.142 35 1.299 1.357 39 32
1	-- -- -- -- -- -- -- -- -- --	51	:JR	
3	-- -- -- -- -- -- -- -- -- --	47		19 1.441 36.715
5	-- -- -- -- -- -- -- -- -- --	43		18 1.412 37.774
7	-- -- -- -- -- -- -- -- -- --	39		17 1.359 37.970
9	-- -- -- -- -- -- -- -- -- --	35		16 1.372 38.399
11	-- -- -- -- -- -- -- -- -- --	31		15 1.344 39.449
13	-- -- -- -- -- -- -- -- -- --	27		14 1.283 39.896
15	-- -- -- -- -- -- -- -- -- --	23		13 1.305 39.268
17	-- -- -- -- -- -- -- -- -- --	19		12 1.263 39.962
19	-- -- -- -- -- -- -- -- -- --	15		11 1.192 40.287
21	-- -- -- -- -- -- -- -- -- --	11		10 1.107 40.589
23	-- -- -- -- -- -- -- -- -- --	7		9 1.013 41.407
25	-- -- -- -- -- -- -- -- -- --	3		8 0.891 41.676
IR: 2 6 10 14 18 22 26 30 34 38 42 46 50			7	0.759 41.418
			6	0.647 42.020
			5	0.537 42.125*
			4	0.451 40.678
Control Rod Density: %	0.00		3	0.394 37.450
			2	0.319 28.730
k-effective:	1.00025	Bottom	1	0.089 7.962
Void Fraction:	0.265			
Core Delta-P: psia	21.225	% AXIAL TILT	26.881	-7.472
Core Plate Delta-P: psia	16.699	AVG BOT 8ft/12ft	0.8486	1.0477
Coolant Temp: Deg-F	545.9			
In Channel Flow: Mlb/hr	72.13	Active Channel Flow: Mlb/hr	70.18	
Total Bypass Flow (%):	10.4	(of total core flow)		
Total Water Rod Flow (%):	2.4	(of total core flow)		
Source Convergence	0.00049			

Top Ten Thermal Limits Summary - Sorted by Margin

Power	MCPR						APLHGR						LHGR											
	Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K	
1.357 35 39 32	2.286	0.680	34	43 38	5.43	0.598	49.2	33	39 38 19	8.10	0.632	29.5	34	11	38	20								
1.355 35 39 28	2.289	0.679	34	45 30	5.48	0.597	48.2	33	37 40 19	8.05	0.628	29.5	34	37	12	20								
1.351 34 41 38	2.291	0.679	34	11 38	5.59	0.597	46.3	33	41 36 19	8.16	0.624	27.4	34	45	22	20								
1.349 35 39 36	2.292	0.679	34	11 14	5.51	0.596	47.5	33	43 34 19	8.09	0.624	28.3	34	45	30	20								
1.348 35 37 30	2.292	0.678	34	37 12	5.46	0.591	47.6	33	43 30 19	6.03	0.623	51.7	33	41	36	19								
1.345 35 37 34	2.292	0.678	34	45 22	5.53	0.590	46.3	33	35 42 19	5.78	0.621	54.9	33	13	38	19								
1.342 35 39 40	2.293	0.678	35	43 22	5.40	0.589	48.3	33	41 32 19	8.12	0.619	27.1	34	45	20	20								
1.342 35 41 34	2.300	0.676	34	13 12	7.11	0.588	24.6	34	41 38 20	5.91	0.619	52.7	33	37	40	19								
1.342 35 35 36	2.305	0.675	35	43 36	7.07	0.585	24.9	34	37 42 20	5.99	0.619	51.7	33	35	42	19								
1.342 34 37 42	2.305	0.675	34	37 44	5.37	0.585	48.2	33	33 44 19	5.94	0.618	52.3	33	43	34	19								

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

* Thermal limit file:

Figure A.70 Brunswick Unit 1 Cycle 19 Control Rod Pattern and Axial Distributions at 20,414.3 MWd/MTU

Appendix B Elevation Views of the Brunswick Unit 1 Cycle 19 Fresh Reload Batch Fuel Assemblies

[

]

**Figure B.1 Elevation View for the Brunswick Unit 1 Cycle 19 Fresh
Fuel Reload Batch BRK1-19 ATRIUM 10XM []
Fuel Assembly Design (Fabrication Batch BRK1-19)**

[

]

**Figure B.2 Elevation View for the Brunswick Unit 1 Cycle 19 Fresh
Fuel Reload Batch BRK1-19 ATRIUM 10XM []
Fuel Assembly Design (Fabrication Batch BRK1-19)**

Appendix C Brunswick Unit 1 Cycle 19 Fresh Fuel Locations

Table C.1 Brunswick Unit 1 Cycle 19 Reload Fuel Identification and Locations (Core Coordinates)

Assembly Type: ATRIUM 10XM BRK1-19
Bundle Description: []
Number Loaded: 96

Fuel ID	Core Coord.						
A19601	5-28	A19625	7-32	A19649	7-36	A19673	11-38
A19602	25-48	A19626	21-46	A19650	17-46	A19674	15-42
A19603	27-48	A19627	31-46	A19651	35-46	A19675	37-42
A19604	47-28	A19628	45-32	A19652	45-36	A19676	41-38
A19605	47-26	A19629	45-22	A19653	45-18	A19677	41-16
A19606	27- 6	A19630	31- 8	A19654	35- 8	A19678	37-12
A19607	25- 6	A19631	21- 8	A19655	17- 8	A19679	15-12
A19608	5-26	A19632	7-22	A19656	7-18	A19680	11-16
A19609	5-30	A19633	5-34	A19657	7-38	A19681	11-40
A19610	23-48	A19634	19-48	A19658	15-46	A19682	13-42
A19611	29-48	A19635	33-48	A19659	37-46	A19683	39-42
A19612	47-30	A19636	47-34	A19660	45-38	A19684	41-40
A19613	47-24	A19637	47-20	A19661	45-16	A19685	41-14
A19614	29- 6	A19638	33- 6	A19662	37- 8	A19686	39-12
A19615	23- 6	A19639	19- 6	A19663	15- 8	A19687	13-12
A19616	5-24	A19640	5-20	A19664	7-16	A19688	11-14
A19617	7-30	A19641	7-34	A19665	9-38	A19689	9-42
A19618	23-46	A19642	19-46	A19666	15-44	A19690	11-44
A19619	29-46	A19643	33-46	A19667	37-44	A19691	41-44
A19620	45-30	A19644	45-34	A19668	43-38	A19692	43-42
A19621	45-24	A19645	45-20	A19669	43-16	A19693	43-12
A19622	29- 8	A19646	33- 8	A19670	37-10	A19694	41-10
A19623	23- 8	A19647	19- 8	A19671	15-10	A19695	11-10
A19624	7-24	A19648	7-20	A19672	9-16	A19696	9-12

**Table C.1 Brunswick Unit 1 Cycle 19 Reload Fuel Identification
and Locations (Core Coordinates) (Continued)**

Assembly Type: ATRIUM 10XM BRK1-19
Bundle Description: []
Number Loaded: 138

Fuel ID	Core Coord.						
A19697	25-26	A19732	39-28	A19767	13-32	A19801	41-20
A19698	27-28	A19733	39-26	A19768	39-32	A19802	11-20
A19699	21-28	A19734	13-26	A19769	39-22	A19803	13-36
A19700	31-28	A19735	15-30	A19770	13-22	A19804	39-36
A19701	31-26	A19736	37-30	A19771	15-34	A19805	39-18
A19702	21-26	A19737	37-24	A19772	37-34	A19806	13-18
A19703	23-30	A19738	15-24	A19773	37-20	A19807	15-38
A19704	29-30	A19739	17-32	A19774	15-20	A19808	37-38
A19705	29-24	A19740	35-32	A19775	17-36	A19809	37-16
A19706	23-24	A19741	35-22	A19776	35-36	A19810	15-16
A19707	25-32	A19742	17-22	A19777	35-18	A19811	17-40
A19708	27-32	A19743	19-34	A19778	17-18	A19812	35-40
A19709	27-22	A19744	33-34	A19779	19-38	A19813	35-14
A19710	25-22	A19745	33-20	A19780	33-38	A19814	17-14
A19711	17-28	A19746	19-20	A19781	33-16	A19815	19-42
A19712	35-28	A19747	21-36	A19782	19-16	A19816	33-42
A19713	35-26	A19748	31-36	A19783	21-40	A19817	33-12
A19714	17-26	A19749	31-18	A19784	31-40	A19818	19-12
A19715	19-30	A19750	21-18	A19785	31-14	A19819	21-44
A19716	33-30	A19751	23-38	A19786	21-14	A19820	31-44
A19717	33-24	A19752	29-38	A19787	23-42	A19821	31-10
A19718	19-24	A19753	29-16	A19788	29-42	A19822	21-10
A19719	21-32	A19754	23-16	A19789	29-12	A19823	9-36
A19720	31-32	A19755	25-40	A19790	23-12	A19824	43-36
A19721	31-22	A19756	27-40	A19791	25-44	A19825	43-18
A19722	21-22	A19757	27-14	A19792	27-44	A19826	9-18
A19723	23-34	A19758	25-14	A19793	27-10	A19827	13-40
A19724	29-34	A19759	9-28	A19794	25-10	A19828	39-40
A19725	29-20	A19760	43-28	A19795	9-32	A19829	39-14
A19726	23-20	A19761	43-26	A19796	43-32	A19830	13-14
A19727	25-36	A19762	9-26	A19797	43-22	A19831	17-44
A19728	27-36	A19763	11-30	A19798	9-22	A19832	35-44
A19729	27-18	A19764	41-30	A19799	11-34	A19833	35-10
A19730	25-18	A19765	41-24	A19800	41-34	A19834	17-10
A19731	13-28	A19766	11-24				

Appendix D Brunswick Unit 1 Cycle 19 Radial Exposure and Power Distributions

	1	3	5	7	9	11	13	15	17	19	21	23	25
52													
50													
48													
46													
44													
42													
40													
38													
36	34.893	22.887	0.000	0.000	0.000	22.331	0.000	22.482	0.000	23.109	0.000	22.856	
34	33.781	22.096	20.658	0.000	0.000	22.095	0.000	22.020	0.000	22.937	0.000	23.119	0.000
32	30.221	19.669	0.000	0.000	22.151	0.000	22.993	0.000	23.133	0.000	22.622	0.000	22.570
30	32.605	20.305	23.517	0.000	0.000	22.462	0.000	22.029	0.000	23.234	0.000	22.606	0.000
28	31.727	19.414	0.000	0.000	22.459	0.000	21.716	0.000	22.624	0.000	22.570	0.000	23.569
26	32.758	19.540	0.000	21.438	0.000	22.610	0.000	22.164	0.000	23.065	0.000	23.733	23.450
24	32.099	19.712	0.000	21.511	0.000	22.556	0.000	22.034	0.000	22.835	0.000	23.181	0.000
22	31.554	19.409	0.000	0.000	22.472	0.000	21.695	0.000	22.580	0.000	22.515	0.000	23.532
20	32.465	20.405	23.523	0.000	0.000	22.428	0.000	21.952	0.000	23.244	0.000	22.348	0.000
18	32.716	19.845	0.000	0.000	22.065	0.000	23.448	0.000	22.370	0.000	22.574	0.000	22.561
16	33.427	22.152	20.709	0.000	0.000	22.148	0.000	22.042	0.000	23.127	0.000	22.993	0.000
14	34.638	22.862	0.000	0.000	0.000	22.392	0.000	22.426	0.000	23.271	0.000	22.884	
12	32.314	20.677	23.463	0.000	0.000	22.223	0.000	22.686	0.000	23.778	0.000		
10	33.008	21.169	0.000	17.898	0.000	0.000	0.000	22.948	0.000	23.242	0.000	23.420	
8	39.813	32.370	17.979	0.000	23.739	0.000	0.000	0.000	23.060	0.000	23.143	0.000	
6		39.076	30.873	21.195	21.376	0.000	0.000	0.000	0.000	0.000	0.000	0.000	21.701
4			38.879	33.762	34.476	22.920	21.157	0.000	23.687	0.000	0.000	0.000	
2						36.828	22.275	20.610	19.772	19.397	19.662		
							33.566	32.655	32.712	32.104	30.785		

Figure D.1 Brunswick Unit 1 Cycle 19 BOC Exposure Distribution (0.0 GWd/MTU)

	27	29	31	33	35	37	39	41	43	45	47	49	51
52	31.902	31.400	32.501	32.297	32.962								
50	20.026	19.769	20.177	20.834	22.652	34.709							
48	0.000	0.000	24.044	0.000	21.242	23.341	32.424	31.678	38.995				
46	22.010	0.000	0.000	0.000	0.000	0.000	21.323	21.583	31.740	38.628			
44	0.000	22.959	0.000	23.265	0.000	0.000	23.771	0.000	18.216	31.056	39.224		
42	23.559	0.000	23.399	0.000	22.765	0.000	0.000	18.308	0.000	21.458	34.644		
40	0.000	23.472	0.000	23.143	0.000	22.664	0.000	0.000	24.000	21.149	32.646		
38	23.025	0.000	23.630	0.000	22.711	0.000	22.564	0.000	0.000	0.000	23.272	35.322	
36	0.000	23.184	0.000	22.863	0.000	22.462	0.000	22.613	0.000	0.000	21.172	22.503	33.165
34	22.720	0.000	22.852	0.000	23.788	0.000	23.655	0.000	22.555	0.000	0.000	20.809	32.516
32	0.000	22.854	0.000	23.414	0.000	22.419	0.000	22.894	0.000	0.000	23.931	20.070	31.618
30	23.704	0.000	23.232	0.000	22.979	0.000	22.178	0.000	22.936	0.000	0.000	19.746	29.636
28	0.000	23.461	0.000	23.221	0.000	22.508	0.000	23.070	0.000	21.887	0.000	20.016	32.263
26	23.889	23.512	0.000	23.330	0.000	22.585	0.000	23.045	0.000	21.728	0.000	19.842	32.052
24	23.742	0.000	22.936	0.000	23.000	0.000	22.181	0.000	22.921	0.000	0.000	19.676	29.789
22	0.000	22.700	0.000	23.626	0.000	22.446	0.000	22.788	0.000	0.000	23.946	19.917	31.574
20	22.779	0.000	23.011	0.000	22.987	0.000	23.847	0.000	22.593	0.000	0.000	20.636	32.474
18	0.000	23.149	0.000	23.505	0.000	22.320	0.000	22.511	0.000	0.000	21.050	22.366	34.378
16	23.222	0.000	23.190	0.000	22.775	0.000	22.763	0.000	0.000	0.000	23.201	35.554	
14	0.000	23.545	0.000	23.240	0.000	22.604	0.000	0.000	24.012	21.103	33.132		
12	23.649	0.000	23.660	0.000	22.837	0.000	0.000	18.285	0.000	21.314	33.639		
10	0.000	23.323	0.000	23.424	0.000	0.000	23.286	0.000	18.093	31.487	38.761		
8	22.037	0.000	0.000	0.000	0.000	0.000	21.378	21.585	30.694	38.805			
6	0.000	0.000	24.120	0.000	21.233	23.312	32.241	33.372	39.185				
4	19.983	19.728	20.179	20.803	22.661	34.521							
2	32.531	31.726	30.683	32.612	32.323								

Figure D.1 Brunswick Unit 1 Cycle 19 BOC Exposure Distribution (0.0 GWd/MTU) (Continued)

**Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLA+ Operating Domain**

ANP-3013(NP)
Revision 0
Page D-4

	1	3	5	7	9	11	13	15	17	19	21	23	25		
52										40.569	41.201	39.810	41.337	42.147	
50								42.627	35.057	35.079	35.404	35.376	35.836		
48					42.844	41.939	43.003	37.762	38.293	19.905	42.231	20.974	21.071		
46					43.030	43.051	35.602	37.904	19.962	21.637	22.600	23.020	23.264	42.740	
44					44.811	41.133	33.696	19.353	42.976	22.735	23.171	44.321	23.721	44.547	23.352
42					42.095	35.408	19.424	38.820	23.495	24.302	44.402	24.090	44.829	23.831	44.542
40					43.165	37.506	42.624	23.544	24.204	44.606	24.165	43.952	23.178	44.193	23.183
38		43.926	37.822	20.127	22.856	24.344	44.568	24.540	44.233	23.673	43.900	22.894	43.866		
36	40.798	34.985	38.138	21.843	23.334	43.974	23.816	43.572	23.157	43.752	22.849	43.855	23.354		
34	38.456	34.402	20.129	22.849	43.816	24.212	44.321	23.345	43.935	22.962	43.594	23.249	44.122		
32	41.184	35.842	42.266	23.308	24.128	44.417	23.186	43.018	23.196	44.370	24.185	44.644	24.500		
30	40.799	35.415	21.206	23.574	44.288	24.190	42.845	22.924	43.758	23.647	44.681	24.575	45.612		
28	41.879	35.808	21.327	42.727	23.670	44.068	22.918	43.077	23.495	44.641	24.518	45.717	44.915		
26	41.375	35.971	21.328	42.775	23.672	44.023	22.928	42.971	23.523	44.480	24.560	45.280	23.836		
24	40.671	35.429	21.207	23.576	44.314	24.204	42.850	22.974	43.814	23.772	44.728	24.697	45.600		
22	41.028	35.924	42.278	23.314	24.140	44.408	23.217	43.005	23.333	44.528	24.286	44.540	24.564		
20	40.761	34.541	20.126	22.858	43.771	24.225	44.719	23.407	43.349	23.051	43.628	23.315	44.154		
18	40.443	35.024	38.184	21.855	23.349	44.046	23.846	43.638	23.215	43.986	22.890	43.805	23.389		
16		43.708	37.807	20.146	22.875	24.368	44.607	24.567	44.205	23.684	44.031	22.888	43.904		
14		43.047	37.532	42.802	23.563	24.224	44.514	24.155	44.265	23.159	44.491	23.188			
12		41.134	35.549	19.431	38.604	23.506	24.299	44.687	24.095	44.798	23.844	44.573			
10		45.716	42.554	33.754	19.355	42.937	22.727	23.171	44.405	23.745	44.553	23.379			
8			45.713	41.090	35.491	37.985	19.934	21.631	22.612	23.048	23.301	42.714			
6				44.819	41.782	44.900	37.637	38.378	19.912	42.261	21.014	21.119			
4							45.478	34.958	35.087	35.255	35.328	35.822			
2								40.494	40.605	41.355	41.111	40.056			

Figure D.2 Brunswick Unit 1 Cycle 19 EOC Exposure Distribution (19.2 GWd/MTU)

	27	29	31	33	35	37	39	41	43	45	47	49	51
52	41.034	40.437	41.065	40.243	39.940								
50	36.080	35.570	35.531	35.224	35.273	43.611							
48	21.051	20.914	42.476	19.811	38.389	38.000	43.053	39.859	44.911				
46	42.927	23.209	22.936	22.490	21.514	19.837	37.877	35.776	41.829	45.229			
44	23.330	44.347	23.630	44.444	23.017	22.569	42.830	19.187	33.820	41.159	45.095		
42	44.661	23.757	44.821	23.928	44.335	24.091	23.282	38.746	19.198	35.633	42.610		
40	23.149	44.151	23.009	44.509	23.935	44.673	23.953	23.278	43.020	37.701	43.255		
38	43.982	22.773	44.197	23.464	44.226	24.273	44.526	24.037	22.541	19.819	37.910	44.112	
36	23.322	43.835	22.704	43.529	22.914	43.706	23.499	44.119	22.987	21.506	38.312	35.112	40.054
34	44.225	23.161	43.676	22.771	44.254	23.053	44.601	23.845	43.864	22.499	19.809	35.192	40.425
32	24.477	44.792	24.038	44.420	23.003	43.101	22.844	44.462	23.757	22.954	42.359	35.429	40.172
30	45.683	24.523	45.081	23.492	43.887	22.621	42.949	23.813	44.360	23.215	20.900	35.519	38.863
28	23.781	45.390	24.345	44.574	23.212	43.098	22.564	44.128	23.291	42.790	21.021	36.039	41.356
26	45.262	45.447	24.327	44.650	23.195	43.151	22.559	44.102	23.292	42.654	21.025	35.885	41.165
24	45.741	24.473	44.845	23.405	43.833	22.595	42.938	23.811	44.352	23.221	20.907	35.463	39.007
22	24.494	44.679	24.018	44.537	22.922	43.109	22.837	44.370	23.762	22.960	42.380	35.288	40.127
20	44.293	23.172	43.812	22.756	43.590	23.050	44.732	23.852	43.901	22.508	19.817	35.030	40.388
18	23.347	43.850	22.707	44.081	22.915	43.586	23.510	44.040	23.000	21.516	38.212	34.983	41.234
16	44.144	22.813	43.851	23.464	44.271	24.270	44.652	24.052	22.557	19.832	37.850	44.320	
14	23.160	44.247	23.041	44.603	23.936	44.620	23.963	23.293	43.051	37.682	43.657		
12	44.743	23.756	45.044	23.927	44.406	24.108	23.303	38.753	19.222	35.540	41.675		
10	23.347	44.609	23.625	44.597	23.037	22.598	42.430	19.211	33.732	41.575	44.683		
8	42.974	23.225	22.950	22.512	21.546	19.872	37.950	35.793	40.868	45.423			
6	21.095	20.955	42.583	19.857	38.428	38.009	42.906	41.449	45.092				
4	36.090	35.592	35.608	35.265	35.346	43.486							
2	41.724	40.800	39.473	40.602	39.390								

Figure D.2 Brunswick Unit 1 Cycle 19 EOC Exposure Distribution (19.2 GWd/MTU) (Continued)

	1	3	5	7	9	11	13	15	17	19	21	23	25
52													
50													
48													
46													
44													
42													
40													
38													
36	0.426	0.732	0.944	1.067	1.065	1.105	1.222	1.167	0.927	0.919	1.207	1.216	1.174
34	0.488	0.826	1.029	1.117	1.087	1.149	1.193	1.203	0.923	0.940	1.188	1.257	1.159
32	0.510	0.874	1.014	1.147	1.184	1.201	1.262	1.230	1.220	1.186	1.258	1.240	1.258
30	0.537	0.890	1.078	1.165	1.154	1.225	1.249	1.284	1.238	1.267	1.246	1.266	1.194
28	0.538	0.898	1.081	1.109	1.031	1.053	1.254	1.299	1.196	1.165	1.266	1.196	0.930
26	0.545	0.896	1.080	1.108	1.031	1.054	1.254	1.260	1.196	1.168	1.265	1.193	0.937
24	0.539	0.889	1.077	1.164	1.155	1.225	1.249	1.284	1.237	1.266	1.244	1.259	1.186
22	0.508	0.872	1.013	1.147	1.183	1.201	1.262	1.231	1.219	1.181	1.255	1.244	1.258
20	0.476	0.823	1.028	1.116	1.086	1.147	1.193	1.203	0.929	0.939	1.186	1.254	1.161
18	0.425	0.730	0.943	1.066	1.063	1.103	1.221	1.165	0.926	0.917	1.201	1.208	1.174
16	0.536	0.824	1.010	1.118	1.200	1.183	1.213	1.154	1.184	1.185	1.251	1.221	
14		0.623	0.927	1.043	1.174	1.191	1.185	1.205	1.172	1.229	1.190	1.217	
12		0.481	0.812	1.021	1.104	1.168	1.188	1.081	1.123	1.159	1.190	1.016	
10		0.363	0.590	0.882	1.017	1.032	1.103	1.045	1.055	1.155	1.125	1.005	
8			0.402	0.594	0.805	0.908	0.993	1.046	1.094	1.123	1.140	1.083	
6				0.363	0.471	0.599	0.805	0.921	1.009	0.995	1.059	1.061	
4							0.508	0.713	0.805	0.861	0.877	0.884	
2								0.415	0.467	0.506	0.528	0.541	

**Figure D.3 Brunswick Unit 1 Cycle 19 Radial Power Distribution
 at 0.0 MWd/MTU**

	27	29	31	33	35	37	39	41	43	45	47	49	51
52	0.533	0.530	0.504	0.467	0.419								
50	0.880	0.873	0.856	0.803	0.712	0.523							
48	1.059	1.056	0.990	1.006	0.920	0.805	0.614	0.484	0.364				
46	1.079	1.137	1.120	1.090	1.043	0.991	0.909	0.804	0.590	0.401			
44	1.003	1.124	1.151	1.048	1.040	1.099	1.028	1.013	0.879	0.592	0.363		
42	1.013	1.187	1.154	1.117	1.074	1.182	1.162	1.095	1.015	0.805	0.472		
40	1.216	1.189	1.224	1.165	1.198	1.174	1.182	1.165	1.030	0.914	0.616		
38	1.218	1.247	1.174	1.176	1.142	1.202	1.180	1.187	1.105	0.997	0.809	0.520	
36	1.172	1.207	1.194	0.910	0.915	1.149	1.205	1.084	1.048	1.051	0.927	0.717	0.418
34	1.155	1.247	1.174	0.928	0.905	1.185	1.171	1.129	1.067	1.101	1.014	0.810	0.469
32	1.253	1.228	1.242	1.167	1.201	1.208	1.241	1.178	1.165	1.131	0.998	0.865	0.509
30	1.180	1.248	1.216	1.249	1.217	1.263	1.224	1.204	1.133	1.147	1.064	0.880	0.546
28	0.934	1.181	1.251	1.149	1.177	1.236	1.233	1.031	1.014	1.090	1.067	0.888	0.538
26	0.926	1.191	1.253	1.149	1.178	1.235	1.233	1.031	1.014	1.092	1.067	0.888	0.539
24	1.191	1.258	1.231	1.251	1.217	1.263	1.225	1.204	1.133	1.147	1.064	0.880	0.544
22	1.257	1.237	1.246	1.165	1.202	1.208	1.242	1.179	1.165	1.130	0.998	0.864	0.508
20	1.158	1.251	1.176	0.930	0.913	1.186	1.173	1.130	1.065	1.100	1.014	0.809	0.469
18	1.173	1.211	1.198	0.907	0.915	1.150	1.205	1.084	1.048	1.050	0.927	0.716	0.415
16	1.216	1.250	1.188	1.178	1.142	1.200	1.167	1.186	1.104	0.996	0.808	0.517	
14	1.216	1.190	1.226	1.164	1.197	1.172	1.179	1.162	1.029	0.914	0.609		
12	1.013	1.186	1.150	1.116	1.073	1.180	1.159	1.094	1.013	0.806	0.475		
10	1.003	1.114	1.149	1.046	1.040	1.098	1.026	1.012	0.878	0.589	0.364		
8	1.080	1.136	1.119	1.090	1.043	0.991	0.908	0.803	0.594	0.402			
6	1.060	1.057	0.990	1.008	0.922	0.806	0.615	0.476	0.363				
4	0.882	0.877	0.861	0.807	0.716	0.527							
2	0.535	0.533	0.518	0.470	0.425								

**Figure D.3 Brunswick Unit 1 Cycle 19 Radial Power Distribution
at 0.0 MWd/MTU (Continued)**

	1	3	5	7	9	11	13	15	17	19	21	23	25	
52										0.299	0.351	0.388	0.400	0.407
50									0.387	0.591	0.686	0.727	0.755	0.770
48					0.258	0.360	0.486	0.709	0.846	1.073	0.908	1.125	1.129	
46				0.291	0.465	0.670	0.800	1.090	1.190	1.233	1.249	1.249	1.031	
44			0.251	0.468	0.745	1.018	0.933	1.235	1.276	1.071	1.293	1.067	1.281	
42			0.347	0.674	1.021	1.009	1.254	1.298	1.090	1.306	1.087	1.307	1.077	
40			0.485	0.806	0.946	1.256	1.299	1.099	1.322	1.108	1.338	1.104	1.332	
38		0.399	0.713	1.094	1.239	1.302	1.098	1.322	1.114	1.339	1.117	1.348	1.107	
36	0.301	0.598	0.852	1.194	1.281	1.099	1.333	1.125	1.353	1.122	1.350	1.110	1.328	
34	0.363	0.692	1.076	1.236	1.083	1.315	1.114	1.350	1.121	1.347	1.108	1.319	1.079	
32	0.376	0.726	0.909	1.252	1.298	1.097	1.351	1.134	1.348	1.099	1.293	1.052	1.252	
30	0.400	0.754	1.125	1.251	1.077	1.317	1.132	1.359	1.112	1.312	1.050	1.227	0.990	
28	0.402	0.771	1.129	1.037	1.288	1.096	1.352	1.128	1.330	1.071	1.248	0.986	0.970	
26	0.410	0.770	1.129	1.037	1.288	1.096	1.351	1.128	1.329	1.073	1.249	0.997	1.185	
24	0.402	0.754	1.124	1.250	1.077	1.315	1.130	1.357	1.109	1.309	1.052	1.235	0.995	
22	0.375	0.724	0.908	1.250	1.296	1.095	1.348	1.132	1.344	1.099	1.292	1.056	1.251	
20	0.355	0.690	1.073	1.233	1.080	1.311	1.104	1.345	1.123	1.342	1.105	1.315	1.077	
18	0.300	0.596	0.850	1.191	1.277	1.096	1.328	1.120	1.347	1.115	1.343	1.109	1.322	
16	0.399	0.712	1.090	1.235	1.298	1.097	1.316	1.109	1.331	1.109	1.340	1.102		
14	0.484	0.802	0.935	1.251	1.293	1.093	1.314	1.099	1.329	1.095	1.323			
12	0.358	0.671	1.016	1.008	1.248	1.291	1.080	1.298	1.080	1.298	1.071			
10	0.246	0.463	0.741	1.013	0.929	1.228	1.269	1.064	1.285	1.060	1.274			
8		0.284	0.464	0.667	0.793	1.083	1.183	1.226	1.242	1.241	1.026			
6		0.249	0.355	0.470		0.704	0.840	1.067	0.902	1.119	1.124			
4						0.379	0.588	0.682	0.724	0.751	0.767			
2							0.295	0.350	0.381	0.397	0.411			

**Figure D.4 Brunswick Unit 1 Cycle 19 Radial Power Distribution
at 18,788.1 MWd/MTU (EOFP)**

	27	29	31	33	35	37	39	41	43	45	47	49	51
52	0.408	0.403	0.383	0.355	0.303								
50	0.769	0.753	0.725	0.686	0.593	0.400							
48	1.129	1.125	0.906	1.076	0.848	0.711	0.489	0.369	0.253				
46	1.030	1.250	1.252	1.237	1.195	1.095	0.805	0.674	0.468	0.290			
44	1.282	1.069	1.297	1.073	1.283	1.242	0.939	1.024	0.748	0.469	0.252		
42	1.077	1.309	1.089	1.312	1.095	1.307	1.262	1.015	1.026	0.675	0.361		
40	1.333	1.106	1.343	1.105	1.330	1.104	1.309	1.265	0.941	0.807	0.493		
38	1.107	1.351	1.122	1.346	1.120	1.334	1.107	1.313	1.249	1.101	0.716	0.400	
36	1.329	1.113	1.357	1.131	1.363	1.132	1.346	1.105	1.293	1.204	0.855	0.599	0.304
34	1.080	1.324	1.112	1.356	1.124	1.363	1.122	1.329	1.092	1.249	1.085	0.693	0.359
32	1.256	1.057	1.303	1.105	1.360	1.142	1.367	1.107	1.314	1.267	0.917	0.734	0.386
30	0.997	1.242	1.055	1.322	1.120	1.374	1.141	1.334	1.088	1.267	1.139	0.763	0.418
28	1.187	0.999	1.258	1.080	1.343	1.138	1.369	1.106	1.306	1.048	1.143	0.779	0.413
26	0.968	0.992	1.255	1.079	1.343	1.137	1.369	1.107	1.306	1.049	1.143	0.780	0.414
24	0.988	1.230	1.052	1.321	1.120	1.374	1.141	1.334	1.087	1.267	1.139	0.763	0.418
22	1.250	1.053	1.298	1.106	1.359	1.141	1.366	1.106	1.313	1.266	0.917	0.735	0.386
20	1.076	1.318	1.107	1.353	1.130	1.361	1.115	1.328	1.090	1.248	1.085	0.694	0.359
18	1.323	1.107	1.351	1.120	1.360	1.130	1.344	1.105	1.292	1.203	0.856	0.599	0.302
16	1.101	1.344	1.115	1.341	1.116	1.330	1.105	1.312	1.248	1.100	0.715	0.398	
14	1.325	1.100	1.336	1.099	1.325	1.101	1.307	1.264	0.940	0.807	0.488		
12	1.070	1.302	1.081	1.307	1.091	1.304	1.261	1.014	1.025	0.676	0.364		
10	1.275	1.062	1.290	1.067	1.279	1.241	0.946	1.023	0.747	0.467	0.253		
8	1.025	1.244	1.247	1.232	1.192	1.094	0.803	0.673	0.469	0.289			
6	1.124	1.121	0.902	1.073	0.846	0.709	0.488	0.364	0.251				
4	0.765	0.750	0.723	0.684	0.592	0.399							
2	0.408	0.402	0.389	0.355	0.305								

Figure D.4 Brunswick Unit 1 Cycle 19 Radial Power Distribution at 18,788.1 MWd/MTU (EOFP) (Continued)

AREVA NP Affidavit Regarding Withholding ANP-3013P, Revision 0,
Brunswick Unit 1 Cycle 19 Fuel Cycle Design
MELLLA+ Operating Domain, May 2013

AFFIDAVIT

STATE OF WASHINGTON)
)
 ss.
COUNTY OF BENTON)

1. My name is Alan B. Meginnis. I am Manager, Product Licensing, for AREVA NP Inc. and as such I am authorized to execute this Affidavit.

2. I am familiar with the criteria applied by AREVA NP to determine whether certain AREVA NP information is proprietary. I am familiar with the policies established by AREVA NP to ensure the proper application of these criteria.

3. I am familiar with the AREVA NP information contained in the report ANP-3013(P), Revision 0, "Brunswick Unit 1 Cycle 19 Fuel Cycle Design MELLLA+ Operating Domain," dated May 2013 and referred to herein as "Document." Information contained in this Document has been classified by AREVA NP as proprietary in accordance with the policies established by AREVA NP for the control and protection of proprietary and confidential information.

4. This Document contains information of a proprietary and confidential nature and is of the type customarily held in confidence by AREVA NP and not made available to the public. Based on my experience, I am aware that other companies regard information of the kind contained in this Document as proprietary and confidential.

5. This Document has been made available to the U.S. Nuclear Regulatory Commission in confidence with the request that the information contained in this Document be withheld from public disclosure. The request for withholding of proprietary information is made in accordance with 10 CFR 2.390. The information for which withholding from disclosure is

requested qualifies under 10 CFR 2.390(a)(4) "Trade secrets and commercial or financial information."

6. The following criteria are customarily applied by AREVA NP to determine whether information should be classified as proprietary:

- (a) The information reveals details of AREVA NP's research and development plans and programs or their results.
- (b) Use of the information by a competitor would permit the competitor to significantly reduce its expenditures, in time or resources, to design, produce, or market a similar product or service.
- (c) The information includes test data or analytical techniques concerning a process, methodology, or component, the application of which results in a competitive advantage for AREVA NP.
- (d) The information reveals certain distinguishing aspects of a process, methodology, or component, the exclusive use of which provides a competitive advantage for AREVA NP in product optimization or marketability.
- (e) The information is vital to a competitive advantage held by AREVA NP, would be helpful to competitors to AREVA NP, and would likely cause substantial harm to the competitive position of AREVA NP.

The information in the Document is considered proprietary for the reasons set forth in paragraphs 6(b), 6(d) and 6(e) above.

7. In accordance with AREVA NP's policies governing the protection and control of information, proprietary information contained in this Document have been made available, on a limited basis, to others outside AREVA NP only as required and under suitable agreement providing for nondisclosure and limited use of the information.

8. AREVA NP policy requires that proprietary information be kept in a secured file or area and distributed on a need-to-know basis.

9. The foregoing statements are true and correct to the best of my knowledge, information, and belief.

An B McCoy

SUBSCRIBED before me this 22

day of May, 2013.

Susan K McCoy

Susan K. McCoy
NOTARY PUBLIC, STATE OF WASHINGTON
MY COMMISSION EXPIRES: 1/14/2016

