

NRR-PMDAPEm Resource

From: Harrison Albon <awharrison@STPEGS.COM>
Sent: Tuesday, September 13, 2016 5:51 PM
To: Regner, Lisa; Klos, John
Subject: [External_Sender] RAI SSIB-3-4 draft clarification
Attachments: SSIB RAI 4 Supplement.pdf

Lisa, John,

Here is a clarification on RAI SSIB-3-4 for discussion with Steve Smith in the 9/14/16 public call.

Wayne Harrison
STP Licensing
(979) 292-6413

Hearing Identifier: NRR_PMDA
Email Number: 3054

Mail Envelope Properties (C08E954F-A7BB-4094-90A6-9F19FC2AAB87)

Subject: [External_Sender] RAI SSIB-3-4 draft clarification
Sent Date: 9/13/2016 5:50:57 PM
Received Date: 9/13/2016 5:51:00 PM
From: Harrison Albon

Created By: awharrison@STPEGS.COM

Recipients:
"Regner, Lisa" <Lisa.Regner@nrc.gov>
Tracking Status: None
"Klos, John" <John.Klos@nrc.gov>
Tracking Status: None

Post Office: stpegs.com

| Files | Size | Date & Time |
|---------------------------|-------------|------------------------|
| MESSAGE | 167 | 9/13/2016 5:51:00 PM |
| SSIB RAI 4 Supplement.pdf | | 23714 |

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

This supplement is written to supplement 2016 RAI SSIB-4 for additional clarification.

Maximum particulate generation was calculated for Di_small sizes at each critical weld location and for DEGB sizes at non-critical weld locations to preserve RoverD fiber evaluation calculated risk. Non-DEGB calculations were performed with angular sweeps of 360 degrees in one degree increments to find the maximum amount of particulate generated at each location .