

Part 21 (PAR)

Event # 51494

Rep Org: EMERSON PROCESS MANAGEMENT	Notification Date / Time: 10/23/2015 16:53 (EDT)
Supplier: FISHER CONTROLS INTERNATIONAL LLC	Event Date / Time: 09/02/2015 (CDT)
	Last Modification: 11/05/2015
Region: 3	Docket #:
City: MARSHALLTOWN	Agreement State: Yes
County:	License #:
State: IA	
NRC Notified by: DENNIS SWANSON	Notifications: ALAN BLAMEY R2DO
HQ Ops Officer: DONG HWA PARK	PART 21/50.55 REACTORS EMAIL
Emergency Class: NON EMERGENCY	
10 CFR Section:	
21.21(d)(3)(i)	DEFECTS AND NONCOMPLIANCE
50.55(e)	CONSTRUCT DEFICIENCY

PART-21 REPORT - CLOSED SWITCH NOT ACTUATING WHEN VALVE IS FULLY CLOSED

The following is a summary of a submitted facsimile:

"Items subject to this Fisher Information Notice (FIN) were provided to Catawba Nuclear Station (CNS) per CNS Order 00178457 (Fisher Order Number 033-D800306145). Specifically, Fisher supplied an 8 inch Design A11 Butterfly Valve with a Type 1052 Actuator and TopWorx Switches, serial number F000458892 ('Equipment'). The issue is with the closed switch not actuating when the valve is fully closed.

"The purpose of this FIN is to alert CNS that as of 2 September 2015, Fisher Controls International LLC (Fisher) became aware of a situation which may affect the performance of the Equipment, including its safety-related function.

"If there are any technical questions or concerns, please contact: Ben Ahrens, Quality Manager, Emerson Process Management, Fisher Controls International LLC, 301 South 1st Avenue, Marshalltown, La 50158, Phone: (641) 754-2249, benjamin.ahrens@emerson.com"

*** UPDATE ON 11/5/15 AT 1731 EST FROM CHAD ENGLE TO DONG PARK ***

The following is a summary of a submitted facsimile:

"The purpose of this document is to correct an erroneous serial number on FIN 2015-03, dated 22 October 2015."

Serial number F000458892 should read F000503836.

JE19
NRR

11/05/2015

U.S. Nuclear Regulatory Commission Operations Center Event Report

Page 2

Notified R2DO (Desai) and PART 21/50.55 REACTORS via email.



Fisher Controls International LLC
301 South First Ave
P.O. Box 190
Marshalltown, Iowa 50158-0190
USA
T (641) 754-3011
F (641) 754-2830

Fisher Information Notice: FIN 2015-03 Amendment A

29 October 2015

Purpose: The purpose of this document is to correct an erroneous serial number on FIN 2015-03, dated 22 October 2015.

From:

A handwritten signature in black ink, appearing to read 'Chad Engle'.

Chad Engle
Nuclear Business Unit Director
Fisher Controls International LLC
301 South First Avenue
Marshalltown, IA 50158
Fax: (641) 754-2854

Revisions:

The section "Equipment Affected by this Information Notice" contains an inaccurate reference to serial number F000458892. F000458892 is the non-problematic construction that shipped under the same order number as the problematic construction subject to FIN 2015-03. This serial number should read as F000503836. Additionally, in the final paragraph of the "Discussion" section, the reference to Item CC2A is meant to be a reference to CC1A.

If there are any technical questions or concerns, please contact:

Ben Ahrens
Quality Manager
Emerson Process Management
Fisher Controls International LLC
301 South 1st Avenue
Marshalltown, IA 50158
Phone: (641) 754-2249
benjamin.ahrens@emerson.com



Facsimile

301 South First Ave
Marshalltown, IA 50158

T 641-754-3011
F 641-754-2830

To: NRC Operations Center - Attn: Bill Huffman
Fax: 301-816-5151
From: George Baitinger, Emerson Process Management
Date: 11/5/2015
Pages: 3
(incl cover)

Attachment: Fisher Information Notice – (FIN) 2015-03 Amendment A

For technical questions please contact George Baitinger at (641) 754-2026.



Fisher Controls International LLC
301 South First Ave.
P.O. Box 190
Marshalltown, Iowa 50158-0190
USA
T (641) 754-3011
F (641) 754-2830

November 5, 2015

To Whom It May Concern:

Attached is a Fisher Information Notice, (FIN) 2015-03.

Emerson Process Management – Fisher Valves complies with the reporting requirements of 10 CFR Part 21 Section 21.21 (b) and 10 CFR Part 50.55 (e) by informing the U.S. Nuclear Regulatory Commission Licensees or Purchaser of deviations or failures to comply.

Please review the attached FIN notice for applicability to your facility.

A handwritten signature in cursive script, appearing to read "George Baitinger".

George Baitinger
Director, Quality Americas

Attachments

