

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9110150295 DOC. DATE: 91/10/08 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 AUTH. NAME AUTHOR AFFILIATION
 TUCKMAN, M.S. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Rev 3 to core operating limits rept for Unit 1, Cycle 14.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 144
 TITLE: OR Submittal: General Distribution

NOTES: *Revised 10/22/91 J.H.*

| | RECIPIENT | | COPIES | | | RECIPIENT | | COPIES | | |
|-----------|-----------------|--|--------|------|--|--------------------|--|--------|------|--|
| | ID CODE/NAME | | LTR | ENCL | | ID CODE/NAME | | LTR | ENCL | |
| | PD2-3 LA | | 1 | 1 | | PD2-3 PD | | 1 | 1 | |
| | WIENS, L | | 2 | 2 | | | | | | |
| INTERNAL: | ACRS | | 6 | 6 | | NRR/DET/ECMB 7D | | 1 | 1 | |
| | NRR/DET/ESGB | | 1 | 1 | | NRR/DOEA/OTSB11 | | 1 | 1 | |
| | NRR/DST 8E2 | | 1 | 1 | | NRR/DST/SELB 7E | | 1 | 1 | |
| | NRR/DST/SICB8H7 | | 1 | 1 | | NRR/DST/SRXB 8E | | 1 | 1 | |
| | NUDOCS-ABSTRACT | | 1 | 1 | | OC/LFMB | | 1 | 0 | |
| | OGC/HDS2 | | 1 | 0 | | <u>REG FILE 01</u> | | 1 | 1 | |
| | RES/DSIR/EIB | | 1 | 1 | | | | | | |
| EXTERNAL: | NRC PDR | | 1 | 1 | | NSIC | | 1 | 1 | |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 24 ENCL 22

R
I
D
S
/
A
D
D
S
/
A
D
D
S

*MAJ
J.H.*

Duke Power Company
Nuclear Production Dept.
P.O. Box 1007
Charlotte, N.C. 28201-1007

M.S. TUCKMAN
Vice President
Nuclear Operations
(704)373-3851



DUKE POWER

October 8, 1991

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Oconee Nuclear Station, Unit 1
Docket No. 50-269
Core Operating Limits Report
Oconee 1 Cycle 14

Gentlemen:

Pursuant to Technical Specification 6.9.4, please find attached Revision 3 of the core operating limits report for the Oconee Nuclear Station, Unit 1, Cycle 14.

Very truly yours,

M. S. Tuckman

SGB100/sgb

Attachment

cc: Mr. S. D. Ebnetter
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. L. A. Wiens
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. P. E. Harmon, Sr. NRC Resident Inspector
Oconee Nuclear Station

9110150295 911008
PDR AD00K 05000269
PDR

A001
11

Oconee Nuclear Station
Core Operating Limits Report
Revision 1

REVISION LOG

| <u>Revision</u> | <u>Effective Date</u> | <u>Effective Pages</u> |
|-----------------|-----------------------|------------------------|
| Original Issue | 13MAR91 | Page 1 - 22 |
| Revision 1 | 06MAY91 | Page 1 - 4D |

Oconee 1 Cycle 14

ROD INDEX OPERATIONAL LIMITS

0 EFPD to EOC

| | POWER <u>% OF 2568MW</u> | RI, %WD | |
|--------|-----------------------------|------------|------------|
| | | <u>MIN</u> | <u>MAX</u> |
| 4 PUMP | 102 | 260.0 | 300.0 |
| | 90 | 260.0 | 300.0 |
| | 80 | 240.0 | 300.0 |
| | 50 | 200.0 | 300.0 |
| | 15 | 90.0 | 300.0 |
| | 5 | 0.0 | 300.0 |
| 3 PUMP | 77 | 236.0 | 300.0 |
| | 50 | 200.0 | 300.0 |
| | 15 | 90.0 | 300.0 |
| | 5 | 0.0 | 300.0 |

Referred to by Tech. Spec.

- 3.1.3.5
- 3.1.11
- 3.5.2.1.b
- 3.5.2.2.d.2.c
- 3.5.2.3
- 3.5.2.5.c

Oconee 1 Cycle 14

ROD INDEX SHUTDOWN MARGIN LIMITS

0 EFPD to EOC

| | POWER <u>% OF 2568MW</u> | RI, %WD | |
|--------|-----------------------------|------------|------------|
| | | <u>MIN</u> | <u>MAX</u> |
| 4 PUMP | 102 | 220.0 | 300.0 |
| | 50 | 160.0 | 300.0 |
| | 15 | 90.0 | 300.0 |
| | 5 | 0.0 | 300.0 |
| 3 PUMP | 77 | 210.0 | 300.0 |
| | 50 | 160.0 | 300.0 |
| | 15 | 90.0 | 300.0 |
| | 5 | 0.0 | 300.0 |

Referred to by Tech. Spec.:

- 3.1.3.5
- 3.1.11
- 3.5.2.1.b
- 3.5.2.2.d.2.c
- 3.5.2.3
- 3.5.2.5.c