

APR1400
Feedback on Draft Response to RAI 255-8285, Question 03.08.05-13
Prepared August 3, 2016

The response is acceptable except for addressing the items below.

Item (1)

The response correctly states that the severe accident load is not considered for the basemat analysis and design, and the severe accident was changed to combustible gas control inside containment. However, the last load combination in Table 1 still identifies a load combination named "Severe Accident" and added a new footnote 11 which states that this is "Beyond design load combination." Also, it identifies Ps as the load to include in this load combination; however, Ps was defined in the response to RAI Question 3.8.1-1 as the load developed from hydrogen generation due to fuel clad water interaction, not severe accident events. So this is an inconsistency that should be addressed. Also, as discussed in the past, normally severe accident evaluation is addressed as part of Section 19 of the DCD, not Section 3.8, and the hydrogen generation load combination needs to be included in Table 1 (RCB) and then combined with the appropriate load combination in Table 2 (AB) because the two structures are supported by the common basemat.

KHNP INPUT

In the table 1 of response, "Severe Accident" of loading condition column will be changed to "Combustible Gas Control inside Containment" in accordance with response to RAI Question 3.8.1-1.

The combustible gas load associated with hydrogen generation caused by the reaction between the fuel cladding and the water coolant is applied to the containment evaluation above design-basis pressure, not related to the design of containment structure.

With regard to load combination of AB structure, in accordance with RG 1.216 Position 2, for combustible gas control load, the concrete containment should meet the Factored Load Category requirements of ASME Code, Section III, Division 2, Subarticle CC-3720. This requirement is for pressure boundary structure not for other structures. Therefore, the combustible gas load is not necessary to add in the load combination of AB structure.

Item (2)

The response states that "There is no impact on any Technical, Topical, or Environmental Report." However, the revised Tables 1 and 2 should be incorporated into the KHNP technical report APR1400-E-S-NR-14006-P, Rev. 1. Also, the load combinations in Tables 1 and 2 are not

consistent with the load combinations presented in Table 3-5 of the technical report. Lastly, Table 3-5 of the technical report separates RCB load combinations from AB load combinations for Test, Normal, and Abnormal loading combinations, while providing RCB and AB (combined) load combinations for only Abnormal/Extreme. This needs to be explained or revised because all load combinations (not just Abnormal/Extreme) need to be considered for the combined RCB and AB basemat analysis, since the basemat is common and monolithic to both structures.

KHNP INPUT

The revised table 1 and 2 will be added to Technical report APR1400-E-S-NR-14006-P/NP. So, the load combination table 3-5 related with feedback item (2) is revised as shown attachment.

Attachment

Table 1. Selected Loading Conditions of Superstructure for Basemat analysis (RCB)

Loading Condition	D	L	F	Pt	G	Pa	Tt	To	Ta	Es	W	Wt	Ro	Ra	Yr	Yj	Ym	Yf	H	Hs	Pv	Ha	Ps	Analysis
Test	1.0	1.0	1.0	1.0	-	-	(1.0)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	yes
Construction	1.0	1.0	1.0	-	-	-	-	1.0	-	-	1.0	-	-	-	-	-	-	-	-	-	-	-	-	no(①)
Normal	1.0	1.0	1.0	-	(1.0)	-	-	(1.0)	-	-	-	-	(1.0)	-	-	-	-	-	-	-	(1.0)	-	-	yes
Severe Environmental	1.0	1.3	1.0	-	(1.0)	-	-	(1.0)	-	-	(1.5)	-	(1.0)	-	-	-	-	-	-	-	(1.0)	-	-	yes
Extreme Environmental	1.0	1.3	1.0	-	1.0	-	-	1.0	-	-	-	-	1.0	-	-	-	-	-	1.5	-	1.0	-	-	no(②)
	1.0	1.0	1.0	-	1.0	-	-	1.0	-	1.0	-	-	1.0	-	-	-	-	-	-	-	1.0	-	-	no(③)
	1.0	1.0	1.0	-	1.0	-	-	1.0	-	-	-	1.0	1.0	-	-	-	-	-	-	-	1.0	-	-	no(④)
Abnormal	1.0	1.0	1.0	-	(1.0)	1.5	-	-	(1.0)	-	-	-	-	(1.0)	-	-	-	-	-	-	-	-	-	yes
	1.0	1.0	1.0	-	1.0	1.0	-	-	1.0	-	-	-	-	1.25	-	-	-	-	-	-	-	-	-	no(⑥)
	1.0	1.0	1.0	-	1.25	1.25	-	-	1.0	-	-	-	-	1.0	-	-	-	-	-	-	-	-	-	no(⑦)
Abnormal/Severe Environmental	1.0	1.0	1.0	-	1.0	1.25	-	-	1.0	-	1.25	-	-	1.0	-	-	-	-	-	-	-	-	-	no(⑧)
	1.0	1.0	1.0	-	1.0	-	-	1.0	-	-	-	-	-	-	-	-	-	-	-	-	-	1.0	-	no(⑨)
	1.0	1.0	1.0	-	1.0	-	-	1.0	-	-	1.0	-	-	-	-	-	-	-	-	-	-	1.0	-	no(⑩)
Abnormal/Extreme Environmental	1.0	1.0	1.0	-	(1.0)	1.0	-	-	(1.0)	1.0	-	-	-	(1.0)	1.0	(1.0)	(1.0)	-	-	-	-	-	-	yes
Combustible Gas Control inside Containment	1.0	-	1.0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	1.0	no(⑪)

* () : load not considered in basemat analysis. * yellow column : considered load combination in basemat analysis.

① - Effect on the basemat due to wind is less than that of Pt, and To is negligible

② - H is not considered to be critical for the basemat (Containment building roof could not contain any rainwater.)

③, ④, ⑤ - Abnormal/ Extreme Environmental combination is more limiting than these combinations.

⑥ - $0.25 \times Ra$ is less critical than $0.5 \times Pa$ for the basemat

⑦, ⑧ - $0.25 \times G$ and $1.25W$ are less critical than $0.25 \times Pa$ for the basemat

⑨, ⑩ - $1.0 \times W$ is less critical than $1.5 \times Pa$ for the basemat

⑪ - Beyond design load combination

Table 2 Selected Loading Conditions of Superstructures for Basemat Analysis (RCB)

Loading Condition	Normal									Severe		Abnormal					Extreme			Analysis
	D	D _d	L	L _h	T _o	R _o	C	P _o	M _o	W	H	P _a	T _a	R _a	Y	M _a	E _s	W _t	H _s	
Construction	1.1	-	1.3	1.1	-	1.1	1.3	-	1.3	1.6	-	-	-	-	-	-	-	-	-	no(①)
	-	0.9	-	1.1	-	-	1.3	-	1.3	1.6	-	-	-	-	-	-	-	-	-	no(②)
Test	1.1	-	1.3	1.1	(1.3)	(1.1)	1.3	(1.3)	(1.3)	-	-	-	-	-	-	-	-	-	-	yes
Normal	1.4	-	1.7	1.4	(1.3)	(1.4)	1.7	(1.7)	(1.7)	-	-	-	-	-	-	-	-	-	-	yes
Severe Environmental	1.4	-	1.7	1.4	1.3	1.4	1.7	1.7	1.7	1.7	-	-	-	-	-	-	-	-	-	no(③)
	1.2	-	-	1.4	1.3	1.2	1.7	1.7	1.7	1.7	-	-	-	-	-	-	-	-	-	no(④)
	1.4	-	1.7	1.4	1.3	1.4	1.7	1.7	1.7	-	1.7	-	-	-	-	-	-	-	-	no(⑤)
	1.2	-	-	1.4	1.3	1.2	1.7	1.7	1.7	-	1.7	-	-	-	-	-	-	-	-	no(⑥)
Abnormal	1.0	-	1.0	1.0	1.0	1.0	1.0	1.0	1.0	-	-	-	-	-	-	1.0	-	-	-	no(⑦)
	1.0	-	1.0	1.0	-	-	1.0	-	(1.0)	-	-	(1.4)	(1.0)	(1.0)	-	-	-	-	-	yes
Extreme Environmental	1.0	-	1.0	1.0	1.0	1.0	1.0	1.0	1.0	-	-	-	-	-	-	-	1.0	-	-	no(⑧)
	1.0	-	1.0	1.0	1.0	1.0	-	1.0	1.0	-	-	-	-	-	-	-	-	1.0	-	no(⑨)
	1.0	-	1.0	1.0	1.0	1.0	-	1.0	1.0	-	-	-	-	-	-	-	-	-	1.0	no(⑩)
Abnormal / Extreme Environmental	1.0	-	1.0	1.0	-	-	1.0	-	(1.0)	-	-	(1.0)	(1.0)	(1.0)	(1.0)	(1.0)	1.0	-	-	Yes

* () : load not considered in basemat analysis. * yellow column : considered load combination in basemat analysis.

①, ② - Governed by the severe environmental load combination

③ - It is the same as Normal loading condition except wind load which is not critical in basemat design.

④ - Governed by the severe environmental load combination

⑤, ⑥ - H is not considered critical for the basemat

⑦, ⑧, ⑨, ⑩ - Abnormal/Extreme Environmental combination is more critical than these combinations

Table 3 Load Combination for NI Common Basemat Analysis

Condition	Load Case	Load Combination	Remark	Reference
Test	LC01	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _t	For RCB basemat design	DCD Table 3.8-2
Normal	LC02	1.0D+1.0L+1.0L ₁ +1.0F		
Severe	LC03	1.0D+1.3L+1.3L ₁ +1.0F		
Abnormal	LC04	1.0D+1.0L+1.0L ₁ +1.0F+1.5Pa		
Test	LC05	1.1D+1.3L+1.1L ₁ +1.0F+1.0P _t	For AB basemat design	DCD Table 3.8-9A
Normal	LC06	1.4D+1.7L+1.4L ₁ +1.0F		
Abnormal	LC07	1.0D+1.0L+1.0L ₁ +1.0F+1.4Pa		
Abnormal /Extreme	LC08	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es01+Lg _d	For RCB & AB Basemat design	DCD Table 3.8-2, 3.8-9A
	LC09	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es02+Lg _d		
	LC10	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es03+Lg _d		
	LC11	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es04+Lg _d		
	LC12	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es05+Lg _d		
	LC13	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es06+Lg _d		
	LC14	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es07+Lg _d		
	LC15	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es08+Lg _d		
	LC16	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es09+Lg _d		
	LC17	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es10+Lg _d		
	LC18	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es11+Lg _d		
	LC19	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es12+Lg _d		
	LC20	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es13+Lg _d		
	LC21	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es14+Lg _d		
	LC22	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es15+Lg _d		
	LC23	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es16+Lg _d		
	LC24	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es17+Lg _d		
	LC25	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es18+Lg _d		
	LC26	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es19+Lg _d		
	LC27	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es20+Lg _d		

LC28	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es21+Lg_d
LC29	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es22+Lg_d
LC30	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es23+Lg_d
LC31	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es24+Lg_d
LC32	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es25+Lg_d
LC33	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es26+Lg_d
LC34	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es27+Lg_d
LC35	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es28+Lg_d
LC36	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es29+Lg_d
LC37	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es30+Lg_d
LC38	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es31+Lg_d
LC39	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es32+Lg_d
LC40	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es33+Lg_d
LC41	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es34+Lg_d
LC42	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es35+Lg_d
LC43	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es36+Lg_d
LC44	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es37+Lg_d
LC45	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es38+Lg_d
LC46	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es39+Lg_d
LC47	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es40+Lg_d
LC48	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es41+Lg_d
LC49	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es42+Lg_d
LC50	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es43+Lg_d
LC51	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es44+Lg_d
LC52	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es45+Lg_d
LC53	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es46+Lg_d
LC54	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es47+Lg_d
LC55	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es48+Lg_d
LC56	1.0D+1.0L+1.0L ₁ +1.0F+1.0P _a +1.0Y _r +1.0Es49+Lg_d

LC57	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es50+Lg_d$
LC58	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es51+Lg_d$
LC59	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es52+Lg_d$
LC60	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es53+Lg_d$
LC61	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es54+Lg_d$
LC62	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es55+Lg_d$
LC63	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es56+Lg_d$
LC64	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es57+Lg_d$
LC65	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es58+Lg_d$
LC66	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es59+Lg_d$
LC67	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es60+Lg_d$
LC68	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es61+Lg_d$
LC69	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es62+Lg_d$
LC70	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es63+Lg_d$
LC71	$1.0D+1.0L+1.0L_1+1.0F+1.0P_a+1.0Y_r$ $+1.0Es64+Lg_d$

Where:

- D = Dead load (Including Hydrostatic load) from RCB and AB
- L = Live load (Including Static Earth Pressure) from RCB and AB
- F = Post-tension load of tendon embedded RCB shell and dome
- P_a = Design internal pressure of RCB shell and dome
- P_t = Internal pressure of RCB shell and dome at testing phase
- Y_r = Pipe break load
- E_s = Seismic load (Including 5% Torision) from RCB and AB
- $L_{g,d}$ = Dynamic Earth Pressure
- L_1 = Buoyance load