

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9006210076 DOC. DATE: 90/06/05 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
 AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H.B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards revised Page 3.1-4 to suppl 900426 proposed Tech Spec change re secondary leakage rate limit.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+6
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR	ENCL	RECIPIENT ID CODE/NAME	COPIES LTR	ENCL
	PD2-3 LA WIENS, L	1	1	PD2-3 PD	1	1
INTERNAL:	ACRS	6	6	NRR/DET/ECMB 9H	1	1
	NRR/DOEA/OTSB11	1	1	NRR/DST 8E2	1	1
	NRR/DST/SELB 8D	1	1	NRR/DST/SICB 7E	1	1
	NRR/DST/SRXB 8E	1	1	NUDOCS-ABSTRACT	1	1
	OC/LFMB	1	0	OGC/HDS2	1	0
	<u>REG FILE 01</u>	1	1	RES/DSIR/EIB	1	1
EXTERNAL:	LPDR	1	1	NRC PDR	1	1
	NSIC	1	1			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 27 ENCL 25

*AA-2
wb*



DUKE POWER

June 5, 1990

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Proposed Technical Specification Change, Supplement
Primary to Secondary Leakage Rate Limit

Dear Sir:

By letter dated May 31, 1988, I had submitted a proposed amendment to the Oconee Nuclear Station (ONS) facility Operating Licenses and revisions to the technical specifications. The proposed revisions were in response to an NRC letter dated October 2, 1987 and had established a specific limit of 1.0 gpm per unit on allowable primary to secondary leakage for all three Oconee units. In addition, several administrative changes were also included. Subsequently, in a letter dated April 26, 1990, I submitted a revised proposed technical specification amendment as a supplement to my May 31, 1988 letter.

The proposed Technical Specification 3.1.6.4 submitted by my letter of April 26, 1990 establishes a limit of 0.35 gallons per minute of primary-to-secondary leakage through the tubes of any one steam generator. The proposed action statement requires a reactor shutdown to be initiated within 4 hours and be in a cold shutdown condition within the next 36 hours. Furthermore, the proposed technical specification requires that if the leakage is less than 0.35 gallons per minute, an assessment be made to determine whether operations may be continued safely or the plant should be shutdown.

In recent conversations between members of my staff and the NRC regarding this amendment request, we expressed our desire to remove the last sentence of the proposed Technical Specification 3.1.6.4 which requires performance of an assessment for continued operation if leakage is less than 0.35 gallons per minute. Based on these discussions, I am supplementing my letter of April 26, 1990 by submitting a revised proposed technical specification amendment which incorporates this recent change. Accordingly, the revised page 3.1-14 in Attachment 1 to this letter replaces the similar page provided by my letter of April 26, 1990.

Attachment 2 to this letter also provides a revised Supporting Technical Justification and the No Significant Hazards Consideration Evaluation which supports the revised proposed change submitted in this letter.


9006210076 900605
PDR ADLOCK 05000269
P PDC

A001
11

This evaluation is intended to supersede in its entirety the contents of Attachment 2 to my letter of April 26, 1990. The No Significant Hazards Consideration Evaluation performed has determined that the attached proposed amendment does not involve a significant hazard consideration. A copy of this supplement to the original application is being forwarded to the South Carolina Department of Health and Environmental Control for Review and, as appropriate, subsequent consultation with the staff.

To assure sufficient time to revise appropriate station procedures, I request that the effective date of the technical specification revisions be 60 days after approval of the Amendment Request.

Very truly yours,



Hal B. Tucker

MAH/wpc

xc: S. D. Ebnetter
Regional Administrator, RII
U. S. Nuclear Regulatory Commission
101 Marietta St., NW, Suite 2900
Atlanta, Georgia 30323

Mr. L. A. Wiens, Project Manager
U. S. Nuclear Regulatory Commission
Division of Reactor Projects
Washington, D.C. 20555

Mr. P. H. Skinner
NRC Resident Inspector
Oconee Nuclear Station

Mr. Heyward Shealy, Chief
Bureau of Radiological Health
S. C. Department of Health & Environmental Control
2600 Bull Street
Columbia, South Carolina 29201