

10 Steam and Power Conversion System

Chapter 10 of this safety evaluation report (SER) describes the review by the staff of the U.S. Nuclear Regulatory Commission, hereinafter referred to as the staff, of Chapter 10, “Steam and Power Conversion System,” of Korea Hydro & Nuclear Power Co., LTD, hereinafter referred to as the applicant, design control document (DCD) for the design certification (DC) of the Advanced Power Reactor 1400 (APR 1400).

Thermal energy from the reactor is transferred to the main turbine generator for conversion into electric energy by the steam and power conversion system. The main elements of the steam and power conversion system include the main steam supply, turbine generator, main condensers, circulating water, condensate and feedwater, and emergency feedwater systems.

10.1 Summary Description

DCD Tier 2, Section 10.1, “Summary Description,” provides a general description of the steam and power conversion system and provides summaries of the protective features incorporated in the design of the system. DCD Table 10.1-1, “Steam and Power Conversion system Major Design Data,” provides data on major system parameters. Figure 10.1-1, “Heat Balance Diagram,” provides a high level flow diagram for the system.

Detailed descriptions of the main elements of the steam and power conversion system are provided in sections 10.2 through 10.4.10 of the DCD. The staff’s review is documented in Sections 10.2 through 10.4.10 of this report.

10.2 Turbine Generator

10.2(A) Introduction

The turbine-generator (T/G) is a nonsafety-related system that converts the energy of the steam produced in the two steam generators (SGs) into mechanical shaft power and then into electrical energy. The flow of steam is directed from the SGs to the turbine through the main steam system (MSS), turbine stop and turbine control valves. After expanding through a series of turbines, which drives the main generator, exhaust steam is transported to the main conventional surface-type condenser, where the steam is condensed. The condensate from the condenser is returned to the SGs through the condensate and feedwater systems. The T/G system also utilizes two moisture separator reheaters to reheat the extraction/exhaust steam from the high-pressure turbine prior to its supply to the low-pressure turbines.

The T/G has a turbine control and overspeed protection system to control turbine action under all normal and abnormal conditions to ensure that a full load turbine trip will not cause the turbine to overspeed beyond acceptable limits and to minimize the probability of generation of turbine missiles in accordance with the requirements of GDC 4.

10.2(B) Summary of Application

DCD Tier 1: Specific design requirements of the T/G system are found in DCD Tier 1 Section 2.7.1, “Power Generation Systems.” Subsection 2.7.1.1, “Turbine Generator,” contains two subsections:

1. Subsection 2.7.1.1.1, "Design Description," which describes the system purpose and functions, location and functional arrangement, key design features such as: high pressure (HP) and low pressure (LP) turbines, steam inlet valves, missile probability analysis, valve testing and in-service inspection program, and control systems and electrical trip signal initiations.
2. Subsection 2.7.1.1.2, "Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC)," which describes the ITAAC for the T/G system (in Table 2.7.1.1-1, "Turbine Generator ITAAC").

DCD Tier 2: The complete description of the T/G system is provided in DCD Tier 2, Section 10.2, "Turbine-Generator." The T/G system performs no safety- related functions and, therefore, has no nuclear safety design bases. Selected T/G principal design features include:

1. The T/G is designed for base load operation and has load following capability.
2. The T/G is designed to trip automatically under abnormal conditions and to accept a sudden loss of full load without exceeding design overspeed.

ITAAC: ITAAC for the T/G system are described in DCD Tier1 Section 2.7.1.1.2, Table 2.7.1.1-1, "Turbine Generator ITAAC."

Initial test Program: Initial plant testing for the T/G system is described in DCD Tier 2, Section 14.2.12.1.62, "Main Turbine Systems Test, and" Section 14.2.12.4.5, "Turbine Trip Test

Technical Specifications: There are no Technical Specification requirements associated with the turbine-generator.

10.2(C) Regulatory Basis

The relevant regulatory requirements for this area of review and the associated acceptance criteria are given in NUREG-0800, Section 10.2, "Turbine Generator," Revision 3, and are summarized below. Review interfaces with other SRP sections also can be found in Item I, "Areas of Review," of the SRP Section 10.2.

3. GDC 4, "Environmental and dynamic effects design bases," as it relates to the protection of structures, systems, and components (SSCs) important to safety from the effects of turbine missiles by providing a turbine overspeed protection system (with suitable redundancy) to minimize the probability of generation of turbine missiles.
4. 10 CFR Part 52, 52.47, "Contents of applications; technical information," Item (b)(1), which requires that a design certification application contain the proposed ITAAC that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the design certification has been constructed will be operated in accordance with the design certification, the provisions of the Atomic Energy Act, and the NRC regulations.

10.2(D) Technical Evaluation

The staff's evaluation of the turbine generator system is based upon the information provided in the applicant's DCD, Revision 0, including Tier 1 and Tier 2.

10.2(D)(a) GDC 4, Dynamic and environmental effects design bases

Although the T/G system is nonsafety-related, missiles generated by turbine failure can adversely affect the integrity of essential SSCs. To satisfy GDC 4, and as discussed in Section 3.5.1.3, "Turbine Missiles," of this safety evaluation (SE), the main turbine must have a low probability of rotor failure to minimize the likelihood that turbine missiles will affect important to safety SSCs. The arrangement and the orientation of the T/G system relative to these essential SSCs are also to be considered in the overall minimization of turbine missiles. Also reviewed by the staff is the performance of the turbine rotor itself. Because turbine rotors have large masses and rotate at relatively high speeds during normal reactor operation, failure of a rotor may cause excessive vibration of the turbine rotor assembly and result in the generation of high energy missiles. The staff's evaluation of the rotor required specifications can be found in Section 10.2.3, "Turbine Rotor Integrity," of this SE.

Since the likelihood of a turbine missile increases as the rotation of the turbine increases, the T/G system design is expected to be protected from overspeed during all modes of operation. SRP Section 10.2.III, Item 2 provides guidance to the staff on how to verify the adequacy of the control and overspeed protection systems to as follows:

- a) For normal speed-load control, an electrohydraulic control system fully cuts off steam and close all valves, including control valves (CVs) and intercept valves (IVs), at 103 percent of the turbine rated speed,
- b) A primary mechanical overspeed trip device to actuate all stop valves (SVs), CVs, reheat stop valves (RSVs), and IVs at approximately 111 percent of the rated speed, and
- c) An independent and redundant backup electrical overspeed trip device to close all steam inlet and control valves at approximately 112 percent of rated speed. This backup emergency trip device may use the same sensing techniques as the normal electrohydraulic control system; however, the control signals from the two systems are isolated from and independent of each other.

For the APR1400, turbine generator control and overspeed protection is accomplished by three independent systems (normal turbine generator control, mechanical overspeed trip, and electrical overspeed trip systems), as described in DCD Tier 2, Section 10.2.2.3. During normal operation, turbine speed is controlled by the turbine generator control system (TGCS) which provides automatic control of the turbine speed and acceleration through the entire speed range. The speed control function of the TGCS is designed to fully close all the control valves before reaching 103 percent of the rated speed and thus serves as the first line of defense against turbine overspeed. If the speed control function of the TGCS fails, the T/G overspeed protection system, which consist of mechanical overspeed trip system and the electrical overspeed trip system, is used to trip the turbine.

The mechanical overspeed trip system (MOST) is activated when the overspeed reaches 110-percent of the rated speed, and brings the turbine to safe shutdown condition. It is described in DCD Tier 2, Section 10.2.2.3.2, "Overspeed Protection," as consisting of an unbalanced ring that is activated by a centrifugal force against a spring when the turbine overspeeds, thus causing an eccentric movement that strikes the trip finger on the emergency trip valve. This action causes a depressurization of the emergency trip system (ETS) hydraulic fluid and, via an interface relay, the common hydraulic safety system. This results in closing all stop and control valves, thus tripping the turbine. If the MOST trip system fails, the electrical

overspeed trip system is automatically activated to trip the turbine at approximately 111.5-percent of the rotor rated speed.

The electrical overspeed trip system is described in DCD Tier 2, Section 10.2.2.3.2. It consists of two speed calculating modules: a primary and a backup. Each module uses the three binary signals from the speed conditioning units to the 2-out-of-3 tripping device. The primary module calculates the trip setpoint from software logic, and the backup module calculates the trip setpoint from its module firmware, which is independent of the primary module. These modules trigger hydraulic solenoid valves, and all stop and control valves are then closed. Each setpoint is 111.5 percent of the rated speed. The turbine is not expected to exceed 115 percent of the rated speed.

Based on the above discussion, the staff finds that the APR1400 normal turbine generator control, mechanical overspeed trip, and electrical overspeed trip systems are designed to provide reactor trips in accordance with the guidance provided in SRP 10.2, Section 10.2.III, Item 2.

In addition to confirming that the T/G overspeed protection system would initiate turbine trips at the required overspeed condition, the staff, in accordance with the SRP, also considered the following in its evaluation of the T/G system: (1) the capability of the T/G control and overspeed protection systems to detect the turbine overspeed conditions and actuate appropriate valves to preclude such condition, and (2) redundancy / independency / diversity, testability, and reliability in the overspeed protection features.

Diversity, Redundancy & Independence

Turbine overspeed protection is accomplished in the APR1400 using the TGCS, and the mechanical and electrical overspeed trip systems. The use of two different types of overspeed trip system (mechanical and electrical) provides for both independent and diverse means of overspeed protection since the systems do not share common components and uses different methods to detect overspeed conditions and close the appropriate valves to preclude the overspeed. Thus the APR1400 design incorporates defense-in-depth, and utilizes diverse protection means to preclude excessive turbine overspeed.

The APR1400 TGCS uses a microprocessor-based controller that has two modes of operation to protect the turbine against overspeed. The first mode is the normal speed control, which maintains the turbine at the desired speed, whereas the second one is an overspeed protection control mode that operates if the normal speed control fails.

In DCD Tier 2, Section 10.2.1.2, "Non-Safety Power Generation Bases," item (f) identifies as a principle design feature that the T/G system is to be designed so that the single failure of any component or subsystem does not disable the turbine overspeed trip function. The TGCS uses three redundant speed inputs and has three redundant control processors, with redundant communication paths between processors within the TGCS. It employs three independent speed sensors. For overspeed protection, each module provides a binary output signal, which is normally energized to the 2-out-of-3 tripping devices. For speed control, multiple speed feedback signals are derived from redundant sensors. A separate probe is provided for each of the triple redundant electrical governor channels.

In addition, DCD Tier 2, Section 10.2.2.3.1 states that redundancy is built into the overspeed protection system such that the failure of a single valve will not disable the trip function. The applicant states that the overspeed protection components are designed to fail in a safe

position. Loss of the hydraulic pressure in the emergency overspeed protection systems causes a turbine trip. Therefore, damage to the overspeed protection components results in the closure of the valves and the interruption of steam flow to the turbine.

Based on the T/G system description in the DCD, it appears that sufficient redundancy is designed into the TGCS for speed and overspeed control to protect the turbine during normal plant operation. However, there was no information provided in the DCD on how the overspeed trips are performed, and what components and subsystems are used in implementing these overspeed trip systems. In addition, no information was provided on how the turbine steam inlet valves and associated hydraulic fluid systems and solenoid valves function in tripping the turbine. Therefore, the staff requested in Request for Additional Information (RAI) 8050 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15226A601). Question 10.02-2, dated July 27, 2015 that the applicant provide additional information on how the overspeed trips are performed, including system schematics and information on failure mode consideration, and how the T/G subsystem and components meet the single failure criteria.

In its response to RAI 8050, Question 10.02-2, dated Oct 27, 2015 (ADAMS Accession No. MI15300A461), the applicant stated that APR1400 does not identify a specific turbine generator design, which it contends will allow the combined license (COL) applicant to select the optimum design from a plant safety and reliability perspective. It further states that providing details such as schematics and detail descriptions is undesirable based on the fact that it might imply or favor pre-approval of a certain turbine generator vendor, and would not address future lessons learned. In response to the staff's RAI, the applicant proposed using COL item 10.2(2) to have the COL applicant to provide schematic(s) of the TGCS and overspeed protection systems that show the entire system end-to-end and all discrete components and interfaces (e.g., sensors, power supplies, control devices, manual emergency trips, the device that eventually drains the hydraulic/air fluid from turbine control valves).

The staff reviewed the applicant's response and found it unacceptable since it failed to provide the requested information the staff was seeking to verify design information in the DCD. The staff has informed the applicant of its review results and the applicant is expected to provide a revised response. The resolution of RAI 8050 is being tracked as **Open Item 10.02-1**.

Fail Safe and Single Failure

The flow of main steam entering the HP turbine is controlled by four main steam valves (MSVs) and control valves (CVs) which are open and closed by an electro-hydraulic actuator as indicated in DCD Tier 2, Section 10.2.2.3.1.4, "Valve Control." The MSVs shutoff steam flow to the turbine when required, such as for actuation of an electrical overspeed trip. The intermediate stop valves (ISVs) and intercept valves (IVs) control steam flow to the LP turbine and completely close on turbine overspeed and turbine trip. The ISVs and IVs are also controlled by hydraulic pressure. Loss of hydraulic pressure in the emergency overspeed protection system results in the closure of the valves and interruption of steam flow to the turbine. Therefore the T/G system valves relied on for overspeed protection are fail safe.

The four turbine stop and four intermediate stop valves are redundant from their respective four control and four intercept valves. The valve arrangements are typical of designs previously approved by the staff. The valve characteristics and closure times are provided in DCD Tier 2, Table 10.2.2-2, "Turbine Valve Closure Times." The valve closure time for the turbine stop and control valves and the reheat stop and intercept valves is 0.3 seconds, and is based on preventing turbine overspeed following a loss-of-full load. Based on the design features

summarized above the staff finds that the APR1400 steam admission and NRVs are designed with adequate provisions to prevent excessive turbine overspeed in the event of a turbine generator system trip signal.

In order to meet the GDC 4 criteria, Item 1.A of the SRP Acceptance Criteria states that the overspeed protection should meet the single failure criteria and should be testable when the turbine is in operation. DCD Tier 2, Section 10.2.1. "Non-Safety Power Generation Design Bases" states "(T)he T/G system is designed so that the single failure of any component or subsystem does not disable the turbine overspeed trip function." DCD Tier 2, Table 10.2.4-1 "Turbine Speed Control System Component Failure Analysis," provides the results of a failure analysis of the APR1400 turbine speed control system, and shows how overspeed is prevented when a single component fail or malfunction.

The turbine trip-block provides an interface between the turbine speed control systems and the turbine valve control fluid systems. In its review of the DCD, the staff could not find any description of the turbine trip-block, which is an interface between the turbine control systems and the turbine steam inlet valves and associated fluid system. Therefore, the staff requested in RAI 8050, Question 10.02-4, dated July 27, 2015 that the applicant provide adequate details of the turbine trip-block and its configuration. The staff also requested that, if the design used a single trip block, the applicant provide information on single failure criteria for turbine overspeed, and justification on how it satisfied requirements for redundancy and diversity.

In its response to RAI 8050, Question 10.02-4, dated Oct 27, 2015 (ADAMS Accession No. ML15300A461), the applicant indicated that this question is covered by its response to RAI 8050, Question 10.02-4. The staff reviewed the applicant's response and found it unacceptable since it failed to provide the requested information the staff was seeking to verify design information in the DCD. The staff has informed the applicant of its review results and the applicant is expected to provide a revised response. The resolution of RAI 8050 is being tracked as **Open Item 10.02-2**.

Common Cause and Common Mode Failure

In DCD Tier 2, Section 10.2, the applicant did not address any guidance items from SRP 10.2 in this regard and issues identified in NUREG-1275 in its design and testing requirements to minimize or eliminate the common cause failures (CCF) in the hydraulic and air systems associated with the T/G control and protection systems, including the T/G steam admission and extraction non-return valves.

Therefore, the staff issued RAI 8050, Question 10.2-5 requesting that the applicant address the details of the air/hydraulic systems as they relate to turbine overspeed systems. Specifically, the staff requested the applicant to address the electrical and fluid flow paths, shared components, failure modes, and CCF vulnerabilities and to also provide a description on reliable operation of the hydraulic/air systems as associated with preventing turbine overspeed conditions. The staff further requested that the description of the turbine overspeed protection systems should clearly indicate what parts are shared. For example, shared air and hydraulic dump lines and components such as trip blocks, dump valves and fluid reservoirs should be described in the DCD. For clarity, the response should include schematic diagrams that show the control fluid flow paths, piping and valves being actuated (i.e., turbine stop, control, reheat stop, intercept, and extraction non-return valves).

In its response to RAI 8050, Question 10.02-5, dated Oct 27, 2015 (ADAMS accession No. ML15300A461), the applicant referenced its response to RAI Question 10.02-2 which the staff

has reviewed and found it unacceptable since it failed to provide the requested information the staff was seeking to verify design information in the DCD. The staff has informed the applicant of its review results and the applicant is expected to provide a revised response. The resolution of RAI 8050 is being tracked as **Open Item 10.02-3**.

Manual Turbine Trip

In DCD Tier 2, Section 10.2.2.3, "Control and Protection," the applicant described various T/G control systems for normal and abnormal operating conditions, including normal control and emergency protection systems to protect the turbine from overspeed. The DCD further describes the automatic turbine startup and shutdown (ATS) in that it receives commands from the operator using the operator interface or from a plant computer through a data link.

However, the DCD did not provide any reference to or description of the Manual Turbine Trip feature for the APR1400 turbine. SRP Section 10.2.III, "Review Procedures," Item 2.A describes the inclusion of an in-depth defense and diverse protection means to preclude an unsafe turbine overspeed conditions. The staff considers manual turbine trip system as one of the diverse turbine protection systems under all modes of plant operation.

Therefore, the staff issued RAI 8050, Question 10.2-3, requesting the applicant to provide detailed information regarding a manual control and/or manual turbine trip system for the APR1400 T/G system. The staff further requested the applicant to include any hard wiring from the main control room (MCR) to the T/G unit, including a push button at the turbine pedestal.

In its response to RAI 8050, Question 10.2-3 dated October 27, 2015 (ADAMS Accession No. ML15300A461), the applicant indicated that APR1400 DCD Section 10.2 will be revised, and the term "emergency trip" will be replaced with "manual emergency trip" for clarification purposes. Further, the applicant indicates that additional text would be added to DCD Tier 1, Section 10.2.2.3.4, to require that the manual emergency trip be designed to ensure that no single failure would prevent a manual trip. The hard wiring part will be deferred to the COL applicant. However, the applicant did not provide the requested information about the wiring but instead referenced its response to RAI 8050, Question 10.2-2.

The staff reviewed the applicant's response and found the descriptive information on the manual trip being added to the DCD acceptable but, as for the information requested on the wiring that was not provided, the staff finds the response unacceptable since it failed to provide the requested information the staff was seeking to verify design information in the DCD. The staff has informed the applicant of its review results and the applicant is expected to provide a revised response. The resolution of RAI 8050 is being tracked as **Open Item 10.02-4**.

Inspection and Testing

The guidance of SRP Section 10.2, Subsection II, "Acceptance Criteria," Item 1C states that the T/G system should have the capability to permit periodic testing of components important to safety. In DCD Tier 2, Section 10.2.2.3.4, "Inspection and Testing," it is stated that the overspeed trip circuits and devices are tested remotely at or above the rated speed by means of controls in the main control room, with the turbine not in operation. Also, these overspeed protection devices are checked under controlled speed conditions at startup or after each refueling or major maintenance outages. It is also stated in that section of the DCD that the MSVs, CVs, ISVs, and IVs are tested at a frequency of once in three (3) months inservice testing and functional checks are performed periodically. MSVs, CVs, ISVs, and IVs are

exercised at least once within quarterly intervals by closing each valve and observing the remote valve position indicator for fully closed position status.

Based on the above, and a review of the inspection and testing details in DCD Tier 2, Section 10.2.2.3.4, the staff finds that the applicant has adequately addressed the considerations described in SRP Section 10.2.II, specifically SRP acceptance criteria to meet the requirements of GDC 4.

10.2(D)(b) Initial Test Program

Although applicants for design certifications are not required to submit plans for an initial test program, RG 1.68 acknowledges that design certification applicants have previously submitted these plans to assist a future COL applicant referencing the design certification in meeting the requirements of 10 CFR 52.79(a)(28). Preoperational test requirements for the Turbine Generator System are listed in DCD Tier 2, Section 14.2.12.1.62, "Main Turbine System Test," and Section 14.2.12.4.5, "Turbine trip Test."

10.2(D)(c) ITAAC

Proposed ITAAC for the Turbine Generator are given in DCD Tier 1, Table 2.7.1.1-1 (Turbine Generator ITAAC). Table 2.7.1.1-1 contains tests and inspections requirements for the turbine generator. These tests and/or inspections confirm: (1) the T/G orientation and arrangement; (2) the mechanical and electrical overspeed trip system performance; (3) control system sending electrical signal to the MCR for T/G trip; (4) closure of stop, control, and intercept valves upon receipt of a T/G trip signal; (5) completion of Turbine and Turbine-Valve In-service inspection; (6) completion of Turbine missile probability analysis; and (7) inspection of the as-built turbine material properties.

Based on a review of the information provided in DCD Tier 1, Table 2.7.1.1-1, the staff concludes that the ITAAC will adequately confirm T/G design capabilities, design features, and systems interfaces. A detailed review of ITAAC is contained in Chapter 14 of this report.

10.2(D)(d) Technical Specifications

There are no technical specification (TS) requirements associated with the APR1400 T/G system.

10.2(E) Combined License Information Items

The following is a list of COL Information Items and descriptions from Table 1.8-2 of the Tier 2 DCD:

Table 10.2.3-1 APR1400 Combined License Information Items

COL Item No.	Description	DCD Tier 2 Section
10.2(1)	The COL applicant is to identify the turbine vendor and model.	10.2.3.5 and 10.2.5
10.2(2)	COL 10.2(2) The COL applicant is to identify how the functional requirements for the overspeed protection system are met and provide a	10.2.5

COL Item No.	Description	DCD Tier 2 Section
	schematic of the TGCS and protection systems from sensors through valve actuators.	
10.2(3)	The COL applicant is to provide a description of how the turbine missile probability analysis conforms with Subsection 10.2.3.6 to ensure that requirements for protection against turbine missiles (e.g., applicable material properties, method of calculating the fracture toughness).	10.2.5

10.2(F) Conclusion

Based on the review above, the staff concludes that the SER remains incomplete pending satisfactory resolution of the **Open Items** identified in staff's technical evaluation in this report. The staff will update Section 10.2 of this SER to reflect the final disposition of the DCD application.

10.2.3 Turbine Rotor Integrity

10.2.3(A) Introduction

Turbine rotors have large masses and rotate at high speeds during normal operation. Failure of a turbine rotor may result in the generation of high-energy missiles that may affect safety-related equipment and components. Therefore, the staff has reviewed the turbine rotor using the guidelines in SRP Section 10.2.3, "Turbine Rotor Integrity," to ensure that the turbine rotor materials have acceptable fracture toughness and mechanical properties to maintain the integrity of the turbine rotor and that the turbine rotor has a low probability of failure.

10.2.3(B) Summary of Application

DCD Tier 1: The applicant describes in Tier 1, Section 2.7.1.1.1 that the low pressure turbine rotor integrity is ensured by the combination of design, material properties (including fracture toughness), tests, and inspections of the rotor to limit the probability of turbine missile generation. Turbine rotor components and turbine stop and control valves will be in-service tested and inspected at intervals in accordance with industry practice or as specified by the manufacturer to meet turbine missile generation probability requirements.

The turbine and turbine valve in-service test and inspection program includes scope, frequency, methods, acceptance, disposition of reportable indications, corrective actions, and technical basis for inspection frequency. The as-built turbine material properties, turbine rotor and blade designs, preservice inspection and testing results and in-service testing and inspection requirements meet the requirements defined in the Turbine Missile Probability Analysis performed by the COL applicant.

DCD Tier 2: The applicant has provided a Tier 2 system description in final safety analysis report (DCD) Section 10.2.3, summarized here in part, as follows:

Turbine rotor integrity is provided by the integrated combination of material selection, rotor design, fracture toughness requirements, tests, and preservice and in-service inspection. This combination results in a low probability of a condition that would cause a rotor failure.

The COL applicant shall identify the turbine vendor and model. Also, the COL applicant is to provide a description of how the turbine missile probability analysis conforms with DCD Section 10.2.3.6 to ensure that requirements for protection against turbine missiles will be met (COL 10.2(3)).

As part of the turbine missile probability analysis, the COL applicant is to identify which of the methods for determining fracture toughness properties of those allowed in SRP Section 10.2.3 acceptance criteria is used.

The as-built turbine material properties, turbine rotor and blade designs, preservice inspection and testing results and in-service testing and inspection requirements shall be verified by ITAAC to meet the requirements defined in the turbine missile probability analysis.

Material Selection

Turbine rotor forgings are made from vacuum-treated or remelted Ni-Cr-Mo-V alloy steel components using processes that minimize flaw occurrence, provide reasonable assurance of uniform strength, and provide adequate fracture toughness. Undesirable elements, such as sulfur and phosphorus, are controlled to the lowest practicable concentrations consistent with good feedstock selection and melting practice, and consistent with obtaining adequate initial and long-life fracture toughness for the environment in which the parts operate. The turbine rotor material conforms with the chemical property limits of American Society for Testing and Materials (ASTM) A-470, "Standard Specification for Vacuum-Treated Carbon and Alloy Steel Forgings for Turbine Rotors and Shafts."

Fracture Toughness

The 50 percent fracture appearance transition temperature (FATT), as obtained from Charpy tests performed in accordance with ASTM A-370, "Standard Test Method and Definitions for Mechanical Testing of Steel Products," is no higher than -18 °C (0 °F) for low-pressure turbine wheel (disc) forgings, and the Charpy V-notch energy at the minimum operating temperature is at least 8.3 kg-m (60 ft-lbf) in the tangential direction.

The fracture toughness (K_{IC}) for actual rotor product is determined using a value of deep-seated FATT based on the measured FATT values from the center bore or trepan specimens from the rotor forging, and a correlation factor obtained from the past manufactured rotor material test data.

Preservice Inspection

Each finished rotor is subjected to 100 percent volumetric (ultrasonic), surface, and visual examinations using procedures and acceptance criteria equivalent to those specified for Class 1 components in the American Society of Mechanical Engineers (ASME) Code, Sections III and V.

After final machining, all surfaces exposed to steam (i.e., all accessible surfaces except for shaft ends) are magnetic particle tested. Special attention is given to the areas of stress risers. Finish-machined bores, keyways, and drilled holes are subjected to magnetic particle or liquid

penetrant examination. No flaw indications in keyway or hole regions are allowed. Either ultrasonic examination of turbine rotor welds or an analysis that demonstrates that defects in the root of the rotor welds will not grow to critical size for the life of the rotor is performed.

Each fully bucketed turbine rotor assembly is spin tested for 3 minutes at 120 percent of the rated speed. This speed is 5 percent greater than the maximum speed anticipated following a turbine trip from full load.

Turbine Rotor Design

The turbine rotor assembly is designed to withstand normal conditions and anticipated transients, including those resulting in turbine overspeed trips, without loss of structural integrity.

Inservice Inspection

The turbine and turbine valve in-service test and inspection program includes scope, frequency, methods, acceptance, disposition of reportable indications, corrective actions, and technical basis for inspection frequency. In-service test, inspection, and operating procedures shall be verified by ITAAC to be in accordance with industry practice and to ensure the validity assumptions/input of turbine missile probability analysis report.

The inspections are performed during refueling outages on an interval consistent with the in-service inspection schedules in ASME Code, Section XI and the inspection intervals from the turbine manufacturer's turbine missile analysis provided by the COL applicant as described in DCD Subsection 3.5.1.3. The COL applicant shall provide the site-specific turbine rotor in-service inspection program and inspection interval consistent with the manufacturer's turbine missile analysis.

Turbine Missile Probability Analysis

The report provides a calculation of the probability of turbine missile generation using established methods and industry guidance applicable to the fabrication technology employed. The analysis is a comprehensive report containing a description of turbine fabrication methods, material quality and properties, and required maintenance and inspections

ITAAC

The ITAAC associated with this area of review are specified in design certification document (DCD) Tier 1, Section 2.7.1.1, "Turbine Generator." The specific ITAAC are given in DCD Tier 1, Table 2.7.1.1-1, "Turbine Generator Inspections, Tests, Analyses, and Acceptance Criteria," summarized here in part, as follows:

Design Commitment 7 which verifies that the turbine and turbine valve in-service test and inspection program includes scope, frequency, methods, acceptance, disposition of reportable indications, corrective actions, and technical basis for inspection frequency. In-service test, inspection and operating procedures are in accordance with industry practice and ensure assumptions/input of turbine missile probability analysis performed by the COL applicant are valid.

Design Commitment 8 which states that the Turbine Missile Probability Analysis Report performed by the COL applicant for the as-built turbine generator (T/G) exist and concludes that

the probability of turbine failure resulting in the ejection of turbine rotor fragments is less than 1×10^{-5} per year.

Design Commitment 9 which states that the as-built turbine material properties, turbine rotor and blade designs, preservice inspection and testing results and in-service testing and inspection requirements meet the requirements defined in the Turbine Missile Probability Analysis performed by the COL applicant.

Technical Specifications: There are no Technical Specifications for this area of review.

Topical Reports: There are no topical reports for this area of review.

Technical Reports: There are no technical reports for this area of review.

10.2.3(C) Regulatory Basis

General Design Criterion (GDC) 4 of Appendix A to Title 10 of the *Code of Federal Regulations*, (10 CFR), Part 50 requires that structures, systems and components (SSCs) important to safety shall be appropriately protected against environmental and dynamic effects, including the effects of missiles that may result from equipment failure. Because turbine rotors have large masses and rotate at relatively high speeds during normal reactor operation, failure of a rotor may result in the generation of high-energy missiles, which may affect the proper function of safety systems. To satisfy GDC 4, turbine rotor integrity must be maintained to minimize the probability of turbine rotor failure.

SRP Section 10.2.3, Revision 2, "Turbine Rotor Integrity," provides guidance to achieve integrity of the turbine rotor. Specifically, SRP Section 10.2.3 provides criteria to ensure that the turbine rotor materials have acceptable fracture toughness and elevated temperature properties to minimize the potential for failure. In addition, these criteria will ensure that the rotor is adequately designed and will be receiving preservice inspections and periodic in-service inspections to monitor potential degradation.

10.2.3(D) Technical Evaluation

The APR 1400 DCD does not specify a turbine design. In a letter dated August 4, 2015, (ADAMS Accession No. ML15216A447) the applicant stated that the APR1400 DCD does not specify a turbine design in order to provide COL applicants the flexibility to use any of the three principal designs described in that letter, provided the turbine vendor's and COL applicant's turbine missile probability analysis meets the regulatory and DCD criteria. Therefore, the APR1400 DCD requires that a COL applicant referencing the APR1400 DCD submit their plant-specific turbine missile probability analysis including as built material properties to the U.S. Nuclear Regulatory Commission (NRC).

Several COL Information Items (i.e., COL 10.2(1), COL 10.2(3) and COL 10.2(4)) are provided in the APR1400 DCD to ensure the information is provided by the COL applicant, and are evaluated by the staff below.

COL 10.2(1) states that the COL applicant is to identify the turbine vendor and model. Since a turbine is not specified, providing the turbine model and vendor will establish the turbine design so that the appropriate turbine missile analysis can be performed and evaluated by the staff and, therefore, the staff finds COL Information Item 10.2(1) acceptable.

COL Information Item 10.2(3) states that the COL applicant is to provide a description of how the turbine missile probability analysis conforms with DCD Section 10.2.3.6 to ensure that requirements for protection against turbine missiles (e.g., applicable material properties, method of calculating the fracture toughness properties per SRP Section 10.2.3 Acceptance Criteria, preservice inspections) will be met. In its letter dated August 4, 2015, the applicant expanded on this COL Information Item to include the following:

If the turbine vendor has performed a turbine missile analysis that has been reviewed and approved by the NRC for a rotor design relevant to the COL applicant's selected design, then the COL should reference the analysis. If an approved analysis is not available, then the COL applicant shall prepare and reference an analysis that provides confidence that the final analysis performed with as-built properties, when available, will be sufficient to demonstrate assurance of turbine rotor integrity.

This revision to COL Information Item 10.2(3) will be tracked as Confirmatory Item 10.2.3(1). The staff finds this acceptable since COL Information Item 10.2(3) specifies that the COL applicant will provide either an NRC-approved turbine missile analysis or a bounding turbine missile analysis for staff review that demonstrates the turbine rotor meets the requirements of Regulatory Guide (RG) 1.115 and SRP Sections 3.5.1.3 and 10.2.3.

In its letter dated August 4, 2015, the applicant provided a new COL Information Item 10.2(4), which states:

The COL applicant shall specify the turbine rotor material properties for the chosen turbine vendor and applicable for the specific rotor designs. The COL applicant shall specify the turbine rotor material properties (in terms of the 50 percent FATT and Charpy V-notch energy tests performed in accordance with ASTM A-370) for the chosen turbine vendor and applicable for the specific rotor designs. Any deviation from material properties in SRP Section 10.2.3, revision in effect on date of regulatory applicability for COL application, shall be identified and justified (COL Information Item 10.2(4)).

The addition of COL Information Item 10.2(4) will be tracked as Confirmatory Item 10.2.3(2). The staff finds this acceptable since COL applicant will provide the turbine rotor material properties once a turbine design is chosen, including the fracture toughness and 50 percent FATT, consistent with the guidance in SRP Section 10.2.3.

10.2.3(D)(a) *Material Specifications*

DCD Tier 2, Section 10.2.3.1 specifies that the turbine rotors are made from vacuum-treated or re-melted Ni-Cr-Mo alloy steel material that conforms to ASTM A-470, and undesirable elements are controlled to the lowest practical concentrations. In addition, DCD Tier 2, Table 10.2.3-1 provides the chemical composition of the alloy steel. The staff determined that Table 10.2.3-1 provides sufficient information concerning the material used for the low pressure turbine rotors in accordance with SRP Section 10.2.3 to assess its acceptability for turbine rotor integrity. Therefore, the staff finds the turbine rotor will use materials that provide uniform strength and homogeneity; furthermore, the COL applicant will provide the as-built turbine rotor material properties, including the fracture toughness and 50 percent FATT based on COL Information Item 10.2(4).

For the reasons described above, the staff finds that the material specification and associated chemical composition in DCD Tier 2, Table 10.2.3-1, and the material properties to be provided

by the COL applicant, will provide a suitable material for the turbine rotor that will maintain its toughness to resist brittle fracture.

10.2.3(D)(b) *Fracture Toughness*

DCD Tier 2, Section 10.2.3.2 states that the fracture toughness (K_{IC}) for actual rotor product is determined using a value of deep-seated FATT based on the measured FATT values from the center bore or trepan specimens from the rotor forging, and a correlation factor obtained from the past manufactured rotor material test data. In addition, DCD Tier 2, Section 10.2.3.2 states that as part of the turbine missile probability analysis, the COL applicant is to identify which of the methods for determining fracture toughness properties of those allowed in SRP Section 10.2.3 acceptance criteria is used. DCD Section 10.2.3.6, which describes the information in the turbine missile analysis to be provided as part of addressing COL Information Item 10.2(3), also specifies that the COL applicant should address methods of determining fracture toughness properties.

The staff finds that the COL applicant will provide the necessary information concerning the fracture toughness properties in the turbine missile probability analysis, as described in DCD Section 10.2.3.6 and as part of fulfilling COL Information Item 10.2(3) and, therefore, is acceptable and consistent with SRP Section 10.2.3.

10.2.3(D)(c) *Turbine Rotor Design*

DCD Tier 2, Section 10.2.3.4 states that the turbine rotor assembly is designed to withstand normal operating conditions and anticipated transients, including those resulting in turbine overspeed trips, without loss of structural integrity. DCD Section 10.2.3.4 also provides criteria that the turbine assembly should meet, such as designing the turbine rotor to withstand an overspeed level of 120 percent of the rated speed. Since the COL applicant will provide the turbine missile analysis as part of fulfilling COL Information Item 10.2(3), the staff finds that pertinent design information is specified in DCD Section 10.2.3.4, and will be used in preparing the turbine missile probability analysis as detailed in DCD Section 10.2.3.6 in order to meet the guidance in RG 1.115.

10.2.3(D)(d) *Preservice Inspection*

The turbine rotor forgings are rough machined prior to heat treatment and a visual, surface, and 100 percent volumetric (ultrasonic) examination will be performed using procedures and acceptance criteria equivalent to those specified for Class 1 components in ASME Code, Sections III and V. The preservice inspection description is acceptable to the staff because it includes a 100 percent volumetric inspection and surface inspection (magnetic particle or liquid penetrant) performed using criteria equivalent to Class 1 acceptance criteria in the ASME Code, Sections III and V. The acceptance criteria are considered appropriate to ensure the initial integrity of the turbine rotor and conform to the guidance in SRP Section 10.2.3.

Therefore, the initial turbine rotor condition provides a baseline for future in-service inspections to ensure that flaws will not propagate resulting in the fracture of the turbine rotor and generation of potential missiles.

10.2.3(D)(e) *In-service Inspection*

DCD Tier 2, Section 10.2.3.5 states that the turbine rotor in-service inspection program uses visual, surface, and volumetric examination to inspect the turbine rotor assembly. It then states

that the COL applicant shall provide the site-specific turbine rotor in-service inspection program and inspection interval consistent with the manufacturer's turbine missile analysis. However, there is no COL information item for providing this in-service inspection program or the turbine valve in-service test program. Therefore, the staff requested in RAI 8328 (ADAMS Accession No. ML15307A049), Question 10.02.03-1, that an applicable COL information item be added to the DCD which specifies that the COL applicant shall provide the site-specific turbine rotor in-service inspection program and inspection interval.

In response to RAI 8328, the applicant's letter dated December 17, 2015, (ADAMS Accession No. ML15351A155), revised COL Item 10.2(3) to clarify that the turbine missile probability analysis takes into account in-service inspection and testing. The applicant's response did not, however, specify that the COL applicant will provide the site-specific turbine rotor in-service inspection program and inspection interval. Therefore, in follow-up RAI 8531 (ADAMS Accession No. ML16053A126), Question 10.02.03-2, the staff requested that an applicable COL information item be added to ensure the COL applicant provides this information. In response to RAI 414-8531, Question 10.02.03-2, the applicant's letter dated March 21, 2016, (ADAMS Accession No. ML16081A358), added COL Item 10.2(5) to the APR1400 DCD which ensures that the COL applicant will provide the site-specific turbine rotor in-service inspection program and inspection interval, including the turbine valve test and inspection program and test and inspection frequency consistent with the manufacturer's turbine missile analysis. The staff finds this additional COL Item 10.2(5) will ensure that the necessary information will be provided by the COL applicant consistent with the guidelines in SRP Section 10.2.3, Paragraphs I.5 and II.5. **The addition of COL Information Item 10.2(5) will be tracked as Confirmatory Item 10.2.3(3).**

The staff finds the in-service inspection of the turbine rotor is acceptable, since it meets the guidelines of SRP Section 10.2.3 to ensure that the turbine rotor integrity is maintained to preclude the generation of missiles, as required by GDC 4 of 10 CFR Part 50, Appendix A.

10.2.3(D)(f) *Turbine Missile Probability Analysis*

As previously noted, the APR1400 DCD does not include a specific turbine design or type of rotor (e.g., monoblock). To ensure the COL applicant will have a suitable turbine missile probability analysis, the DCD includes COL Information Items and ITAAC to direct the COL applicant to evaluate the turbine using established methods and industry guidance applicable to the fabrication technology employed. In its letter dated August 4, 2015, the applicant stated that the APR1400 DCD will be revised to require the COL applicant to reference an approved turbine design (i.e., previously reviewed and accepted by the NRC) that is applicable to the APR1400 or, for a design not previously approved, perform an analysis to provide confidence prior to COL approval that the design and associated specifications will ensure acceptable turbine integrity once the as built analysis can be performed. This pre-as-built analysis would be incorporated by reference in the COL, facilitating NRC review in support of COL approval. The APR1400 DCD will be revised by clarifying COL Item 10.2.5(3). Final verification of as-built turbine acceptability will still be provided through several ITAAC in Tier 1 Table 2.7.1.1-1. **These revisions to the DCD will be tracked as Confirmatory Item 10.2.3(4).**

The APR1400 DCD, Tier 2, Section 10.2.3.6 states that the probability of turbine missile generation is less than 1×10^{-5} per reactor-year for the APR1400 design. This probability of turbine missile generation is lower than that specified by the guidance in SRP Section 3.5.1.3, Table 3.5.1.3-1 for loading the turbine and bringing the plant on line. This probability is to be confirmed by calculation and/or analysis in the turbine missile probability analysis in accordance

with ITAAC. In addition, APR1400 DCD Section 10.2.3.6 provides the information the turbine missile probability analysis will evaluate in order to meet the guidance in RG 1.115 and SRP Sections 3.5.1.3 and 10.2.3. The NRC staff finds that the specified value of less than 1×10^{-5} per reactor-year for the APR1400 probability of turbine missile generation is acceptable because this value is lower than that specified by the guidance in SRP Section 3.5.1.3, and that COL Information Item 10.2(3) will ensure the COL provides a turbine missile probability analysis.

10.2.3(D)(g) ITAAC

The staff also reviewed DCD Tier 1, Table 2.7.1.1-1, which provides the inspections, tests, analysis, and acceptance criteria regarding the turbine rotor. There are three commitments numbered 7 (as modified by applicant’s letter dated August 4, 2015), 8 and 9. **This clarification of ITAAC Commitment No. 7 will be tracked as Confirmatory Item 10.2.3(5).** ITAAC Commitment No. 7 states that in-service inspection and testing will be performed at a frequency and in accordance with operating procedures consistent with the turbine manufacturer’s recommendations and assumptions/input in the turbine missile probability analysis. The staff finds this acceptable since it will ensure that the turbine inspection, and turbine valve testing programs will be in place in order so that the probability of turbine failure resulting in a turbine missile will continue to be less than 10^{-5} per turbine-year, consistent with the guidance in RG 1.115.

ITAAC Commitment No. 8 states that turbine missile probability analysis performed by the COL applicant for the as-built T/G exists and concludes that the probability of turbine failure resulting in a turbine missile is less than 1×10^{-5} per turbine-year. The staff finds that ITAAC Commitment No. 8 will ensure that an as-built turbine missile probability analysis will be performed and meet the guidance in RG 1.115, in minimizing the potential for generating turbine missiles.

The staff finds that ITAAC Commitment No. 9, as described in Section 10.2.3(B) of this report, will ensure that the as-built turbine rotors, with respect to the turbine material property data, rotor and blade design, and preservice and in-service inspection and testing, will conform to the manufacturer's turbine missile probability analysis.

10.2.3(E) Combined License Information Items

The following is a list of COL information items numbers and descriptions from DCD Tier 2, Table 1.8-2:

Table 10.2.3-1 APR1400 Combined License Information Items

Item No.	Description	DCD Tier 2 Section
10.2(1)	The COL applicant is to identify the turbine vendor and model.	10.2.2.2

Item No.	Description	DCD Tier 2 Section
10.2(3)	<p>The COL applicant is to provide a description of how the turbine missile probability analysis conforms with Subsection 10.2.3.6 to ensure that requirements for protection against turbine missiles (e.g., applicable material properties, method of calculating the fracture toughness properties per SRP Section 10.2.3 Acceptance Criteria, preservice inspections) will be met.</p> <p>If the turbine vendor has performed a turbine missile analysis that has been reviewed and approved by the NRC for a rotor design relevant to the COL applicant's selected design, then the COL should reference the analysis. If an approved analysis is not available, then the COL applicant shall prepare and reference an analysis that provides confidence that the final analysis performed with as-built properties, when available, will be sufficient to demonstrate assurance of turbine rotor integrity.</p>	10.2.3
10.2(4)	<p>The COL applicant shall specify the turbine rotor material properties for chosen turbine vendor and applicable for the specific rotor designs. The COL applicant shall specify the turbine rotor material properties (in terms of the 50 percent FATT and Charpy V-notch energy) for the chosen turbine vendor and applicable for the specific rotor designs. Any deviation from material properties in SRP 10.2.3, revision in effect on date of regulatory applicability for COL application, shall be identified and justified.</p>	10.2.3.1
10.2(5)	<p>The COL applicant shall provide the site-specific turbine rotor in-service inspection program and inspection interval, including the turbine valve test and inspection program and test and inspection frequency consistent with the manufacturer's turbine missile analysis.</p>	10.2.3.5

The staff evaluated, in Section 10.2.3.4 of this safety evaluation report (SER) above, whether sufficient COL information items were identified in Table 1.8-2 of the APR1400 DCD.

10.2.3(F) Conclusion

The staff concludes, subject to closure of the five **Confirmatory Items** noted above, that the integrity of the turbine rotor will be acceptable, including the information to be provided by the COL applicant based on the applicable COL information items, and will meet the requirements of 10 CFR Part 50, Appendix A, GDC 4, since the turbine rotor assemblies will be conservatively designed and will use suitable materials with acceptable fracture toughness that will be

inspected before and during service. Maintaining rotor integrity provides reasonable assurance that the probability of generating a turbine missile from a turbine rotor failure is low during normal operation, including transients up to design overspeed. The staff also concludes that the applicant has established ITAAC to perform proper inspection and testing of the turbine to ensure the probability of turbine failure resulting in a turbine missile is less than 1×10^{-5} per turbine-year, consistent with RG 1.115.

10.3 Main Steam System

10.3(A) Introduction

The main steam system (MSS) transfers steam produced in the steam generators (SGs) to the high pressure turbine of the main turbine-generator. The MSS also provides steam to the second stage steam reheaters, deaerator pegging steam (for startup), and backup auxiliary steam. The MSS extends from the SGs steam outlet nozzles to the turbine stop valves and includes safety and nonsafety-related components. The safety-related portion of the MSS is the portion between the SG nozzle outlet to and including the main steam valve house (MSVH) penetration anchor wall. The safety-related components of the MSS consist of main steam isolation valves (MSIVs), main steam safety valves (MSSVs), main steam atmospheric dump valves (MSADVs), and piping and valves in the main steam supply lines up to and including MSVH penetration anchor wall.

10.3(B) Summary of Application

DCD Tier 1: The MSS is described in DCD Tier 1, Section 2.7.1.2, "Main Steam System," and in Table 2.7.1.2-1, "Main Steam System Equipment and Piping Location/Characteristics." The basic configuration of the system is shown in DCD Tier 1 Figure 2.7.1.2-1, "Main Steam System," and equipment, component, and instrumentation data are listed in Table 2.7.1.2-1, Table 2.7.1.2-2, and Table 2.7.1.2-3, respectively.

DCD Tier 2: DCD Tier 2, Section 10.3 provides supplemental system information to Tier 1. DCD Tier 2, Section 10.3.1, "Design Basis," indicates the following functions of the MSS include:

Under accident conditions, the MSS isolates the steam generators and the safety-related portion of the system from the nonsafety-related downstream piping and components, such as the nonsafety-related main turbine.

Provides initial residual heat removal (RHR) under accident conditions by venting steam to the atmosphere.

Dissipates heat from the reactor coolant system (RCS) following a turbine and reactor trip, and also when the main condenser is not available.

Conforms to applicable design codes

Permits visual inspection

Provides steam for the auxiliary feedwater pumps

Provides adequate overpressure protection for the SGs and MSS

The safety-related portions of the MSS are designed to perform their required functions during normal conditions, adverse environmental occurrences, and accident conditions, including a loss of offsite power (LOOP) with a single malfunction or failure of an active component.

ITAAC: ITAAC criteria for the MSS are given in DCD Tier 1, Table 2.7.1.2-4, "Main Steam System ITAAC."

Technical Specifications: The technical specifications (TS) for the MSS components are identified in DCD Tier 2, Chapter 16.

10.3(C) Regulatory Basis

NRC regulations for this area of review and the associated acceptance criteria are listed in NUREG-0800, Section 10.3, "Main Steam Supply System," and are summarized below. Review interfaces with other SRP sections are also provided in SRP Section 10.3, Item I, "Review Interfaces."

1. GDC 2, "Design bases for protection against natural phenomena," as it relates to safety-related portions of the system being capable of withstanding the effects of natural phenomena such as earthquakes, tornadoes, hurricanes, and floods.
2. GDC 4, "Environmental and dynamic effects design bases," with respect to safety-related portions of the system to withstand the effects of external missiles, internal missiles, pipe whip and jet impingement forces associated with pipe break.
3. GDC 5, "Sharing of structures, systems and components," as it relates to the capability of shared systems, structures and components (SSCs) important to safety to perform required safety functions.
4. GDC 34, "Residual heat removal," as it relates to the system function of transferring residual and sensible heat from the reactor system in indirect-cycle plants.
5. 10 CFR 50.63, "Loss of All Alternating Current," as it relates to the ability of a plant to withstand for a specified duration and then recover from a station blackout (SBO).
6. 10 CFR 52.47(b)(1), which requires that a design certification application contain the proposed ITAAC that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the design certification is built and will operate in accordance with the design certification, the provisions of the Atomic Energy Act, and NRC regulations.

10.3(D) Technical Evaluation

The staff reviewed the MSS design, described in DCD Tier 1 and Tier 2 sections, in accordance with SRP Section 10.3. As described above in the regulatory basis of this report, the acceptability of the system is based on meeting the requirements of the GDC and the SRP acceptance guidance

DCD Tier 1, Section 2.7.1.2.1, "Design Description," provides a brief description of the MSS safety-related portion of the system which consists of the main steam piping and valves located between the steam generator outlet nozzles in the containment up to and including the main

steam isolation valves (MSIVs) in the main steam valve houses (MSVHs). The MSS has the following safety-related functions:

To supply steam to the auxiliary feedwater pump turbine; to protect the steam generator and pressure boundary components in the MSS from overpressurization; to cooldown the RCS through a controlled discharge of steam to the atmosphere; and to isolate the containment and steam generators.

Also, DCD Tier 1, Section 2.7.1.2.1, "Design Description," provides a brief description of the functions of nonsafety-related portions of the MSS located downstream of the MSIVs, and within the auxiliary building and the turbine building. Further, DCD Tier 1, Section 2.7.1.2.1 and Table 2.7.1.2-1, "Main Steam System Equipment and Piping Location/Characteristics," provides functional descriptions and identifies ASME class and seismic categories of the MSS piping and valves.

A detailed design description of the APR1400 MSS is provided in DCD Tier 2, Section 10.3.2.1, "General Description." The primary function of the MSS is to transport high pressure steam from the SGs to the high pressure turbine. The secondary function of the system is to supply steam to the main feedwater pump turbines, auxiliary feedwater pump turbines, second stage of the moisture separator reheater (MSR), deaerator pegging steam (during startup), and auxiliary steam system. This secondary steam supply is provided from the main steam lines upstream of the turbine stop valves. The MSS consists of safety-related, as well as nonsafety-related portions. The safety-related portions of the MSS include piping and valves between each SG outlet nozzle and its respective MSIV. The remainder of the system and equipment including main turbine are nonsafety-related. Under accident conditions, the MSS isolates the SGs and the safety-related portion of the system from the nonsafety-related portions.

The MSS consists of two SGs, main turbine-generator, including MSR, and associated piping, valves, and instrumentation. Each of the two SGs has two steam lines connecting to the SG outlet nozzle and terminating in the turbine building at each of four turbine stop valves. Each steam line exits the reactor building, passes into a divisional valve room, and is routed across a pipe bridge into the turbine building. A flow diagram of the system is provided in DCD Tier 2, Figure 10.3.2-1, "Main Steam System Flow diagram," and Figure 10.3.2-2, "Turbine System Flow Diagram."

Major MSS components include, but are not limited to, the MSSVs, MSADVs, MSIVs, and turbine stop valves. Five spring-loaded MSSVs are supplied per steam line and are normally closed during operation. These valves provide overpressure protection for the steam generators and main steam piping, and discharge directly to the outside atmosphere. The MSSVs are designed to ASME Section III, Class 2, Seismic Category I requirements. One MSADV is installed on each steamline in order to remove heat from the reactor coolant system and is used for emergency cooldown in conjunction with the auxiliary feedwater system. The MSADVs are designed to ASME Section III, Class 2, Seismic Category I requirements and are sized to allow a controlled plant cooldown in the event of a steamline break or steam generator tube rupture. The main turbine stop and control valves and the valves associated with the reheaters are described in DCD Tier 2, Section 10.2, "Turbine Generator."

With respect to design standards for MSS piping and components, SRP Section 10.3, Subsection III, "Review Procedure," Item 3 indicates that the essential portions of the MSS should be designed to Quality Group B and/or Seismic Category I requirements. The U.S. APR1400 main steam lines, from the SGs up to and including the MSVH penetration wall

anchor, are designed and constructed in accordance with Quality Group B and Seismic Category I, which the staff finds acceptable as the APR1400 proposed design is in accordance with the SRP guidelines and RG 1.29 regulatory position C1. Further, the DCD states that the remaining MSS piping up to the turbine stop valve and second stage reheaters will be designed in accordance with ASME Code B31.1, "Power Piping Code," which the staff finds acceptable, because this complies with power piping codes and standards (see Section 3.2.2, "System Quality Group Classification," of this report). Furthermore, DCD Tier 2, Table 3.2-1 provides the quality group and seismic design classification details of components and equipment of the MSS.

ASME Section III, Class 2 piping is inspected and tested in accordance with ASME Sections III and XI. ANSI/ASME B31.1 piping is inspected and tested in accordance with ANSI/ASME B31.1 Code. A description of periodic inservice inspection and inservice testing of ASME Section III, Class 2 and 3 components is provided in DCD Tier 2, Subsection 3.9.6 and Section 6.6. Safety-related active components in the MSS are designed to be tested during plant operation. Provisions are made to allow for inservice inspection of components at times that are consistent with those specified in ASME Section XI.

Please check if there is still an open issue. The RAI response was provided in Jun. 2016.

MSIVs are located just outside containment in valve rooms. These valves isolate the steam generators in the event of excessive steam flow to prevent reactor over-cooling. The MSIVs, including the main steam isolation valve bypass valves (MSIVBVs), are interlocked to close upon initiation of a main steam isolation signal (MSIS). The parameters that initiate an MSIS are given in DCD Tier 2, Section 7.3. During normal operation, the MSIVs are held open by hydraulic oil pressure. MSIV pilot solenoid valves are normally closed and only energized to open the MSIV. Therefore, on loss of either hydraulic pressure or electric power, the MSIVs will fail closed. The staff reviewed DCD Tier 2, Section 10.3, but could not verify the valve closure times or whether the MSIVs are capable of closing against maximum steam flow. Therefore, the staff issued RAI 8570 (ADAMS Accession No. ML16110A018), Question 10.03-05 requesting the applicant to provide a tabulation and descriptive text of all flowpaths that branch off the main steamlines between the MSIVs and turbine stop valves as specified by SRP 10.3, Section III.5.E. **This is being tracked as Open Item 10.3-1.**

Auxiliary steam from the MSS has the non-safety function of supplying turbine gland steam during startup and the second-stage reheater tube side of the MSR. Backup sources of auxiliary steam are used during startup and during low-power operation. Also, DCD Tier 2, Subsections of 10.3 provides details on MSS sampling, and Tables 10.3.5-4 and 10.3.5-5 identify the recommended secondary sampling and laboratory analysis frequencies during normal operation and startup/wet layup, respectively.

The MSS operational aspects are provided in DCD Tier 2, Section 10.3.2.3, "System Operation," which includes brief descriptions during plant startup, normal operation, abnormal operations, and shutdown operations. An evaluation of the MSS abnormal and anticipated operational occurrences is described in DCD Tier 2, Chapter 15, "Transient and Accident Analyses," of the application where the APR1400 responses to several postulated accidents are considered including an evaluation of a main steamline break, feedwater line break, and SG tube rupture (SGTR). For this reason, this section of the report does not cover these accident analyses.

In the event of a steam line break, feedwater line break, or SGTR, the MSIVs are automatically signaled to close upon receipt of the main steam line isolation signal (MSIS). Monitored variables that provide inputs to the MSIS include containment pressure, SG pressure, and SG

level. The staff evaluation of the controls regarding the MSIV isolation is included in Section 7.3, "Engineered Safety Features Systems," of this report.

In DCD Tier 2, Section 10.3.3, "Safety Evaluation," the applicant provided its evaluation of the safety-related portions of the MSS and its compliance with the requirements of the GDC identified in the "Regulatory Basis" for this section. The staff compared the DCD information against these GDC and regulatory requirements in 10 CFR 50.63 regarding SBO and 10 CFR 52.47(b)(1) on ITAAC, and the staff presents its evaluation below.

10.3(D)(a) GDC 2, "Design bases for protection against natural phenomena"

Compliance with GDC 2 is based on meeting the requirements related to the safety-related portions of the MSS being capable of withstanding the effects of natural phenomena. DCD Tier 2, Section 10.3.3 states that safety-related portions of the MSS are located in the reactor containment building and the auxiliary building. The containment and the auxiliary buildings are designed to withstand the effects of natural phenomena, such as hurricanes, floods, tsunamis, earthquakes, and tornadoes, and therefore protect the MSS from these events. The staff reviewed DCD Tier 2, Figure 10.3-1 to confirm the locations of the safety-related portions of the MSS as stated by the applicant. However, the staff noted that the discharge piping from the MSADVs and MSSVs are classified as seismic category II, quality group D. Therefore, the staff issued RAI 8570 (ADAMS Accession No. ML16110A018), Question 10.03-4 questioning how, with this seismic classification, this section of piping can perform its safety-related function of discharging steam to the atmosphere during a seismic event. This is being tracked as Open

Item 10.3- Please check if there is still an open issue. The RAI response was provided in Jun. 2016.

Based on Open Item 10.3-2, the staff cannot reach a conclusion on the acceptability of the APR1400 MSS design as related to withstanding the effects of natural phenomena in accordance with the requirements of GDC 2 and meets the guidance of RG 1.29, positions C.1 and C.2.

10.3(D)(b) GDC 4 "Environmental and dynamic effects design bases"

With respect to the requirements of GDC 4, the DCD states the safety-related portions of the MSS are designed to withstand the effects of external missiles, as well as internally-generated missiles, pipe whip, and jet impingement forces from postulated pipe breaks. Also, the safety-related portions of the MSS outside containment are to be protected from internal missiles and other dynamic piping effects by separated valve rooms so that, at most, only one valve room is affected. The turbine-generator is oriented to direct potential turbine missiles away from the MSS such that the MSS is protected against turbine missiles. The DCD describes that the safety-related and nonsafety-related portions of the system are separated by a fixed seismic anchor to ensure that non-seismic piping does not impact the safety system, as shown in DCD Tier 2, Figure 10.3-1. The staff reviewed the DCD and determined that the fixed anchor points between the nonsafety-related and safety-related piping, and the appropriate turbine orientation will provide protection against dynamic affects.

Further, regarding the GDC 4 requirements, the applicant addressed consideration of steam and water hammer and relief valve discharge load effects on the MSS and included COL item 10.3(1) for the COLA to develop operating and maintenance procedures to address the potential for water hammer. However, neither COL item 10.3(1) nor DCD Tier 2, Section 10.3 include the attributes to be included in the procedure. The staff issued RAI 8053 (ADAMS Accession No. ML15209A461), Question 10.03-1, requesting the applicant to list the items to be incorporated into operating and maintenance procedures consistent with NUREG-0927. On October 28,

2015, the applicant provided its response to RAI 8053, Question 10.03-1 ADAMS Accession No. ML15301A864), and as a result removed existing text from COL item 10.3(1), and did not include the requested information. The staff found the response to be unacceptable. Therefore, the staff issued RAI 8575 (ADAMS Accession No. ML16110A019), Question 10.03-6 requesting the applicant to list the items to be incorporated into operating and maintenance procedures consistent with NUREG-0927. This is being tracked as **Open Item 10.3-3**.

Based on the review above, the staff concludes that the SER remains incomplete pending satisfactory resolution of the **Open Items** identified in staff's technical evaluation in this report. The staff will update Section 10.3 of this SER to reflect the final disposition of the DCD application.

Please check if there is still an open issue. The RAI response was provided in Jun. 2016.

10.3(D)(c) GDC 5, "Sharing of structures, systems, and components"

GDC 5 contains provisions restricting the sharing of structures, systems, and components important to safety between nuclear power units. The MSS in the APR1400 design is not shared between or among other nuclear units. Therefore, the requirements of GDC 5 are met.

10.3(D)(d) GDC 34, "Residual heat removal"

The MSS is designed with redundancy to provide sufficient cooldown capacity assuming a single failure. Taking into account a single failure, the MSS is still capable of providing heat sink capability for the reactor, both residual and sensible; providing pressure relief for the shell side of the steam generator and main steam lines upstream of the MSIVs; and providing steam to the steam-driven safety-related auxiliary feedwater pumps necessary for safe shutdown. In response (ADAMS Accession No. ML15301A864) to RAI 8053, Question 10.03-2, the applicant clarified that there are no isolation valves in the main steam lines between the steam generators and the MSSVs. Based on the information above, the staff finds that the MSS design conforms to the requirements of GDC 34 with respect to the system function of transferring residual and sensible heat from the reactor coolant system.

10.3(D)(e) 10 CFR 50.63 Loss of all alternating current power

DCD Tier 2, Section 10.3.3 states that the safety-related portions of the MSS are designed to perform their safety functions during a station blackout (SBO) event; however, the application lacked information sufficient to confirm the capability of the MSS to cope with and recover from an SBO event. Therefore, the staff issued RAI 8053 (ADAMS Accession No. ML15209A461), Question 10.03-3 requesting the applicant to provide additional design and operating details about the MSS and its components. In a letter dated October 28, 2015 (ADAMS Accession No. ML15301A864), the applicant stated in response to RAI 8053, Question 10.03-3 that, during an SBO event, Class 1E onsite DC power is available and an alternate alternating current (AAC) source will be connected to the shutdown bus within 10 minutes from the onset of the SBO. Further, in the event of total loss of power, each MSADV can be operated locally, either by handwheel or by manual operation of the hydraulic actuator mounted on the valve. The staff finds the applicant's response acceptable because the safety-related portions of MSS are designed such that they perform their safety function and the system has sufficient capability to cope with an SBO. Therefore, the portion of SBO mitigation provided by the MSS is adequate, and the staff concludes the requirements of 10 CFR 50.63, as related to the MSS, are met. RAI 8053, Question 10.03-3 is considered closed. Further staff evaluation of the SBO event is in Section 8.4 of this report.

10.3(D)(f) 10 CFR 20.1406 10 CFR 20.1406 Minimization of contamination

10 CFR 20.1406 requires, in part, that each design certificate applicant describe how the facility design and procedures for operation will minimize, to the extent practicable, contamination of the facility and environment, as well as the generation of radioactive waste. DCD Tier 2, Section 10.3.2.4, "Design Features for Minimization of Contamination," states that the MSS includes components that may contain radiologically contaminated fluid resulting from a steam generator tube leakage. The applicant performed a leakage identification evaluation which indicated that the MSS is designed to facilitate early leak detection and the prompt assessment and response to manage collected fluids.

Features for prevention and minimization of unintended contamination, and reduction of cross-contamination, decontamination, and waste generation include the use of radiation monitors on the main steamlines, steam generator blowdown lines, and condenser vacuum pump exhaust line that will alert operators of a steam generator tube rupture, sloped piping in the direction of steam flow to avoid water entrenchment, and collection of condensate drainage.

The staff reviewed DCD Tier 2, Section 10.3.2.4, as related to prevention and minimization of the contamination. Because the APR1400 DCD design provides adequate measures for early leak detection and controls in the MSS design to minimize contamination as described above, the staff concludes that the system as described in the DCD conforms to 10 CFR 20.1406.

10.3(D)(g) Initial Test Program

Although applicants for design certification are not required to submit plans for an initial test program, RG 1.68 acknowledges that design certification applicants have previously submitted these plans to assist a future COL applicant referencing the design certification in meeting the requirements of 10 CFR 52.79(a)(28). Preoperational test requirements for the MSS are located in DCD Tier 2 Section 14.2.12.1.63, "Main Steam Safety Valve Test;" Section 14.2.12.1.64, "Main Steam Isolation Valves and MSIV Bypass Valves Test;" Section 14.2.12.1.65, "Main Steam System Test;" and Section 14.2.12.4.15, "Main Steam Atmospheric Dump and Turbine Bypass Valves Capacity Test."

The initial test program for the APR1400 is evaluated in Section 14.2 of this SER.

10.3(D)(h) ITAAC

The proposed ITAAC for the MSS are given in DCD Tier 1, Table 2.7.1.2-4, "Main Steam System ITAAC." Section 14.3.7 of this report evaluates the DCD Tier 1 information for plant systems SSCs. The evaluation of Tier 1 information in this section is an extension of the evaluation provided in SER Section 14.3.7 and only pertains to the MSS.

The staff's review for the MSS Tier 1 information included review of descriptive information, safety-related functions, arrangement, mechanical, I&C and electric power design features, environmental qualification, as well as system and equipment performance requirements provided in DCD Tier 1, Section 2.7.1.2. Based on its review, the staff finds that that the DCD Tier 1 information and ITAAC requirements adequately describe the design certification requirements for the MSS. Further the staff concludes that the ITAAC requirements are sufficient to demonstrate that the MSS will be designed and will operate in accordance with the design certification, the provisions of the Atomic Energy Act of 1954, and NRC regulations which include 10 CFR 52.47(b)(1).

10.3(D)(i) Technical Specifications

The staff reviewed DCD Tier 2, Chapter 16, technical specifications 3.7.1, 3.7.2, and 3.7.4 for applicability to the main steam system. These technical specifications provide limiting conditions for operation and surveillance requirements for the MSSVs, MSIVs, and MSADVs. The staff also reviewed the associated technical specification bases and found the description to be consistent with the DCD Tier 2 description of the components. The staff concludes that technical specifications 3.7.1, 3.7.2, and 3.7.4 appropriately address the limiting conditions for operation and surveillance requirements for the MSSVs, MSIVs, and MSADVs. For the staff's complete review of technical specifications and associated bases see Chapter 16 of this report.

10.3(E) Combined License Information Items

The following is a list of COL information item numbers and descriptions from DCD Tier 2 Section 10.3.7:

Table 10.2.3-1 APR 1400 Combined License Information Items

Item No.	Description	DCD Tier 2 Section
10.3(1)	The COL applicant is to provide operating and maintenance procedures including adequate precautions to prevent water (steam) hammer and relief valve discharge loads and water entrainment effects in accordance with NUREG-0927 and a milestone schedule for implementation of the procedure.	10.3.2.3.5
10.3(2)	The COL applicant is to establish operational procedures and maintenance programs as related to leak detection and contamination control.	10.3.6.3

10.3(F) Conclusion

Based on the review above, the staff concludes that the SER remains incomplete pending satisfactory resolution of the **Open Items** identified in staff's technical evaluation in this report. The staff will update Section 10.3 of this SER to reflect the final disposition of the DCD.

10.3.6 Steam and Feedwater System Materials**10.3.6(A) Introduction**

This section evaluates the material used in the main steam and feedwater systems including aspects of flow accelerated corrosion (FAC).

10.3.6(B) Summary of Application

The main steam and feedwater systems in the APR1400 power plant provide feedwater to the steam generators and direct steam from the steam generators to the main turbine. Additionally, the main steam and feedwater systems provide two Engineered Safety Features (ESF) functions: 1) the main steam system delivers steam to the auxiliary feedwater pump and 2) both

systems have isolation valves which ensure containment integrity in the event of a containment isolation signal. The applicant has provided a Tier 2 description of the main steam and feedwater systems' materials in DCD Tier 2 Revision 0, DCD Section 10.3.6, which is summarized herein.

System Design and Codes of Construction

The main steam and feedwater systems contain safety-related American Society of Mechanical Engineers Boiler and Pressure Vessel Code (henceforth referred to as the ASME Code) Section III, Class 2 and Class 3 components and non-safety-related ASME B31.1, "Power Piping," components. The individual classification of systems, structures, and components is presented in DCD Tier 2, DCD Table 3.2-1. Transitions between codes of construction are shown in DCD Tier 2, DCD Figures 10.3.2-1 and 10.4.7-1. The staff's review of conformance to 10 CFR 50.55a(c)-(e) and the adequacy of system classification is evaluated in SER Section 3.2.

The applicant commits to meeting all requirements of ASME Code, Section III for safety-related portions of the main steam and feedwater systems. ASME Code, Section III Code Cases are not used for the design of any components in the main steam and feedwater systems. By committing to meeting the requirements of the ASME Code, Section III, components will meet the fracture toughness and non-destructive examination requirements detailed in ASME Code, Section III, Subsections NC and ND. The applicant commits to meeting ASME Section III, Appendix D, Article D-1000 concerning preheat temperatures for welding of ferritic steels.

Material specifications for main steam and feedwater system components are provided in DCD Tier 2, DCD Tables 10.3.2-2, 10.3.2-3, and 10.3.2-4 and are summarized as follows:

Component Materials
A/SA-105
A/SA-106 Gr. B
A/SA-106 Gr. C
A/SA-182 Gr. F22
A/SA-216 WCB
A/SA-216 WCC
A/SA-217 Gr. WC9
A/SA-234 WP22
A/SA-234 WPB
A/SA-234 WPC
A/SA-335 Gr. P22
A-588 Gr. C

A-672 Gr. B60
SA-333 Gr. 6
SA-350 Gr. LF2
SA-352 LCB
SA-352 LCC
SA-420 WPL6

The “A/SA” designation denotes materials/components procured to identical material specifications but different Quality Assurance (QA) requirements (i.e., ASME NQA-1 “Quality Assurance Requirements for Nuclear Facility Applications” for ASME Code components/materials, and ASME B31.1, Mandatory Appendix J for ASTM components/materials utilizing ASME B31.1).

In their February 3, 2016 response (ADAMS Accession No. ML16034A035) to RAI 8378 (ADAMS Accession No. ML 15320A353), Question 10.03.06-13, the applicant committed to supplementing DCD Tier 2, DCD Table 10.3.2-4 with material specifications and grades of components in the Condensate Feed – Feed Water Chemical Injection Line. **This item is tracked as Confirmatory Item MCB-10.3.6-8.**

The materials selected by the applicant fit into two general categories: chrome-molybdenum steels (material specifications A/SA 335 Gr P22, A/SA-234 WP22) and carbon steels (remainder of the material specifications contained in the previous table).

In response to several non-technical RAIs the applicant will revise the DCD Tier 2 DCD, Chapter 10 to correct errors and remove contradictions:

- In their response dated January 11, 2016 (ADAMS Accession no. ML16011A239) to RAI 8378, Question 10.03.06-8, the applicant committed to revise DCD Table 10.3-32 to correct a typographical error for the Main Steam Isolation Valves (MSIVs). **This item is tracked as Confirmatory Item MCB-10.3.6-4.**
- In response dated January 11, 2016 (ADAMS Accession No. ML16011A239) to RAI 8378, Question 10.03.06-9, the applicant committed to delete carbon steel specifications from DCD Table 10.3.2-4 that contradicted statements describing areas of the feedwater system which utilized chrome-molybdenum steels. **This item is tracked as Confirmatory Item MCB-10.3.6-5.**
- In their response February 3, 2016 (ADAMS Accession no. ML16034A035), to RAI 83788378, Question 10.03.06-11, the applicant committed to delete flanges and valves in the pipe chase for the main steam branch piping (DCD Table 10.3.2-3) which were included in error. **This item is tracked as Confirmatory Item MCB-10.3.6-7.**
- In their response dated January 11, 2016 (ADAMS Accession no. ML16011A239), to RAI 8378, Question 10.03.06-6, the applicant committed to revise a misstatement in DCD

Section 10.3.6.3 and delete a discussion of the Steam Generator Blowdown System (the information on this system is contained in DCD Tier 2, DCD Section 10.4.8). **This item is tracked as Confirmatory Item MCB-10.3.6-3.**

In their response dated January 11, 2016 (ADAMS Accession No. ML16011A239), to RAI 8378, Questions 10.03.06-3, 10.03.06-5, 10.03.06-7, and 10.03.06-9, the applicant revised material specifications and pipe diameters listed in DCD Tier 2, DCD Tables 10.3.2-2, 10.3.2-3, and 10.3.2-4. The staff noted three changes in the applicant's response that were beyond the scope of the RAI: 1) removal of fittings, valves, and flanges from the table, 2) changing pipe diameters and removing pipe diameters that were not the subject of the previously mentioned RAIs, and 3) pipe diameters were slightly changed to become inconsistent with ASME B36.10, "Welded and Seamless Wrought Steel Pipe" (this standard "covers the standardization of dimensions" of pipes). The staff issued follow-up RAI 8545 (ADAMS Accession No. ML16088A073), Question 10.03.06-20 and the applicant responded by letter dated April 28, 2016, (ADAMS Accession No. ML16119A107) with proposed revisions to DCD Tier 2, Tables 10.3.2-2, 10.3.2-3, and 10.3.2-4. The staff reviewed the applicant's proposed revisions and concluded that some of the changes were satisfactory but the RAI was not fully addressed. **The staff tracks the satisfactory proposed DCD changes as Confirmatory Item MCB-10.3.6-12.** The staff issued followup **RAI 8671, Question 10.03.06-29481** related to the unaddressed portions of RAI 8545, Question 10.03.06-20 and **this item is tracked as Open Item MCB-10.3.6-5.**

Material Degradation

The entirety of the main steam piping is made from carbon steel. An additional 0.035 inches of material is added to the thickness of components as a general corrosion allowance.

The majority of the feedwater system is made from carbon steel. The carbon steel portions of the system have an additional 0.06 inches of material added to the thickness of components as a general corrosion allowance. Portions of the feedwater system identified in DCD Section 10.3.6 as being fabricated from chrome-molybdenum steels do not have a corrosion allowance added to the thickness of the components.

Prevention and Management of Flow Accelerated Corrosion

The applicant provides a description of the Flow Accelerated Corrosion (FAC) program for the APR1400 in DCD Tier 2, Section 10.3.6.3. The APR1400 FAC program is generally based on Electric Power Research Institute (EPRI) NSAC-202L-R3, "Recommendations for an Effective Flow-Accelerated Corrosion Program."

Prevention of FAC is integrated in the design of the APR1400 by: selective use of chrome-molybdenum steels in locations where FAC is a significant concern, eliminating high turbulence points, optimizing flow near orifices to reduce the potential for cavitation, using long-radius elbows in piping systems, smoothing transitions of shop and field welds, and selecting pipe diameters which correspond to industry suggested flow velocities. The design of the APR1400 plant integrates FAC operating experience from the OPR1000 nuclear plants located in South Korea.

10.3.6(C) Regulatory Basis

The staff reviewed APR1400 DCD Tier 2, Revision 0, Section 10.3.6, in accordance with U.S. Nuclear Regulatory Commission (NRC), NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)," Section 10.3.6, Revision 3 (hereafter referred to as the SRP). In the APR1400 DCD, Tier 2, Revision 0, Section 10.3.6, the applicant described the selection, fabrication, and compatibility of materials with the feedwater and main steam system environments. The NRC staff (staff) based its review of DCD Tier 2, Revision 0, Section 10.3.6 and its acceptance criteria on the relevant requirements in Title 10 of the *Code of Federal Regulations* (10 CFR) 50.55a; Appendix A, "General Design Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities;" General Design Criteria (GDC) 1 and 35; and Appendix B, "Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants," to 10 CFR Part 50:

- GDC 1, "Quality standards and records," and 10 CFR 50.55a(a)(1) require that structures, systems, and components (SSCs) important to safety be designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety functions they perform.
- GDC 35, "Emergency core cooling," requires a system to provide abundant emergency core cooling. GDC 35 also requires that, during activation of the system, clad metal-water reaction will be limited to negligible amounts.
- Appendix B to 10 CFR Part 50 mandates that applicants establish quality assurance (QA) requirements for the design, construction, and prevention or mitigation of the consequences of postulated accidents that could cause undue risk to the health and safety of the public.

10.3.6(D) Technical Evaluation

10.3.6(D)(a) *System Design and Codes of Construction*

The applicant committed to meeting Regulatory Guide (RG) 1.28, "Quality Assurance Program Criteria (Design and Construction)," RG 1.50, "Control of Preheat Temperature for Welding of Low-Alloy Steel," and RG 1.71, "Welder Qualification for Areas of Limited Accessibility." Conformance with the aforementioned RGs is consistent with Standard Review Plan, NUREG-800, Section 10.3.6, with the caveat that RG 1.28 is not mentioned in the SRP. The use of RG 1.28 in lieu of RG 1.37, "Quality Assurance Requirements for Cleaning of Fluid Systems and Associated Components of Water-Cooled Nuclear Power Plants," is consistent with staff guidance because the withdrawal notice for RG 1.28 specifies that the updated guidance is found in RG 1.37.. SRP Section 10.3.6 will be updated at a future time to reflect the new staff guidance.

The staff reviewed the ASME classifications of the feedwater and main steam systems to verify that DCD Tier 2, DCD Section 10.3.6 is consistent with the codes of construction. Portions of the main steam and feedwater system which are classified as ASME Code Class 2 or Class 3 SSCs utilize material specifications that are listed in ASME Code, Section II-D, Table 1A. The selection of material specifications is in conformance with the ASME Code. Additionally, the staff performed a consistency check between DCD Tier 2, DCD Section 3 and DCD Section 10.3.6. The staff tracks the following DCD revisions related to ASME Code compliance:

- In their January 11, 2016, response (ADAMS Accession No. ML16011A239) to RAI 8378 (ADAMS Accession No., ML15320A353), Question 10.03.06-1, the applicant committed to: revising the ASME Code compliance statement, removing a non-applicable reference, and clarifying that no ASME material Code Cases will be used. **This item is tracked as Confirmatory Item MCB-10.3.6-1.**
- In their February 3, 2016, response (ADAMS Accession No. ML16034A035) to RAI 8378, Question 10.03.06-14, the applicant committed to update DCD Table 10.3.2-3 to specify that the Auxiliary Feedwater Pump Turbine Steam Isolation Valve is an ASME Code, Section III, Class 3 component. **This item is tracked as Confirmatory Item MCB-10.3.6-9.**
- In their February 3, 2016, response (ADAMS Accession No. ML16034A035) to RAI 8378, Question 10.03.06-12 and their May 23, 2016, response (ADAMS Accession No. ML16144A851) RAI 8545, Question 10.03.06-21, the applicant committed to update DCD Tier 2, DCD Section 10.3.6 and add COL Item COL 10.3(5). This COL item will require a COL applicant to provide welding material specifications that will be used for ASME Code, Section III components. **This item is tracked as Confirmatory Item MCB-10.3.6-10.**

The staff performed a review of the main steam and feedwater systems constructed to the ASME B31.1 code. The selection of this code of construction is consistent with the recommendations in RG 1.26, "Quality Group Classifications and Standards for Water-, Steam, and Radioactive-Waste-Containing Components of Nuclear Power Plans," for Quality Category D components. The staff found that material specifications selected by the applicant are consistent with rules of ASME B31.1.

In RAI 8378, Question 10.03.06-5, the staff identified that the steam extraction lines are constructed from ASTM A-588 Grade C, which is a grade of "weathering steel." The staff issued RAI 8378, Questions 10.03.06-5 and 10.03.06-7, and followup RAI 8545, Question 10.03.06-19 (ADAMS Accession No. ML16088A073) seeking information on the use of ASTM A-588 Grade C, how the material complies with ASME B31.1 (the specified code of construction), and the FAC resistance of the material. In response (ADAMS Accession No. ML16152B015) to RAI 8545, Question 10.03.06-19, the applicant states that the A-588 material specification was provided by a possible turbine vendor and that the DCD is not intended to "lock in" a specific turbine vendor. The applicant proposes to add a new COL item which requires a COL applicant to describe the material specifications for piping between the turbine and the moisture separator reheater and provide a justification that the piping thickness is sufficient considering the FAC susceptibility of the lines. The staff finds the use of a COL item acceptable because the turbine and moisture separator reheaters are a non-safety systems and the COL item is sufficient in scope to capture the safety concerns associated with to gross failure of main steam or feedwater systems. **The addition of this COL item is tracked as Confirmatory Item MCB-10.3.6-13.**

Material Selection and Degradation

The feedwater system connects to two systems made from austenitic stainless steel (the Auxiliary Feedwater System and the CF FW Chemical Injection System) downstream of the main steam valve housing and upstream of the steam generators. In the February 3, 2016, response (ADAMS Accession No. ML16034A035) to RAI 8378, Question 10.03.06-15 and the

May 23, 2016, response (ADAMS Accession No. ML16144A851) to RAI 8545, Question 10.03.06-21, the applicant committed to update DCD Tier 2, DCD Section 10.3.6.2 with requirements for welding the stainless steel auxiliary feedwater connection to the feedwater system. **This item is tracked as Confirmatory Item MCB-10.3.6-14.** By meeting RG 1.50, RG 1.71, RG 1.31, "Control of Ferrite Content in Stainless Steel Weld Metal," and RG 1.44, "Control of processing and Use of Stainless Steel," the applicant provides sufficient assurance that the fabrication of these dissimilar metal weld will be controlled adequately.

The material specifications and grades of components in the main steam and feedwater systems are generally consistent with operating nuclear power plants and other certified designs (appendices to 10 CFR Part 52). The applicant has chosen to construct the main steam and feedwater systems from carbon steel and chrome-molybdenum steel. Carbon steels have extensive history in steam power-conversion systems and the material is suitable for steam and elevated temperature water service provided that controls are provided to prevent material degradation.

The applicant will prevent degradation of the carbon steel by controlling the water chemistry. The secondary water chemistry program is evaluated by the staff in SER Section 10.3.5. In a January 11, 2016, response (ADAMS Accession No. ML16011A239) to RAI 8378, Question 10.03.06-2, the applicant committed to remove statements in the DCD which erroneously describe carbon steel as a material which minimizes oxygen-induced corrosion. Additionally, as part of the response to RAI 8378, Question 10.03.06-2, the applicant will remove a statement allowing the use of "equivalent" materials in the feedwater and main steam systems. **This item is tracked as Confirmatory Item MCB-10.3.6-2.**

Chrome-molybdenum steels are used in areas of the feedwater system where applicant predicts significant FAC may occur. Chrome-molybdenum steels have significant operating experience in steam power-conversion systems and are more corrosion resistant than carbon steel.

Significant operating experience has shown that the material specifications and grades chosen by the applicant are adequate. However, because the APR1400 utilizes carbon steel in portions of the main steam and feedwater system the staff conducted a detailed review of the FAC program.

10.3.6(D)(b) FAC Program

In DCD Tier 2, Section 10.3.6.3 the applicant states that the APR1400 will implement a FAC program "generally based on" NSAC-202L-Revision 3. SRP Section 10.3.6, item III.3 states that NSAC-202L-Revision 2 is the acceptance criteria for a FAC program. The use of NSAC-202L-Revision 3 is acceptable because both revisions are endorsed in NUREG-1801, Rev 2, "Generic Aging Lessons Learned (GALL) Report," Section XI.M17.

In RAI 8378, Question 10.03.06-10 (ADAMS Accession No. ML15320A353), the staff sought clarification on the FAC program required by the DCD; COL item 10.3(3) requires the FAC program should be consistent with NSAC-202L-Revision 3, but DCD Section 10.3.6.3 specifies that the design is "generally based on" NSAC-202L-Revision 3. The response from the applicant (ADAMS Accession No. ML16011A239) clarified the COL. **The proposed change to this COL item and corresponding changes to the DCD text are tracked as Confirmatory Item MCB-10.3.6-6.** The staff issued follow-up RAI 8545, Question 10.03.06-18 requesting a clear statement from the applicant if conformance to NSAC-202L-Revision 3 was required or if conformance to a FAC program "generally based on" NSAC-202L-Revision 3 was required. In

response (ADAMS Accession No. ML16119A107) to RAI 8545, Question 10.03.06-18 the applicant clarified that the unmodified EPRI NSAC-202L will be the licensing basis for the FAC monitoring program.

An important aspect of a NSAC-202L FAC program is the use of ASME Code Case N-597-2, "Requirements for Analytical Evaluation of Pipe Wall Thinning," when the thickness of a component is reduced below than the ASME Code, Section III or ASME B31.1 required nominal thickness. The use of ASME Code Case N-597-2 is acceptable to the staff provided that the conditions specified in RG 1.147, "Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1," are met. The staff reviewed DCD Tier 2, DCD Section 10.3.6 and 10.3.4 and found that the applicant references ASME Code, Section XI, but does not integrate the terms and conditions specified in 10 CFR Part 50.55a(b)(5) regarding RG 1.147 and conditions on the use of ASME Code Cases. Follow-up [RAI 8649 Question 10.03.06-xx Pending issuance](#) was issued to require the applicant to describe this regulatory requirement in the DCD and the **topic is tracked as Open Item MCB-10.3.6-1**.

Pending resolution of Open Item MCB-10.3.6-1, the staff concludes that the proposed APR1400 FAC program is acceptable.

FAC and the APR1400 Plant Design

A FAC program is the framework which provides confidence that the main steam and feedwater systems will not experience unacceptable degradation due to FAC. The initial FAC predictions are based upon conservative predictions associated with the flow conditions in the piping system. As such, it was necessary to review the assumptions made by the applicant which could impact FAC program.

The applicant states that FAC prevention is integrated into the APR1400 design by: reducing high-turbulence areas, designing piping systems to reduce cavitation, selecting long-radius elbows in piping systems when possible, smoothing weld transitions, and choosing pipe sizes to optimize flow velocities. The use of these strategies is consistent with reduction the probability of FAC and the recommendations in NSAC-202L-Revision 3.

In DCD Tier 2, DCD Section 10.3.6.3, the applicant states that the main steam and feedwater systems will be procured with an additional 0.035 and 0.06 inches, respectively, of material thickness to provide a corrosion allowance. The corrosion allowance is provided "in consideration of the 40 years of design life." The staff reviewed CHECWORKS wear data from extended power uprates and stretch power uprates of operating plants in the United States and found that most operating nuclear power plants experience wear rates that would exceed the APR1400 corrosion allowance before 40 years of operation.

The discrepancy between the APR1400 corrosion allowance and the CHECWORKS data from the operating fleet in the United States resulted in the staff issuing RAI 8378, Question 10.03.06-17 which requested a justification on the sufficiency of the corrosion allowance. In their response dated February 3, 2016 (ADAMS Accession No. ML16034A035) the applicant provided CHECWORKS data from several OPR1000 nuclear power plants whose data was used as the basis for calculating the APR1400 corrosion allowance. The staff reviewed the CHECWORKS data from the OPR1000 and found that the wear rates exceeded those from the United States operating plants and that the corrosion allowance was insufficient for FAC.

The staff concluded that a more detailed and expanded examination of the APR1400 plant design was warranted to determine if the plant design is consistent with the FAC program. The

staff examined three topic areas: 1) how the applicant determined component thicknesses were sufficient, 2) the applicability of the OPR1000 FAC data, and 3) a detailed review of the APR1400 design for FAC susceptible areas.

Sufficiency of the Thickness of Components

During a staff audit conducted on **May 10, 2016 (ADAMS Accession No. MLXXXX)** in which the staff reviewed the FAC program for the main feedwater and steam system, the applicant discussed how the “corrosion allowance” is consistent with the FAC program. The applicant stated that the corrosion allowance is sufficient for the majority of the carbon steel portions of the main steam and feedwater systems where FAC susceptibility is relatively low. For carbon steel areas where significant FAC is predicted to occur, the applicant will utilize the additional thickness margin built into the system. The margin is provided by use of standard piping thicknesses exceeding the required ASME Code, Section III or ASME B31.1 design thicknesses and using ASME Code Case N-597-2 when the piping thickness is below t_{nominal} . The CHECWORKS software has the built-in capability to track the loss of base material and ensures that the performance-based minimum wall thickness (consistent with the ASME Code methodology and staff conditions placed on the Code Case) is not violated. The staff issued RAI 86158615, Question 10.03.06-23 which provided the context of the audit discussion and requested updates to the DCD which capture how the applicant determines a component is operable once the corrosion allowance is depleted. In the June 17, 2016, response (ADAMS Accession No. ML16169A033) the applicant committed to revising DCD Tier 2, DCD Section 10.3.6 to identify and describe additional margin that may be used beyond the corrosion allowance. **This item is tracked as Confirmatory Item MCB-10.3.6-11.**

Applicability of the OPR1000 FAC data

The CHECWORKS FAC management program merges the measured thickness of components and FAC wear data to predict component lifetimes. The lifetime predictions provide a reasonable basis that the APR1400 piping system is designed for a 40 year life. This approach is consistent with the current operating fleet.

Because significant FAC data on the APR1400 has not been obtained, the component lifetimes in the APR1400 plant are projected from the OPR1000 FAC data. To determine if the OPR1000 FAC data is applicable to the APR1400 design the staff examined two topics: 1) whether the OPR1000 FAC program would reliably generate data which could be used to predict APR1400 FAC rates and 2) a comparison of the APR1400 and the OPR1000 plant designs to determine if any differences in the designs could result in significantly different FAC rates.

a. Examination of OPR1000 FAC Program

In their response dated January 11, 2016 (ADAMS Accession No. ML16011A239) to RAI 8378, Question 10.03.06-4, the applicant stated that there are seven programmatic differences between the FAC programs used at OPR1000 plants and a program like that proposed for the APR1400 which would comply with EPRI NSAC-202L. Two aspects could impact the relevance of the OPR1000 wear rate measurements and were reviewed by the staff: the method of wear evaluation and the use of ultrasonic testing (UT) for inspection within the OPR1000 FAC program.

1) Method of Wear Evaluation

The applicant described the LSPTP (Least Squares Point-to-Point), LSSM (Least

Squares Slope Method), and Near Area Minimum (NAM) wear evaluations and the statement “piping inspected repeatedly over twice” during the May 10, 2016 audit. The staff reviewed each of the aspects and determined that they did not introduce non-conservatism which could affect the relevance of the OPR1000 data for use in establishing the design of the APR1400. Details regarding the staff’s conclusion are included in the staff’s audit [report \(ADAMS Accession No. MLXXX\)](#).

2) Method of UT inspection

During the May 10, 2016 audit, the applicant stated that the OPR1000 data was gathered from UT examinations and RT was not used. NSAC-202L-Revision 3 allows both volumetric examination techniques to be used. The use of RT is suggested for complex geometry components but it is not required. Additionally, the UT inspection procedure was provided during the audit. The staff reviewed the document and found that the grid spacing requirements, the use of encoded UT, the use of high temperature markers, and surface preparation requirements is consistent with NSAC-202L-Revision 3, Section 4.5.

The staff’s review of the methodology used for gathering data from the OPR1000 plants via UT resulted in the staff’s conclusion that the data could be reliably used as the basis for determining corrosion allowances in the APR1400 design. Details regarding the staff’s conclusion are included in the staff’s audit report (ADAMS Accession No. MLXXX).

b. Comparison of the OPR1000 and APR1400 plant designs

During the audit on May 10, 2016, the applicant provided Piping and Instrumentation Diagrams (P&IDs) and material specifications for the OPR1000 plant. The staff conducted a component-by-component comparison of the P&IDs for the OPR1000 and APR1400 plants and concluded that configuration of components in the both designs were nearly identical with the exception of: 1) the APR1400 utilized piping of larger diameters and 2) the APR1400 eliminated several flanges and replaced the connections with welds. The staff reviewed the material specifications in the APR1400 and OPR1000 plants and found that the material specifications were similar; in some cases a larger diameter component necessitated a different material specification, but the chemistry of the material was the same.

Based upon the information provided, the staff concludes that the OPR1000 power plant is sufficiently similar to the APR1400 plant that the CHECWORKS data from the OPR1000 plant can represent reasonable FAC predictions. The CHECWORKS data supports the applicant’s assertion that the feedwater and main steam systems in the APR1400 are designed for 40 years of operation. Ultimately, the lifetime of each components (as well as the inspection intervals and repair/replacement activities) will be determined from the FAC data obtained from the operating APR1400 plant.

APR1400 Design as it relates to FAC Susceptibility

To assess the FAC susceptibility of the APR1400 plant, the staff reviewed the design’s conformance to recommendations in EPRI NSAC-202L-Revision 3 and FAC insights provided by the OPR1000 data.

a. NSAC-202L-Revision 3 Recommendations

EPRI NSAC-202L-Revision 3 recommends that a susceptibility analysis should be performed to document the potential for FAC in every piping system. The staff reviewed the APR1400 susceptibility analysis data during the May 10, 2016 audit. The susceptibility analysis correctly determined that portions of the main steam and feedwater systems are not susceptible to FAC based upon the exclusion guidelines described in EPRI NSAC-202L-Revision 3, Section 4.2.2. The staff concludes that the APR1400 susceptibility analysis is consistent with NSAC-202L-Revision 3 and provides reasonable assurance that each piping system was examined for general FAC susceptibility.

The main feedwater line separates into two lines downstream of the feedwater header: the downcomer and economizer feedwater lines. Both the downcomer and economizer feedwater lines utilize FAC resistant chrome-molybdenum steel in portions of the system. The staff noted a configuration of: chrome-molybdenum steel to carbon steel to chrome-molybdenum steel in the downcomer line. This configuration is more susceptible to FAC as discussed in NSAC-202L-Revision 3. **The staff issued follow-up RAI 8649, Question 10.03.06-29430 on this item and tracks this as Open Item MCB-10.3.6-3.** The staff also noted that this configuration did not exist in the economizer line. The staff issued follow-up RAI 8629, Question 10.03.06-29431 requesting further information on why the economizer line did not require a FAC resistant material considering that the flow is similar to the downcomer line. **This item is tracked as Open Item MCB-10.3.6-4.**

b. OPR1000 FAC data insights

The applicant provided a full set of OPR1000 CHECWORKS data during the May 10, 2016 audit. The staff review of the OPR1000 CHECWORKS data focused on components and portions of systems with documented failure or degradation in the Nuclear Energy Agency Piping Failure Data Exchange Project database. The OPR1000 CHECWORKS data does predict greater wear rates for portions of the main steam and feedwater system where FAC failure or significant degradation has occurred in operating plants.

The staff notes that there is significant uncertainty in OPR1000 CHECWORKS predictions; the OPR1000 data incorporates limited operational experience (the components have 1- 4 years of operating time). The lack of operating time may have temporarily passivated corrosion cells or corrosion cells may not have reached a steady state condition. The OPR1000 wear rates and the corresponding predicted component lifetimes may be under or over predicted. Additionally, the extended power uprate and stretch power uprate CHECWORKS data from US nuclear power plants reflect “aged” conditions where materials have relatively steady state corrosion. As the APR1400 plant ages, the staff expects the wear rates will approach wear rates in the currently operating US plants based upon the water chemistry requirements, the flow rates in the systems, and the use of material specifications common to operating plants in the United States.

10.3.6(E) Combined License Information Items

DCD Tier 2, DCD Section 10.3.7 contains “Combined License Information” which describes the information that must be submitted to the staff by a COL applicant referencing the APR1400 design. This information is duplicated in DCD Tier 2, Table 1.8-2, “Combined License

Information Items.” One COL item pertains to the main steam and feedwater materials:

Item No.	Description
COL 10.3(3)	The COL applicant is to provide a description of the FAC monitoring program for carbon steel portions of the steam and power conversion systems that contain water or wet steam and are susceptible to erosion-corrosion damage. The description is to address consistency with GL 89-08 and NSAC-202L-R3 and provide a milestone schedule for implementation of the program.

Item COL 10.3(3) describes the implementation a FAC monitoring program. As written the COL item reduces the scope of the FAC program to systems which are predicted to be susceptible to FAC. The EPRI NSAC-202L program requires that all systems are added into the FAC program and allows lines to be excluded from inspections based upon certain criteria; COL Item 10.3(3) prescreens systems from the NSAC-202L program. [Follow-up RAI 8649 Question 10.03.06-29429](#) was issued on this item and the **topic is tracked as Open Item MCB-10.3.6-2**.

As was previously stated, Confirmatory Item MCB-10.3.6-10 tracks the applicant’s addition of COL Item COL 10.3(5) regarding welding material specifications used for ASME Code, Section III components:

(Proposed) Item No.	(Proposed) Description
COL 10.3(5)	The COL applicant is to provide material specifications that will be utilized for ASME Section III components.

As was previously stated, Confirmatory Item MCB-10.3.6-13 tracks the applicant’s addition of COL Item COL 10.3(6) regarding material specifications for piping between the turbine and the moisture separator reheater and requiring justification that the piping thickness is sufficient considering the FAC susceptibility of the lines:

(Proposed) Item No.	(Proposed) Description
COL 10.3(6)	The COL applicant is to provide the description about the material specifications for components between 1) the high pressure turbine and the moisture separator reheater and 2) the moisture separator reheater and the low pressure turbine when the T/G design is selected. The COL applicant is also to specify that the pipe thickness is adequate for the plant design life in terms of FAC in place of the components between 1) the high pressure turbine and the moisture separator reheater and 2) the moisture separator reheater and the low pressure turbine when the T/G design is selected.

10.3.6(F) Conclusion

The SER for the APR 1400 is not yet complete pending the closure of Open Items MCB-10.3.6-1, MCB 10.3.6-2, MCB 10.3.6-3, 10.3.6-4, and 10.3.6-5. The staff will update Section 10.3.6 of this SER to reflect the final disposition of the design certification application.

Other Features of the Steam and Power Conversion System

10.4.1 Main Condensers

10.4.1(A) Introduction

The APR1400 main condenser (MC) functions as the steam cycle heat sink which condenses and deaerates the exhaust steam from the low-pressure main turbine. It is designed to accept full load exhaust steam from the main turbine and up to 55 percent of the full power steam flow via the turbine bypass system (TBS). The main condenser is not safety-related and does not perform any safety-related functions.

10.4.1(B) Summary of Application

DCD Tier 1: There are no Tier 1 requirements specific to the main condensers.

DCD Tier 2: DCD Tier 2, Section 10.4.1, "Main Condensers," provides the MC system design. Table 10.4.1-1, "Main Condenser Design Data," provides design parameters for the MC.

DCD Tier 2, Section 10.4.1 discusses the MC system design basis; system and component description; safety evaluation; inspection and testing requirements; and instrumentation requirements.

DCD Subsection 10.4.1.1, "Design Bases," and 10.4.1.2, "System Description," describe the design and functions of the MC. The portions of the MC that are outside the scope of the design certification are presented as conceptual design information in DCD Tier 2, delineated by double brackets ([[]]). The MC is a single-pressure, three-shell and single-pass surface condenser designed to condense the low-pressure turbine exhaust steam so condensate can be efficiently pumped through the steam cycle. The condensate is drawn from the hotwell of each condenser to a single header which provides suction to the condensate pumps of the condensate and feedwater system (CFS) as depicted in DCD Tier 2 Figure 10.4.7-1, "Condensate and Feedwater System Flow Diagram." Therefore, all three condenser shells operate at the same pressure and temperature. The condenser hotwells serve as storage reservoirs for the CFS with sufficient volume to supply maximum condensate flow for five minutes. In support of the turbine bypass function, the MC can condense up to 55% of total full power steam. It also serves as a collection point for feedwater heater drains and vents, miscellaneous equipment drains and vents, and feedwater pump turbine exhaust steam. Heat is removed from the MC by the circulating water system (CWS).

DCD Subsection 10.4.1.3, "Safety Evaluation," provides an evaluation of the operation.

In DCD Tier 2, Subsection 10.4.1.4, "Inspection and Testing Requirements," the applicant describes the operational testing and inspections as well as the design features to allow such inspections and testing to occur.

DCD Tier 2, Subsection 10.4.1.5, "Instrumentation Requirements," describes the instrumentation and protection devices for the condenser. All instrumentation is for normal power operation and not required for safe shutdown.

DCD Tier 2, Table 3.2-1, "Classification of Structures, Systems, and Components," (Item 10.b) identifies the MC as non-nuclear safety system, seismic category III, designed to American Society of Mechanical Engineers (ASME) B31.1-2010, and not applicable to the quality assurance requirements of 10 CFR Part 50, Appendix B.

ITAAC: There are no ITAAC specific to the MC system.

Technical Specifications: There are no technical specifications (TS) associated with the MC system.

Initial Test Program: Preoperational testing for the MC is described under DCD Tier 2, Subsection 14.2.12.1.67, "Main Condenser and Condenser Vacuum Systems Test."

10.4.1(C) Regulatory Basis

Conformance with the applicable requirements of 10 CFR Part 50, Appendix A, "General Design Criteria for Nuclear Power Plants," and the provisions of the following additional requirement constitutes an acceptable basis for a satisfactory MC design.

5. GDC 2, "Design bases for protection against natural phenomena," as it relates to the failure of nonsafety-related systems or components due to natural phenomena such as earthquakes, tornadoes, hurricanes, and floods not to adversely affect the safety-related SSCs.
6. GDC 4, "Environmental and dynamic effects design bases," as it relates to a failure of the system or component that results in environmental conditions such as discharging fluids (i.e., flooding) that could adversely affect safety-related SSCs.
7. GDC 60, "Control of releases of radioactive materials to the environment," as it relates to provisions being included in the nuclear power unit design to control suitably the release of radioactive materials in gaseous and liquid effluents during normal reactor operation, including anticipated operational occurrences (AOOs). GDC 60 is applicable to the design of the MC system because in PWRs radioactive materials may be deposited in the main condensers if there is a primary-to-secondary steam generator tube leak.
8. GDC 64, "Monitoring radioactivity releases," as it relates to provisions being included in the nuclear power unit design for monitoring the effluent discharge paths and the plant environs for radioactivity that may be released from normal operations, including AOOs, and from postulated accidents.
9. 10 CFR 52.47(b)(1), which requires that a DC application contain the proposed ITAAC that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the DC is built and will operate in accordance with the DC, the provisions of the Atomic Energy Act of 1954, as Amended, and the NRC's regulations.

In addition to the above GDCs, the Standard Review Plan (SRP), Section 10.4.1, "Main Condenser," Subsection II, "Acceptance Criteria," "SRP Acceptance Criteria," Item 1.B, states that acceptance of GDC 60 is based on meeting the following:

If there is a potential for explosive mixtures to exist, the MC is designed to withstand the effects of an explosion and instrumentation is provided to detect and annunciate the buildup of potentially explosive mixtures, dual instrumentation is provided to detect, annunciate, and effect control measures to prevent the buildup of potentially explosive mixtures, as outlined in SRP Section 11.3, subsection II, "Acceptance Criteria," SRP Acceptance Criteria, Item 6.

10.4.1(D) Technical Evaluation

The staff reviewed the design of the APR1400 MC system in accordance with SRP, Section 10.4.1, Revision 3.

10.4.1(D)(a) *GDC2, Design bases for protection against natural phenomena, and GDC 4, Environmental and dynamic effects design bases*

The staff reviewed the design of the main condenser for compliance against the requirements of GDC 2 which requires that SSCs important to safety be designed to withstand the effects of postulated local natural phenomena, such as earthquakes, tornadoes, hurricanes, floods, tsunami, and seiches without loss of the capability to perform their safety functions. DCD Section 10.4.1.3, "Safety Evaluation," states that the condenser does not perform any safety-related functions. Therefore, acceptance of GDC 2 is based on the guidance provided by regulatory position C.2 of Regulatory Guide (RG) 1.29, "Seismic Design Classification," which specifies that failure of non- safety-related systems should not have an adverse effect on safety-related systems

The staff also reviewed the design of the MC for compliance with the requirements of GDC 4. The staff's review was performed to verify that the system was protected against environmental and dynamic effects or that a failure of the MC and the resulting discharging fluid (i.e., flooding) would not adversely affect safety-related SSCs. In DCD Section 10.4.1.3, the applicant states that "flooding due to failure of a condenser hotwell does not prevent safe shutdown of the reactor." The flooding water cannot reach safety-related equipment located in auxiliary building because the opening or access door between the turbine and auxiliary buildings is located higher than the basic grade of the turbine building. The flooding in the turbine building that results from a failure of the main condenser is bounded by that of a circulating water system line break in the turbine building. Further staff evaluation of the circulating water system can be found in Section 10.4.5 of this SE.

Based on the above review, the staff finds that the main condenser design is in compliance with GDC 2, and 4, because regulatory position C.2 of RG 1.29 is met and the potential flooding due to a failure to the MC does not result in SSCs important to safety being adversely effected

10.4.1(D)(b) *GDC 60, Control of releases of radioactive materials to the environment, and GDC 64, Monitoring radioactivity releases*

The staff reviewed the design of the MC for compliance with the requirements of GDC 60 with respect to control of release of radioactive materials and GDC 64 with respect to the monitoring of radioactive releases. Compliance with GDC 60 and GDC 64 requires provisions be included in the nuclear power unit design to monitor and control suitably the release of radioactive materials during normal operation, including AOOs.

Meeting these requirements provides a level of assurance that the release of radioactive materials in gaseous and liquid effluents from the main condensers during normal operation, including AOOs, is kept as low as is reasonably achievable, in accordance with 10 CFR Part 50, Appendix I.

DCD Subsection 10.4.1.3 states that during normal operation and shutdown, the MC does not have radioactive contaminants. The DCD states that radioactive contaminants are only through primary-to-secondary system leakage due to steam generator (SG) tube leaks. A discussion of these leaks is included in DCD Tier 2, Subsection 11.1.1.3, "Secondary System Activity."

Regarding potential buildup of explosive mixtures, the DCD states that no hydrogen buildup in the MC is anticipated, including in the form of non-condensable gas constituents. The condenser vacuum system in the main condenser is designed to remove leaked air and non-condensable gases from condensing steam using mechanical vacuum pumps. See DCD Subsection 10.4.2 for further information on the condenser vacuum system. However, conformance to GDC 60, as stipulated in SRP Section 10.4.1, Section II, "Acceptance Criteria," Item 1, requires that the design of the MC is acceptable if the integrated design of the system meets the requirements of GDC 60 as related to failures in the design of the system which do not result in excessive releases of radioactivity to the environment. Item 1.B, "SRP Acceptance Criteria", of the above SRP Acceptance Criteria states in part that the requirements of GDC 60 are met if instrumentation is provided to detect and annunciate the buildup of potentially explosive mixtures. Although control measures were described in the form of the condenser vacuum system, the DCD did not describe any instrumentation to detect any explosive mixtures within the MC and did not describe whether there was annunciation in the main control room to alert operators of any potential explosive mixtures within the MC. Therefore, the staff requested in RAI 7836, Question 10.04.01-1 the applicant provide additional information, in the DCD, in regards to monitoring the condenser for the buildup of combustible gas conducted, including information on the instrumentation used, and how the control room operators are alerted of potential explosive mixtures within the MC.

In the October 2, 2015, response (ADAMS Accession No. ML15275A323) to RAI 7836, Question 10.04.01-1, the applicant points to DCD Subsection 10.4.2.2.2 which states, in part, that thermal decomposition of hydrazine can be considered as a source for hydrogen within the condenser shells. However, the potential for hydrogen buildup within the condenser shells does not exist because three vacuum pumps operate continuously during normal operation with another pump in standby. The DCD goes on to state that the vapor content is maintained above 58 percent by volume in non-condensable gases in accordance with SRP Section 10.4.2. Further evaluation of DCD Section 10.4.2 is provided in Section 10.4.2 of this SER. Therefore the applicant concludes that there is no potential for a build-up of explosive mixtures within the condenser shells and, as a result, the detection of potential explosive mixtures and the main control room annunciation is not required. In addition, the applicant provided proposed related revisions to DCD Tier 2, Subsection 10.4.1.3. This revision is being tracked under **Confirmatory Item 10.04.01-1**. The staff has reviewed the applicants RAI response and find it acceptable because the applicant has demonstrated that potential explosive mixtures will not exist and if there is no potential then the requirements to detect and annunciate do not apply. Because the unacceptable buildup of combustible gases cannot occur, the staff finds that MC meets the SRP guidance provided in Item 1 of the SRP acceptance criteria and Item 3.B of the SRP review procedures, as it relates to instrumentation provided to detect and annunciate the buildup of potentially explosive mixtures, and provision for control measures to prevent the buildup of potentially explosive mixtures.

Regarding controlling and collecting cooling water leakage into the condensate, the DCD states that the tube leak detection system is provided to permit sampling of the condensate in the condenser hotwell as described in Subsection 9.3.2. The tube leak detection system identifies which tube bundle has sustained leakage if circulating water in-leakage occurs. The affected condenser hotwell and CWS are designed to permit manual isolation of the tubes by closing the motor-operated hotwell discharge valve when condenser tube leakage exceeds the design value for the condensate polishing system (CPS). Plant power is reduced as necessary. The waterbox is then drained and the affected tubes are either repaired or plugged. Upon review of the information in the DCD, the staff was unable to find specific details on provisions taken for the controlled collection of waterbox drainage which may contain radioactive contaminants. The SRP guidance provided in Item 2.A of the SRP review procedure requires a means for controlling and collecting cooling water leakage into the condensate. The requirements of GDC 60 require provisions to prevent excessive releases of radioactivity to the environment as a result of a failure within the MC. Therefore, the staff issued RAI 7836 (ADAMS Accession No. ML15204A914), Question 10.04.01-2, requesting that the applicant provide additional information in the DCD as related to provisions to determine which MC bundles is affected by leakage and how water containing radioactive effluents drained from the waterbox is processed.

In the October 2, 2015, response (ADAMS Accession No. ML15275A323) to RAI 7836, Question 10.04.01-2, the applicant stated that the secondary sampling system continuously samples and analyzes the condensate water. This secondary sampling system is capable of identifying which condenser hotwell and tube bundle by any in-leakage. In addition, the applicant's response states that when a MC tube bundle is affected by in-leakage, alarms will be annunciated in the main control room (MCR) and remote shutdown room (RSR). In addition, the applicant provided proposed revisions to DCD Tier 2, Subsection 10.4.1.2, to provide the discussion in the DCD. This revision is being tracked under **Confirmatory Item 10.04.01-2**. The staff has reviewed the applicants RAI response and, because of the continuous sampling and control room annunciators for tube bundle in-leakage, finds the portion related to in-leakage detection acceptable. However, the RAI response remainder is unacceptable because the response did not provide information on the controlled collection of the waterbox drainage that may contain radioactive contaminants. The staff issued supplemental RAI 8477 (ADAMS Accession No. ML16041A092), Question 10.04.01-5 requesting the applicant provide this information and revise the DCD accordingly. In the March 21, 2016, response letter (ADAMS Accession No. ML16081A207), the applicant explains that the waterbox drains are connected to the condenser pit sumps. From there, fluids travel to the condensate polishing area sump and then onto the waste water treatment facility or, if radiation is detected in either sump location, to the liquid waste management system. These sumps are part of the equipment and floor drainage system and further evaluated in Section 9.3.3 of this SER. The staff has reviewed the applicants RAI response and finds it acceptable because the applicant's design for the collection of waterbox drainage will be controlled, monitored, and contaminated water will be transferred to the appropriate system via a system designed to handle contaminated liquids. Based on the above review, the staff finds the requirements of GDC 60, as it relates to controlling and collecting cooling water leakage into the condensate is satisfied. In addition, the applicant provided proposed related revisions to DCD Tier 2, Section 10.4.1. This revision is being tracked under **Confirmatory Item 10.04.01-5**.

The APR1400 MC system is designed to contain titanium tubes and titanium-clad carbon steel, or equivalent material, tube sheets to maintain good corrosion and erosion resisting properties. DCD Table 10.4.1-1 describes the material specifications for the MC. The staff finds this acceptable since it meets the SRP guidance provided in Item 2.B of the SRP review procedure,

as it relates to compatibility of materials of construction used to reduce the corrosion and/or erosion of MC tubes and components.

In the event of high condenser pressure, the DCD states the condenser shells are protected from the high internal pressure by using the relief diaphragm on the top of the low-pressure (LP) hood. If the pressure inside the LP hood exceeds atmospheric pressure, the relief diaphragm will pop, and the steam inside the LP turbine is released to the atmosphere. An expansion connection between the condenser neck and the turbine exhaust is provided which also serves to protect the MC from high internal pressure. The condenser shells have pressure transmitters to detect loss of the condenser vacuum. When the pressure from the pressure transmitters exceeds the set point, a turbine trip signal is generated. The staff finds this acceptable since it meets the SRP, Section 10.4.1, Subsection III, "Review Procedures," Item 3.C, as it relates to detecting loss of condenser vacuum and isolating the steam source

The DCD indicates that tube support plates are designed to protect the condenser tubes by minimizing tube vibrations due to steam impingement forces. These steam impingement forces come from normal operation and from the turbine bypass valve quick-opening events. The staff finds that these design provisions conform to SRP, Section 10.4.1, Subsection III, "Review Procedures," Item 3.D as it relates to incorporating provisions into the MC design that will preclude component or tube failures due to steam blowdown from the turbine bypass system (TBS). The staff's review of the TBS can be found in Section 10.4.4 of this SER.

Regarding conformance to GDC 64, which requires in part that effluent discharge paths shall be provided with a means to monitor for radioactivity that may be released during anticipated operational occurrences, such as steam generator tube leakage. DCD Tier 2, Section 10.4.1 states that during normal operation and shutdown, the MC does not have radioactive contaminants. Typically, MCs would only be expected to receive radioactive contaminants through a steam generator tube leak. A discussion of the radiological aspects of these leaks is included in DCD Tier 2, Subsection 11.1.1.3. While reviewing the DCD, the staff did not find adequate details to justify the requirements of GDC 64, as it relates to the detection and main control room annunciation of radioactive contaminants found in the MC. Therefore, the staff issued RAI 7836 (ADAMS Accession No. ML15204A914), Question 10.04.01-4, requesting the applicant provide additional information and justification in the DCD to conform to the criteria in GDC 64 described above.

In the October 2, 2015, response (ADAMS Accession No. ML15275A323) to RAI 7836, Question 10.04.01-4, the applicant indicated that DCD Section 10.4.2, "Condenser Vacuum System," addresses the conformance to GDC 64 for effluents in the main condenser. DCD Subsection 10.4.2.2.2 states, in part, that the non-condensable gases in MC are not radioactively contaminated during normal operation. The radioactive materials are processed in condenser vacuum system only if there is a primary-to-secondary steam generator (SG) tube leak due to a SG tube rupture (SGTR). If radioactivity in the exhaust flow exceeds acceptable level, the condenser vacuum pump vent effluent monitor actuates an alarm in the MCR and automatically diverts the exhaust flow from vacuum pumps to the containment drain sump area in reactor containment building, and then adequate operating procedures are implemented to preclude significant release to the environment. The effluent monitor design, configuration, and its associated parameters are addressed in Subsections 11.5.2.1 and 11.5.2.2, respectively. The location of radiation detector is shown in Figure 11.5-1. Further staff evaluations related to gaseous effluent monitoring can be found in Sections 11.3 and 11.5 of this SER. The staff has reviewed the applicants RAI response and finds it acceptable because the applicant's design for the MC effluents, including during anticipated operational occurrences such as steam generator

tube leakage, will be monitored for radioactivity. Based on the above review, the staff finds GDC 64, as it relates to monitoring of effluent discharge paths is satisfied.

10.4.1(D)(c) Inspection and Testing

DCD Tier 2, Subsection 10.4.1.4, "Inspection and Testing Requirements," states in part that the condenser is designed to be capable of being filled with water for hydrostatic tests. Provisions are made to allow draining and cleaning of the hotwell. The condenser shells, hotwells, and waterboxes are provided with access openings to permit inspection and repairs. The DCD also states that periodic visual inspections and preventive maintenance on the condenser components are conducted per normal industry practice. The staff finds these operational inspection and testing requirements acceptable for this nonsafety-related system.

10.4.1(D)(d) Instrumentation

DCD Tier 2, Subsection 10.4.1.5, "Instrumentation Requirements," describes the instrumentation and protection devices for the condenser. All instrumentation is for normal power operation and not required for safe shutdown. Condensate temperature, condenser pressure, circulating water temperature and pressure, and differential pressure waterbox-to-waterbox are indicators provided for verifying condenser performance. The MC hotwell level and pressure are indicated locally and in the MCR for each condenser shell. The MC hotwell levels are maintained automatically by transferring to and from the condensate storage system.

A turbine trip is activated when condenser pressure reaches or exceeds the setpoint [[0.26 kg/cm²A (7.5 in HgA)]] indicating a loss of condenser vacuum. DCD Subsection 7.7.1.1 describes the process controls and monitoring from the MCR. The staff finds these instrumentation requirements acceptable, as they are consistent with SRP 10.4.1, Subsection III, "Review Procedures," Item 3.C guidance for detection of loss of condenser vacuum.

10.4.1(D)(e) Initial Test Program

Although applicants for design certification are not required to submit plans for an initial test program, RG 1.68 acknowledges that design certification applicants have previously submitted these plans to assist a future COL applicant referencing the design certification in meeting the requirements of 10 CFR 52.79(a)(28). Preoperational test requirements for the main condenser are described in DCD Tier 2 Subsection 10.4.5.4 and Subsection 14.2.12.1.67. The initial test program for the APR1400 is evaluated in Section 14.2 of this SER.

10.4.1(D)(f) ITAAC

There are no ITAAC required for this system. The system is not safety-related and is not required for safe shutdown. Therefore the staff finds this acceptable in accordance with 10 CFR 52.47(b)(1).

10.4.1(D)(g) Technical Specifications

There are no APR1400 TS sections for the auxiliary steam system. The system is not safety-related and is not required for safe shutdown; therefore the staff finds this acceptable.

10.4.1(E) Combined License Information Items

The staff reviewed the COL information items as listed in Tier 2 of the DCD, Section 1.8, "Interfaces with Standard Design," and Table 1.8-2, "Combined License Information Items", and

found that there are no items relevant to the MC. The staff concluded that this is appropriate and that no COL information items are needed for the APR1400 MC system.

10.4.1(F) Conclusion

The staff evaluated the MC for the APR1400 standard plant design in accordance with guidance that is referred to in the technical evaluation section of this SER. Based on its review of the information that was provided in the DCD, the staff has concluded that sufficient information has been provided by the applicant in APR1400 DCD Tier 2, Section 10.4.1. In addition, the staff has compared the design information in the DC application to the relevant NRC regulations, acceptance criteria defined in NUREG-0800 - SRP Section 10.4.1, and other NRC RGs. In conclusion, the APR1400 design for the MC system is acceptable and meets the requirements of 10 CFR 52.47 (b)(1), GDC 2, GDC 4, GDC 60, GDC 64, and the guidelines of SRP Section 10.4.1 for protection against natural phenomena, dynamic effects, and control and monitoring of releases of radioactive materials to the environment.

10.4.2 Condenser Vacuum System

10.4.2(A) Introduction

The condenser vacuum system is designed to remove air and non-condensable gases from the main condenser in order to establish and maintain a vacuum during startup and normal operation. The condenser vacuum system is designed as non-safety class with the exception of the containment isolation portion which is designed as Safety Class 2. The condenser vacuum system is not required for safe shutdown of the plant.

10.4.2(B) Summary of Application

Tier 1: DCD Tier 1, Section 2.7.1.6, "Condenser Vacuum System," states that there are no entries for the condenser vacuum system.

Tier 2: DCD Tier 2, Section 10.4.2 provides information on the condenser vacuum system. The system performs no safety-related function and is designed to meet the following functional criteria:

- Remove air and non-condensable gases from the condenser during startup, cooldown, and normal operations
- Maintain adequate condenser vacuum for proper turbine operation during startup and normal operations
- Prevent an uncontrolled release of radioactive material to the environment

DCD Tier 2, Table 10.4.2-1, "Condenser Vacuum Pump Design Parameters," provides parameters for the vacuum pumps used in the condenser vacuum system.

ITAAC: There are no ITAAC related to the condenser vacuum system.

Technical Specifications: There are no TS requirements associated with the main condensers or the main condenser evacuation system.

Initial Plant Test Program: Inspection and testing of the condenser vacuum system is performed prior to plant operation as described in DCD Tier 2, Section 14.2.12.1.67, “Main Condenser and Condenser Vacuum Systems Test.”

10.4.2(C) Regulatory Basis

The relevant requirements of NRC regulations for this area of review, and the associated acceptance criteria, are given in NUREG-0800, SRP Section 10.4.2, “Main Condenser Evacuation System,” and are summarized below. Review interfaces with other SRP sections also can be found in SRP Section 10.4.2, Item I.

GDC 60, “Control of Releases of Radioactive Materials to the Environment,” as it relates to provisions being included in the nuclear power unit design to suitably control the releases of radioactive materials in gaseous and liquid effluents during normal operation, including anticipated operational occurrences. GDC 60 is applicable to the design of the condenser vacuum system because, in PWRs, radioactive materials may be deposited in the main condensers if there is a primary-to-secondary steam generator (SG) tube leak.

GDC 64, “Monitoring radioactivity releases,” as it relates to the condenser vacuum system design for monitoring of releases of radioactive materials to the environment during normal operation, including anticipated operational occurrences.

10 CFR 52.47(b)(1), as it relates to the requirement that a design certification application contain the proposed ITAAC that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the design certification is built and will operate in accordance with the design certification, the provisions of the Atomic Energy Act, and NRC regulations.

10.4.2(D) Technical Evaluation

The staff reviewed the condenser vacuum system in accordance with SRP Section 10.4.2. Also, the staff reviewed the condenser vacuum system in accordance with the guidelines contained in RG 1.26, “Quality Group Classifications and Standards,” and RG 1.33, “Quality Assurance Program Requirements (Operation),” as it relates to QA programs for components that may contain radioactive materials. Acceptability of the condenser vacuum system, described in the DCD, is based on meeting the requirements of GDC 60 for controlling the releases of radioactive materials to the environment and the requirements of GDC 64 for monitoring the releases of radioactive materials to the environment.

The staff reviewed the applicant’s design description, system flow diagrams, and design criteria for the components of the condenser vacuum system. The staff finds that the condenser vacuum system is appropriately classified as non-safety-related in accordance with the guidance in RG 1.26 and designed to Heat Exchange Institute (HEI) “Standards for Steam Surface Condensers,” 9th Edition, 2006. The condenser vacuum system includes equipment and instruments to establish and maintain condenser vacuum and to prevent uncontrolled releases of radioactive materials to the environment.

The condenser vacuum system performs no safety-related function and has no safety-related design basis. The condenser vacuum system is designed to remove air and non-condensable gases from the main condenser shells and connected steam systems and to establish and maintain a vacuum during startup, shutdown, and normal operation. The condenser vacuum system is also designed to remove non-condensable gases when the turbine bypass system is

in operation, such as during hot shutdown. The steam and air mixture extracted from each condenser shell is routed to one of three 33.3 percent capacity vacuum pumps. A standby vacuum pump is automatically activated in the event of excessive air in-leakage that results in a rise of condenser backpressure. The vacuum pumps capacity meets or exceeds the capacity recommended in HEI Standards for Steam Surface Condensers, 9th Edition, 2006. The vacuum pumps remove the non-condensable gases from the condenser shells by hogging operation during startup, and by holding evacuation during normal plant operation. The vacuum pumps discharge the steam air mixture to moisture separators, where the steam condenses while the air is exhausted through the turbine generator building's ventilation system. The exhausted air is monitored for radiological activity.

A high condenser pressure alarm annunciates in the MCR if the condenser pressure reaches the high-pressure set-point and the turbine trips if the condenser vacuum system cannot maintain condenser operating pressure. In the event that the condenser vacuum system malfunctions and the condenser becomes unavailable, the RCS heat rejection is accommodated by the main steam atmospheric dump valves.

The requirements of GDC 60 are met when the evacuation system design includes provisions to prevent excessive releases of radioactivity to the environment which may result from the failure of a structure, system, or component. Such releases may result from potential explosive mixtures. If there is a potential for explosive mixtures to exist, the evacuation system should be designed to withstand the effect of an explosion and instrumentation should be provided to detect and annunciate the buildup of potentially explosive mixtures in the condenser. Such potential does not exist where systems are designed to maintain steam content above 58 percent by volume in hydrogen-air mixtures or nitrogen content above 92 percent by volume in hydrogen-air mixtures in all components of the condenser vacuum system.

In PWRs, radioactive materials may be deposited in the main condensers if there is a primary-to-secondary SG tube leak. In DCD Tier 2, Section 10.4.2.2.2, the applicant stated that the thermal decomposition of hydrazine can be considered as a source of hydrogen within condenser shells. However, a potential for hydrogen buildup within condenser shells does not exist because three vacuum pumps operate continuously during normal operation, and a standby vacuum starts when one vacuum pump fails. Additionally, condenser shells are considered to maintain the water vapor content above 58 percent by volume in non-condensable gases in conformance with SRP Section 10.4.2, Acceptance criteria 1.A. The trace amounts of oxygen dissolved in the condensate and condenser hotwell inventory are considered negligible compared to the amounts of air evacuated by the vacuum pumps. Therefore, a potential for explosive mixtures within the condenser shells does not exist and the condenser vacuum system is not required to be designed to withstand the effects of an explosion.

Since the water vapor content in the condenser vacuum system will remain above 58 percent by volume of the total mixture and there is no potential for explosive mixtures within the condenser vacuum system in accordance with SRP Section 10.4.2, the staff concludes that the design of the condenser vacuum system satisfies GDC 60.

The requirements of GDC 64 are met when the condenser evacuation system is provided with a means of monitoring the effluent discharge paths and the plant environs for radioactivity that may be released from normal operations, including anticipated operational occurrences, and from postulated accidents. Mixtures of non-condensable gases and vapor that are discharged to the environment from the main condenser are not normally radioactive during normal plant

operation. However, as described above, it is possible for the mixture to become contaminated in the event of primary-to-secondary system leakage resulting from SG tube leaks. Should this occur, radioactivity would be detected by a radiation monitor provided for in the vent system for air removal as described in DCD Tier 2, Section 11.5.2.2 (g) "Condenser vacuum pump vent effluent monitor (RE-063)," and Table 11.5-1, "Gaseous Process and Effluent Radiation Monitors, Sheet 2 of 3." If radioactivity in the exhaust flow exceeds acceptable level, the radiation monitor actuates an alarm in the MCR and automatically diverts the exhaust flow from the vacuum pumps to the containment drain sump area in the reactor containment building. The effluent monitor design, configuration, and its associated parameters are addressed in DCD Tier 2, Sections 11.5.2.1, "Monitor Design and Configuration," and 11.5.2.2, "Gaseous Process and Effluent Radiation Monitoring and Sampling System (PERMSS)."

DCD Tier 2, Figure 10.4.2-1, "Condenser Vacuum System Flow Diagram," Sheets 1 and 2, depict the condenser vacuum system. DCD Tier 2, Figure 11.5-1, "Radiation Monitoring System (PR)," sheet 2 of 3, depicts the radiation monitoring equipment in the discharge vent of the condenser vacuum system which is located in the turbine generator building.

Since the condenser vacuum system is provided with a means to monitor the effluent discharge path for radioactivity, and if the exhaust flow exceeds acceptable radiation levels there is an alarm provided in the MCR and the discharge flow is automatically diverted to the containment drain sump, the staff concludes that the design of the condenser vacuum system satisfies GDC 64.

DCD Tier 2, Table 3.2-1, "Classification of Structures, Systems, and Components," provides the quality group and seismic design classification of components and equipment of the condenser vacuum system. System components in the turbine building are non-seismic and designed in accordance with Quality Group D standards. System components in the auxiliary building and-reactor containment building are seismic Category II and Quality Group D, except for the containment isolation portion, which is designed as seismic Category I and Quality Group B. Piping and valves (Quality Group B and D) are designed in accordance with ASME Section III, Class 2, and ASME B31.1 respectively.

The condenser vacuum system is designed with specific features to meet the requirements of 10 CFR 20.1406, "Minimization of contamination," and Regulatory Guide 4.21 "Minimization of Contamination and Radioactive Waste Generation: Life-Cycle Planning." The basic principles of NRC RG 4.21, and the methods of control suggested in the regulations, are described in DCD Tier 2 Section 12.4.2.

The condenser vacuum system has no direct impact on the reactor system. The loss of condenser vacuum results in a turbine trip. The loss of condenser vacuum event is evaluated and addressed in DCD Tier 2, Section 15.2.3, "Loss of Condenser Vacuum."

The condenser vacuum system is tested during the initial plant testing program along with the main condenser (DCD Tier 2, Section 14.2.12.1.67.) The objective of this testing is to demonstrate the ability of the main condenser and vacuum systems to provide a continuous heat sink for normal as well as a sink for the turbine bypass system under certain condition

10.4.2(E) Combined License Information Items

The following is a list of COL information item numbers and descriptions from DCD Tier 2, Table 1.8-2 pertaining to the condenser vacuum system:

Table 10.4.2-1 APR1400 Combined License Information Items

Item No.	Description
COL 10.4 (1)	The COL applicant is to establish operational procedures and maintenance programs for leak detection and contamination control
COL 10.4 (2)	The COL applicant is to maintain the complete documentation of system design, construction, design modifications, field changes, and operations

The staff finds the above listing to be complete. Also, the list adequately describes actions necessary for the COL applicant. No additional COL information items need to be included in DCD Tier 2, Table 1.8-2 for condenser vacuum system considerations.

10.4.2(F) Conclusion

The staff has concluded that sufficient information has been provided by the applicant in DCD Tier 2, Section 10.4.2. In addition, the staff has compared the design information and the COL information items in the DCD to the relevant NRC regulations, acceptance criteria defined in NUREG-0800, SRP Section 10.4.2, and other NRC regulatory guides. In conclusion, for the reasons set forth above, the design for the condenser vacuum system is acceptable and meets the guidelines of SRP Section 10.4.2 and the requirements of GDC 60 and GDC 64 for controlling and monitoring releases of radioactive material to the environment.

10.4.3 Turbine Gland Sealing System

10.4.3(A) Introduction

The turbine steam seal system (TSSS), more commonly referred to in the industry as the turbine gland sealing system (TGSS), is designed to provide a source of sealing steam to the annulus space where the turbine and large steam valve shafts penetrate their casings to prevent air leakage into and steam leakage out of these components. This includes the equipment to collect and route the system effluents to the appropriate destination. Review of the TSSS is focused on the system features incorporated to monitor and control releases of radioactive materials in the effluents.

10.4.3(B) Summary of Application

Tier 1: There is no Tier 1 information associated with this section

Tier 2: DCD Tier 2, Section 10.4.3, "Turbine Steam Seal System," includes the TSSS system description, as well as relevant information on the TSSS design, including the design basis, instrumentation, and the inspection and testing program.

In Section 10.4.3, the DCD states that the TSSS performs no safety function and has no nuclear safety-related design basis. The system is designed to meet the following functional criteria:

- Prevent air leakage into and steam leakage out of the casings of the turbine generator

- Return condensed steam to the condenser and exhaust non-condensable gases into the atmosphere.
- Prevent uncontrolled release of radioactive materials to the environment in accordance with GDC 60, "Control of Releases of Radioactive Materials to the Environment," and GDC 64, "Monitoring Radioactivity Releases."

The TSSS is shown in DCD Tier 2, Figure 10.4.3-1, "Turbine Steam Seal System Flow Diagram."

ITAAC: There are no ITAAC for the TSSS in DCD Tier 1.

Technical Specifications: There are no Technical Specification requirements associated with the TSSS.

10.4.3(C) Regulatory Basis

The relevant requirements of the Commission regulations for this area of review, and the associated acceptance criteria, are given in Section 10.4.3, "Turbine Gland Sealing System," of NUREG-0800, "Standard Review Plan (SRP) for the Review of Safety Analysis Reports for Nuclear Power Plants," and are summarized below. Review interfaces with other SRP sections are also indicated in SRP Section 10.4.3.

10. GDC 60 from 10 CFR 50, Appendix A, as related to the TSSS design for the control of releases of radioactive materials to the environment.
11. GDC 64 as related to the TSSS design for monitoring of releases of radioactive materials to the environment during normal operation, including anticipated operational occurrences.

10 CFR 52.47(b)(1) as related to requiring that a DC application contain the proposed ITAAC that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the design certification is built and will operate in accordance with the design certification, the provisions of the Atomic Energy Act of 1954, and the NRC's regulations.

10.4.3(D) Technical Evaluation

During its review of DCD Section 10.4.3 the staff noticed that the applicant sometimes makes reference to a turbine gland sealing system, and at other times makes reference to a turbine steam seal system. Since it was not clear whether the applicant was referring to a single turbine sealing single system using two different names or whether there was actually two separate systems, the staff issued RAI 8070 (ADAMS Accession No. ML15225A100), Question 10.04.03-1, requesting that the applicant clarify the difference (if any) between the TGSS and TSSS.

In its response to RAI 10.04.03-1, dated September 18, 2015, (ADAMS Accession No. ML15264B143) the applicant stated that the turbine gland sealing system and turbine steam seal system are the same system. The applicant also proposed to revise the DCD so that the system would be referred to only as the "turbine steam seal system," and include a markup to the DCD as part of its RAI response.

The staff reviewed the applicant's RAI response and found it to be acceptable since it clarified that "turbine gland sealing system" and "turbine steam seal system" are the same system, and revised the DCD to remove the use of the "turbine gland sealing system" name. The RAI is therefore considered closed, and the incorporation of DCD markup provided with the RAI response is being tracked as a [confirmatory item \(Confirmatory Item 10.04.03-1\)](#).

10.4.3(D)(a) GDC 60, "Control of releases of radioactive materials to the environment" and GDC 64, "Monitoring radioactivity releases"

The staff reviewed the design of the TSSS for compliance with the requirements of GDC 60 with respect to control of release of radioactive materials and GDC 64 with respect to the monitoring of radioactive releases. Compliance with GDC 60 and GDC 64 requires that provisions be included in the nuclear power unit design to monitor and control the releases of radioactive materials to the environment.

In Section 10.4.3.2, the DCD states that the mixture of non-condensable gases discharged from the gland steam condenser is not normally radioactive. However, in the event of a steam generator tube leak due to a steam generator tube rupture, it is possible to discharge radioactively contaminated gases. According to the DCD, the TSSS effluents are monitored by a radiation detector installed downstream of the TSSS in the condenser vacuum system discharge line. In Section 10.4.3.2, "System Description," the DCD also states that a radiation detector with an alarm is provided for monitoring. This alarm actuates in the main control room (MCR). The design and configuration of the effluent monitor is provided in Section 11.5 of the DCD. The applicant also indicates in DCD Tier 2, Section 10.4.3.2, that if radioactivity in the exhaust flow exceeds an acceptable level, the condenser vacuum pump vent effluent monitor actuates an alarm in the main control room, and then operating procedures are implemented to preclude significant release to the environment.

The staff reviewed the information in the DCD on the TSSS including the system description, system flow diagram and information in DCD Sections 11.3 and 11.5 on radiation effluent monitoring of the condenser vacuum system. The staff confirmed, via DCD Table 11.5-1 that the condenser vacuum pump vent effluents are monitored and alarmed in the main control room as described in DCD Section 10.4.3.2. Based on the above discussion, the staff found that the TSSS conforms to the requirements of GDC 64, as related to the detection and monitoring of the radioactive materials in TSSS effluents. However, in order to conform to GDC 60 as related to control of the releases of radioactive effluents to the environment, the DCD did not provide adequate details regarding the operating procedures that are to be used to instruct operators on performing needed action if/when an alarm level is reached. Therefore, the staff issued RAI 8070 (ADAMS Accession No. ML15225A100), Question 10.04.03-2, requesting that the applicant provide information on the applicable procedures including information on what the procedures are to address, and how they are to be implemented.

In its response to RAI 10.04.03-2, dated September 18, 2015, (ADAMS Accession No. ML15264B143) the applicant stated that air and non-condensable gases from the steam packing exhaust blower are generally discharged to the atmosphere. It also states that the discharged gases are monitored by a radiation monitor installed inside the discharge line and if radioactivity exceeds a predetermined setpoint, alarms activate in the control room and operator action is taken. The operating procedures are to be implemented in accordance with the "radioactive effluents controls program" described in Technical Specification 5.5.4. The applicant also provided a markup of the DCD to clarify this point.

The staff reviewed the applicant's RAI response and found it to be acceptable since the system design provides means to monitor the system discharges for radiation and operating procedures are to be implemented in accordance with the "radioactive effluents controls program." Thus, design features are in place to control and monitor releases of radioactive materials in the effluents of the TSSS; accordingly, the staff finds these sampling and monitoring provisions for the TSSS to meet the requirements of GDC 60 and GDC 64, respectively, as they relate to control and monitoring of the releases of the radioactive materials to the environment. The incorporation of DCD markup provided with the RAI response is being tracked as a **confirmatory item (Confirmatory Item 10.04.03-2)**.

10.4.3(D)(b) Initial Test Program

In DCD Tier 2, Section 10.4.3.4, the applicant described the TSSS inspection and testing program, which includes the performance of hydrostatic test for piping and valves. The TSSS components are also inspected during construction and functionally tested during unit startup. TSSS related preoperational and startup testing is performed as described in DCD Tier 2, Section 14.2.12.1.70, "Turbine Steam Seal System Test"

The staff finds that test performed as part of the initial plant test program will verify the TSSS ability to provide adequate sealing to the turbine shaft, to prevent air leakage into, and steam leakage out of the casings.

10.4.3(D)(c) ITAAC

Tier 1 of the APR 1400 DCD provides the design descriptions and associated ITAAC for systems which require such under 10 CFR 52.47(b)(1). There are no ITAACs for the TSSS shown in Tier 1. The staff agrees that no ITAAC is required for the TSSS under 10CFR 52.47(b)(1).

10.4.3(D)(d) Technical Specifications

There are no TS requirements associated with the TSSS. . The staff finds this acceptable because the TSSS was not addressed by the standard TS.

10.4.3(E) Combined License Information Items

There are no COL information items for the TSSS.

10.4.3(F) Conclusion

The staff finds the APR1400 turbine steam seal system acceptable because it meets appropriate regulatory requirements including GDC 60 with respect to control of release of radioactive materials and GDC 64 with respect to the monitoring of radioactive releases.

10.4.4 Turbine Bypass System

10.4.4(A) Introduction

The turbine bypass system (TBS) is located in the turbine building and is designed to transport up to 55 percent of the total main steam flow at normal full power steam generator (SG) pressure from the SGs directly to the main condenser, bypassing the main turbine. This process, which is accomplished in a controlled manner, enables the plant to take step-load

reductions up to the TBS capacity without the reactor or turbine tripping. This process also minimizes transient effects on the RCS during plant startup, hot standby, cooldown, generator step-load reductions, and following turbine and reactor trips.

10.4.4(B) Summary of Application

Tier 1: The APR1400 DCD Tier 1, Section 2.7.1.3, "Turbine Bypass System," states that there are no Tier 1 entries for the turbine bypass system.

Tier 2: The APR1400 DCD Tier 2, Section 10.4.4, "Turbine Bypass System," indicates that the TBS performs no safety function and has no nuclear safety-related design basis. The TBS is designed to accomplish the following functions:

1. Regulate steam flow in order to dissipate excess energy from the nuclear steam supply system (NSSS) following load rejections of any magnitude without tripping the reactor or lifting primary or secondary safety valves.
2. Bypass 55 percent of the total saturated steam flow at normal full-power SG pressure to the main condenser.
3. Maintain NSSS thermal conditions at no-load conditions.
4. Provide a means for manual control of RCS temperature during NSSS heatup or cooldown.

Section 10.4.4 of the APR1400 DCD contains the TBS design bases, system and component description, system operation, safety evaluation, inspection and testing requirements, and instrumentation requirements.

ITAAC: There are no ITAACs for the TBS as indicated in Tier 1, Section 2.7.1.3, "Turbine Bypass System," of the APR 1400 DCD.

Technical Specifications: There are no TS requirements associated with the TBS.

10.4.4(C) Regulatory Basis

The relevant requirements of the Commission regulations for this area of review, and the associated acceptance criteria, are given in Section 10.4.4, "Turbine Bypass System," of NUREG-0800, "Standard Review Plan (SRP) for the Review of Safety Analysis Reports for Nuclear Power Plants," and are summarized below. Review interfaces with other SRP sections are also indicated in SRP Section 10.4.4.

1. General Design Criterion (GDC) 4 from 10 CFR 50, Appendix A, as related to the dynamic effects associated with possible failure of the TBS due to a pipe break or malfunction of the TBS not adversely affecting systems or components necessary for safe shutdown or accident prevention or mitigation.
2. GDC 34 as related to the ability to use the system for shutting down the plant during normal operations. The operation of the TBS eliminates the need to rely solely on safety systems.

3. 10 CFR 52.47(b)(1), which requires that a DC application contain the proposed inspections, tests, analyses, and acceptance criteria (ITAAC) that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the design certification is built and will operate in accordance with the design certification, the provisions of the Atomic Energy Act of 1954, and the NRC's regulations.

10.4.4(D) Technical Evaluation

The staff reviewed the APR1400 TBS design as described in the APR1400 Design Control Document (DCD). The review, which was performed in accordance with SRP Section 10.4.4, was based on the Tier 1 and Tier 2 information contained in Revision 0 of the APR1400 DCD. The results and conclusions of the staff's review of the TBS are discussed below.

In Tier 2, Section 10.4.4.1, "Design Bases," the DCD provides the safety and power design bases for the TBS. The system has no safety design basis, since it performs no safety-related function. The section describes the TBS of the APR 1400 as designed to bypass 55 percent of the total steam to the main condenser at full power operation. Also, the DCD states that the system is designed to sustain a load rejection of any magnitude, without generating a reactor trip, and without actuating POSRVs or MSSVs. The TBS is also designed to maintain no-load thermal conditions. Further, the APR1400 TBS is designed to bypass steam to the main condenser during plant startup and also to permit a normal cooldown. These design features minimize transient effects on the RCS during plant startup, hot shutdown and cooldown, step load reductions in generator load, and following a reactor trip.

In Tier 2, Section 10.4.4.2, "System Description," the DCD provides a general and component description of the APR 1400 TBS. The TBS includes all components and piping from the branch connection at the main steam system to the main condenser. The system consists of two turbine bypass valve (TBV) headers tapped off of the main steam system piping after the main steam isolation valves and upstream of the main turbine stop valves. A total of 8 TBVs are provided to discharge to the three shells of the main condenser. DCD Tier 2, Figures 10.3.2-1, "Main Steam System Flow Diagram," depicts the TBS, and is shown as part of the main steam system (MSS).

The staff reviewed the information presented in the DCD as described above and evaluated the TBS against the GDC 4, and GDC 34 criteria as follows:

10.4.4(D)(a) GDC4, "Environmental and dynamic effects design basis"

The staff reviewed the TBS for compliance with the requirements of GDC 4, "Environmental and Dynamic Effects Design Bases." Conformance to GDC 4 requires that failure of the TBS due to a pipe break or malfunction of the system should not adversely affect essential systems or components that are necessary for safe shutdown or accident prevention or mitigation.

Section 10.4.4.3 of the DCD states that the TBS has no safety function and there is no safety-related equipment or components that exist in the vicinity of the TBS components. The DCD also states that all high-energy lines of the TBS are located in the TB and that failure of TBS high-energy lines will not affect any safety-related equipment. The staff verified that the TBS is located in the non-seismic TB, and that there are no safety-related SSCs in the TB or nearby the TBS.

Based on the above discussion, the staff finds that the TBS meets the GDC 4 criteria as it relates to the adverse effects of a pipe break or malfunction on those components of the system necessary for safe shutdown or accident prevention or mitigation since the TB does not contain such components.

10.4.4(D)(b) GDC 34, “Residual heat removal”

The staff reviewed the TBS for compliance with the requirements of GDC 34 as related to the ability to use the system for shutting down the plant during normal operations by removing residual heat without using the turbine generator. The operation of the TBS eliminates the need to rely solely on safety systems which are required to meet the redundancy and power source requirements of this criterion. DCD Tier 2, Section 10.4.1.3 states that the condenser is normally used to remove residual heat from the RCS during the initial cooling period after shutdown, when main steam is bypassed to the condenser through the TBS. It also states that the condenser is also used to condense the main steam bypassed to the condenser in the event of sudden loads rejection by the turbine generator (T/G) or a turbine trip. In Section 10.4.4 of the DCD it is indicated that the TBS is designed to bypass steam to the main condenser during a plant shutdown to facilitate a manually controlled cooldown of the nuclear steam supply system (NSSS). Also, the DCD states that the TBS has the capacity to bypass 55 percent of the main steam flow to the main condenser at full power, and is designed to sustain a load rejection, without generating a reactor trip and without actuating POSRVs, or MSSVs. The DCD further states that the TBS is designed to follow a rapid turbine load reduction. A rapid reduction of reactor power is produced through the RPCS if the magnitude of the load rejection exceeds SBCS turbine bypass capacity.

Information concerning the instrumentation used for the TBS is discussed in Section 10.4.4.5, “Instrumentation Requirements,” of the DCD. When the staff reviewed DCD section 10.4.4.5 it found that specific information on the instrumentation used by TBS had not been addressed in the section. Therefore the staff issued RAI 8072 (ADAMS Accession No. ML15208A585), Question 10.04.04-1 requesting that the applicant provide information on the TBS instrumentation.

In its response to RAI 10.04.04-1, dated August 20, 2015, (ADAMS Accession No. ML15233A439) the applicant stated that TBVs are normally controlled by the steam bypass control system (SBCS) but are capable of MCR/RSR or local manual operation. The response also stated that TBV instrumentation and SBCS instrumentation constitutes that valve position indication, valve inoperable alarms and valve leakage alarms for the TBVs are monitored in the main control room (MCR) and the remote shutdown room (RSR). A DCD markup revising the text in DCD section 10.4.4.5 was also include as part of the RAI response.

The staff reviewed the applicant's response and determine it to be acceptable since the requested information was provided in the DCD markups. The RAI is therefore closed. However, the incorporation of the DCD markups, provide as part of the RAI response, into the DCD will be tracked as a confirmatory item (Confirmatory Item 10.4.4-1).

Based on its review, the staff finds that the APR 1400 TBS conforms to the GDC 34 requirements because adequate controls are provided to support reliable TBS operation, and the TBS along with the main condenser provides for the initial residual heat removal from the RCS function immediately following plant shutdown without use of the T/G.

10.4.4(D)(c) Initial Test Program

Inspecting and testing of the TBS is performed prior to plant operation as indicated in DCD Section 10.4.4.4, "Inspection and Testing Requirements." The DCD states that testing will be conducted to verify opening of the TBVs in response to a signal simulating bypass from the SBCS. The applicant will include preoperational and startup tests in accordance with Regulatory Guide 1.68. DCD Section 14.2.12.1.29, "Steam Bypass Control System Test," describes the test to demonstrate proper operation of the steam bypass control system. DCD Section 14.2.12.1.15, "Main Steam Atmospheric Dump and Turbine Bypass Valves Capacity Test," verifies the steam flow capacity of the turbine bypass valves. As indicated in DCD Section 14.2.12.1.29, the dynamic operation of the turbine bypass valves is demonstrated during hot functional testing, and capacity testing of the turbine bypass valves is demonstrated during power ascension testing. Based on the staff's review of the information in the DCD it was unclear whether hydrostatic testing would be performed on the TBS; therefore the staff issued RAI 8072 (ADAMS Accession No. ML15208A585), Question 10.04.04-3 asking the applicant to clarify whether hydrostatic testing will be performed on the TBS.

In its response to RAI 10.04.04-3, dated September 24, 2015, (ADAMS Accession No. ML15269A013) the applicant stated that the TBS will be hydrostatically tested after installation, and that functional test will be performed in accordance with the initial test program, during startup of the plant.

The staff finds that a test performed as part of the initial plant test program will ensure proper opening of the turbine bypass valves in response to a signal simulating bypass from the SBCS. The staff also finds these test practices acceptable, since they demonstrate proper operation of the TBS and are commensurate with the TBS safety classification.

10.4.4(D)(d) ITAAC

Tier 1 of the APR 1400 DCD provides the design descriptions and associated ITAAC for systems which require such under 10 CFR 52.47(b)(1). In Tier 1, Section 2.7.1.3, "Turbine Bypass System," the applicant indicated that there is no entry for the TBS. Since 10 CFR 52.47 (B)(1) requires the application to contain the proposed ITAAC that are necessary and sufficient to provide reasonable assurance that, if the ITAAC are performed and acceptance criteria met, a facility that incorporates the design certification has been constructed and operated in conformity with the design certification, the staff issued RAI 8072 (ADAMS Accession No. ML15208A585)10.04.04-2 requesting that the applicant provide justification for the lack of entry for an ITAAC for the TBS.

In its response to RAI 10.04.04-2, dated September 24, 2015, (ADAMS Accession no. ML15269A013) the applicant stated that the TBS is part of the main steam system and a specific ITAAC entry for the TBS was not necessary. The staff reviewed the Tier1 Section 2.7.1.2, "Main Steam System," and confirmed that the functional arrangement of the MSS, which is shown in DCD Tier 1 Figure 2.7.1.2-1, did include the TBS. The main steam system ITAAC in Table 2.7.1.2-4 requires inspection of the as-built MSS, which includes the TBS, to be performed in order to confirm that the as-built system conforms to the functional arrangement in figure 2.7.1.2-1. Therefore, essential features of the TBS will be confirmed by such ITAAC.

The staff reviewed the applicant's response and determine it to be acceptable since the TBS system configuration and major SSCs are covered by the main steam system ITAAC in Tier 1, Table 2.7.1.2-4. The RAI is therefore closed.

10.4.4(D)(e) Technical Specifications

There are no TS requirements associated with the TBS. The staff finds this acceptable because the TBS was not addressed by the standard TS.

10.4.4(E) Combined License Information Items

No COL information items are identified for the TBS in the DCD. The staff finds this acceptable because the proposed main steam system ITAAC and the initial plant test program assure that the TBS will be constructed in accordance with the certified design.

10.4.4(F) Conclusion

The staff finds the APR1400 turbine bypass system design acceptable because it meets appropriate regulatory requirements including GDC 4 with respect to the system being designed such that a TBS failure due to a pipe break or malfunction will have no adverse effect on the essential systems or components that are necessary for safe shutdown or accident prevention or mitigation, GDC 34 with respect to the ability of the TBS for shutting down the plant during normal operations by removing residual heat without using the TG, and 10 CFR 52.47(b)(1) regarding ITAAC.

10.4.5 Circulating Water System

10.4.5(A) Introduction

The circulating water system (CWS) is designed to provide a continuous supply of cooling water to the main condensers and the turbine generator (turbine) building open cooling water system (TGBOCWS). After the heat is absorbed by the circulating water (CW), the discharge water is returned to the normal heat sink. In the APR 1400 design, the mechanical draft cooling tower is used as the conceptual normal heat sink. Staff evaluation of the TGBOCWS is described in Subsection 9.2.9 of this report.

10.4.5(B) Summary of Application

DCD Tier 1: DCD Tier 1, Section 2.7.1.7 states there are no Tier 1 entries for the CW system.

DCD Tier 2: The applicant has provided Tier 2 system description in Section 10.4.5, "Circulating Water System," of the APR1400 DCD. The layout of the CW system is shown in DCD Tier 2, Figure 10.4.5-1, "Circulating Water System Flow Diagram."

The CWS is a nonsafety-related system consisting of CW pumps, cooling towers (CT), condensers, piping, valves, instrumentation, condenser tube cleaning system, CW pump bearing lubrication system, cooling water makeup and blowdown system, and the cooling tower chemical injection system. The CW system draws cool water from the CW cooling tower basin, passes it through the main condenser tubes to take heat from the main condenser, and returns the heated water to the cooling towers via a common discharge conduit. In addition, the CW system supplies cooling water to the TGBOCWS system and heated water from the TGBOCWS. The TGBOCWS is used to cool the TGBCCW, a system used to cool the various equipment within the turbine building.

The applicant chose to use a conceptual design approach for describing a portion of the CW system. As indicated in 10 CFR 52.47(a)(24), an applicant does not seek certification for such information but presents it in order to aid the staff in its review of the application. In DCD Tier 2, Section 10.4.5, the portions of the CW system identified as conceptual design are indicated by

double brackets ([[]]). A future COL applicant shall provide all the necessary information related to the conceptual design portion of the CW system, which will then be reviewed by the staff.

The staff noted that, contrary to DCD Tier 2, Section 10.4.5, the circulating water pumps were listed as non-conceptual in DCD Tier 2, Table 3.2-1, "Classification of Structures, Systems, and Components." 10 CFR 52.6 states in part that the design certification applicant shall provide complete and accurate information. Therefore, the staff issued RAI 8597 (ADAMS Accession No. ML16139A579), Question 10.04.05-2, to request the applicant to clarify which portions of the circulating water system is conceptual and modify the DCD with this clarification. In response to RAI 8597, Question 10.04.05-2, dated June 17, 2016 (ADAMS Accession No. ML16169A072) the applicant stated that the COL applicant will provide the design parameters, as identified in DCD Tier 2, Table 10.4.5-1, "Design Parameters for Major Components of Circulating Water System," as well as the location and design of the cooling tower(s), basin, and CW pump house. The applicant goes on to clarify the following conceptual and non-conceptual design portions:

1. Conceptual Design Information
 - Circulating Water Pumps (No. and capacity of CWP, Max./Min. System design pressure)
 - Cooling towers and auxiliaries
 - Cooling water makeup and blowdown system
 - Cooling tower chemical injection system
2. Non-conceptual Design Information
 - Condenser tube cleaning system components
 - CW pump bearing lubrication system

The applicant will revise DCD Tier 2, Table 3.2-1, to correctly identify the CW pumps as conceptual design information and not part of the design certification. The staff finds this response acceptable as it provides consistency within the DCD and the staff considers this RAI closed. Furthermore, the staff finds the identified conceptual design information acceptable as these portions of the system are outside the turbine generator building and site specific. The applicant's Table 10.4.5-1 has identified parameters that will ensure that a COL applicant is able to establish proper heat removal and system design interfaces. This correction is being tracked as **Confirmatory Item 10.4.5-2**.

that

ITAAC: There are no ITAAC specific to the circulating water system.

Technical Specifications: There are no technical specifications (TS) associated with the circulating water system.

Initial Test Program: Preoperational testing for the CW system is described under DCD Tier 2, Subsection 14.2.12.1.71, "Circulating Water System Test."

10.4.5(C) Regulatory Basis

The relevant regulatory requirements for this area of review and the associated acceptance criteria are given in NUREG-0800, Section 10.4.5, "Circulating Water System," and are summarized below.

1. GDC 2, "Design bases for protection against natural phenomena," in that failure of a nonsafety-related system or component due to natural phenomena such as earthquakes, tornadoes, hurricanes, and floods should not adversely affect the safety-related structures, systems, and components (SSCs).
2. GDC 4, "Environmental and dynamic effects design bases," as it relates to design provisions provided to accommodate the effects of discharging water that may result from a failure of a component or piping in the CW system.
3. 10 CFR 20.1406, "Minimization of contamination," as it relates to the standard plant design certifications and how the design and procedures for operation will minimize contamination of the facility and the environment facilitate eventual decommissioning and minimize to the extent practicable, the generation of radioactive waste.
4. 10 CFR 52.47, "Contents of applications; technical information," Item (b)(1), which requires that a design certification application contain the proposed ITAAC that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a facility that incorporates the design certification has been constructed and will be operated in accordance with the design certification, the provisions of the Atomic Energy Act, and NRC regulations.

10.4.5(D) Technical Evaluation

The staff's evaluation of the circulating water system is based upon the information provided in the applicant's DCD Tier 2, Revision 0.

10.4.5(D)(a) GDC2, Design bases for protection against natural phenomena

The staff's review the APR1400 CW system conformance to GDC 2 criteria, is based on adherence to Position C.1 of Regulatory Guide 1.29, "Seismic Design Classification." Based on its review of the APR1400 DCD, the staff finds that the KHNP CW system is a non-safety and a non-seismically designed system and it does not interface with any safety-related and/or important to safety SSCs. Therefore, failure of the CW system or its components due to natural phenomena will have no adverse effects on safety-related SSCs, since such components are not located in the turbine generator building. Therefore, the staff finds that the APR1400 CW system meets the requirements of GDC 2 criteria.

10.4.5(D)(b) GDC 4, Environmental and dynamic effects design bases

According to SRP 10.4.5, the requirements of GDC 4 are met when the CW system design includes provisions to accommodate the effects of discharging water that may result from a failure of a component or piping in the CW system. Specifically, means should be provided to prevent or detect and control flooding of safety-related areas so that the intended safety function of a system or component will not be precluded due to leakage from the CW system. The SRP also describes provisions to minimize hydraulic transients (e.g., water hammer) and their effect upon the functional capability and the integrity of system components.

Flooding

The staff considers the CW system to be the largest internal flood source for the turbine building. The internal and external flood level for the turbine building is stated in the DCD to be

below the height of any non-watertight penetration or door leading from the turbine building into the auxiliary building (or other areas containing safety-related SSCs). As stated in DCD Tier 2, Subsection 10.4.5.2.5, a CW line leak is detected with high-high condenser pit water level switches in the condenser pit sump. In the event of gross leakage into the condenser pit, the condenser pit alarm is initiated and the CW pumps are manually stopped to prevent flooding of the turbine building.

According to the drawings in DCD Tier 2, Appendix 9.5A, there are no internal openings between the turbine building and the auxiliary building. However, the DCD did not provide sufficient details on the provisions recommended to keep flood water from reaching the safety-related equipment in other buildings. The staff reviewing the main condenser in DCD Tier 2, Section 10.4.1, also had a similar question and issued RAI 7836 (ADAMS Accession No. ML15204A914), Question 10.04.01-3 asking the applicant to provide additional information regarding flooding effects due to failure of the main condenser, including a comparison of the flood height to the height of the bottom of non-watertight openings and the drainage away from structures containing safety-related equipment (e.g., auxiliary building).

In the October 29, 2015, response (ADAMS Accession No. ML15308A583) to RAI 7836, Question 10.04.01-3, the applicant stated the flood height in the turbine building is postulated by a pipe failure of the circulating water system with its six pumps operating to runout conditions. This flood height is determined to be at the 104 ft elevation (plant grade is at the 100 ft elevation). In addition, the applicant provided proposed revisions to DCD Tier 2, Section 10.4.1.3, to change the language to state that no opening between the auxiliary and turbine buildings is located at a lower level than the flood height of the turbine building (i.e., 104 ft). The DCD had originally stated this opening would be higher than plant grade (i.e., 100 ft) which could have meant flood waters could enter into the auxiliary building and potentially affect safety-related equipment. Regarding drainage away from the structures containing safety-related equipment, the applicant's response to RAI 7836, Question 10.04.01-3, stated that there are no openings below the flood height and that water will flow outside via the emergency relief panel.

Regarding the turbine generator building flooding discharge to the outside and away from structures containing safety-related equipment, the staff notes the applicant's response to RAI 7836, Question 10.04.01-3, only described openings to the wall connecting the auxiliary building and turbine building. The applicant did not provide information to ensure flooding drainage that exits the turbine building does not flow back into the auxiliary building by means of grade slope and exterior openings along the outside of the auxiliary building (or any other structure containing safety-related equipment). Therefore, the staff issued a supplemental RAI 8477 (ADAMS Accession No. ML16041A092), Question 10.04.01-6 requesting the applicant to provide this information and revise the DCD accordingly.

In the April 16, 2016, response letter (ADAMS Accession No. ML16107A048) to RAI 8477, Question 10.04.01-6, the applicant stated that all penetrations in exterior walls at or below the postulated flood level are sealed as described in DCD Tier 2, Subsection 3.4.1.2. Also, in response letter dated January 28, 2016 (ADAMS Accession No. ML16028A449), to RAI 135-8001 (ADAMS Accession No. ML15220A036), Question 09.02.06-1, the applicant stated that watertight doors are installed at the exterior entrances of the safety-related buildings in order to prevent flood source from entering into the safety-related SSCs. Regarding grade slope, the applicant provided a new COL information Item, COL Item 3.4(5), in letter dated October 28, 2015, (ADAMS Accession no. ML15301A917). It requires the COL applicant to provide the site-specific design of plant grading and drainage away from the plant structures. The staff has

reviewed the applicant's RAI response and found it acceptable because the sealed exterior penetrations and the sloping design will ensure any flooding waters exiting the turbine building will not enter into the safety-related SSCs in other areas of the plant.

In parallel, the staff reviewing DCD Tier 2, Section 10.4.5, also issued RAI 8052 (ADAMS Accession No. ML15201A502), Question 10.04.05-1, requesting the applicant to provide additional information on how the floodwater in the turbine building is released from the building. In the May 31, 2016, response letter (ADAMS Accession No. ML16152B012) to RAI 8052, Question 10.04.05-1, the applicant states that the turbine generator building emergency flood relief panel is installed at the 100-foot elevation. The staff has reviewed the applicant's RAI response and found it acceptable because the applicant has accounted for a CW system flooding event and provided measures, including a relief panel, to mitigate the flood waters. The applicant has proposed DCD mark-ups to DCD Tier 2, Subsection 10.4.5.2.5, to add the discussion about the determined flood height inside the turbine building and the emergency relief opening panel. The staff considers this portion of RAI 10.4.5-1 closed. This is being tracked under **Confirmatory Item 10.4.5-1**.

In DCD Tier 2, Section 10.4.5.2.5, the applicant stated that the CW system meets the GDC 4 criteria because design provisions are implemented to accommodate the effects of discharge water which could result from a failure of a component or piping system. The DCD states that, if there is flooding in the yard area due to a failure in a portion of the CW system, the yard is sloped to drain the water away from the auxiliary building and compound building. Further, the CTs are to be located sufficiently far from important to safety SSCs. According to the applicant, therefore, the safe shutdown capability is not compromised by flooding in the yard area. The DCD states that the COL applicant is to provide the location and design of the cooling tower, basin, and CW pump house in this regard (COL Information Item 10.4(3)). The DCD also states that the COL applicant is to provide elevation (e.g., drainage, topographical, grade slope) drawings in this regard (COL Information Item 10.4(4)).

In summary, the CW system design includes the following flooding provisions: no safety-related equipment inside the turbine generator building, ability to detect a flooding event via sump level monitors and tripping the CW pumps, no internal openings below the flood height between turbine and auxiliary buildings, emergency relief panel to discharge flood waters to outside of turbine generator building, sloping of the yard elevation away from the auxiliary building and compound building (and other buildings containing safety-related equipment), and the auxiliary building exterior doors are watertight. The staff finds all of these provisions acceptable, as they meet the SRP guidance to conform to the GDC 4 requirement as related to discharge water in the yard area from the CW system.

Water Hammer

The staff noticed that DCD Tier 2, Section 10.4.5 addresses the possibility of water hammer for the CW pump butterfly valves; however, the application did not address the possibility of water hammer from other components of the CW system. For this reason, in RAI 8052 (ADAMS Accession No. ML15201A502), Question 10.04.05-1, the staff requested the applicant to provide additional information on how water hammer effects are avoided. In the May 31, 2016, response letter (ADAMS Accession No. ML16152B012) to RAI 8052, Question 10.04.05-1, the applicant proposed a new COL Information Item 10.4(11), which directs "the COL applicant to confirm that water hammer events are bounded by the system design pressure value with a hydraulic transient analysis or, otherwise, demonstrate that the design is acceptable to satisfy GDC 4 in regard to the design provisions that are implemented to accommodate the effects of

discharging water that could result from a malfunction or failure of a component or piping in the system.” The staff considers the remaining portion of the RAI closed because the applicant’s response provides for how water hammer effects in the CW system will be avoided. This is being tracked as **Confirmatory Item 10.4.5-1**.

10.4.5(D)(c) Conformance with 10 CFR 20.1406, Minimization of contamination

In DCD Tier 2, Section 10.4.5.2.6, “Design Features for Minimization of Contamination,” the applicant stated that the CW system is designed with features to meet the requirements of 10 CFR 20.1406 and the guidance of NRC RG 4.21, as related to minimization of contamination. The APR1400 CW system is a non-safety system and, in general, does not contain radioactive materials. However, there is a potential for the CW system to become contaminated if there is a primary-to-secondary leakage, due to steam generator tube rupture, and a leak in the main condenser heat exchanger. The applicant stated that the CW system incorporates methods of early leak detection and leakage control features. Furthermore, under subsection, “Prevention/Minimization of Unintended Contamination,” the applicant states that system components, including the piping and heat exchangers, are designed with corrosion and erosion resistant materials for life cycle planning. Also, the system is sampled and analyzed periodically to assess water quality including the level of radiological contamination. According to KHNP, the COL applicant is to address design features for the prevention of contamination (COL 10.4(5)). The staff finds this COL item appropriate.

The staff reviewed DCD Tier 2, Section 10.4.5.2.6, as related to prevention/minimization of CW system contamination. Because, the CW system design incorporates adequate measures such as, sampling, early leak detection, and controls are incorporated in the CW system design to minimize of the contamination, the staff concludes that the CW system, as described in the DCD, meets the requirements of 10 CFR 20.1406 with regards to design features. The staff notes that DCD Tier 2, Chapter 12 contains the site-wide master program and procedures for all systems required to satisfy 10 CFR 20.1406.

10.4.5(D)(d) Initial Test Program

Although applicants for design certification are not required to submit plans for an initial test program, RG 1.68 acknowledges that design certification applicants have previously submitted these plans to assist a future COL applicant referencing the design certification in meeting the requirements of 10 CFR 52.79(a)(28). Preoperational test requirements for the circulating water system are described in DCD Tier 2, Subsections 10.4.5.4 and 14.2.12.1.71. The initial test program for the APR1400 is evaluated in Section 14.2 of this SER.

DCD Tier 2, Table 14.2-7, “Conformance Matrix of RG 1.68 Appendix A versus Individual Test Descriptions,” states that the COL applicant is to prepare the pre-operational test of cooling tower(s) and associated auxiliary systems per RG 1.68, Appendix A, 1.d.3.j. The staff finds this information acceptable because these system components are conceptual and will be addressed by the COL applicant.

10.4.5(D)(e) ITAAC

Applicants for standard plant design certification must provide proposed ITAAC necessary to ensure that a plant incorporating the certified design is built and will operate in accordance with 10 CFR 52.47(b)(1). There are no ITAAC required for the circulating water system. The system

is not safety-related and is not required for safe shutdown; therefore the staff finds this acceptable.

10.4.5(D)(f) Technical Specifications

There are no APR1400 technical specifications (TS) sections for the circulating water system. The system is not safety-related and is not required for safe shutdown; therefore the staff finds this acceptable.

10.4.5(E) Combined License Information Items

The following is a list of COL information item numbers and descriptions from DCD Tier 2, Table 1.8-2:

Table 0-1 APR1400 Combined License Information Items

Item No.	Description	DCD Tier 2 Section
10.4(1)	The COL applicant is to establish operational procedures and maintenance programs for leak detection and contamination control.	10.4.5.2.6
10.4(2)	The COL applicant is to maintain the complete documentation of system design, construction, design modifications, field changes, and operations.	10.4.5.2.6
10.4(3)	The COL applicant is to provide the location and design of the cooling tower, basin, and CW pump house.	10.4.5.2
10.4(4)	The COL applicant is to provide elevation drawings.	10.4.5.2.5
10.4(5)	The COL applicant is to address the design features for the prevention of contamination.	10.4.5.2.6
10.4(9)	The COL applicant is to determine the wet bulb temperature correction factor to account for potential interference and recirculation effects.	10.4.5.2.5 Table 10.4.5-1
10.4(11)	The COL applicant to confirm that the water hammer events are bounded by the system design pressure value with a hydraulic transient analysis or otherwise demonstrate that the design is acceptable to satisfy GDC 4 in regard to the design provisions that are implemented to accommodate the effects of discharging water that could result from a malfunction or failure of a component or piping in the system.	10.4.5.2.5

The staff finds that no additional COL information items need to be included in DCD Tier 2, Table 1.8-2 for the circulating water system.

10.4.5(F) Conclusion

Based on a review of the information that is provided and as discussed above in the technical evaluation section, the staff finds that the applicant has met the requirements of GDC 2, GDC 4 and 10 CFR 52.47(b)(1), and 10 CFR 20.1406 for Section 10.4.5, "Circulating Water System," of the APR1400 DCD.

10.4.6 Condensate Polishing System

10.4.6(A) Introduction

The CPS is designed to remove dissolved and suspended impurities from the condensate. The CPS provides condensate cleanup capability and maintains condensate quality through demineralization. It does not perform a safety-related function. Also discussed in this section is secondary plant water chemistry as described in design certification document (DCD) Section 10.3.5, "Secondary Water Chemistry."

10.4.6(B) Summary of Application

The applicant has provided a Tier 2 system description in Section 10.4.6, "Condensate Polishing System," of the APR1400 DCD, summarized here in part, as follows:

- The CPS is designed with seven mixed-resin demineralizers (cation-bed and mixed-bed) to remove ionic impurities from the condensate during plant startup, hot standby, shutdown operations, and power operation. A condensate bypass valve is located in the condensate pump discharge header to bypass the condensate purification when not needed. The CPS consists of the following components: cation-bed ion exchanger vessels, mixed-bed ion exchanger vessels, resin traps, resin collection tank, spent-resin holding tank, resin mixing and addition tank, sampling system, and instrumentation.
- DCD Section 10.3.5 describes the secondary water chemistry, but its evaluation is included under Section 10.4.6 of this safety evaluation (SE) because the CPS is one of the principal means of effecting secondary water chemistry control and the staff has indicated it accordingly in NUREG-0800 Standard Review Plan (SRP) Section 10.4.6.

10.4.6(C) Regulatory Basis

The relevant requirements of the Commission's regulations for this area of review, and the associated acceptance criteria, are given in NUREG-0800 SRP Section 10.4.6, "Condensate Cleanup System," and are summarized below.

1. GDC 14, "Reactor Coolant Pressure Boundary," in Appendix A to Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50, requires that the reactor coolant pressure boundary be designed, fabricated, erected, and tested to ensure an extremely low probability of abnormal leakage, rapidly propagating failure, and gross rupture. Section 10.4.6 of NUREG-0800 applies to GDC 14 because the condensate cleanup system maintains water quality to avoid corrosion-induced failure of the reactor pressure boundary, specifically the steam generator (SG) tubing.

2. 10 CFR 52.47(b)(1), which requires that a DC application include the proposed inspection, test, analysis, and acceptance criteria (ITAAC) that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the DC is built and will operate in accordance with the DC, the provisions of the Atomic Energy Act of 1954, and the U.S. Nuclear Regulatory Commission (NRC) regulations.

10.4.6(D) Technical Evaluation

The staff reviewed the information provided in final safety analysis report (DCD) Tier 2, Sections 10.4.6, "Condensate Polishing System" Revision 0, 10.3.5, "Secondary Water Chemistry" Revision 0, and the supplemental information provided in applicant's letter dated July 22, 2015 (ADAMS Accession No. ML15198A549) against the requirements of GDC 14. GDC 14 is applicable to the CPS since the system is designed to maintain water quality and to avoid corrosion-induced failure of the reactor coolant pressure boundary, specifically the SG tubing. As described in the SRP, an acceptable method of conforming to GDC 14 is for the applicant to meet the latest version in the Electric Power Research Institute (EPRI) report series, "PWR Secondary Water Chemistry Guidelines."

The EPRI PWR Secondary Water Chemistry Guidelines (EPRI *Guidelines*) provide several criteria for the secondary water chemistry control program including sampling frequency and other sampling requirements, guidelines for continuously monitoring water chemistry parameters, and operating limits for impurities and additives, as well as associated action responses to be carried out if limits are exceeded.

DCD Tier 2, Section 10.3.5 states that the secondary water chemistry program will be consistent with the latest version of the EPRI *Guidelines*, and a COL applicant that incorporates DCD Tier 2, Section 10.3.5 by reference commits to these specifications. The EPRI Guidelines provide specific Action Level 1, 2, and 3 limits for many secondary water chemistry control parameters. Specific actions including reduced power and/or shutdown are required if these limits are exceeded. DCD Tier 2 combined operating license (COL) Item 10.3(4) requires the COL applicant to address secondary side chemistry controls (e.g., threshold values, operator actions) that are in compliance with the latest version of the EPRI *Guidelines*. This commitment will ensure that aspects of the secondary water chemistry program such as Action Levels and pH control and optimization of the condensate/feedwater cycle are in accordance with the latest EPRI Guidelines. Although the staff does not formally review or issue a SE of the various EPRI water chemistry guidelines (including the PWR Secondary Water Chemistry Guidelines), these guidelines are recognized as representing the industries best practices in water chemistry control. Extensive experience in operating reactors has demonstrated that following the EPRI Guidelines minimizes the occurrence of corrosion-related failures. Further, the EPRI Guidelines are periodically revised to reflect evolving knowledge with respect to best practices in chemistry control. Therefore, as stated in the SRP, the staff accepts the use of the latest version of the EPRI *Guidelines* as the basis for the APR1400 secondary side water chemistry program. The staff will confirm in revision 1 of the DCD the addition of COL 10.3(4) as agreed in supplemental information provided in applicant's letter dated July 17, 2015 (ADAMS Accession No. ML15198A549).

The CPS purifies secondary water by passing it through mixed-resin (cation and anion) demineralizers. Each of the seven demineralizers has its own resin trap, and all three are served by two spent resin holding tanks and a single resin mixing/holding tank, where fresh resin is prepared and stored. As described in DCD Tier 2, Section 10.4.6.2.2, "Component

Description,” all of these vessels are constructed of carbon steel, and all but the resin traps have a rubber lining. In the operating fleet, the use of rubber linings have been proven to provide adequate protection from corrosion of the carbon steel, and to prevent impurities from entering the secondary water. Design details for each vessel are shown in DCD Tier 2, Table 10.4.6-1 and Figure 10.4.6-1. The design capacity of 16-100 percent flow is more than adequate to allow the plant to operate while abnormal secondary water chemistry conditions are corrected. In the event that the capacity is insufficient, the plant will be shut down in accordance with the secondary water chemistry control program action levels.

Secondary water chemistry is focused on preventing corrosion in SGs, condensers, piping, and other equipment. Principal parameters that must be controlled are impurity ion concentrations, including sodium (Na⁺), chloride (Cl⁻), and sulfate (SO₄⁻²) ions; pH; and dissolved oxygen.

As stated in DCD Tier 2, Section 10.3.5.1, “Chemical Control Basis,” ammonia and ethanolamine are used as pH controllers, and hydrazine is added to control dissolved oxygen. These additives are quite volatile and would normally travel with the steam through the turbines and to the condensers. Hence, depletion of these chemicals in the CFS will be detected in the main condensers. Thus, the injection of new chemicals occurs continuously downstream of the condensate pumps or demineralizers (DCD Tier 2, Section 10.3.5).

In addition to providing suitable water quality to prevent corrosion-induced failure of the pressure boundary, adequate instrumentation and sampling must be provided to verify the effectiveness of the CPS in order to meet GDC 14 and the recommendations of NUREG-0800 SRP Section 10.4.6. Concentrations are monitored using continuous analyzers (supplemented by grab samples), as described in DCD Tier 2, Section 9.3.2, “Process and Post-Accident Sampling Systems,” and additive injections are determined either automatically or manually from the analytical data. The continuous monitors identified in this section are consistent with the EPRI Guidelines. The staff finds the instrumentation and sample points provided are acceptable, because they meet those recommended by the EPRI Guidelines.

Additionally, NUREG-0800 SRP Section 10.4.6 recommends that the system be connected to radioactive waste disposal systems to allow disposal of spent resin or regenerant solutions when necessary. DCD Tier 2, Section 10.4.6.2.3 states that radioactive resin will be transferred to the radioactive waste treatment system from the spent resin holding tank. The staff finds this acceptable because it conforms to the SRP guidance.

10.4.6(E) Combined License Information Items

The following is a list of item numbers and descriptions from Table 1.8-2 of the DCD.

Combined License Information Items

Item No.	Description
10.3(4)	The COL applicant is to provide secondary side water chemistry threshold values and recommended operator actions for chemistry excursions in compliance with the latest version of the EPRI PWR Secondary Water Chemistry Guidelines in effect at the time of COLA submittal. The COL applicant is to establish the operational water chemistry program six months before fuel load.

Item No.	Description
10.4(1)	The COL applicant is to establish operational procedures and maintenance programs for leak detection and contaminant control.
10.4(2)	The COL applicant is to maintain the complete documentation of system design, construction, design modifications, field changes, and operations.

For the reasons described above, COL Items 10.3(4), 10.4(1) and 10.4(2) are deemed appropriate. The staff will confirm in revision 1 of the DCD the addition of COL 10.3(4) updates to 10.4(1) and 10.4(2) as agreed in the supplemental information provided in applicant's letter dated July 17, 2015 (ADAMS Accession No. ML15198A549).

10.4.6(F) Conclusion

The applicant has described effective systems and procedures to maintain the purity of secondary side coolant. Additional details of the secondary side water chemistry will be provided by the COL holder as stated in COL Item 10.3(4) and will meet the applicable criteria in the latest version of the EPRI *Guidelines*. The staff therefore, concludes, based on the information supplied by the applicant, that the requirements of GDC 14 and to maintain the reactor coolant pressure boundary will be satisfied. In addition, in accordance with 10 CFR 52.47(b)(1), the staff verified that no ITAAC is required for this section.

However, the staff needs to confirm that the supplemented information provided in letter dated July 17, 2015 (ADAMS Accession No. ML15198A549) is added correctly to the DCD.
(Confirmatory Item 10.4.6-1)

10.4.7 Condensate and Feedwater System

10.4.7(A) Introduction

The condensate and feedwater system (CFS) provides feedwater at the required temperature, pressure, and flow rate to the steam generators (SGs). The CFS includes all of the components and equipment from the condenser hotwell outlet up to the SG inlet including the piping and connections to the extraction steam; heater drains; feedwater pump turbine; and feedwater vents and drains subsystems. The CFS is not a safety-related system; however, the portion of the feedwater system required to provide containment and feedwater isolation following a design-basis accident, and the portion of the feedwater piping used by the auxiliary feedwater system both perform safety-related functions and are therefore safety-related.

10.4.7(B) Summary of Application

Tier 1: The Tier 1 information associated with this section is found in Tier 1, Section 2.7.1.4, "Condensate and Feedwater System," of the APR1400 DCD. Figure 2.7.1.4-1, "Condensate and Feedwater System," provides an illustration of the main feedwater system configuration and shows the arrangement of the safety-related CFS components.

Tier 2: The applicant has provided a Tier 2 system description in Section 10.4.7, "Condensate and Feedwater System," of the APR1400 DCD, summarized here in part as follows:

The condensate and feedwater system is composed of a condensate system and a feedwater system. The boundary of the condensate system is from the condenser hotwell outlet to the deaerator, and the feedwater system boundary is from the outlet of the deaerator to the inlet of the SGs.

The condensate system consists of three condensate pumps, three stages of three parallel low-pressure (LP) heaters, a deaerator, and two deaerator storage tanks. The three 50-percent-capacity motor-driven condensate pumps (two operating and one standby) deliver condensate from the condenser hotwells through the condensate polisher, a steam packing exhauster, and three stages of LP feedwater heaters to the deaerator storage tank

The feedwater system consists of three main feedwater pumps, three feedwater booster pumps, a startup pump, three stages of two parallel high-pressure (HP) heaters, main feedwater isolation valves (MFIVs), feedwater check valves, and feedwater control valves. Feedwater is pumped from the deaerator storage tank by the feedwater booster pumps and main feedwater pumps through the HP feedwater heaters to the SGs.

The entire condensate system is nonsafety-related. The portion of the feedwater system required to mitigate the consequences of an accident and allow safe shutdown of the reactor is safety-related and provides containment and feedwater isolation. SSCs from the main steam valve house (MSVH) to the SG are designed as ASME Section III Class 2, and seismic Category I. All other portions are designed as non-nuclear safety (NNS) and seismic Category III in conformance with NRC RG 1.29. DCD Section 3.2, Table 3.2-1 provides the classification of SSCs in the feedwater and condensate system and its conformance with NRC RG 1.29.

ITAAC: The ITAAC associated with Tier 2, Section 10.4.7, are given in Tier 1, Section Table 2.7.1.4-4, "Condensate and Feedwater ITAAC"

Technical Specifications: The Technical Specifications (TS) associated with Tier 2, Section 10.4.7, are given in Tier 2, Chapter 16, Section 3.7.3 of the APR 1400 DCD

10.4.7(C) Regulatory Basis

The relevant requirements of the Commission regulations for this area of review, and the associated acceptance criteria, are given in Section 10.4.7, "Condensate and Feedwater System," of NUREG-0800, "Standard Review Plan (SRP) for the Review of Safety Analysis Reports for Nuclear Power Plants," and are summarized below. Review interfaces with other SRP sections are also indicated in SRP Section 10.4.7.

1. GDC 2 from 10 CFR 50, Appendix A, as related to important to safety portions of the CFS designed to withstand the effects of natural phenomena such as earthquakes, tornadoes, hurricanes, floods, tsunamis, and seiches without loss of capability to perform their safety functions.
2. GDC 4 as related to the dynamic effects associated with possible fluid flow instabilities (e.g., water hammer) during normal plant operation, as well as during upset or accident conditions.
3. GDC 5 as related to the capability of shared systems and components important to safety to perform required safety functions.

4. GDC 44 as related to:
 - The capability to transfer heat loads from the reactor system to a heat sink under both normal operating and accident conditions.
 - Redundancy of components so that under accident conditions, the safety function can be performed assuming a single active component failure. (This may be coincident with the loss of offsite power for certain events.)
 - The capability to isolate components, subsystems, or piping if required so that the system safety function will be maintained.
5. GDC 45 as related to design provisions to permit periodic in-service inspection of system components and equipment.
6. GDC 46 as related to design provisions to permit appropriate functional testing of the system and components to ensure structural integrity and leak-tightness, operability and performance of active components, and capability of the integrated system to function as intended during normal, shutdown, and accident conditions.
7. 10 CFR 20.1406, "Minimization of Contamination," as it relates to the design features that will facilitate eventual decommissioning and minimize, to the extent practicable, contamination of the facility and the environment, facilitate eventual decommissioning, and minimize, to the extent practicable, the generation of radioactive waste.
8. 10 CFR 52.47(b)(1), which requires that a DC application contain the proposed inspections, tests, analyses, and acceptance criteria (ITAAC) that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the design certification is built and will operate in accordance with the design certification, the provisions of the Atomic Energy Act, and the NRC's regulations.

10.4.7(D) Technical Evaluation

The staff reviewed the APR1400 condensate and feedwater system design as described in the APR1400 Design Control Document (DCD). The review, which was performed in accordance with SRP Section 10.4.7, "Condensate and Feedwater System," Revision 4, March 2007, was based on the Tier 1 and Tier 2 information contained in Revision 0 of the APR1400 DCD. The results and conclusions of the staff's review of the condensate and feedwater system are discussed below.

The condensate and feedwater system is designed to supply feedwater at the required temperature, pressure, and flow rate to the steam generator (SG) secondary side inlet during normal operation, and to provide containment and feedwater isolation following a design basis accident. It consists of the condensate system (CDS) which runs from the condenser hotwell outlet to the deaerator; and the feedwater system (FWS) which runs from the outlet of the deaerator to the SG nozzles. The CDS and nonsafety-related portions of the FWS are located within the turbine building. The safety-related portion of the FWS is located within the reactor building and inside containment. The major components of the condensate and feedwater system include condensate pumps; condensate polishers; a gland steam condenser; three strings of low-pressure heaters; main feedwater pumps, feedwater booster pumps, two strings of high pressure feedwater heaters; condensate and feedwater regulating valves; main

feedwater isolation valves; and associated piping, valves instrumentation, and controls. The system description, including component design parameters and system flow diagrams are given in Section 10.4.7, "Condensate and Feedwater System," of the APR1400 DCD.

10.4.7(D)(a) GDC 2, "Design basis for protection against natural phenomena"

The staff reviewed the condensate and feedwater system for compliance with the requirements of GDC 2, which are based on adherence to Position C.1 of RG 1.29, "Seismic Design Classification," for the safety-related portion of the system, and Position C.2 for the nonsafety-related portions of the system.

Regulatory Guide 1.29, Position C.1.f states that the pertinent quality assurance requirements of Appendix B to 10 CFR 50 shall apply to all activities affecting the safety-related function of those portions of the steam and feedwater systems of PWRs extending from and including the secondary side of the steam generator up to and including the outmost containment isolation valves, and connecting piping of a nominal size of 2.5 inches or larger, up to and including the first valve that is either normally closed or capable of automatic closure during all modes of normal operation.

DCD Section 10.1, "Summary Description," indicates that the portion of the main feedwater piping and components from each SG nozzle inlet up to and including the main steam valve house (MSVH) penetration have safety-related functions when providing for containment and feedwater isolation following a design basis accident. In DCD section 10.4.7.2.2, "Component Description," it is stated that the valves, piping, and associated support and restraints of the main feedwater system from and including the MSVH to the SG feedwater nozzles are Seismic Category I and designed to ASME Section III, Class 2 requirements. This information is also provided in DCD Table 3.2-1, item 39, which indicates compliance with the requirements of 10 CFR 50, Appendix B. In addition, DCD Section 10.4.7.3, "Safety Evaluation," states that safety-related portions of the feedwater system are located in seismic Category I structures designed to protect against environmental hazards such as wind, tornadoes, hurricanes, floods and missiles, as well as the effects of high and moderate energy pipe ruptures.

Regulatory Guide 1.29, Position C.2 provides guidance for nonsafety-related portions of the system. The design should be such that failure of the nonsafety-related portions of the system not designed to seismic category I standards will not affect surrounding SSCs important to safety, or preclude operation of the safety-related essential parts of the system.

DCD Section 10.4.7.1, "Design Basis," states that the portions of the condensate and feedwater system that are not safety-related are designed as non-nuclear safety and seismic Category III and are in conformance with NRC RG 1.29 position C.2. In its review of the CFS the staff found that the portions of the system that did not perform safety-related function were all housed in the turbine building and since the building does not contain any important to safety SSC, the seismic category III designation is found to be acceptable.

Since the safety-related portions of the system are designed in accordance with RG 1.29 (Position C.1) and are protected against environmental hazards by being housed in seismic Category I structures designed to protect against the environmental hazards; and since the nonsafety-related portions of the system are designed in accordance with RG 1.29 (Position C.2), the staff concludes that the condensate and feedwater system meets the requirements of GDC 2 as they relate to protecting the system against seismic and other natural phenomena.

10.4.7(D)(b) GDC 4, “Environmental and dynamic effects design bases”

The staff reviewed the condensate and feedwater system for compliance with the requirements of GDC 4, “Environmental and Dynamic Effects Design Bases,” as related to dynamic effects associated with possible fluid flow instabilities including water hammer and effects of pipe breaks. Compliance with the requirements of GDC 4 is based on identification of the essential portions of the system that need to be protected from dynamic effects, including internally and externally generated missiles, pipe whip and jet impingement due to high and moderate energy missiles and water hammer. The guidance in Branch Technical Position (BTP) 10-2, “Design Guidelines for Avoiding Water Hammer in Steam Generators,” specifically recommends that the condensate and feedwater system be designed to achieve the following provisions:

Prevent or delay water draining from the feedring following a drop in SG water level.

Minimize the volume of feedwater piping external to the SG which could pocket steam using the shortest horizontal run of inlet piping to the feedring.

Perform tests, acceptable to the NRC, to verify that unacceptable feedwater hammer will not occur and provide test procedures for staff approval.

Implement pipe refill flow limits where practical.

The applicant states in DCD Tier 2, Section 10.4.7.1, “Design Bases,” that the safety-related portions of the condensate and feedwater system are designed to accommodate the effects of the environmental conditions associated with normal operation, maintenance, testing, and postulated accidents, including loss-of-coolant accidents (LOCA). It is also stated in the design bases that the CFS design includes protection against dynamic effects, including internally generated missiles, pipe whipping, and discharging fluids due to equipment malfunctions.

The applicant addresses water hammer prevention in DCD Section 10.4.7.6, “Water Hammer Prevention,” stating that the feedwater system design minimizes the potential for a water hammer and its effects. Design features identified in the DCD for prevention and mitigation of water hammer include:

- The connection of each SG is at the highest point of each feedwater line downstream of the MFIV.
- Minimization of horizontal length of feedwater from the main nozzle to the downward turning elbow of each steam generator.
- Top feedwater lines being maintained full at all times.

Providing a check valve upstream of the auxiliary feedwater connection to the top feedwater line.

To ensure that adequate precautions are taken to prevent water hammer once the system has been put into operation, the applicant states in DCD Section 10.4.7.6 that the COL applicant is to provide operating and maintenance procedures in accordance with NUREG-0927, and a milestone schedule for implementation of these procedures. The applicant also provides a list containing the key elements that these procedures need to address.

COL item 10.4(6) is contained in Section 10.4.11 of the application and states that “the COL applicant is to provide operating and maintenance for the following items in accordance with NUREG-0927 and milestone schedule for implementation of the procedures.” However, no items are identified in COL 10.4 (6). The COL item needs to be revised to either identify the items to be addressed, or make reference to the applicable information included in DCD section 10.4.7.6. Therefore the staff issued RAI 8002 (ADAMS Accession No. ML15197A266), Question 10.4.7-1, to have the applicant clarify what COL item 10.4(6) requires of the COL applicant.

In its response to RAI 10.4.7-1, dated August 12, 2015, (ADAMS Accession No. ML15224B411) the applicant indicated that there was an editorial error in the COL item. The applicant provided a revised description for the COL item which removed the reference that indicated that procedures would be developed for “the following items,” so that the COL Item 10.4(6), will read as follows:

“The COL applicant is to provide operating and maintenance in accordance with NUREG-0927 and a milestone schedule for implementation of the procedures”

The staff reviewed the applicant’s response and determine it to be acceptable since the proposed revision clarifies that the operating and maintenance procedures are to be in accordance with the recommendations in NUREG-0927, and DCD Section 10.4.7.6 specifies that the procedures are to address:

- a. Prevention of rapid valve motion
- b. Introduction of voids into water-filled lines and components
- c. Proper filling and venting of water-filled lines and components
- d. Introduction of steam or heated water that can flash into water-filled lines and components
- e. Introduction of water into steam-filled lines or components
- f. Proper warmup of steam-filled lines
- g. Proper drainage of steam-filled lines
- h. Effects of valve alignments on line conditions

The applicant also provided the applicable markups for DCD Tier 2, Section 10.4.11, and DCD Table 1.8.2. The staff finds that the concern raised by RAI 10.4.7-1 has been adequately addressed, and based on the review of the condensate and feedwater system, as discussed above, the staff finds that the condensate and feedwater system design satisfies the requirements of GDC 4 as it relates to the dynamic effects associated with possible fluid flow instabilities. The incorporation of the DCD markups, provided as part of the RAI response, into the DCD is a confirmatory item (Confirmatory Item 10.4.7-1).

10.4.7(D)(c) GDC 5, “Sharing of structures, systems, and components”

The APR1400 is designed as a single facility, so the requirement of GDC 5 for sharing of systems between units does not apply.

10.4.7(D)(d) GDC 44, "Cooling water"

The staff reviewed the condensate and feedwater system for compliance with the requirements of GDC 44, "Cooling water," as related to the capability to transfer heat from SSCs important to safety to an ultimate heat sink are met by demonstrating that the condensate and feedwater system is capable of providing heat removal under both normal operating and accident conditions; has redundancy of components so that under accident conditions the safety function can be performed assuming a single active component failure; and has the capability to isolate components, subsystems, or piping if required so that the system safety function will be maintained.

GDC 44 applies to the APR1400 because the system must be designed to remove heat from the reactor during normal operation, thus limiting fuel clad temperature from exceeding design limits. Preoperational tests of the condensate and feedwater systems, as described in DCD Section 14.2.12.1.68 and 14.2.12.1.69, respectively, will be performed to show that these systems are designed to supply adequate water flow for heat removal.

The condensate and feedwater system does not perform the safety function of heat removal during accident conditions. During accidents heat removal is accomplished using the auxiliary feedwater system (AFWS), which is discussed in DCD Tier 2, Section 10.4.9. The staff's evaluation for the AFWS is included in Section 10.4.9 of this report.

The staff reviewed the condensate and feedwater system design for redundancy of components, and the ability that under accident conditions the safety function can be performed assuming a single active component failure, as well as the capability to isolate components, subsystems, or piping if required. Suitable redundancy of components and power supplies are provided to assure containment and feedwater isolation under accident conditions. The main feedwater isolation valves (MSIVs) are described in DCD Section 10.4.7.2.2, "Component Description."

The MFIVs provide complete termination of feedwater flow to the SGs after receipt of a main steam isolation signal even after the effects of a single failure are imposed. Two redundant and fail-closed type MFIVs in series are installed in the economizer feedwater lines and downcomer feedwater lines, and each MFIV actuator is physically and electronically independent of the other in series, so that failure of one does not cause the failure of the other.

The staff found that the condensate and feedwater system meets the requirements of GDC 44 with respect to heat removal from the reactor during normal operation, and that feedwater and containment isolation can be accomplished during accident conditions, assuming a single active component failure.

10.4.7(D)(e) GDC 45, "Inspection of cooling water system"

The staff reviewed the condensate and feedwater system design to ensure design provisions are provided for periodic inspections of systems, components, and equipment, as required by GDC 45. The applicant states in DCD Section 10.4.7.1 that the condensate and feedwater system is designed to permit appropriate periodic in-service inspection of important components in conformance with GDC 45. Also, in DCD Section 10.4.7.4 it is stated that for the condensate

and feedwater system, ASME Section III piping is ~~inspected and tested~~ in accordance with ASME Section III and XI. Therefore, GDC 45 is satisfied with respect to permitting periodic in-service inspection (ISI) of system components and equipment.

Delete

10.4.7(D)(f) GDC 46, "Testing of cooling water system"

The design of the safety-related portions of the condensate and feedwater system was reviewed by the staff to ensure that there are provisions for the performance of periodic functional testing of the system and components, as required by GDC 46. In DCD Tier 2, Section 10.4.7.4, it is stated that the condensate and feedwater system testing includes functional testing of the systems and components to provide reasonable assurance of structural integrity, leak tightness, operability and performance of active components, and testing of the capability of integrated system function as intended during normal, shutdown, and accident conditions. It also states that ASME Section III, Class 2, valves are periodically in-service tested for exercising and leakage in accordance with ASME OM, and that MFIVs are in-service tested in accordance with ASME Section XI. Based on the above, the staff concludes that the condensate and feedwater system design meets the requirements of GDC 46 since it includes provisions for the performance of periodic functional testing of the system and components.

Delete.

DCD 10.4.7.4 will be revised to delete this sentence.

10.4.7(D)(g) 10CFR 20.1406 Minimization of contamination

10 CFR 20.1406 requires in part that each design certification applicant describe how the facility design and procedures for operation will minimize, to the extent practicable, contamination of the facility and the environment, as well as the generation of radioactive waste. The condensate and feedwater system, along with the main steam system (MSS), make up the secondary cooling system. In general the condensate and feedwater system does not contain radioactive fluids. However, since the condensate and feedwater system provides cooling on the secondary side of the steam generator tubes, there is the potential for the condensate and feedwater system fluid to become contaminated if significant primary-to-secondary leakage occurs across the steam generator tubes.

In DCD Section 10.4.7.2.4, "Design Features for Minimization of Contamination," the applicant states that the CFS is designed with specific features to meet the requirements of 10 CFR 20.1406. Specifically, it is stated that, for every subsystem that may potentially contain radioactive materials, an evaluation was performed which included leakage determination for the areas and pathways where leakage may occur, and the methods of leakage control incorporated in the system design. Based on its evaluation the applicant determined that the system design facilitates early leak detection, allowing prompt assessment and response to manage collected fluids.

With the exception of a FW piping section in the containment and auxiliary building containing flow elements and feedwater control and isolation valves, the CFS components and its associated subsystems are located inside the turbine generator building which has floors that are sloped, coated and provided with drains which are routed to the turbine building sumps, which are monitored for radiological contamination. Drainage that is detected to be contaminated is routed to the liquid waste management system for treatment. Provisions for early leak detection include radiation monitors on the condenser vacuum pump exhaust line and the steam generator blowdown line to monitor radiation levels associated with the condensate and steam generator blowdown systems. Leak detection is also included at all tube-to-tube sheet interfaces.

Additionally, there is no embedded or buried piping incorporated in the condensate and feedwater system design. The feedwater piping between the turbine generator building and the auxiliary building is routed at a high elevation and is provided with a piping sleeve. Any leakage is drained back to the turbine generator building and is collected by the floor drain system.

Cross-contamination is protected against through design and operation; normal and emergency drains are routed to the condenser and are forwarded to the condenser polishers for treatment, minimizing the spread of radiation. If leakage occurs from the condensate and feedwater system equipment, the water is drained to local drain hubs by gravity and transferred to the turbine generator building drain system sump for collection.

Based on the above discussion, the staff concludes that the condensate and feedwater system design, as described in the DCD, complies with 10 CFR 20.1406 since it provides for monitoring and leakage detection, collection and control of potential contamination, and provides accessibility for inspection and maintenance so that leaks can be readily identified and corrective actions taken.

10.4.7(D)(h) Initial Test Program

Although applicants for design certification are not required to submit plans for an initial test program, RG 1.68 acknowledges that design certification applicants have previously submitted these plans to assist a future COL applicant referencing the design certification in meeting the requirements of 10 CFR 52.79(a)(28). Preoperational test requirements for the CFS are listed in DCD Tier 2, Section 14.2.12.1.30, "Feedwater Control System Test;" Section 14.2.12.1.68, "Feedwater System Test;" Section 14.2.12.1.69, "Condensate System Test;" and Section 14.2.12.1.73, "Heater Drains System Test."

The initial test program for APR1400 is evaluated in Section 14.2 of this SER.

10.4.7(D)(i) ITAAC

The proposed ITAAC for the CFS are given in DCD Tier 1, Table 2.7.1.4-4 (Condensate and Feedwater System ITAAC). Section 14.3.7 of this SER evaluates the DCD Tier 1 information for plant systems SSCs. The evaluation of Tier 1 information in this section is an extension of the evaluation provided in SER Section 14.3.7 and only pertains to the CFS.

The staff's review for the CFS Tier 1 information included review of descriptive information, safety-related functions, arrangement, mechanical, I&C and electric power design features, environmental qualification, as well as system and equipment performance requirements provided in DCD Tier 1, Section 2.7.1.4. Based on its review, the staff finds that that the DCD Tier 1 information and ITAAC requirements adequately address the design certification requirements for the CFS. Further, the staff concludes that the ITAAC requirements are sufficient to demonstrate that the CFS will be designed and will operate in accordance with the design certification, the provision of the Atomic Energy Act of 1954, and NRC regulations which include 10 CFR 52.47(b)(1).

10.4.7(D)(j) Technical Specifications

The staff reviewed DCD Tier 2 Chapter 16, TS 3.7.3, for applicability to the main feedwater system (MFWS). TS 3.7.3 provides limiting conditions for operation and surveillance requirements for the MFIVs. TS Bases 3.7.3 background description is consistent with the DCD

Tier 2 description of MFIV. The staff concludes that TS 3.7.3 appropriately addresses the limiting conditions for operation and surveillance requirements for the MFIVs.

10.4.7(E) Combined License Information Items

The following is a list of COL Information Items and descriptions from Table 1.8-2 of the DCD Tier 2:

Table — APR1400 Combined License Information Items

Item No.	Description	DCD Tier 2 Section
10.4(1)	The COL applicant is to provide operational procedures and maintenance programs as related to leak detection and contamination control. Procedures and maintenance programs are to be completed before fuel is loaded for commissioning.	10.4.7
10.4(2)	The COL applicant is to maintain complete documentation of the system design, construction, design modifications, field changes, and operations.	10.4.7
10.4(6)	The COL applicant is to provide operating and maintenance procedures for the following items in accordance with NUREG-0927 and a milestone schedule for implementation of the procedures.	10.4.7

10.4.7(F) Conclusion

The staff finds the APR1400 condensate and feedwater system design acceptable because it meets applicable regulatory requirements including GDC 2 regarding protection from natural phenomena, GDC 4 regarding protection against missiles and effects of pipe breaks, GDC 5 regarding shared systems, GDC 44 regarding transferring heat to the ultimate heat sink, GDC 45 regarding inspections, GDC 46 regarding periodic testing, 10 CFR 20.1406 and 10 CFR 52.47(b)(1) regarding ITAAC.

10.4.8 Steam Generator Blowdown System

10.4.8(A) Introduction

The steam generator blowdown system (SGBS) assists in maintaining the chemical characteristics of the secondary water within acceptable limits during normal operation and during anticipated operational occurrences such as condenser in-leakage and primary-to-secondary steam generator (SG) tube leakage. This is accomplished by removing accumulated impurities with continuous blowdown from the SG secondary side. The SGBS includes a non-

safety-related wet layup system (WLS) used to control water chemistry during long-term shutdown. The SGBS has a safety-related function of providing SG isolation and containment isolation during design-basis events. Therefore, the system is classified as safety-related inside the containment up to and including the first isolation valves outside containment. The remainder of the system is classified as non-safety-related.

10.4.8(B) Summary of Application

DCD Tier 1: In Final Safety Analysis Report (DCD) Tier 1, Subsection 2.7.1.8, “Steam Generator Blowdown System,” the applicant describes the secondary water purification function and the safety-related isolation function of the SGBS. The Tier 1 information includes design information and Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) related to functional arrangement, American Society of Mechanical Engineers (ASME) Code requirements, seismic design, instrumentation, controls, and radioactive waste handling.

DCD Tier 2: In DCD Tier 2, Subsection 10.4.8, “Steam Generator Blowdown System,” the applicant describes the main components, design requirements, equipment capacities, monitoring and controls capabilities, and operation. The SGBS consists of a flash tank, regenerative heat exchangers, filters, demineralizers, pumps, piping, valves, and instrumentation. In addition to describing the system components, the Tier 2 information describes the safety-related and non-safety-related functions, the system operating modes, and testing and inspection requirements.

The SGBS flow diagrams are shown in Figure 10.4.8-1, “Steam Generator Blowdown System Flow Diagram (1 of 2),” and “Steam Generator Blowdown System Flow Diagram (2 of 2).” The interface with the sampling system is shown in Figure 9.3.2-2, “Process Sampling System Flow Diagram (3 of 6).” Additional system design information is provided in Table 10.4.8-1, “Steam Generator Blowdown System Major Component Design Parameters,” Table 10.4.8-2, “Steam Generator Blowdown System Failure Modes and Effects Analysis,” and Table 10.4.8-3, “Codes and Standards for Equipment in the SGBS.”

ITAAC: The ITAAC related to the SGBS are listed in DCD Tier 1, Subsection 2.7.1.8.

Technical Specifications: There are no technical specifications (TS) for this area of review.

10.4.8(C) Regulatory Basis

The relevant requirements of the Commission’s regulations for this area of review, and the associated acceptance criteria, are given in Section 10.4.8, “Steam Generator Blowdown System,” of NUREG-0800, the Standard Review Plan (SRP), and are summarized below. Review interfaces with other SRP sections are listed in SRP Section 10.4.8.

1. General Design Criterion (GDC) 1 of Appendix A to 10 CFR Part 50, as it relates to system components being designed, fabricated, erected, and tested to quality standards.
2. GDC 2, as it relates to system components being designed to seismic Category I requirements.
3. GDC 13, as it relates to monitoring system variables that can affect the reactor coolant pressure boundary (RCPB) and to maintaining them within prescribed operating ranges.

4. GDC 14, as it relates to secondary water chemistry control to maintain the integrity of the RCPB.
5. 10 CFR 52.47(b)(1) requires that a design certification (DC) application include the proposed ITAAC that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the DC is built and will operate in accordance with the DC, the provisions of the Atomic Energy Act, and the NRC regulations.

10.4.8(D) Technical Evaluation

The staff reviewed DCD Tier 2, Section 10.4.8 and Tier 1, Section 2.7.1.8 in accordance with SRP Section 10.4.8, "Steam Generator Blowdown System." Acceptance of the SGBS is based on meeting the requirements of GDC 1, GDC 2, GDC 13, and GDC 14. As stated in DCD Subsection 10.4.8.2.4, the system is also designed to meet the requirements of 10 CFR 20.1406, "Radiological Criteria for Unrestricted Use," and the guidance in Regulatory Guide (RG) 4.21, "Minimization of Contamination and Radioactive Waste Generation." The staff also reviewed supplemental information the applicant provided in letters dated November 24, 2015 (ADAMS Accession No. [ML15328A218](#)), January 20, 2016 (ADAMS Accession No. [ML16020A523](#)), March 4, 2016 (ADAMS Accession No. [ML16064A047](#)), March 11, 2016 (ADAMS Accession No. [ML16071A078](#)), March 25, 2016 (ADAMS Accession No. [ML16085A341](#)), April 2, 2016 (ADAMS Accession No. [ML16093A018](#)), May 19, 2016 (ADAMS Accession No. [ML16142A005](#)), and June 29, 2016 (ADAMS Accession No. [ML16181A244](#)).

10.4.8(D)(a) *GDC 1, Quality standards and records; GDC 2, Design bases for protection against natural phenomena; GDC 13, Instrumentation and control; and GDC 14, Reactor coolant pressure boundary*

The principal function of the SGBS is to maintain the secondary-side water chemistry in the SGs within specified limits by removing particulate and dissolved impurities. The SGBS consists of the blowdown subsystem (BDS) and WLS. During operation, the SGBS is designed to use the BDS to continuously perform a blowdown of each of the two SGs, purify the blowdown, and return it to the steam cycle through the condenser. During long-term shutdown, the SGBS is designed to control the water chemistry using the WLS. The WLS is also used to refill the SGs following draining or dry layup.

Each blowdown line contains two isolation valves in series in order to maintain the SG inventory. The system is designed to close the valves automatically under any of the following conditions: containment isolation actuation signal, main steam isolation signal, auxiliary feedwater actuation signal, diverse protection system auxiliary feedwater actuation signal, and high radiation signal from the monitor near the post-filter outlet. The staff found apparent inconsistencies between Chapters 10, 6, and 7 in the descriptions of the containment isolation signals for the SGBS. Therefore, in **RAI 84678467 (Adams Accession No. ML16032A028)**, **Question 10.04.08-1**, the staff asked the licensee to clarify how the containment isolation signals for the SGBS are consistent with the design of instrumentation and controls (Chapter 7) and the design of containment isolation (Chapter 6).

The applicant responded in a letter dated April 2, 2016 (ADAMS Accession No. [ML16093A018](#)). The response stated that the signals listed in DCD Chapter 6 are correct (Table 6.2.4-1, "List of Containment Penetrations and System Isolation Positions"), and it proposed revisions to DCD Tier 1, Chapter 2 and DCD Tier 2, Chapter 10 for consistency with DCD Chapter 6. Specifically, the response proposed adding the High Radiation Actuation Signal (HRAS) and Blowdown

The actuation signals (HRAS and BFTHHLAS) are indicated in DCD Figure 2.7.1.8-1 and provided the detailed description in DCD chapter 7 subsection 7.3.1.9.

Flash Tank High-High Level Actuation Signal (BFTHHLAS) to DCD Tier 1, Table 2.7.1.8-2, "Steam Generator Blowdown System Component List," and the BFTHHLAS to DCD Tier 2, Subsection 10.4.8.2.3.5.b. However, the response did not propose adding the HRAS and BFTHHLAS signals to DCD Tier 1, Figure 2.7.1.8-1, "Steam Generator Blowdown System," for consistency with DCD Table 2.7.1.8-2. The response also stated that that discussion of instrumentation and control signals in DCD Chapter 7 was intentionally general rather than detailed. The staff subsequently issued RAI 8596 (ADAMS Accession No. ML16125A324), Question 10.04.08-6, to address the missing actuation signals (HRAS and BFTHHLAS) in DCD Figure 2.7.1.8-1 and to provide additional detail in DCD Chapter 7 for consistency and clarity. The staff discussed this information with the applicant in a teleconference on June 13, 2016.

RAI 8596, Question 10.04.08-6 is being tracked as Open Item MCB-10.4.8-1.

To meet the requirements of GDC 1, 2, and 13, the SGBS must be designed to control the concentration of chemical impurities and radioactive materials in the secondary coolant. The blowdown is normally routed to filters and demineralizers for return to the condensate. It can also be routed to the wastewater treatment system or liquid radwaste system. To determine if the design meets the requirements, the staff reviewed piping and instrumentation diagrams, seismic and quality group classifications, design process parameters, and instrumentation and process controls. The review included the applicant's evaluation of the proposed system operation and the applicant's estimate of the controlling process parameters.

During normal power operation the blowdown flow rate for each SG is designed to be approximately 0.2 to 1 percent of the steam generator maximum steaming rate (SGMSR) of 4,071 tons per hour per SG (8,975,000 lbm per hour per SG). This is defined as continuous blowdown (CBD). The CBD rates of 0.2 percent and 1 percent apply to Normal Blowdown (NBD) and Abnormal Blowdown (ABD), respectively. NBD is defined as measured water chemistry within the normal limits. ABD is defined as measured water chemistry outside the normal limits. Intermittent High Capacity Blowdown (HCBd) of 5 percent of the SGMSR is designed for removing accumulated sludge in the tubesheet area. The system is designed to allow HCBd of one SG plus simultaneous ABD up to 1 percent of the second SG for two minutes. These three blowdown modes – NBD, ABD, and HCBd – are part of normal operation. Emergency Blowdown (EBD) is defined as the use of HCBd valves and piping for one SG at up to 14 percent of the SGMSR in order to reduce SG water level in the case of a beyond-design-basis multiple steam generator tube rupture (MSGTR) event. A summary paragraph in DCD Subsection 10.4.8 to describe the blowdown modes, the definition of one percent steaming rate in terms of mass per unit time, and clarification of the design blowdown rates are based on Enclosure 3 to the applicant's November 24, 2015, letter. Verification of these changes to Subsections 10.4.8, 10.4.8.2.3.1, 10.4.8.2.3.2, and 10.4.8.2.3.6 in the applicant's next revision of the DCD is being tracked as **Confirmatory Item MCB-10.4.8-1**

The staff reviewed the design of the SGBS to determine if it meets the requirements of GDC 14 with respect to equipment capacity to perform the water cleanup function. The guidance in SRP Section 10.4.8 is that the SGBS should be sized to accommodate the blowdown flow needed to maintain secondary coolant chemistry for normal operation, including anticipated operational occurrences. As an example, the Electric Power Research Institute (EPRI), which publishes the industry guidelines for primary and secondary water chemistry, provides quantitative recommendations for blowdown capacity for recirculating steam generators in Revision 1 of the "Steam Generator Reference Book" (Technical Report 103824, 1994). The recommendations are a maximum continuous blowdown rate of one percent of the main steaming rate during normal operation and three to seven percent for short periods (two to five minutes) for removing tubesheet sludge. Based on the information in the application, as supplemented by the

information in the applicant's November 24, 2015 letter (ADAMS Accession No. [ML15328A218](#)), the staff finds that the APR1400 is consistent with these design recommendations.

Under normal operating conditions, the blowdown flow rate of one percent of the SGMSR provides reasonable assurance that the SG water quality will be within specifications. This blowdown rate is typical of the design of current United States operating pressurized water reactors (PWRs). The capability to blow down a SG at up to five percent provides additional assurance that under abnormal conditions involving one SG with an unusually high impurity ingress rate the affected SG can be cleaned up rapidly. Under abnormal conditions such as contamination from a condenser leak or condensate polisher failure, protection of the SGs is provided by conformance with the EPRI Secondary Water Chemistry Guidelines. The EPRI Secondary Water Chemistry Guidelines require that power be reduced or the plant shut down if parameters exceed the specified action levels. Therefore, the SGBS is not solely relied upon to protect the integrity of the reactor coolant pressure boundary (RCPB) under abnormal conditions.

The blowdown capacity and purification capabilities of the SGBS are adequate to provide interim control of the SG water chemistry while the plant power level is reduced or the plant is shut down in accordance with EPRI Secondary Water Chemistry Guidelines. In addition, the design of the SGBS includes provisions to bypass individual components and provisions to route the effluent to the waste management system if the SGBS cannot remove the impurities from the blowdown. Therefore, even if the purification function does not operate properly, the SGBS design prevents an adverse impact on the secondary water quality.

The blowdown water is drawn from near the center of the tubesheet into pipes with holes. There is one blowdown pipe on the hot side and one on the cold side of the tubesheet. According to the applicant's supplemental letter dated November 24, 2015, letter (ADAMS Accession No. [ML15328A218](#)), the applicant has experience with the central blowdown design at other plants with no degradation generating loose parts or SG tube damage. Also in the November 24, 2015, letter, the applicant proposed correcting a typographical error in DCD Subsection 10.4.8.2.3.2 by changing "Figure 10.4.8-3" to "Figure 10.4.8-2." Verification of this change to the last paragraph in Subsection 10.4.8.2.3.2 in the applicant's next revision of the DCD is being tracked as **Confirmatory Item MCB-10.4.8-2**. Since the November 24, 2015, letter did not identify the material used for these blowdown pipes, the staff requested this information in RAI 84678467 (ADAMS Accession No. [ML16032A028](#)), Question 10.04.08-2. In the March 11, 2016, response letter (ADAMS Accession No. [ML16071A078](#)), the applicant stated that the piping is made of carbon steel. The NRC does not have detailed requirements or guidelines for these pipes, but carbon steel is compatible with the steam generator environment and used for other internals in steam generators. As discussed in Subsection 5.4.2.1 of the DCD and this report, this region of the steam generator is accessible for inspection and cleaning, enabling degradation to be detected and managed. Based on the material, the accessibility for inspection and cleaning, and the applicant's operating experience, the staff finds the design of the blowdown pipes acceptable with respect to meeting GDC 14 as it relates to the SGBS performing its secondary-side cleanup function in support of maintaining the integrity of the RCPB. On this basis, RAI 8467, Question 10.04.08-2 is resolved.

The SGBS also includes a non-safety-related WLS used to control water chemistry during long-term shutdown. Each SG has a WLS recirculation pump and piping circuit that interfaces with the SGBS filters and demineralizers. The water chemistry requirements for the blowdown water during wet layup conditions are consistent with the EPRI Secondary Water Chemistry Guidelines. The containment isolation valves for each return line include a gate valve that is

locked closed during normal operation in series with a check valve, so there is no need to actuate these valves for containment isolation.

Each SG blowdown has branch lines connected to the hot leg and to the economizer region of the secondary side. The blowdown is routed to the flash tank. Flashed steam returns to the steam and feedwater cycle by passing from the flash tank to the high-pressure feedwater heaters. The liquid in the flash tank flows to the regenerative heat exchanger, where it is cooled for processing in the demineralizers. The two demineralizers can be aligned to be used separately or simultaneously. The blowdown passes through a pre-filter prior to the demineralizers to remove solid particles that could cause blockage. Similarly, the blowdown passes through a post-filter after the demineralizers to remove demineralizer resin particles. If the water exiting the demineralizers does not meet the secondary water chemistry specifications or contains radioactive contamination, it is routed to the wastewater treatment system or liquid radwaste system as appropriate. Changing the criteria for abnormal water chemistry from sodium concentration to the specifications in DCD Table 10.3.5-1, "Operating Chemistry Conditions for Secondary Steam Generator Water," is based on Enclosure 3 to the applicant's November 24, 2015, letter. Verification of this change to Subsection 10.4.8.2.3.5.c in the applicant's next revision of the DCD is being tracked as **Confirmatory Item MCB-10.4.8-3**.

Instrumentation and process controls are provided to control flashing, liquid levels, and process flow through the proper components. This includes instruments to measure flow, temperature, pressure, differential pressure, level, and conductivity. Therefore, the instrumentation and controls allow the SGBS to maintain secondary water chemistry in a range protective to the reactor coolant pressure boundary. In addition, the system is designed with a radiation monitor for isolating the blowdown lines in the event of a high radiation level, such as from SG tube leakage. The monitor, designated RE/RT-104, is located downstream of the demineralizer post-filter and shown in DCD Figure 11.5-1, "Radiation Monitoring System (PR) (1 of 3)." The staff's review concludes that the SGBS design meets the requirements of GDC 13 because the instrumentation described is capable of monitoring system parameters and maintaining them in a range that allows the system to perform its impurity removal function. The staff's detailed review of instrumentation and controls for the APR1400 is documented in Chapter 7, "Instrumentation and Controls," of this SER.

As stated in SRP Section 10.4.8, in order to comply with GDC 14, temperature limits should not be exceeded for heat-sensitive processes. The APR1400 contains mixed-bed (anion/cation) demineralizers that contain temperature-sensitive resins. According to various sources, such as the Department of Energy Fundamentals Handbook (Chemistry, Volume 2, DOE-HDBK-1015/2-93) and data sheets from resin manufacturers, the temperature of mixed-bed ion exchange resins should be less than about 140°F to prevent thermal decomposition of the anion resin. Resin decomposition products can cause degradation of structural materials, including the steam generator tubes. The blowdown liquid from the flash tank flows to a regenerative heat exchanger, which cools the blowdown using condensate. From there, it flows through one of two pre-filters and then the demineralizers before returning to the condensate system. The APR1400 SGBS uses a temperature measurement at the exit of the regenerative heat exchanger to control the blowdown flow path. If the temperature of the blowdown water exiting the regenerative heat exchanger is greater than 57.2°C (135°F), the water is directed to the wastewater treatment system to avoid damage to the demineralizer resin. The SGBS is thus designed to prevent the temperature from exceeding the temperature limit of the demineralizer resin, and the staff finds that it meets GDC 14 as it relates to preventing temperature limits from being exceeded that could affect the chemistry of the secondary coolant and the reactor coolant pressure boundary. Identifying protection of the demineralizer resin as the basis for the

temperature limit is based on Enclosure 3 to the applicant's November 24, 2015, letter. Verification of this change to Subsection 10.4.8.2.3.2 in the applicant's next revision of the DCD is being tracked as **Confirmatory Item MCB-10.4.8-4**. The staff's review concludes that the SGBS design meets the requirements of GDC 13 with respect to process monitoring and control because the instrumentation described is capable of monitoring system parameters and maintaining them in a range that allows the system to perform its impurity removal function. However, the staff is unable to determine if the design meets the requirements of GDC13 until Open Item MCB-10.4.8-1 on containment isolation valve actuation signals is resolved

DCD Tier 1, Subsection 2.7.1.8, "Steam Generator Blowdown System," and Tier 2, Subsection 10.4.8.1, "Design Bases," discuss the design bases for the SGBS. Compliance with GDC 1 and GDC 2 is based on SGBS components and piping from the connection inside the primary containment up to and including the first isolation valve outside the containment being designed as seismic Category I and Quality Group B. This is based on conformance with RG 1.29, "Seismic Design Classification," and RG 1.26, "Quality Group Classification and Standards for Water, Steam, and Radioactive Waste Containing Components of Nuclear Power Plants," as stated in SRP Section 10.4.8. In addition to DCD Tier 1, Subsection 2.7.1.8 and DCD Tier 2, Subsection 10.4.8, the staff reviewed the DCD Tier 2, Subsection 3.2, "Classification of Structures, Systems, and Components," as it relates to the SGBS. According to DCD Table 3.2-1, "Classification of Structures, Systems, and Components," the SGBS design is seismic Category I and Safety Class 2 from its connection to the SG inside primary containment up to and including the first isolation valve outside the containment. In addition, DCD Table 10.4.8-3 shows that the design of the SGBS follows the Codes and Standards listed in RG 1.143. In DCD Table 3.2-1, SG Blowdown Items 86a and 86m, replacing the general term "portion of" with "valves and piping" is based on Enclosure 3 to the applicant's November 24, 2015, letter. Verification of this change to Table 3.2-1 in the applicant's next revision of the DCD is being tracked as **Confirmatory Item MCB-10.4.8-5**.

In the January 20, 2016, response (ADAMS Accession No. [ML16020A523](#)) to RAI 254-8270 (ADAMS Accession No. ML15293A568), Question 11.02-7, from the Radiation Protection and Accident Consequences Branch (RPAC), the applicant proposed a clarification of the safety classification in the SGBS described in DCD Subsection 10.4.8.1.2. The revised DCD would add the word "isolation" in stating that the safety classification for the SGBS component applies to the components, up to and including the nearest isolation valves, fittings, and/or welded/flanged nozzle connections. The staff finds the proposed change acceptable because it conforms to the guidance in RG 1.143. RPAC is tracking RAI 254-8270, Question 11.02-7, including the change to DCD Subsection 10.4.8.1.2, as an **open item** in Chapter 11 because of inconsistent wording proposed for different DCD sections.

For the portion of the system downstream of the outer containment isolation valves, SRP Section 10.4.8 states that position C.1.1, "Liquid Radwaste Treatment System," of RG 1.143 provides guidance for the codes and standards (position C.1.1.1), materials selection (C.1.1.2), and height of the foundations of walls and structures (C.1.1.3). DCD Section 10.4.8.1.2 and DCD Table 3.2-1 show that the components in the downstream portion of the SGBS are designed according to the codes and standards of Position C.1.1 in RG 1.143. The building housing the downstream part of the radwaste system is classified as RW-IIa, which meets the requirement for non-safety radwaste systems. Classification of the auxiliary building housing the liquid radwaste system is reviewed in Chapter 11, and the structural design of the auxiliary building is reviewed in Chapter 3. Changing the classification of the auxiliary building from RW-IIc and seismic Category I to RW-IIa in DCD Section 10.4.8.1.2 and Table 3.2-1 is based on the

applicant's January 20, 2015, response (ADAMS Accession No. [ML16020A523](#)) to RAI 254-8270, Question 11.02-8 from RPAC, which is tracking these changes as a **confirmatory item** in Chapter 11.

Clarification in DCD Subsection 10.4.8.1.2 that the design meets the RG 1.143 positions (rather than the "intent"), is based on Enclosure 3 to the applicant's November 24, 2015, letter. Verification of this in the applicant's next revision of the DCD is being tracked as **Confirmatory Item MCB-10.4.8-6**. Addition to DCD Subsection 10.4.8.1.2 of a cross-reference to DCD Table 3.2-1 for a description of the quality assurance program for SGBS components is based on Enclosure 3 to the applicant's November 24, 2015, letter. Verification of this in the applicant's next revision of the DCD is being tracked as **Confirmatory Item MCB-10.4.8-7**. Pending resolution of the confirmatory items and RAIs, the staff finds that the design of the portion of the SGBS inside containment conforms to the guidance in SRP Section 10.4.8 and RG 1.143 and, therefore, complies with GDC 1 and GDC 2 as they relate to the SGBS.

Flow accelerated corrosion (FAC) for the SGBS was addressed for steam and feedwater materials in Subsection 10.3.6.3 of Revision 0 of the DCD, "Flow Accelerated Corrosion." The paragraph on the SGBS described the use of carbon steel, chromium-molybdenum low-alloy steel, and stainless steel. In its November 24, 2015, letter (ADAMS Accession No. [ML15328A218](#)), the applicant provided clarifying information about materials selection in the SGBS and proposed deleting the paragraph on the SGBS in DCD Subsection 10.3.6.3. The applicant provided additional clarifying information in two letters. The first letter, dated April 2, 2016 (ADAMS Accession No. [ML16093A018](#)), in response to RAI 8467, Question 10.04.08-3, proposed a new DCD Subsection 10.4.8.2.2.f to describe how the SGBS design addresses FAC. The second letter, dated June 29, 2016 (ADAMS Accession No. [ML16181A244](#)), in response to 8596, Question 10.04.08-7, proposed additional information about FAC management in new DCD Subsection 10.4.8.2.2.1 to replace the proposed Subsection 10.4.8.2.2.f. The proposed DCD subsection identifies the portions of the system that use stainless steel or chromium-molybdenum steel, which are both resistant to FAC. The proposed subsection also identifies the portions that are carbon steel, and it states that these portions are managed by the FAC program, which will be addressed by a COL applicant as part of COL 10.3(3).

The staff finds the proposed Subsection 10.4.8.2.2.1 acceptable because it clarifies how FAC will be addressed for the SGBS. Verification of the addition of Subsection 10.4.8.2.2.1 to the applicant's next revision of the DCD is being tracked as **Confirmatory Item MCB-10.4.8-10**. The staff is reviewing the FAC program, including COL 10.3(3), as part of DCD Subsection 10.3.6. The June 29, 2016 letter also proposes editorial corrections to DCD Table 10.4.8-1, which the staff finds acceptable because they correct information about SGBS equipment design.

Tier 1

DCD Tier 1, Section 2.7.1.8, "Steam Generator Blowdown System," describes the SGBS, including equipment/piping characteristics (Table 2.7.1.8-1), system component list (Table 2.7.1.8-2), and system ITAAC (Table 2.7.1.8-3). This DCD subsection also includes Figure 2.7.1.8-1, a schematic diagram showing the safety-related components addressed in the Tier 1 design description, the ASME Code class boundaries, the containment boundary, and the valves that perform safety functions. The staff is unable to reach a conclusion on the

acceptability of Tier 1 information related to the SGBS until resolution of **Open Item MCB-10.4.8-1**. The staff will track **Confirmatory Item MCB-10.4.8-8**, to ensure that the appropriate markups to the applicable information discussed in SRP Section 14.3.7 for plant systems are incorporated in the DCD.

10.4.8D(b) Preoperational Testing

DCD Tier 2 Subsection 14.2.12.66, “Steam Generator Blowdown System Test,” describes preoperational testing for the SGBS. The objectives of the testing are to demonstrate the proper operation of isolation and control valves, process interlock signals, alarm and status lights, response to safety signals, and process flow paths. The staff’s review of the SGBS preoperational test plan is documented in Chapter 14 of this report.

10.4.8D(c) ITAAC

ITAAC for the SGBS are provided in DCD Tier 1, Table 2.7.1.8-3, “Steam Generator Blowdown System ITAAC.” The purpose of these ITAAC is to ensure the safety-related function of isolating the secondary side of the SGs in accordance with 10 CFR 50.47(b)(1). The ITAAC address the following topics: the functional arrangement of the as-built SGBS, ASME Code Section III requirements, seismic category requirements, electrical requirements, environmental qualification requirements, functional testing, and division separation requirements. These ITAAC define the safety-related portion of the system as extending from the SG blowdown nozzles to the outermost containment isolation valves.

The components covered by ITAAC match the safety significance of the system (i.e., the piping and components designed to ASME Code, Section III and seismic Category I). However, there is a discrepancy between the location of the safety-related portion of the system defined in DCD Tier 1, Subsection 2.7.1.8.1 (containment and the auxiliary building) and that defined in DCD, Table 2.7.1.8-1 (containment building). In RAI 84678467 (ADAMS accession NO. ML16032A028), Question 10.04.08-4, the staff requested clarification of the location of the portion of the system defined as safety-related, and consistency within the DCD. The staff needs to determine if these ITAAC are adequate to ensure future plants will be built in accordance with the DC related to the SGBS because they include the applicable items listed in SRP Section 14.3 for fluid systems. In the March 4, 2016, response (ADAMS Accession No. [ML16064A047](#)), the applicant clarified that the safety-related portion of the SGBS is located in the containment and the auxiliary building. The response proposed a revision to DCD Tier 1, Table 2.7.1.8-1 to add “Auxiliary Building” to the location. The staff finds this acceptable because it makes the text of DCD Tier 1, Subsection 2.7.1.8.1 consistent with DCD Table 2.7.1.8-1. Verification of this change to Tier 1 Table 2.7.1.8-1 in the applicant’s next revision of the DCD is being tracked as **Confirmatory Item MCB-10.4.8-8**.

10.4.8(E) Combined License Information Items

The table below lists the COL items related to the SGBS. COL Item 10.4(7) states that a COL applicant will describe the system for the steam generator drain. It was not clear to staff whether “drain” refers to a component or to how the SG will be drained. Since DCD Subsection 10.4.8.2.3.4 states that the SGBS is used to drain the SG, it is the staff’s understanding that the COL applicant is to describe a system for draining the SG, rather than the drain itself. The staff requested clarification of the required COL information in RAI 8467 (ADAMS Accession No. ML16032A028), Question 10.04.08-5. In the May 19, 2016, response (ADAMS Accession No. [ML16142A005](#)), the applicant proposed clarifying the COL information by requiring the COL applicant to provide the nitrogen or equivalent system design for the SG drain mode. The staff

finds this acceptable because adding the word “mode” clarifies the information required from the COL applicant. Verification of the revised changes in the applicant’s next revision of the DCD is being tracked as **Confirmatory Item MCB-10.4.8-9**. COL Item 10.4(8) requires a COL applicant to prepare the Site Radiological Environmental Monitoring Program. This program is necessary and is related to the SGBS because of the potential to contain liquid radwaste. COL Items 11.2(11) and 11.3(6) include this same requirement, and the staff is reviewing these COL items in Chapter 11.

Item No.	Description in DCD Table 1.8-2	DCD Section	Action Required by COL Applicant	Action Required by COL Holder
10.4(7)	The COL applicant is to describe the nitrogen or equivalent system design for SG drain mode	10.4.8.2.3.4 10.4.11	Y	N
10.4(8)	The COL applicant is to prepare the Site Radiological Environmental Monitoring Program	10.4.8.2.4 10.4.11	Y	N

10.4.8(F) Conclusion

Based on the review above, the staff concludes that the SER remains incomplete pending satisfactory resolution of the **Open Items** identified in staff’s technical evaluation in this report. The staff will update Section 10.4.8 of this SER to reflect the final disposition of the DCD application. Additionally, the staff will verify that updates to the DCD address the confirmatory items.

10.4.9 Auxiliary Feedwater System

10.4.9(A) Introduction

The auxiliary feedwater system (AFWS) provides an independent safety-related means of supplying the steam generators (SGs) with feedwater when the reactor coolant temperature is above the cut-in temperature for shutdown cooling, and the main feedwater system is unavailable. It is designed to provide adequate cooling water to the steam generators following transient conditions or postulated accidents such as a reactor trip, main steam line break, feedwater line break, small break loss-of-coolant accident (LOCA), loss of offsite power (LOOP), station blackout (SBO), anticipated transient without scram (ATWS) and steam generator tube rupture (SGTR). The AFWS consists of two mechanical divisions, each of which has two independent auxiliary feedwater trains which are aligned to feed into the respective steam generator. Each mechanical division has an AFW tank, a full-capacity motor driven pump that is powered from a safety-related electric bus, and a full-capacity turbine-driven pump which is driven with steam from the main steam system. The AFWS is a safety-related system.

10.4.9(B) Summary of Application

DCD Tier 1: The Tier 1 information associated with this section is found in DCD Tier 1, Section 2.7.1.5, "Auxiliary Feedwater System (AFWS)." Figure 2.7.1.5-1, "Auxiliary Feedwater System," illustrates the AFWS.

DCD Tier 2: The applicant has provided a Tier 2 system description in DCD, Tier 2 Section 10.4.9, "Auxiliary Feedwater System," summarized here in part as follows:

- The AFWS is normally in standby mode, available for operation during normal power operation and during plant transients and accident. The AFWS is not used during plant startup and normal plant shutdown.
- The AFWS consist of two 100 percent capacity motor-driven pumps, two 100 percent capacity turbine-driven pumps, two 100 percent capacity auxiliary feedwater storage tanks (AFWSTs), valves, two cavitating flow-limiting venturis, and instrumentation. The AFWS flow diagram is shown in DCD Tier 2, Figure 10.4.9-1, "Auxiliary Feedwater System Flow Diagram," and the AFWS design parameters and flow requirements are given in DCD Tier 2, Tables 10.4.9-1, "Auxiliary Feedwater System Component Parameters", and 10.4.9-6, "Steam Generator Makeup Flow Requirements."
- Each AFWS pump takes suction from its respective AFWST and has a respective discharge header. One motor driven and one turbine-driven pump are configured into one mechanical division and are joined together inside containment to feed their respective steam generator through a common AFW header, which connects to the SG downcomer feedwater line. Each of the common AFW headers contains a cavitating venturi to restrict the maximum AFW flow rate to each SG.
- A cross-connection is provided between the AFWSTs so that either tank can supply either division of the AFWS. The AFWSTs are seismic Category I and has a minimum usable safety-related water volume of 400,000 gallons, which is sufficient to achieve safe cold shutdown based on eight hours operation in hot standby, followed by six hours of cooldown to shutdown cooling entry conditions. A non-safety backup water source by gravity feed to AFW pump suction is also available from the condensate storage tank and raw water storage tank.

Technical Specifications: The AFWS Technical Specifications associated with DCD Tier 2, Section 10.4.9, are given in DCD Tier 2, Chapter 16, Sections 3.7.5, "Auxiliary Feedwater System," and 3.7.6, "Auxiliary Feedwater Storage Tank."

10.4.9(C) Regulatory Basis

The relevant regulatory requirements for this area of review and the associated acceptance criteria are given in NUREG-0800, Section 10.4.9, "Auxiliary Feedwater System (PWR)," Revision 3, and are summarized below. Review interfaces with other SRP sections also can be found in this NUREG-0800, Section 10.4.9.

1. GDC 2, "Design bases for protection against natural phenomena," as it relates to structures housing the system and the system itself being capable of withstanding the effects of natural phenomena such as earthquakes, tornadoes, and hurricanes.

2. GDC 4, "Environmental and dynamic effects design bases," as it relates to the capability of the system and the structure housing the system to withstand the effects of pipe breaks and external missiles.
3. GDC 5, "Sharing of structures, systems, and components," as it relates to sharing of SSCs of the steam and power conversion systems of different nuclear power units.
4. GDC 19, "Control Room," as it relates to the design capability of system instrumentation and controls for prompt hot shutdown of the reactor and potential capability for subsequent cold shutdown.
5. GDC 34, "Residual Heat Removal," and GDC 44, "Cooling water," as they relate to the capability of the system to transfer heat loads from the reactor system under both normal operating and accident conditions, assuming any single active failure, coincident with the loss of offsite power for certain events, and the capability to isolate components, subsystems, or piping if required to maintain system safety function.
6. GDC 45, "Inspection of cooling water system," as it relates to design provisions made to permit periodic in-service inspection of system components and equipment.
7. GDC 46, "Testing of Cooling Water System," as it relates to design provisions made to permit appropriate functional testing of the system and components.
8. GDC 60, "Control of Releases of Radioactive Materials to the Environment," as it relates to design provisions for tanks handling radioactive material in liquids.
9. 10 CFR 50.62, "Requirements for Reduction of Risk from ATWS Events for Light-Water-Cooled Nuclear Power Plants," as it relates to the design provisions for automatic initiation of the EFWS in an ATWS event.
10. 10 CFR 50.63, "Loss of all Alternating Current Power," as it relates to the design provisions for withstanding and recovering from a station blackout.
11. 10 CFR 52.47, "Contents of applications; technical information," Item (b)(1), which requires that a design certification application contain the proposed ITAAC that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a facility that incorporates the design certification has been constructed and will be operated in accordance with the design certification, the provisions of the Atomic Energy Act, and NRC regulations.
12. 10 CFR 20.1406, "Minimization of Contamination," as it relates to the standard plant design certifications and how the design and procedures for operation will minimize contamination of the facility and the environment facilitate eventual decommissioning and minimize to the extent practicable, the generation of radioactive waste.

10.4.9(D) Technical Evaluation

The staff's evaluation of the auxiliary feedwater system and storage tanks is based upon the information provided in the applicant's DCD, Revision 0, including Tier 1 and Tier 2. The staff reviewed the AFWS and AFWSTs in accordance with the review procedures in Standard Review Plan (SRP) Section 10.4.9, "Auxiliary Feedwater System (PWR)," Revision 3.

Applicable portions of SRP 9.2.6, "Condensate Storage Facilities," Revision 3, were also used for the review of the AFWSTs.

10.4.9(D)(a) GDC 2, Design bases for protection against natural phenomena

The staff reviewed the AFWS and AFWST for compliance with the requirements of GDC 2 with respect to their designs for protection against the effects of natural phenomena such as earthquakes, tornados, hurricanes and floods. Compliance with the requirements of GDC 2 is based on adherence to Position C.1 of RG 1.29, "Seismic Design Classification," for the safety-related portion of the system, and position C.2 for the nonsafety-related apportions of the system.

GDC 2 requires that nuclear power plant structures, systems, and components (SSCs) important to safety withstand the effects of earthquakes without loss of capability to perform their safety functions. DCD Tier 2, Section 10.4.9.1.1 contains the AFWS design basis functional requirements. In that section it is stated (in item i) that "The AFWS is an ASME Section III, Class 2 and 3, seismic Category I, redundant system with Class 1E electrical components, and that the AFWS is designed to remain functional after a safe shutdown earthquake (SSE).

The location, safety classification and seismic category for the AFWS components are listed in DCD Tier 2, Table 3.2-1, "Classification of Structures, Systems, and Components." Based on the information on the system and its components in DCD Tier 2, Table 3.2-1, the staff confirmed that AFWS system components and piping essential to AFWS operation are designed as seismic Category I, and therefore are designed to withstand the effects of earthquakes with no loss of function.

GDC 2 also requires that the nuclear power plant structures housing the AFWS be capable of withstanding the effects of natural phenomena such as earthquakes, tornadoes, and hurricanes. DCD Tier 2, Section 10.4.9.1.2 states that the AFWS components are located in the auxiliary building which is designed as seismic Category I and protects the AFWS components from external environmental hazard such as wind, tornado, hurricane, flood, and earthquakes, as described in DCD Tier 2, Sections 3.3, 3.4, and 3.7.

The staff reviewed the AFWS flow diagram (DCD Tier 2, Figure 10.4.9) and confirmed that the AFWS components and piping are located inside the auxiliary building and the reactor containment buildings, both of which are seismic category I structures, designed to provide protection against tornadoes, floods, missiles, and other external environmental hazards. The protection provided by these buildings against the above mention natural phenomena are evaluated in Section 3.2, 3.3, 3.4, 3.5 and 3.8, of this SER.

DCD Tier 2, Table 3.5-4, "Essential Systems and Components to be Protected from Externally Generated Missiles," contains a list of protected SSCs as well as the credited missile barrier. Table 3.5-4 did not identify the AFWS components as being components to be protected from external missiles in the original submittal of the DCD. However, the applicant has identified AFWS components among those to be protected in its proposed revision to Table 3.5-4 in the June 30, 2016, response (ADAMS Accession No. ML16182A536) to RAI 8046 (ADAMS Accession No. ML15201A473), Question 03.05.02-3. The review of the information in DCD Tier 2, Table 3.5-4, and the response to RAI 8046, Question 03.05.02-3 is included in section 3.5 of this report.

The AFWSTs are discussed in DCD Tier 2, Section 10.4.9.2.2.3. Each tank, which consists of a stainless-steel-lined reinforced enclosure, is an integral part of the safety-related, seismic Category I auxiliary building and is protected against environmental hazards. The location, safety classification and seismic category for the auxiliary feedwater storage and transfer system components are listed as item 6 under heading II, "System and Components," in DCD Tier 2, Table 3.2-1. The information on the system and its components in DCD Tier 2, Table 3.2-1, and DCD Tier 2, Figure 10.4.9-1, "Auxiliary Feedwater System Flow Diagram," was used by the staff to confirm that the AFWSTs, along with the auxiliary feedwater makeup piping from the storage tank up to and including the AFWST inlet manual valves, and the auxiliary feedwater piping from the storage tank up to the auxiliary feedwater suction manual valves are safety class 3 and seismic Category I. The AFWST cross connection line up to and including the AFWST connection manual valves and the non-safety backup supply lines up to and AFW pump suction manual valves are also safety class 3 and seismic Category I. The rest of the auxiliary feedwater storage and transfer system components located in the auxiliary building that are not safety-related are designed to seismic Category II.

The safety-related AFWS and AFWSTs are designed in accordance with RG 1.29 Position C.1. In addition, the non-safety components are designed in conformance with RG 1.29 Position C.2. The AFWS and AFWSTs are housed in the auxiliary building and the reactor containment building, and are therefore protected from external environmental hazard such as wind, tornado, hurricane, and floods. Based on the above review, the staff concludes that the AFWS design conforms to the guidelines of Positions C.1 and C.2 of RG 1.29 and the requirements of GDC 2 as they relate to protecting the system against natural phenomena and are protected from the effects of natural phenomena such as earthquakes, tornados, hurricanes and floods.

10.4.9(D)(b) GDC 4, Environmental and dynamic effects design bases

The staff reviewed the AFWS for compliance with the requirements of GDC 4 with respect to the capability of the system and the structures housing the system to withstand the effects of pipe breaks and internally and externally generated missiles, and pipe whip and jet impingement due to high and moderate energy pipe breaks. Compliance with the requirements of GDC 4 is based on identification of the essential portions of the system as protected from dynamic effects including internal and external missiles and meeting the guidance in BTP 10-2, "Design Guidelines to Avoid Water Hammer in Steam Generators."

In the APR1400 design, the AFWS and AFWSTs are located inside the auxiliary building and the reactor containment building, both of which are seismic Category I structures. Since these structures are designed to withstand the effects of severe natural phenomenon, including external missiles, as discussed in Section 3.5 of this report, the safety-related portions of the AFWS and AFWST are protected from external missiles. With respect to internal hazards, the design bases for the AFWS and AFWST call for the safety-related portions of these systems to be appropriately protected against the possible effects of postulated high or moderate energy pipe failure including whip or jet impingement as described in DCD Tier 2, Section 3.6, and internal flooding, and internal missiles as described in DCD Tier 2, Sections 3.4 and 3.5, respectively.

The protection of the safety-related AFWS and AFWST SSCs from the effects of the above mentioned internal hazards is generally accomplished in the APR1400 design by physical separation of redundant trains, and by enclosing redundant trains in separate compartments which provide both a physical/structural barrier for the SSCs in the compartment and separation distance between the redundant trains. The staff reviewed the general plant arrangement

drawings (DCD Tier 2 Figures 1.2-13 and 1.2-14) and confirmed that the general arrangement of the system is such that the redundant components of the AFWS and AFWST are protected from internal hazards due to separation of the two safety-related divisions, and their location in enclosures provide protection from dynamic effects.

BTP 10-2 and NRC GL 2008-01, "Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems," contain design guidelines and recommendations to reduce or eliminate piping damage caused by water hammer transients.

The applicant addresses water hammer prevention for the AFWS in DCD Tier 2, Section 10.4.9.3, "Safety Evaluation," indicating that the AFWS is designed to preclude water hammer in accordance with BTP 10-2 and NUREG-0927, "Evaluation of Water Hammer Occurrence in Nuclear Power Plants." Specifically, the APR1400 temperature upstream of the AFW isolation check valve is continuously monitored for early detection of back leakage from the main feedwater to minimize heated water introduction, and is alarmed in the main control room. Also for the APR1400, the steam supply line up to the AFW pump turbine steam isolation valve is warmed during normal power operation to minimize condensation and, as part of the design, a low-point drain upstream of the AFW turbine steam isolation valve provides a continuous blowdown through a pressure-reducing orifice to minimize water entrainment.

To ensure that adequate precautions are taken to prevent water hammer once the system has been put into operation, the applicant states in DCD Tier 2, Section 10.9.3, that the COL applicant is to provide operating and maintenance procedures in accordance with NUREG-0927 and a milestone schedule for implementation of the procedure, and has included COL information Item 10.4(6) in the DCD. It also provides a list containing the key elements that the procedures need to address. Therefore the staff concludes that the essential portions of the AFWS are protected against the effects of pipe breaks and internally and externally generated missiles, pipe whip and jet impingement due to high and moderate energy pipe breaks and water hammer and meets the requirements of GDC 4.

10.4.9(D)(c) GDC 5, Sharing of structures, systems, and components

The staff reviewed the APR14000 design for compliance with the requirements of GDC 5 with respect to sharing of SSCs. Acceptance is based on the failure of any component including a pipe break and single active failure not preventing the safe shutdown and cool down of either unit (together or singularly). As stated in DCD Tier 2, Section 3.1.5, "Criterion 5 - Sharing of Structures, Systems, and Components," the APR1400 is a single plant, and does not share safety-related SSCs with other units or plants. Thus, the requirement of GDC 5 for sharing systems between units does not apply.

10.4.9(D)(d) GDC 19, Control room

The staff reviewed the AFWS for compliance with the requirements of GDC 19, as the system relates to the design capability of system instrumentation and controls for prompt hot shutdown of the reactor and potential capability for subsequent cold shutdown. Compliance with the requirements of GDC 19 is based on conformance to BTP 5-4, "Design Requirements of the Residual Heat Removal System," in regard to cold shutdown from the control room using only safety grade equipment.

The APR1400 has a main control room (MCR) from which actions can be taken to operate the plant under normal conditions and to maintain it in a safe manner under accident conditions. In DCD Tier 2, Section 10.4.9.2.4, "Auxiliary Feedwater System Operation and Control," it is stated that the AFWS can be manually or automatically actuated by an auxiliary feedwater actuation signal (AFAS) from the engineered safety features actuation system (ESFAS) or the diverse protection system (DPS). It is also stated that the AFWS and supporting systems are designed to provide the required flow to the SG(s) during a loss of offsite power event, assuming a single active failure and, following the event, the AFWS is capable of maintaining hot standby and facilitating a plant cooldown from hot shutdown to shutdown cooling system initiation. In the event of a station blackout the turbine-driven pump lines provided with battery-backed power are capable of providing auxiliary feedwater to the SGs coincident with a single failure for 16 hours.

The MCR and remote shutdown room (RSR) have instrumentation that provides indication of AFW pump suction pressure, discharge pressure and pump flow, as well as temperature and level indication for the AFWSTs and inlet pressure and turbine speed for the AFW pump turbines. As discussed in DCD Tier 2, Sections 7.3 and 7.8.1.1, the diverse protection system (DPS) initiates an AFWS actuation when the level in either of the two SGs decreases below the nominal setpoint value in DCD Table 7.8-1. At the low water level setpoint of the SG, the AFAS from the engineered safety features system (ESFAS) and the DPS actuates the AFWS which delivers flow to the SG within 60 seconds. Thus the APR1400 is designed to provide automatic initiation of the AFWS, and is consistent with the recommendation of item II.E.1.2 (Auxiliary Feedwater System Automatic Initiation and Flow Indication) of NUREG-0737, "Clarification of TMI Action Plan Requirements," and satisfies the requirement GDC 19 with respect to timely initiation of the AFW system.

DCD Tier 2, Section 10.4.9.2, (item m) states that the automatic initiation signals and circuits are designed so that their failure does not result in the loss of ability to manually initiate the AFWS.

In describing the APR1400 compliance with Regulatory Guide 1.62, the applicant indicated that the ESFAS, which includes the AFAS signals, can be manually activated with switches located on the safety console in the MCR, and that some engineered safety function (ESF) also have

manual actuation at the remote shutdown room. The DCD states that the manual initiation of a protective system is provided at the system level and causes the same actions to be performed by the protection system as would be performed if the protection system had been initiated by automatic action. The manual initiation of the ESFAS, which includes the AFAS signals, is discussed in DCD Tier 2, Sections 7.3.1.3 and 7.3.1.4. In section 7.8.2.2, "Diverse Manual Engineered Safety Features Actuation Switches," the applicant states that the diverse manual action (DMA) switches are provided to permit the operators to manually actuate the ESF functions from the control room, and that the DMA switches are diverse from the manual and automatic logic functions performed by the PPS and ESF-CCS. The applicant also states in the DCD that the AFWS, as indicated in DCD Tier 2, Section 10.9.4.3, is provided with AC and DC emergency power and suitable redundancy in components and features to supply auxiliary feedwater to the SG(s) for removal of heat in the event of a single active component failure. Therefore, the staff finds that the APR1400 provides adequate instrumentation and controls for prompt initiation of shutdown using safety-related equipment consistent with the recommendation of item II.E.1.2 of NUREG-0737 and branch technical position 5-4 and in accordance with the requirements of GDC 19.

10.4.9(D)(e) GDC 34, Residual heat removal and GDC 44, Cooling water

The staff reviewed the AFWS for compliance with the requirements of GDC 34 and GDC 44, with respect to the capability to transfer heat loads from the reactor system to a heat sink under both normal operating and accident conditions, assuming any single active failure, coincident with the LOOP for certain events, and the capability to isolate components, subsystems, or piping if required to maintain system safety function. To demonstrate compliance with GDC 34 and GDC 44, SRP Section 10.4.9 states, in part, that the system design should conform to the guidance of BTP 10-1, "Design Guidelines for Auxiliary Feedwater System Pump Drive and Power Supply Diversity for Pressurized Water Reactor Plants," as it relates to AFWS pump drive and power supply diversity.

The staff reviewed the AFWS for compliance with the requirements of BTP 10-1, as related to AFW pump drive and power supply diversity. Guideline B.1 in BTP 10-1 states that the AFWS should have at least two full-capacity, independent systems with diverse power sources.

The APR1400 design provides diversity by using two types of pump drives (electric motors and steam turbines). DCD Tier 2, Section 10.4.9.2, "System Description," states that the AFWS has two 100 percent capacity motor-driven and two 100 percent capacity turbine-driven AFW pumps. The turbine-driven AFW pump trains are controlled and powered from battery-backed Class 1E power supplies as specified in DCD Tier 2, Section 10.4.9.2.3, and therefore their operation is completely independent from the motor-driven AFW pumps and controls. DCD Tier 2, Section 10.4.9.3 states that, in the case of a station blackout, the turbine-driven pump lines provided with battery backup are capable of providing auxiliary feedwater to the SGs coincident with a single failure for 16 hours, and that battery-backed power is also available to the turbine governor speed control. Redundancy and independence is provided through the use of two independent auxiliary feedwater trains as shown in DCD Tier 2, Figure 10.4.9-1. Each pump takes suction from a respective AFWST and discharges to a respective discharge header, and one motor-driven pump and one turbine-driven pump are configured into one mechanical division and joined together inside containment to feed their respective SG through a common auxiliary feedwater header, which connects to the SG downcomer feedwater line. Based on a review of the AFWS design description and corresponding system flow diagram (DCD Tier 2, Figure 10.4.9-1) the staff finds that the guidance in of BTP 10-1, as related to EFW pump drive and power diversity, is satisfied.

The staff reviewed the AFWS for its capability to transfer heat loads from the reactor system to a heat sink under both normal operating and accident conditions, assuming any single active failure and its ability to maintain required system safety function. DCD Tier 2, Section 10.4.9.1 states, as a functional requirement, that the AFWS and its supporting systems are to be designed to provide the required flow to the SG(s) with a loss of offsite power event, assuming an active failure. Each AFW pump is capable of providing 650 gpm assuming the maximum SG downcomer nozzle pressure, and the pump suction at the minimum suction pressure.

The AFWSTs provides a minimum of water inventory of 400,000 gal in each of the two storage tanks. The applicant has determined that for limiting case the required AFW storage inventory will be approximately 378,000 gallons of water would be needed to support AFW operation to maintain the plant at hot standby for eight hours and then six hours to cooldown down to shutdown cooling entry conditions. The AFWS can operate for approximately 14 hours with the water in a single AFWST. The staff therefore finds that the 800,000 gallons (400,000 per tank) exceeds the minimum water volume required and thus provides sufficient inventory to enable the AFWS to remove the required heat from the RCS under normal operating and accident conditions, assuming any single active failure, coincident with the LOOP. The AFWS can also be supplied with makeup water from the demineralized water storage tank (DWST).

Based on the staff's review as detailed above, the staff finds that the AFWS and AFWSTs are capable of transferring heat loads from the reactor system to a heat sink under both normal operating and accident conditions assuming single active failure and thus satisfy the requirements of GDC 34 and GDC 44.

10.4.9(D)(f) Generic Recommendations

As identified in the Acceptance Criteria of SRP 10.4.9, in addition to addressing GDC 34 and 44, the applicant is also expected to meet the generic recommendations of NUREG-0611, "Generic Evaluation of Feedwater Transients and Small Break Loss-of-Coolant Accidents in Westinghouse - Designed Operating Plants," NUREG-0635, "Generic Evaluation of Feedwater Transients and Small Break Loss-of-Coolant Accidents in Combustion Engineering – Designed Operating Plants," and 10 CFR 50.34(f)(1)(ii).

Generic Short Term Recommendation No. 3 (GS-3): GS-3 recommends that measures be taken to eliminate or reduce the potential for water hammer from AFWS discharge. A review of measures taken to eliminate or reduce the potential for water hammer was discussed above in this section of the SE, with regard to the applicant's compliance with the requirements of GDC 4. These measures include system design provisions which help preclude water hammer, AFWS monitoring to detect backleakage, which could contribute to condition for water hammer to occur, and the inclusion of COL information item 10.4(6) to ensure that appropriate operation and maintenance procedures will be used to minimize the probability of water hammer occurrences. Based on the above, and the staff's review of the AFWS compliance with GDC 4, as discussed above, the staff concludes that the APR1400 design meets GS-3

Generic Short Term Recommendation No. 4 (GS-4): GS-4 recommends emergency procedures to be available for transferring to alternative sources of AFW supply. DCD Tier 2, Section 10.4.9.5.4 states that level indication and low-level alarms for the AFWSTs are provided in the MCR and RSR by redundant level instrumentation on each tank. The low-level alarm is set to allow 30 minutes for alignment of the other AFWST or the non-safety backup makeup supply before the level decrease to a point where pump suction is lost. DCD Tier 2, Section 10.4.9.2.2.3 states that the AFWS is supplied with makeup water from the demineralized water storage tank, and that a nonsafety-related backup water source by gravity feed is also available

from the condensate storage tank and raw water storage tank. There are also two external water injection lines provided to makeup AFWST at the AFWST cross-connection line when the AFWSTs and nonsafety-related water source runs out. While the staff was able to confirm the presence of various sources that may be available to supply makeup to the AFWS, the staff could not find a specific commitment that procedures are or would be developed that specifically address the switch to a backup water source. The applicant also did not provide sufficient information on what water level the alarm would be set at and the level at which AFW pump suction will be lost (inadequate NPSH). Therefore, that staff requested in RAI 8003 (ADAMS Accession No. ML15197A269), Question 10.04.09-1, that the applicant demonstrate how it will be assured that the emergency procedures will be developed for the switch over of water to the DWST, CST, or other backup water source and what AFWST water level will be used to assure pump suction is not lost.

In their response to RAI 8003, Question 10.04.09-1, dated Oct 28, 2015 (ADAMS Accession No. ML15301A860), the applicant stated that it indicated in DCD Tier 2, Section 13.5.2.1.3, "Emergency Operating Procedure Program," that the COL applicant is to provide a program for developing and implementing emergency procedures. The applicant also include COL item 13.5(5) to ensure that the emergency procedures for switch over of water to the alternate source will be prepared by the COL applicant in accordance with DCD Tier 2, Subsection 13.5.2.1.3. In regards to the AFWST level used to provide the alarm in the control room alerting operators to switch over to the alternate source, the applicant indicates that the reserved volume from the level requiring operator action to empty is 22,063 gallons. Therefore, the level requiring operator action is appropriate to meet the minimum dedicated AFW capacity.

On the basis of its review of the applicant's response, the staff finds that the concerns identified in RAI 8003, Question 10.04.09-1 are resolved, given that the applicant has included COL Item 13.5(5) for the COL applicant to develop the necessary emergency procedures for switch over to backup water supplies, and the applicant has selected an AFWST level alarm that will provide for sufficient time for operator action to be taken to switch backup water source once the low tank level alarm setpoint is reached.

Generic Short Term Recommendation No. 5 (GS-5): GS-5 recommends the plant to be capable of providing required AFW flow for at least two hours from AFWS pump trains independent of any ac power source. Each of the AFWS trains can be operated using a turbine-driven pump during SBO conditions. The use of the turbine driven pumps allows for establishment of the required AFW flow to the steam generators. DCD Tier 2, Section 10.4.9.3 states that, in the event of a station blackout, the turbine driven pump lines provided with battery-backed power are capable of providing auxiliary feedwater to the SGs coincident with a single failure for 16 hours; thus under a station blackout scenario the AFWS can provide the required flow for greater than two hours. However, during a station blackout the alternate ac (AAC) power source can be credited and thus the safety-related cubicle coolers for the motor-driven auxiliary feedwater pump rooms may be used to cool the area. If no AC power is available the pump room temperature will increase. The staff could not find information regarding the effect of the loss of cooling in the pump room would have on the turbine-driven pump availability or accessibility if required by operators to perform manual actions need for operation of the pumps. Therefore, that staff requested in RAI 8003, Question 10.04.09-2, that the applicant provide information on the time dependent room temperature and the environmental qualification the turbine-driven AFW (TDAFW) pump and its supporting equipment (mechanical and electrical).

In their response to RAI 8003, Question 10.04.09-2, dated Oct 28, 2015 (ADAMS Accession No. ML15301A860), the applicant stated that the EQ envelope temperature of the TDAFW pump room in an abnormal condition when room cooling is not available is 160 °F for 24 hours, and the calculated transient room temperature is 133 °F for 24 hours. Additionally the applicant stated that the TDAFW pump is automatically started on receipt of AFAS or DPS-AFAS. Therefore, operators will not need access to the TDAFW pump room at the start of or during TDAFW operation. And the guidance of GS-5 is met.

Generic Short Term Recommendation No. 6 (GS-6): GS-6 recommends confirmation of the availability of the AFW flow path that has been taken out of service to perform periodic testing or maintenance, including TS requirement and procedures that require an operator to verify proper alignment of the flow path. The staff identified that TS SR 3.7.5.5 in Chapter 16 of the DCD Tier 2 requires a flow test to verify proper alignment of required AFW flow paths by verifying flow from auxiliary feedwater storage tanks to each steam generator whenever the reactor has been in cold shutdown, refueling, or defueled for a period greater than 30 days, consistent with the recommendations of GS-6. The procedures should include an independent check by a second operator to verify the flow alignment. However, the staff could not find a specific commitment that the COL applicant would develop procedures that specifically require confirmation of the availability of an AFW flow path that has been previously taken out of service to perform periodic testing or maintenance, including independent verification by a second operator. Accordingly, the staff requested in RAI 8003, Question 10.04.09-3 that the applicant provide the procedures that demonstrate how verification of the propose flow path will be accomplished.

In its response to RAI 8003, Question 10.04.09-3, dated Oct 28, 2015 (ADAMS Accession No. ML15301A860), the applicant added COL item 10.4(10) to DCD Tier 2, Section 10.4.9.4.1, "Auxiliary Feedwater Performance Test." The new COL item provides that the COL applicant develop procedures to perform periodic test, including independent verification in accordance with NUREG-0635. Thus, the recommendation for confirmation of availability of AFWS flow path for system returning to service has been met.

On the basis of its review of the applicant's response, the staff finds that the concerns identified in RAI 8003, Question 10.04.09-3 is resolved and, based on the above, recommendation GS-6 has been met. This RAI is closed, incorporation of the DCD markup provided as part of the RAI response is being tracked as a **confirmatory item**.

Additional Short-term Recommendation (Primary AFWS Water Source Low Level Alarm):

In accordance with this additional short-term recommendation, the plant should provide redundant level indication and low level alarms in the control room for the AFWS primary water supply. The low level alarm setpoint should allow at least 20 minutes for operator action, assuming the largest capacity AFW pump is operating. In accordance with DCD Tier 2, Section 10.4.9.5.4, level indication and low-level alarms for the AFWSTs are provided in the MCR and RSR, and the low-level alarm is set at a point to allow 30 minutes for manual alignment of the other AFWST or the non-safety backup supply before the level decrease to a point where pump suction is lost. Since the APR1400 is provided with AFWST level indication which provides for 30 minutes for operator action to establish an alternate water source, the staff finds that the short term recommendation concerning the AFWS low level alarm is satisfied.

Additional Short-term Recommendation (AFW Pump Endurance Test): In accordance with this additional short-term recommendation, it is requested that a one-time 72-hour endurance test be performed on the AFWS pumps. Following the 72-hour pump run, the pumps should be shutdown and cooled down and then restarted for one hour. In accordance with SRP 10.4.9

Section III, Item 3, a 48-hour test is acceptable rather than the 72-hour test. In DCD Tier 2, Section 10.4.9.4.2, "Reliability Tests and Inspections," the applicant indicates that a 48-hour endurance test is to be performed on the AFW pumps to demonstrate that the pumps have the capability for continuous operation over an extended period of time. While the applicant makes reference to a 48-hour endurance test in section 10.4.9 of the DCD, the staff was unable to find any information on the requirements of the endurance test in DCD Tier 2, Section 14.2.12.1.34, "Auxiliary Feedwater System Test." Therefore, the staff requested in RAI 8003, Question 10.04.09-4 that the applicant specify the requirement for the endurance test, by including the test objectives and the verification by listing the duration in DCD Tier 2, Section 14.2.12.1.34.

In its response to RAI 8003, Question 10.04.09-4, dated April 16, 2016 (ADAMS Accession No. ML16107A042), the applicant revised DCD Tier 2, Section 14.2.13.1.34, "Auxiliary Feedwater System Test," by indicating that a 48-hour endurance test is to be performed. The 48-hour test included in DCD Tier 2, Section 14.2.12.1.34 satisfies the recommendation for endurance testing of the AFW contained in NUREG-0611.

On the basis of its review of the applicant's response, the staff finds that the concerns identified in RAI 8003, Question 10.04.09-4 are resolved, given that the applicant has included in DCD Section 14.2.12.1.34 a 48-hour test in accordance with the recommendation in NUREG-0611 on AFW pump endurance testing. This RAI is closed, incorporation of the DCD markup is being tracked as a confirmatory item.

Generic Long Term Recommendation No. 3 (GL-3): The GL-3 recommendation is the same as GS-5 discussed above in this section of this SE. The staff concluded above that the APR1400 is in compliance with recommendation GS-5. Therefore, the staff also concludes that the AFWS is in compliance with GL-3.

10 CFR 50.34(f)(1)(ii): In accordance with this recommendation a simplified AFWS reliability analysis that uses event-tree and fault-tree logic techniques to determine the potential for AFWS failure under various loss-of-feedwater transient conditions should be performed. Particular emphasis should be given to determining potential failures that could result from human errors, common causes, single-point vulnerabilities, and test and maintenance outages.

DCD Tier 2, Section 10.4.9.1.2 (Item O) indicates that an AFWS reliability analysis was performed in accordance with the Three Mile Island (TMI) Action Item II.E.1.1 of NUREG-0737, and that the AFWS is designed to have unreliability from 10^{-5} to 10^{-4} per demand as described in DCD Tier 2, Chapter 19. The staff was unable to locate the referenced information in Chapter 19. Therefore, the staff requested in RAI 8003, Question 10.04.09-6 that the applicant provide the staff with the description and results of the AFWS reliability analysis that reference was made to in DCD Tier 2, Section 10.4.9.1.2.

KHNP has not receive the follow-up RAI 8664 yet.

In its response to RAI 8003, Question 10.04.09-6, dated June 1, 2016 (ADAMS Accession No. ML16153A479), the applicant states that "the AFWS reliability analysis was performed in accordance with TMI action item II.E.1.1 of NUREG-0737, and that the results of the reliability analysis will be added as Table 10.4.9-6 in the DCD." However, the description of the performed reliability analysis was not provided and there was no discussion as to why such analysis is in accordance with TMI Action Item II.E.1.1 of NUREG -0737. Therefore, the staff issued follow-up RAI 8664 (Pending Issuance), Question 10.04.09-7, dated July xx 2016, requesting the applicant to provide a description of the AFWS reliability analysis that was performed to support DCD Tier 2, Section 10.4.9.1.2 (Item O), and clarify how the information demonstrates compliance with the AFWS unavailability target. The response to RAI 8664, Question 10.04.09-7, and the resolution of this issue is being tracked as open item 10.04.09-1.

The results of AFWS reliability analysis have already been provided in the response of RAI 86-8003. The description of the performed AFWS reliability analysis can be identified through the electrical reading room (ERR).

Based on the review above, the staff concludes that the SER remains incomplete pending satisfactory resolution of the **Open Items** identified in staff's technical evaluation in this report. The staff will update Section 10.4.9 of this SER to reflect the final disposition of the DCD application.

10.4.9(D)(g) GDC 45, Inspection of cooling water system and GDC 46, Testing of cooling water system

The staff reviewed the AFWS for compliance with the requirements of GDC 45 as related to design provisions to permit periodic ISI of system components and equipment, and GDC 46 regarding provisions to permit appropriate functional testing of the system and components.

The staff reviewed the AFWS for compliance with the requirements and found that the AFWS pumps and the appropriate system valves were included in the plant In-Service Testing (IST) program (Table 3.9-13) as described in DCD Tier 2, Section 3.9.6, "Functional Design Qualification, and In-service Testing Programs for Pumps, Valves, and Dynamic Restraints." DCD Tier 2, Section 10.4.9.2.2.1 states that each AFW pump has adequate flow capacity to provide the required design flow to the SGs plus the capacity to continuously recirculate the flow, and that the recirculation lines are adequately sized so that full pump flow can be recirculated through the bypass provided around the flow restrictive orifice for full flow pump testing during power operation. The bypass line contains a manual flow control valve to vary the pump flow for performance testing.

The applicant indicates in DCD Tier 2, Section 10.4.9.43 that the AFWS system is designed to allow inspection of the system components and functional testing for the system operability and functionality performance.

Based on the above review, the staff finds that **the EFWS** satisfies the requirements of GDC 45 and GDC 46, since design provisions are provided to permit periodic ISIs of **EFWS** components and equipment and operational testing of **the EFWS** during normal plant conditions.

AFWS

10.4.9(D)(h) GDC 60, Control of releases of radioactive materials to the environment

The staff reviewed the design of the AFWSTs for compliance with the requirements of GDC 60 with respect to control of releases of radioactive materials.

GDC 60 requires that a means be provided to control the release of radioactive materials in liquid effluents system. AFWST overflow would not be subject to radioactive contamination, given that the AFWST inventory is provided by means of the DWST. Since the AFWSTs will not contain liquid effluents containing radioactive material, the staff concludes that there is no potential for the release of radioactive material to the environment from the AFWSTs and GDC 60 does not apply.

10.4.9(D)(i) 10 CFR 50.62, Requirements for reduction of risk from ATWS events for light-water-cooled nuclear power plants

The staff reviewed the AFWS for compliance with the requirements of 10 CFR 50.62 regarding provisions for automatic initiation in an ATWS. It is stated in DCD Tier 2, Section 10.4.9.2, Item P, that the AFWS can be either manually or automatically actuated by an auxiliary feedwater actuation signal (AFAS) from the ESFAS, as described in DCD Tier 2, Section 7.3, or the DPS. As previously indicated, DCD Tier 2, Section 10.4.9.2 (item m) states that the automatic initiation signals and circuits are designed so that their failure does not result in the loss of ability

to manually initiate the AFWS. In describing the APR1400 compliance with Regulatory Guide 1.62, the applicant indicated that the ESFAS, which includes the AFAS signals, can be manually activated with switches located on the safety console in the MCR, and that some ESF functions also have manual actuation at the remote shutdown room. In DCD Tier 2, Section 7.8.2.1, it is stated that the DPS is designed to mitigate the effects of an ATWS event characterized by an anticipated operational occurrence (AOO) followed by failure of the reactor trip portion of the protection system. Therefore, based on the above, the design was found to satisfy 10 CFR 50.62 regarding provisions for automatic initiation in an ATWS.

10.4.9(D)(j) 10 CFR 50.63, Loss of all alternating current

The staff reviewed the AFWS for compliance with the requirements of 10 CFR 50.63 regarding the capability for responding to a SBO. An applicant may demonstrate compliance with this requirement by meeting Positions 3.2.2, 3.3.2 and 3.3.4 of RG 1.155, "Station Blackout," which is based on the AFWS design providing for sufficient decay heat removal in a SBO. DCD Tier 2, Section 8.4.1 states that during a Station Blackout a non-Class 1E AAC gas turbine generator (GTG), with sufficient capacity and reliability, provides power for the set of required shut down loads enough to bring the plant to safe shutdown.

Both trains of the AFWS have turbine-driven AFW pumps that can operate during SBO conditions. In DCD Tier 2, Section 10.4.9.3 it is stated that, in the event of a station blackout, the turbine-driven pump lines provided with battery-backed power are capable of providing auxiliary feedwater to the SGs coincident with a single failure for 16 hours, and that battery-backed power is also available to the turbine governor speed control. In addition the AAC GTG is provided for the operation of the motor-driven AFW pump lines during an extended SBO.

With credit for AAC generated electrical power, the plant can withstand an SBO condition for at least 16 hours. DCD Tier 2, Section 10.4.9.3 indicates that the total usable water inventory in the AFWSTs (800,000 gallons) is sufficient for decay heat removal during the 16 hour SBO duration. Therefore, based on the above, the staff concluded that the design satisfies 10 CFR 50.63 regarding the capability for responding to a SBO.

10.4.9(D)(k) 10 CFR 20.1406 Minimization of contamination

10 CFR 20.1406 requires in part that each design certification applicant describe how the facility design and procedures for operation will minimize, to the extent practicable, contamination of the facility and the environment, as well as the generation of radioactive waste. The AFWS is not used during normal operation and in general does not contain radioactive fluids. However, there is a segment of AFWS piping, connected to the high-pressure feedwater lines after the containment penetration to the SGs that may become contaminated by the feedwater. In addition the turbine driven AFW pumps may also be subject to contamination since they receive steam from the main steam system.

In DCD Section 10.4.9.2.5, "Design Features for Minimization of Contamination," the applicant states that the CFS is designed with specific features to meet the requirements of 10 CFR 20.1406. Specifically, it is stated that, AFW piping is required to be fabricated of stainless steel material, be welded construction, and be designed to safety class 3 and seismic Category I requirements. In addition to minimize leakage of unintended contamination of the facility and the environment leakage developed in the segment of AFWS piping, connected to the high-pressure feedwater lines after the containment penetration to the SGs will be collected in the sump, and for the AFWS valve stem leak-offs and drains are collected and directed to the liquid radwaste system for treatment and release. Based on the above, the staff concludes that the

applicant provided an adequate description of how the facility design will minimize contamination.

10.4.9(D)(l) *Initial Test Program*

Although applicants for design certification are not required to submit plans for an initial test program, RG 1.68 acknowledges that design certification applicants have previously submitted these plans to assist a future COL applicant referencing the design certification in meeting the requirements of 10 CFR 52.79(a)(28). Preoperational test requirements for the AFWS are listed in DCD Tier 2, Section 14.2.12.1.34, "Auxiliary Feedwater System Test," and Section 14.2.12.4.13, "Feedwater and Auxiliary Feedwater System Test."

10.4.9(D)(m) *ITAAC*

Proposed ITAAC for the AFWS are given in DCD Tier 1, Table 2.7.1.5-4 (Auxiliary feedwater System ITAAC). Table 2.7.1.5-4 contains test and inspection requirements for the AFWS. These tests and/or inspections confirm: (1) the as-built AFWS conforms with the functional as described in DCD Tier 1, Section 2.7.1.5 and Figure 2.7.1.5-1; (2) adequate NPSH to the system pumps [Item 10a]; (3) design flow rates to SGs for design conditions [Item 12]; (4) adequate AFWSTs volume [Item 10b]; (5) the functional arrangement of the AFWS [Item 1]; (6) remotely operated valves can be opened and closed from the main control room [Item 8]; and (7) the two mechanical divisions are physically separated [Item 9].

Based on a review of the information provided in DCD Tier 1, Table 2.7.1.5-4, the staff concludes that the ITACC will adequately confirm AFWST and AFWSTs design capabilities, design features, and systems interfaces.

10.4.9(D)(n) *Technical Specifications*

The staff reviewed the TS requirements for the AFWS as presented in DCD Tier 2, Chapter 16. In MODES 1, 2, and 3, the AFWS, including the AFWSTs, are required to be operable. For MODE 4, when a steam generator is relied upon for heat removal, only one AFW train, which includes a motor driven pump, is required to be operable.

Applicable AFWS Limiting Conditions for Operation (LCO) are provided in DCD Tier 2 Chapter 16 LCO 3.7.5. For applicability to MODES 1, 2, and 3, the LCO and the associated Bases were reviewed and found to be acceptable. A detailed evaluation of the technical specifications is contained in Chapter 16 of this report.

SRs for the following parameters are provided: (1) valve alignment confirmation, (2) pump developed head, (3) verification that automatic valves actuate to correct position on actual or simulated actuation signal, (4) pump start on actual or simulated actuation signal, and (5) verification that the AFWS is properly aligned from AFWSTs to the SGs prior to entering MODE 2 after more than 30 days in MODE 5 or 6. AFW alignment is also verified following extended outages.

The staff determined that the surveillance parameters listed above for the AFWS are reasonable, since they provide for pump operability, proper system alignment, and correct automatic response of the AFWS pumps and valves.

The staff reviewed the LCO and the associated Bases for the AFWSTs and found them to be acceptable. The applicable LCO for the AFWSTs is provided in DCD Tier 2 Chapter 16;

LCO 3.7.6. The LCO includes two action levels for a condition in which one or both AFWSTS become inoperable.

There is one surveillance requirement for the AFWSTS, namely that the tank level be maintained at or above 1,524,165 L (400,000 gallons) (SR 3.7.6.1).

Based on a detailed review of proposed TS Sections 3.7.5 and 3.7.6 and Bases 3.7.5 and 3.7.6, the staff finds the AFW will be operated in accordance with its design bases requirements.

10.4.9(E) Combined License Information Items

The following is a list of COL item numbers, with the table-provided descriptions, from DCD Tier 2, Table 1.8-2, "Compilation of All Combined License Applicant Items for Chapters 1-19," that are directly applicable to the AFW. **Table — APR1400 Combined License Information Items**

Item No.	Description	DCD Tier 2 Section
10.4(1)	The COL applicant is to provide operational procedures and maintenance programs as related to leak detection and contamination control. Procedures and maintenance programs are to be completed before fuel is loads for commissioning.	10.4.9
10.4(2)	The COL applicant is to maintain complete documentation of the system design, construction, design modifications, field changes, and operations	10.4.9
10.4(6)	The COL applicant is to provide operating and maintenance procedures for the following items in accordance with NUREG-0927 and a milestone schedule for implementation of the procedures.	10.4.9

10.4.9(F) Conclusion

Based on the review above, the staff concludes that the SER remains incomplete pending satisfactory resolution of the Open Items identified in staff's technical evaluation in this report. The staff will update Section 10.4.9 of this SER to reflect the final disposition of the DCD application.

10.4.10 Auxiliary Steam System

10.4.10(A) Introduction

The auxiliary steam system is a nonsafety-related system that supplies auxiliary steam required for plant use during startup, cleanup/recirculation, and shutdown when the main steam is not available. The system includes a control valve to reduce the main steam pressure, an auxiliary steam header, a condensate receiver tank with vent condenser, condensate return pumps, an auxiliary boiler package, and associated piping, valves, instrumentation, and controls.

10.4.10(B) Summary of Application

DCD Tier 1: DCD Tier 1, Section 2.7.1.9 states that there are no Tier 1 requirements specific for the auxiliary steam system.

DCD Tier 2: DCD Tier 2, Section 10.4.10, "Auxiliary Steam System," provides the design description and operational details for the auxiliary steam system. The auxiliary steam system is supplied by the main steam system (MSS) through a pressure-reducing valve, when the unit is in operation and by the auxiliary boiler at all other times. A schematic of the system is depicted in DCD Tier 2 Figure 10.4.10-1

DCD Tier 2 Subsection 10.4.10.2.1, "General Description," indicates that for operation as required during startup, shutdown, plant regular inspection, and normal operation, the auxiliary steam from the auxiliary boiler or main steam is supplied to the components continuously or intermittently depending on the task and mode of operation of the plant. During plant normal operation, the auxiliary steam system supplies steam to various equipment for the following purposes: deaerator pegging during recirculation/clean up and low power operation, turbine seals until main turbine extraction steam is available, feedwater pump turbine seals until main steam is available, feedwater pump turbine testing during plant shutdown, auxiliary feedwater pump turbine testing during plant shutdown, boric acid concentrator package and gas stripper package in the chemical and volume control system, decontamination services in the reactor containment building and fuel handling area, and to the solid radwaste system (SRS) for heating the SRS concentrates treatment system.

The auxiliary steam system operation for the APR1400 is provided in DCD Subsection 10.4.10.2.2, "System Operation."

DCD Subsection 10.4.10.2.3 provides details of the auxiliary steam system design features for minimization of contamination. The DCD describes the prevention/minimization of unintended contamination, adequate and early leak detection, reduction of cross-contamination, decontamination, waste generation, and operational details and documentation. Also, the DCD provides guidance to combined license (COL) applicants to establish operational procedures and maintenance programs as related to leak detection and contamination control in accordance with NRC RG 4.21 (COL 10.4(1)).

DCD Subsection 10.4.10.5, "Instrumentation Requirements," indicates that the auxiliary steam system is provided with the necessary controls and indications for local or remote monitoring of system operation. A radiation monitor is provided to monitor for the presence of leaked radioactive materials in the condensed water from the boric acid concentrator package, gas stripper package, or solid waste treatment system. If the condensate is contaminated, the

radiation monitor will actuate an alarm in the main control room (MCR) and automatically redirect the condensate to the liquid waste management system for treatment.

ITAAC: There are no ITAAC specific to the auxiliary steam system.

Technical Specifications: There are no technical specifications (TS) associated with the auxiliary steam system.

10.4.10(C) Regulatory Basis

The relevant requirements of the NRC regulations for this area of review, and the associated acceptance criteria, are summarized below:

General Design Criteria (GDC) 2, "Design bases for protection against natural phenomena," as it relates to the failure of nonsafety-related systems or components due to natural phenomena such as earthquakes, tornadoes, hurricanes, and floods not to adversely affect the safety-related SSCs.

GDC 4, "Environmental and dynamic effects design bases," as it relates to a failure of the auxiliary steam system due to pipe break or malfunction of the auxiliary steam system to not adversely affect essential systems or components necessary for safe shutdown or accident prevention or mitigation.

GDC 60, "Control of releases of radioactive materials to the environment," as it relates to the ability of the auxiliary steam system design to control releases of radioactive materials to the environment.

GDC 64, "Monitoring radioactivity releases," as it relates to provisions being included in the nuclear power unit design for monitoring the effluent discharge paths and the plant environs for radioactivity that may be released from normal operations, including AOOs, and from postulated accidents.

10 CFR 20.1406, "Minimization of contamination," as it relates to the design features that will facilitate eventual decommissioning and minimize, to the extent practicable, the contamination of the facility and the environment and the generation of radioactive waste.

Acceptance criteria to meet the above requirements include:

1. Regulatory Guide (RG) 1.29, "Seismic Design Classification," as it relates to identifying and classifying system portions that should be designed to withstand the effects of a safe-shutdown earthquake.
2. RG 4.21, "Minimization of Contamination and radioactive Waste Generation – Life-Cycle Planning" as it relates to design consideration employed for facility life-cycle planning to meet the requirements of 10 CFR 20.1406.

10.4.10(D) Technical Evaluation

The staff reviewed the auxiliary steam system described in Tier 2 of the DCD, Revision 0, to determine if a failure or malfunction of the system could adversely affect safety-related systems and components (SSCs), or result in the release of radioactive materials to the environment. The staff's acceptance of the auxiliary steam system is based on the compliance of the system

design with the requirements of GDC 2, GDC 4, GDC 60, GDC 64 and the adherence to 10 CFR 20.1406.

10.4.10(D)(a) *GDC2, Design bases for protection against natural phenomena, and GDC 4, Environmental and dynamic effects design bases*

The staff reviewed the auxiliary steam system for compliance with the requirements of GDC 2 and 4. Compliance with the requirements of GDC 2 is based on the determination, by the staff through its review, that auxiliary steam system is designed to withstand the effects of postulated natural phenomena, including earthquakes, such that it would not result in the loss of the capability of the important to safety SSCs to perform their safety functions. Compliance with the requirements of GDC 4 is based on the determination, by the staff through its review, that failure of the auxiliary steam system due to pipe break or malfunction of the auxiliary steam system does not adversely affect any of the plant's essential systems or components (i.e., those necessary for safe shutdown or accident prevention or mitigation).

The staff reviewed DCD Tier 2, Section 10.4.10, Figure 10.4.10-1, Figures 1.2-1 through 1.2-49, and Table 3.2-1. The staff found that all the major components of the auxiliary steam system, except the auxiliary boiler, are located in enclosed cubicles inside the auxiliary building. The auxiliary boiler is located in the auxiliary boiler building in the yard area. Piping for the auxiliary steam system can be found outside the auxiliary building, such as the reactor containment building, the turbine building, the compound building, and the concrete tunnel running between the auxiliary boiler building and the turbine building. The cubicle enclosure provides protection against the effects of pipe breaks and component failures. The auxiliary steam system piping supplies steam to various equipment including the boric acid concentrator package and the gas stripper package. The auxiliary steam system piping are considered high energy lines. The auxiliary steam system is not required to be seismic category I because it is a nonsafety-related system and is therefore not relied upon to remain functional following a seismic event. The piping in the auxiliary building is seismic category II and quality group D as identified in DCD Tier 2 Figure 10.4.10-1 and Table 3.2.1. This classification meets the guidance in Regulatory Guide (RG) 1.29, "Seismic Design Classification," Revision 4, and will not adversely impact those safety-related systems co-located within the auxiliary building.

Regarding auxiliary steam system piping located within the compound building and turbine building, this piping is classified as seismic category III and quality group D. There are no safety-related SSCs located in these areas and therefore the adverse effects of a pipe break or component failure on any safety-related equipment is not required. Consequently, the auxiliary steam system piping classification in the turbine and compound building meets RG 1.29.

DCD Tier 2, Figure 10.4.10-1, "Auxiliary Steam Flow Diagram," (sheet 1 of 3), depicts the auxiliary steam system piping as seismic category II, quality group D inside the reactor containment building except for the containment penetration which is classified as seismic category I between and including the isolation valves. In accordance with RG 1.29, these isolation valves perform a safety-related function and therefore must be seismic category I and quality group B. Further staff evaluation of containment isolation is found under Section 6.2 of this safety evaluation. The remaining portions of the auxiliary steam system piping within the reactor containment building must be at a minimum seismic category II since this building houses safety-related equipment.

However, DCD Tier 2, Table 3.2-1, "Classification of Structures, Systems, and Components," (3 of 86), does not indicate any auxiliary steam system components within the reactor containment building other than the containment penetration itself which is classified as seismic category I

Please check if there is still an open issue. The RAI response was provided in June, 2016.

and quality group B. Table 3.2-1, Item 4.c does state that "others" would be seismic category III. Without proper classification of this system's components within the reactor containment building, failures of those portions could damage safety-related equipment. If one were to bin the reactor containment building piping and components under Table 3.2-1, Item 4.c, then this portion of the system would be seismic category III. This classification would be unacceptable for steam piping located in the reactor containment building that contains safety-related equipment (other than the aux steam system). This safety-related equipment inside the RCB is required to withstand the effects of a safe shutdown earthquake and therefore must remain functional. Therefore, the staff issued RAI 8556 (ADAMS Accession No. ML16130A085), Question 10.4.10-2, requesting the applicant to clarify the actual seismic and quality group classifications of the auxiliary steam system components and piping within the reactor containment building. The applicant is requested to modify the DCD Figure 10.4.10-1 and Table 3.2-1 to clearly depict a consistent design. **This is being tracked as Open Item 10.4.10-2.**

RCB is

Based on the Open Item, the Staff is unable to reach a conclusion in this subsection.

10.4.10(D)(b) GDC 60, control of releases of radioactive materials to the environment, and GDC 64, Monitoring radioactivity releases

NRC staff reviewed the design of the auxiliary steam system for compliance with the requirements of GDC 60 with respect to control of releases of radioactive materials and GDC 64 with respect to the monitoring of radioactive releases. The requirements of GDC 60 and 64 are met if the auxiliary steam system design includes provisions to monitor and prevent excessive release of radioactivity to the environment in the event of an auxiliary steam system, or component failure.

The auxiliary steam system provides steam to the boric acid concentrator, gas stripper, and solid waste treatment system, and thus the auxiliary steam system may potentially contain radioactive effluents. DCD Subsection 10.4.10.2.1 states that condensate from the boric acid concentrator package, gas stripper package, and solid waste treatment system is collected in the condensate receiver tank and transferred to the condenser if the source of steam is from the MSS, or back to the auxiliary boiler if the source of steam is from the auxiliary boiler via the condensate return pumps. It also states that at the discharge of the condensate return pump, the condensate is monitored continuously for radioactivity. If contaminated, the radiation monitor actuates an alarm in the MCR and automatically diverts the radioactive or potentially radioactive condensate to the liquid radwaste system. Based on the provisions described above, the staff finds that the design includes sufficient provisions to prevent excessive release of radioactivity to the environment and to monitor for any potential amounts of radioactivity released in the event of failure of the SSC's in the auxiliary steam system.

10.4.10(D)(c) Conformance with 10 CFR 20.1406, Minimization of contamination

10 CFR 20.1406, "Minimization of contamination," requires in part that each DC applicant shall describe how the facility design and procedures for operation will minimize, to extent practicable, contamination of the facility and environment and the generation of radioactive waste.

In DCD Tier 2, Subsection 10.4.10.2.3 "Design Features for Minimization of Contamination," the applicant states that the APR1400 is designed with specific features to meet the requirements of 10 CFR 20.1406 and RG 4.21, "Minimization of Contamination and Radioactive Waste Generation: Life-Cycle Planning." The applicant also indicated that Subsection 12.4.2 of the DCD provides summary information on how the auxiliary steam system meets the basic

principles of RG 4.21, and specifically delineates the four design objectives and two operational objectives contained in the RG. The following evaluation summarizes the primary features included by the applicant to address the design and operational objectives for the auxiliary steam system.

Among the design features for minimization of contamination identified in DCD Subsection 10.4.10.2.3, "Minimization of contamination," is the use of a system designed to contain any leaks, and has sufficient space for prompt assessment and evaluation of the adequacy and the appropriateness of responses to isolate and mitigate leaked areas, the locating of the auxiliary steam system condensate receiver tank, vent condenser, and pumps in an enclosed area at the foundation level inside the auxiliary building, and the auxiliary boiling building outside the auxiliary building to house the boiler. To the extent practicable, cubicles housing auxiliary steam system equipment will be designed with early leak detection capabilities to detect component leakage, overflow, and/or tank rupture, and will have provisions to initiate alarm signals for operator actions; concrete sumps will be coated and have seals to prevent unintended infiltration of liquid into the concrete sumps, and the use of embedded piping will be minimized. Where embedment cannot be avoided, consideration is given to minimizing embedded piping lengths and use of double-walled piping with leak detection capabilities on the outer piping, and a minimization of the use of buried piping in the yard between buildings and facilities, and the use of pipe tunnels with leak detection capability and accessibility for piping that contains radioactive or potentially radioactive fluids. However, during the review of Tier 2 information, the staff identified contrary information in Subsection 10.4.10.2.3, under "Decommissioning Planning," which stated that no embedded or buried piping exists for this system. Although either option would satisfy RG 4.21 and 10 CFR 20.1406, the applicant should choose one option and revise their response to RAI 8556 (ADAMS Accession No. ML16130A085), Question 10.4.10-1 stating clearly which option they chose to meet 10 CFR 20.1406 regarding embedded and buried piping. This is being tracked as **Open item 10.4.10-1**.

The leak identification evaluation indicates that the auxiliary steam system is designed to facilitate early leak detection and the prompt assessment and response to manage collected fluids. In addition to design features, the minimization of contamination is achieved through the use of appropriate operation procedures and maintenance programs. The programs are to be developed by the COL applicant as stated in COL Information Item 10.4(1), which requires that the COL applicant establish operational procedures and maintenance programs for leak detection and contamination control. During the review of the combined license information item, the staff noted inconsistencies among the Chapter 9 and Chapter 10 subsections in providing operational procedures and maintenance programs with leak detection and contamination control required in part to satisfy 10 CFR 20.1406. In addition, the COL Information Item 10.4(1), as a standalone statement, does not identify which plant systems under DCD Tier 2, Section 10.4 are applicable. *[The staff reviewers for Chapters 11 and 12 have decided to take on this issue and ask the applicant to remove all COL items dealing with procedures and programs for 10 CFR 20.1406 and placing a central COL item in Chapter 11 or 12 to satisfy this requirement. This is being tracked as Open Item 10.4-3]*

Based on the review above, the staff concludes that the SER remains incomplete pending satisfactory resolution of the **Open Items** identified in staff's technical evaluation in this report. The staff will update Section 10.4.10 of this SER to reflect the final disposition of the DCD application.

KHNP had considered the removal of all COL items related to 10 CFR 20.1406 in Chapters 9 and 10. During a teleconference between KHNP and the NRC staff, it was agreed upon to keep the current COL items as is. The resolution to this issue was submitted in the revised response to RAI No. 246-8307, Question 09.02.08-3.

10.4.10(D)(d) Initial Test Program

Although applicants for design certification are not required to submit plans for an initial test program, RG 1.68 acknowledges that design certification applicants have previously submitted these plans to assist a future COL applicant referencing the design certification in meeting the requirements of 10 CFR 52.79(a)(28). Preoperational test requirements for the auxiliary steam system are described in DCD Tier 2 Subsection 10.4.10.4 and Subsection 14.2.12.1.128. The initial test program for the APR1400 is evaluated in Section 14.2 of this SER.

10.4.10(D)(e) ITAAC

There are no ITAAC required for this system. The system is not safety-related and is not required for safe shutdown; therefore the staff finds this acceptable.

10.4.10(D)(f) Technical Specifications

There are no APR1400 technical specifications (TS) sections for the auxiliary steam system. The system is not safety-related and is not required for safe shutdown; therefore the staff finds this acceptable.

10.4.10(E) Combined License Information Items

The following is a list of COL Information Items:

Table 10.4.10-1 APR1400 Combined License Information Items

Item No.	Description	DCD Tier 2 Section
10.4(1)	The COL applicant is to establish operational procedures and maintenance programs <i>for the auxiliary steam system</i> as related to leak detection and contamination control <i>in accordance with Regulatory Guide 4.21. Procedures and maintenance programs are to be completed before fuel is loaded for commissioning. [Open Item 10.4-3]</i>	10.4.10.2.3
10.4(2)	The COL applicant is to maintain complete documentation of system design, construction, design modifications, field changes, and operations.	10.4.10.2.3

The review of COL Information Item 10.4(1) can be found in Subsection 10.4.10(D) under “10 CFR 20.1406” of the SER.

10.4.10(F) Conclusions

Based on the review above, the staff concludes that the SER remains incomplete pending satisfactory resolution of the **Open Items** identified in staff’s technical evaluation in this report.

The staff will update Section 10.4.10 of this SER to reflect the final disposition of the DCD application..