

Beaver Valley Power Station

Radiation Protection Technical Position/Evaluation/Calculation

Subject Liquid Monitor Alert Emergency Action Level (EAL) Set Points	No. ERS-LMR-14-001	PAGE 1 OF 10
Reference HPP _____ EPP : NEI 99-01 rev 6 T/S _____ CR _____ DCP _____		
Category <input type="checkbox"/> Technical Position <input checked="" type="checkbox"/> Technical Evaluation <input type="checkbox"/> Calculation		Unit 1 Unit 2 <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>

Purpose

NEI 99-01 Revision 6 changed the methodology for calculating Alert set points for Liquid Radiation Monitors. The previous Alert set points were to be 200 x ODCM set points. However, they are now to be calculated for 10 mrem TEDE or 50 mrem thyroid CDE.

Note: This Technical Evaluation is not an implementing document. Any application of the information contained herein must be reviewed and approved using the established review/approval process for that application.

ORIGINAL ISSUE

REVISION # 1

Made correction to page 3: annual drinking water ingestion volume of 730 liters per year, not per day.

by <i>Zanamay</i> 4-20-15	checker/reviewer <i>Jahfolla</i> 4-20-15	independent review (calculation only)
Checklist		Attachments
<input checked="" type="checkbox"/> Purpose <input checked="" type="checkbox"/> Methodology <input checked="" type="checkbox"/> Input Data	<input checked="" type="checkbox"/> Results <input checked="" type="checkbox"/> References	<input checked="" type="checkbox"/> Data Sheets <input type="checkbox"/> Illustrations <input type="checkbox"/> Printouts <input type="checkbox"/> Code Listings
<input checked="" type="checkbox"/> Transmittal to BVRC <input checked="" type="checkbox"/> Original RP ERF FILE <input type="checkbox"/> MGR, Radiation Protection	<input type="checkbox"/> Supt, Rad Ops <input type="checkbox"/> Supv, RP Services <input type="checkbox"/> Supv, Rad Waste/Effluents	<input checked="" type="checkbox"/> Author: Dr. Lara Renz <input checked="" type="checkbox"/> John Lebda <input checked="" type="checkbox"/> Hal Szklinski - BV-SIM <input checked="" type="checkbox"/> Rebecca Novak - BV-A

Beaver Valley Power Station		
Radiation Protection Technical Position/Evaluation/Calculation	REVISION: 1	
Subject: Liquid Monitor Alert Emergency Action Level (EAL) Set Points	No.: ERS-LMR-14-001	Page: 2

DISCUSSION:

This technical evaluation used ODCM source terms for liquid discharges, radiation monitor nuclide detection efficiencies, and nuclide dose conversion factors to calculate radiation monitor readings that correspond to offsite doses of 10 mrem TEDE and 50 mrem child thyroid. These monitor indicator values may be used for an Alert level in Emergency Plan Emergency Action Levels (EAL), EPP-I-1a and EPP-I-1b, when NEI 99-01 revision 6 is implemented (Reference 1). The calculated radiation monitor readings may be used for Emergency Action Level (EAL) determination following an accident with consequent release of radioactivity, and when the results of more rigorous assessments are not available.

METHODOLOGY

The bases for the EAL values for the four emergency classifications are:

Unusual Event (UE): ODCM limit multiplied by two (x2) for greater than 60 minutes. ODCM limits are calculated in ERS-ATL-93-021 (Reference 2).

Alert: Effluent pathway radiation monitor indication that corresponds to 10 mrem TEDE or 50 mrem child thyroid dose. The lower of the two values is used. Gaseous doses are calculated at the site boundary; liquid doses are calculated at Midland Water Intake.

There are no liquid effluent pathways associated with a Site Area or General Emergency.

INPUT DATA/ASSUMPTIONS

References

1. A_i = Particulate Activity from the release path (Ci/yr) [3, 5]
2. ALlg = Ingestion Annual Limit of Intake from 10 CFR 20 Appendix B Table 2 [4]
3. F = Dilution Water Flowrate
= 22,800 GPM (= 15,000 GPM BV-1 + 7,800 GPM BV-2) [3]
4. ODCM site specific mixing effect of the discharge structure = 3 [3]
5. ODCM river dilution factor = 200 [3]
6. f = Maximum Acceptable Discharge Flowrate (GPM)
= 35 gpm for RM-1LW-104 [3]
= 15 gpm for RM-1LW-116 [3]
= 80 gpm for 2SGC-RQ100 [3]
7. Ei = Monitor Sensitivity (cpm/uCi/cc) [6, 7]
8. DCF = Dose Conversion Factors for child thyroid from RG 1.109 [9]

Release source terms (A_i) used to determine the monitor EAL values are listed in the spreadsheets in Attachments 1 through 3.

NEI 99-01 revision 6 discusses assumptions and requirements for this set point calculation. Site-specific dose receptor points are expected to be used in the calculation with a one hour exposure duration. The ODCM liquid effluent receptor point is a down river potable drinking water intake structure with in 1/4 mile of

Beaver Valley Power Station

Radiation Protection Technical Position/Evaluation/Calculation	REVISION: 1
Subject: Liquid Monitor Alert Emergency Action Level (EAL) Set Points	No.: ERS-LMR-14-001 Page: 3

the release point. With the assumption that the release concentration is fully mixed by the Ohio River, the nearest drinking water supply is at the Midland Water Intake (at 1.3 miles down river from the release point). ICRP 23 (Reference 8) gives an annual drinking water ingestion volume of 1950 ml per day (for adults). USNRC Regulatory Guide 1.109 Table E-5 (Reference 9) gives an annual drinking water ingestion volume of 730 liters per year (for adults), which equates to approximately 2000 ml per day. In order to equate this to drinking water per hour, it is assumed that all 2000 ml are consumed during the one hour release. For child thyroid doses, the ICRP 23 value of 1400 ml is utilized in the same way.

Radiation monitor nuclide detection efficiencies for each monitor and for each nuclide are taken from ERS-SFL-92-039 [Unit 1] and ERS-SFL-86-026 [Unit 2] (Reference 6 and 7). Due to the availability of both 843-30 and 843-30R detectors at Unit 1, set points for both detectors were calculated (Reference 6). Detection Efficiencies are listed in the spreadsheets in Attachments 1 through 3.

The TEDE conversion factors were derived from 10 CFR 20 stochastic ALIg with 1 ALI = 5000 mrem CEDE, and 1 CEDE = 1 TEDE for a liquid ingestion scenario with the assumption that no external exposure occurs during this release.

NEI 99-01 revision 6 acknowledges that the use of EPA PAG guidance provides adult thyroid dose conversion factors, which are not always consistent with state required methodologies. BVPS has previously agreed with the states of PA, OH and WV that child thyroid doses will be calculated. This technical evaluation will remain consistent with past practices. The child thyroid dose conversion factors (DCF) are taken from USNRC Regulatory Guide 1.109 Table E-13 (units of mrem/pCi ingested) (Reference 9). DCFs are listed in the spreadsheets in Attachments 1 through 3.

The following is a description of the math performed by the EXCEL spreadsheets used in this Technical Evaluation.

An EXCEL spreadsheet was made utilizing the ODCM default source term for each unit and radiation monitor combination. Each spreadsheet consists of 15 columns with a row for each radionuclide. At the bottom of each spreadsheet, there is a section to total the count rate (CR) in cpm for 10 mrem TEDE and the count rate in cpm for 50 mrem child thyroid. Unit 2 is calculated for both cpm and uCi/ml. Details of all spreadsheet math is provided below:

Column 1 – List of the individual isotopes that comprise the ODCM source term. Each isotope occupies a row.

NOTE: Isotopes individually listed in the ODCM but not included in the dose calculation are Br-85 (172s half-life), Rh-106 (29.9s half-life). As short lived daughters of longer lived parents, production & intake limits are included with the parent values. Because of the short half life, the initial individual quantities are assumed to be insignificant. Ba-137m and Cs-137 isotopes are also individually listed in the ODCM. However, Ba-137m (2.55 min half life) will contribute to the count rate at the monitor, but will be decayed by the time it reaches Midland Water Intake. All Ba-137m daughter isotopes that an individual is exposed to are included in the Cs-137 dose factors. Therefore, Ba-137m is included in total count rate, but not dose calculations.

Column 2 – [A_i] - Total release quantity (Ci) for each isotope, specific to Unit 1 or Unit 2.

Column 3 - Stochastic Annual Limit of Intake (ALIg) for ingestion taken from 10 CFR 20 Appendix B Table 2.

Beaver Valley Power Station

Radiation Protection Technical Position/Evaluation/Calculation	REVISION: 1
Subject: Liquid Monitor Alert Emergency Action Level (EAL) Set Points	No.: ERS-LMR-14-001

Column 4 – TEDE mrem amount associated with each individual radionuclide, based upon 10 CFR 20 definition 1 ALI = 5000 mrem TEDE.

$$\text{Col 4} = [(\text{Col 2 uCi} * 1\text{E}6 \text{ uCi/Ci}) / \text{Col 3 uCi}] * 5000 \text{ mrem / ALI}$$

Column 5 – Intake amount scaled to 10 mrem TEDE:

$$\text{Col 5} = [(\text{Col 2 uCi} * 1\text{E}6 \text{ uCi/Ci}) / \Sigma \text{col 4 mrem}] * 10 \text{ mrem}$$

Column 6 – Concentration of individual radionuclide at Midland Water Intake equal to 10 mrem TEDE for a one hour adult intake. (Assumes water ingestion occurs over a 1 hour period.)

$$\text{Col 6} = [\text{Col 5 uCi} / (2000 \text{ ml/hr})]$$

Column 7 and 10 – Concentration of individual radionuclide at associated BVPS radiation monitor equal to 10 mrem TEDE for a one hour adult intake. The concentrations at the radiation monitor(s) were calculated using:

$$C_i = \frac{F * 3 * 200}{f} * C_t$$

$$\text{Col 7} = [(22800 * 3 * 200) \text{ gpm} / f \text{ gpm}] * \text{Col 6 uCi/ ml}]$$

where: C_i = Liquid effluent concentration prior to dilution

C_t = Liquid effluent concentration after dilution

F = Dilution water flow rate (gpm)

= 22,800 gpm (15,000 gpm U1 CTBD+ 7,800 gpm U2 CTBD)

3 = ODCM site specific mixing effect of the discharge structure

200 = ODCM river dilution factor

f = Maximum acceptable discharge flow rate prior to dilution (gpm)

= 35 gpm for RM-1LW-104

= 15 gpm for RM-1LW-116

= 80 gpm for 2SGC-RQ100

Column 8 & 11 – [E_i] - List of the monitor specific isotope detection efficiencies. A set of calculations is done for the 843-30 and the 843-30R detectors available for Unit 1 monitors (isotope efficiencies in units of cpm/uCi/ml).

Beaver Valley Power Station

Radiation Protection Technical Position/Evaluation/Calculation	REVISION: 1
Subject: Liquid Monitor Alert Emergency Action Level (EAL) Set Points	No.: ERS-LMR-14-001 Page: 5

Column 9 & 12 – The monitor count rate (CR) was calculated using:

[Reference 2]

$$CR = \sum_i C_i * E_i$$

where: CR = monitor count rate attributed from each radionuclide in ncpm

C_i = previously described

E_i = detection efficiency for the appropriate monitor (cpm/uCi/cc)[References 6 and 7]

FOR UNIT 2 ONLY:

The Unit 2 monitor display value (DV) was calculated using:

$$DV = CF11 \sum_i C_i E_i$$

where:

CF11 = 5.61E-9 uCi/ml/cpm; calculated in ERS-ATL-93-021:

[Reference 2]

E_i = Previously described

C_i = Previously described

Application of Monitor Background: Because the liquid monitors do not have a background subtract feature, the indicated values are net values. Therefore, monitor background needs to be accounted for when changing the set points on a monitor.

Column 13 – Dose Conversion Factors (DCF) for child thyroid taken from Regulatory Guide 1.109 (Reference 9) in mrem/pCi ingested.

Column 14 – Converted RG 1.109 DCFs into mrem/uCi.

$$\text{Col 14} = [\text{Col 13 mrem / pCi} * 1E6 \text{ pCi / uCi}]$$

Column 15 – Child Thyroid dose per hour from ingestion concentrations equal to 10 mrem TEDE.
(Assumes water ingestion occurs over a 1 hour period.)

$$\text{Col 15} = [\text{Col 14 mrem / uCi} * \text{Col 6 uCi / ml} * 1400 \text{ ml / hr}]$$

Beaver Valley Power Station

Radiation Protection Technical Position/Evaluation/Calculation

REVISION: 1

Subject:

**Liquid Monitor Alert Emergency Action Level
(EAL) Set Points**

No.:

ERS-LMR-14-001

Page:

6

Conversion of Child Thyroid Dose to a Count Rate equal to 50 mrem Committed Dose Equivalent (CDE):

$$CR \text{ for } 50 \text{ mrem CDE (CThy)} = \frac{CR \text{ for } 10 \text{ mrem TEDE}}{\sum_i CDE_i / 50 \text{ mrem}}$$

RESULTS

An EXCEL spreadsheet was generated to perform the alarm set point calculations. See Attachments 1 through 3.

Alarm Set Point Calculation Summary - Unit 1 [all units in cpm]				
	10 mrem TEDE	50 mrem Child Thyroid	Minimum Set Point	Monitor Range
RM-1LW-104 843-30	1.81E+09	5.89E+08	5.89E+08	10 to 1E6
RM-1LW-104 843-30R	2.09E+09	6.80E+08	6.80E+08	10 to 1E6
RM-1LW-116 843-30	4.22E+09	1.38E+09	1.38E+09	10 to 1E6
RM-1LW-116 843-30R	4.87E+09	1.59E+09	1.59E+09	10 to 1E6

Alarm Set Point Calculation Summary - Unit 2 [all units in uCi/ml]				
	TEDE	Child Thyroid	Minimum Set Point	Display Range
2SCG-RQ100	5.89E+00	2.42E+00	2.42E+00	5.6E-8 to 5.6E-2

Readability/Range Discussion:

As displayed in the tables above, all calculated set points are significantly greater (>4000%) than the range of the associated instrument. Generally when an over range EAL value occurs, it has been acceptable to choose a value of approximately 80% of the high range of the monitor. For example, 80% of 1E6 = 8E5 cpm. However, if this value would be employed as an EAL indication, an ALERT level would be declared significantly sooner than required for 10 mrem TEDE and/or 50 mrem child thyroid dose. More specifically, even at the 95% range values, ALERT EAL indication would be declared at doses less than 0.1 mrem TEDE and less than 1 mrem child thyroid for all available radiation detectors at both units. These values are far below the required EAL thresholds of 10 mrem TEDE and 50 mrem thyroid, which, if employed, would cycle plant and industry resources unnecessarily.

Beaver Valley Power Station		
Radiation Protection Technical Position/Evaluation/Calculation	REVISION: 1	
Subject: Liquid Monitor Alert Emergency Action Level (EAL) Set Points	No.: ERS-LMR-14-001	Page: 7
Conclusions/Recommendations:		
<p>NEI 99-01 recognizes that this Initiating Condition may result in a value beyond the display range of the monitor. Therefore, guidance states that if the calculated set point is greater than approximately 110% of the highest accurate monitor reading, then developers may choose not to include this monitor value as an EAL indication and are instructed to identify an alternate EAL threshold. The only viable alternate methodology is a liquid isotopic sample analysis. Sampling methodology is covered under its own distinct EAL according to NEI 99-01 revision 6. Therefore, it is recommended that BVPS EALs do not contain a liquid effluent monitor threshold value that equates to 1% of the PAG for an ALERT classification.</p>		
REFERENCES		
<ol style="list-style-type: none"> 1. NEI 99-01, <u>Development of Emergency Action Levels for Non-Passive Reactors</u>, Revision 6, 2012. 2. FENOC, <u>Process Alarm Set Points for Liquid Effluent Monitors</u>, ERS-ATL-93-021, Revision 4, 2012. 3. FENOC, <u>Offsite Dose Calculation Manual Procedure 1/2-ODC-2.01, ODCM: Liquid Effluents</u>, Revision 14, 2014. 4. 10 CFR 20 Appendix B Table 2. 5. SWEC, UR(B)-160, <u>BVPS Liquid Radwaste Releases and Concentrations - Expected and Design Cases: Per Unit and Site</u>, Revision 3; 1983 6. FENOC, <u>Isotopic Efficiencies For Unit 1 Liquid Process Monitors</u>, ERS-SFL-92-039, Revision 3; 2010. 7. FENOC, <u>Unit 2 DRMS Isotopic Efficiencies</u>, ERS-SFL-86-026, Revision 6; 1991 8. ICRP 23, <u>Report of the Task Group on Reference Man</u>, 1974. 9. Regulatory Guide 1.109, <u>Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I</u>, Revision 1, 1977. 		
ATTACHMENTS		
<ol style="list-style-type: none"> 1. (see page 8) Unit 1 Liquid Monitors Alert EAL Set Points for 843-30 Detectors 2. (see page 9) Unit 1 Liquid Monitors Alert EAL Set Points for 843-30R Detectors 3. (see page 10) Unit 2 Liquid Monitors Alert EAL Set Points 		

Beaver Valley Power Station

Radiation Protection Technical Position/Evaluation/Calculation

REVISION:

1

Subject:

Liquid Monitor Alert Emergency Action Level
(EAL) Set Points

No.:

ERS-LMR-14-001

Page:

8

Attachment 1 - Unit 1 Liquid Monitors Alert EAL Set Points for 843-30 Detectors

Unit 1 Liquid Monitors Alert EAL Set Points

843-30 Detectors

	RG 1.109 Annual (mJ)	RG 1.109 Daily (mJ) =	Annual mJ OOC site specific mixing effect
	(mJ)	/385.25 days	the discharge structure =
Adult water intake =	7.30E+05	1950	2.00E+03
Child water intake =	5.10E+05	1400	1.40E+03
ODCM: River dilution factor =			200
UL/U2 Combined CTBD (ppm) =			22600
Discharge rate (ppm) =			35
Discharge rate (ppm) =			15

A _i	G _i			G _j			G _k			DETECTION			10 mrem TEDE			DETECTION			10 mrem TEDE				
	ANNUAL RELEASE	10 CFR 20	Intake for 10	Mid and intake conc	= (2280*1*200)/15*	TEDE	for hour intake	IW-104 undiluted	EFFICIENCY	IW-104	IW-116 undiluted conc	EFFICIENCY	IW-116	cpm	RG 1.109 Child thyroid DCF								
NUCLIDES	ICSI	uCi	mrem	uCi	mCi/mL	uCi/mL	(cpm/uCi/mL)	cpm	uCi/mL	(cpm/uCi/mL)	cpm	uCi/mL	cpm	cpm	cpm	cpm	cpm	cpm	cpm	cpm	cpm		
Cs-51	1.30E-03	4.E+01	1.63E+02	2.64E+04	1.32E+07	5.16E+02	1.16E+07	6.05E+05	1.40E+01	1.38E+07	1.42E+05	2.57E+02	2.59E+07	2.47E+05									
Mn-51	3.10E-04	2.E+03	7.75E+02	6.29E+05	1.15E+08	1.23E+02	8.59E+07	1.05E+05	1.48E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00		
Fe-55	1.60E-03	3.E+03	8.89E+02	3.25E+04	1.82E+07	6.35E+02	0.00E+00	0.00E+00	1.48E+01	3.02E+05	9.17E+07	2.69E+02	9.17E+07	7.03E+05									
Fe-59	8.33E-04	8.E+02	5.19E+03	1.68E+04	8.43E+08	3.29E+02	9.17E+07	3.02E+05	1.48E+01	1.35E+01	1.64E+07	1.30E+00	1.35E+01	1.50E+08									
Co-58	1.40E-02	1.E+03	7.00E+04	2.84E+03	1.02E+06	5.56E+01	1.16E+08	6.45E+07	1.30E+01	1.35E+01	1.73E+08	1.35E+01	1.35E+01	3.10E+07									
Co-60	2.00E-03	5.E+02	2.00E+04	4.06E+04	2.08E+07	7.94E+02	1.73E+08	1.37E+07	1.35E+01	1.73E+08	2.49E+00	4.67E+07	1.15E+08										
Zn-65	2.69E-02	4.E+02	3.38E+05	5.46E+03	2.78E+06	1.07E+00	4.67E+07	4.98E+07	1.35E+01	4.67E+07	1.07E+00	1.35E+01	4.67E+07	1.15E+08									
Br-229	1.60E-01	2.E+03	3.57E+02	2.84E+05	1.42E+08	5.56E+03	0.00E+00	0.00E+00	1.35E+01	1.35E+01	1.35E+08	2.32E+03	1.35E+01	1.35E+08									
Br-83	2.50E-05	7.E+04	1.79E+03	5.07E+06	2.54E+09	9.92E+04	1.35E+06	1.35E+02	1.35E+01	1.35E+06	8.71E+04	1.35E+06	8.71E+04	3.15E+03									
Br-84	7.50E-05	1.E+04	4.17E+03	5.07E+06	2.54E+09	9.92E+04	9.75E+07	9.68E+04	1.35E+06	9.75E+07	9.75E+04	2.28E+05	9.75E+07	7.03E+05									
Br-85	2.70E-06	1.E+04	6.00E+03	5.48E+07	2.74E+10	1.07E+04	6.10E+05	6.58E+02	2.50E+05	6.10E+04	6.10E+05	6.10E+04	6.10E+05	6.10E+04	1.55E+03								
Rb-86	7.50E-05	5.E+02	7.50E+02	1.57E+05	7.62E+09	2.59E+03	0.00E+00	0.00E+00	6.95E+03	0.00E+00	6.95E+03	0.00E+00	6.95E+03	0.00E+00	6.95E+03								
Sr-89	2.50E-04	5.E+02	2.90E+03	5.19E+05	2.95E+08	1.15E+02	0.00E+00	0.00E+00	6.95E+02	0.00E+00	6.95E+02	0.00E+00	6.95E+02	0.00E+00	6.95E+02								
Sr-90	1.10E-05	4.E+01	1.38E+03	2.23E+06	1.17E+09	4.37E+04	0.00E+00	0.00E+00	1.02E+03	0.00E+00	1.02E+03	0.00E+00	1.02E+03	0.00E+00	1.02E+03								
Y-90	9.40E-06	5.E+02	9.40E+01	1.31E+06	9.55E+07	3.73E+04	0.00E+00	0.00E+00	8.71E+04	0.00E+00	8.71E+04	0.00E+00	8.71E+04	0.00E+00	8.71E+04								
Y-91m	8.70E-06	1.E+05	4.35E+01	1.77E+06	8.89E+07	3.45E+04	8.98E+07	3.10E+04	8.06E+01	8.98E+07	8.39E+07	7.24E+04	8.39E+07	7.24E+04	8.39E+07								
Y-91	5.70E-05	6.E+01	4.75E+02	1.68E+06	7.27E+09	7.59E+06	2.00E+05	5.88E+02	5.28E+03	2.00E+05	5.28E+03	2.50E+05	5.28E+03	2.50E+05	1.37E+03								
Y-93	7.30E-07	1.E+03	3.76E+06	1.50E+07	7.57E+11	2.94E+05	0.00E+00	0.00E+00	6.85E+05	0.00E+00	6.85E+05	0.00E+00	6.85E+05	0.00E+00	6.85E+05								
Zr-95	5.10E-05	1.E+02	2.55E+02	1.04E+05	5.18E+08	2.02E+03	1.62E+07	1.74E+05	4.72E+03	1.62E+07	4.72E+03	8.60E+05	4.72E+03	8.60E+05	4.06E+05								
Nd-35	5.20E-04	2.E+03	1.30E+02	1.06E+05	5.28E+08	2.06E+03	1.64E+07	1.78E+05	4.82E+03	1.64E+07	4.82E+03	8.64E+05	4.82E+03	8.64E+05	4.16E+05								
Pr-91	1.30E-05	2.E+03	3.25E+01	2.64E+06	1.31E+09	5.16E+04	6.97E+07	1.00E+04	6.97E+04	6.97E+07	1.00E+04	6.97E+07	1.00E+04	6.97E+07	1.00E+04								
Mo-99	1.10E-02	1.E+03	5.50E+01	2.23E+03	1.12E+06	4.37E+01	2.84E+07	1.24E+07	1.02E+00	2.84E+07	1.02E+00	2.84E+07	1.02E+00	2.84E+07	1.02E+00								
Tc-99m	1.10E-02	8.E+01	6.64E+02	2.23E+03	1.12E+06	4.37E+01	8.59E+07	3.91E+07	1.02E+00	8.59E+07	3.91E+07	1.02E+00	8.59E+07	3.91E+07	1.02E+00								
Ru-103	3.00E-05	2.E+03	6.50E+01	6.90E+06	1.35E+09	1.53E+03	9.50E+07	1.20E+05	1.17E+03	9.50E+07	1.17E+03	1.17E+03	1.17E+03	1.17E+03	1.17E+03								
Ru-105	1.00E-05	2.E+02	2.50E+02	2.03E+06	1.02E+09	3.97E+04	1.17E+08	2.93E+05	1.02E+00	1.17E+08	1.02E+00	9.26E+04	1.02E+00	9.26E+04	1.02E+00								
Ru-103m	4.40E-05	4.E+01	8.95E+01	6.80E+06	1.45E+09	3.08E+03	1.02E+08	1.78E+05	4.37E+03	1.02E+08	4.37E+03	3.10E+03	1.02E+08	3.10E+03	1.02E+08								
Tc-125m	2.50E-05	1.E+02	1.75E+02	5.07E+06	5.25E+09	5.92E+04	1.83E+05	1.82E+02	2.35E+03	1.83E+05	1.82E+02	3.20E+02	1.83E+05	1.82E+02	3.20E+02								
Tc-127m	2.60E-04	6.E+02	2.17E+03	5.28E+05	2.64E+08	1.03E+02	4.02E+04	4.22E+02	7.41E+02	4.02E+04	7.41E+02	4.02E+04	7.41E+02	4.02E+04	7.41E+02								
Tc-127	2.70E-04	7.E+03	1.93E+03	5.48E+05	2.74E+08	1.07E+02	3.88E+04	4.38E+02	7.30E+02	3.88E+04	4.38E+02	7.30E+02	3.88E+04	4.38E+02	7.30E+02								
Tc-128m	1.10E-03	5.E+02	1.23E+04	1.12E+06	1.23E+09	4.02E+03	4.02E+04	4.02E+03	1.02E+00	4.02E+04	4.02E+03	1.02E+00	4.02E+04	4.02E+03	1.02E+00								
Tc-129	6.70E-04	3.E+02	1.12E+03	4.36E+05	1.12E+08	3.18E+03	1.17E+04	1.17E+03	1.17E+00	1.17E+04	1.17E+03	1.17E+00	1.17E+04	1.17E+03	1.17E+00								
I-131	1.00E-01	1.E+03	3.25E+06	9.34E+03	4.67E+06	1.83E+03	1.99E+08	4.26E+00	1.99E+08	4.26E+00	1.99E+08	4.26E+00	1.99E+08	4.26E+00	1.99E+08								
I-131	1.00E-01	9.E+01	8.89E+05	3.25E+02	1.62E+05	6.19E+03	1.11E+08	1.11E+03	1.11E+08	1.11E+03	1.11E+08	1.11E+03	1.11E+08	1.11E+03	1.11E+08								
I-132	4.30E-03	7.E+02	3.07E+04	8.73E+04	4.37E+07	1.71E+01	1.17E+08	2.00E+07	1.17E+01	1.17E+08	2.00E+07	1.17E+01	1.17E+08	2.00E+07	1.17E+01								
I-133	4.00E-02	5.E+02	4.00E+02	8.12E+03	4.06E+06	1.59E+02	9.90E+07	1.57E+03	3.70E+02	9.90E+07	1.57E+03	3.70E+02	9.90E+07	1.57E+03	3.70E+02								
I-134	8.00E-05	3.E+01	1.33E+01	1.62E+05	8.17E+05	3.18E+03	2.70E+08	3.57E+05	7.41E+03	2.70E+08	3.57E+05	7.41E+03	2.70E+08	3.57E+05	7.41E+03								
I-135	4.00E-02	3.E+03	7.17E+03	4.37E+04	1.71E+01	1.19E+08	2.03E+07	1.03E+01	1.19E+08	2.03E+07	1.03E+01	1.19E+08	2.03E+07	1.03E+01	1.19E+08								
I-136	4.90E-03	4.E+02	1.11E+05	1.81E+03	9.04E-07	3.53E+01	8.08E+07	2.08E+03	8.08E+07	8.24E+01	8.08E+07	8.24E+01	8.08E+07										

Beaver Valley Power Station

Radiation Protection Technical Position/Evaluation/Calculation

REVISION:

1

Subject:

Liquid Monitor Alert Emergency Action Level
(EAL) Set Points

No.:

ERS-LMR-14-001

Page:

9

Attachment 2 - Unit 1 Liquid Monitors Alert EAL Set Points for 843-30R Detectors

Unit 1 Liquid Monitors Alert EAL Set Points

843-30R Detectors

	RG 1.109 Intake (ml)	RG 1.109 Daily (ml)	Annual ml OCRM site specific mixing effect of the discharge structure =	3
	/365.25 days			
Adult water intake =	7.30E+05	nd	1950	2.00E+03
Child water intake =	5.10E+05	nd	1400	1.40E+03
ODCM river dilution factor =			200	
UI/U2 Combined CTED (gpm) =			22600	
Discharge Rate (gpm) =			35	
Discharge Rate (gpm) =			15	

A	ANNUAL RELEASE	10 CFR 20 stochastic Alig	TEDE	Intake for 10 years TEDE	Midland intake conc	=(22800'3'200)/35*	DETECTION	10 nrem TEDE	=(22800'3'200)/15*	DETECTION	10 nrem TEDE	RG 1.109 Child thyroid	RG 1.109 Child	
												DCF	Hydroy DCF	Cthy CDE
NUCLIDE	(g)	uCi	mrem	uCi	uCi/ml	uCi/ml	EFFICIENCY	LW-104	LW-116 undiluted conc	EFFICIENCY	LW-116	DCF	Hydroy DCF	Cthy CDE
Cr-51	1.30E-03	4.E+01	1.69E+02	2.84E-04	1.32E-07	5.18E-02	1.24E+07	6.40E+05	1.20E+01	1.24E+07	1.24E+05	4.94E-09	4.94E-03	9.11E-07
Mn-54	3.10E-04	2.E+01	7.75E+02	6.29E-05	3.15E-08	1.23E-02	1.05E+08	1.29E+05	2.10E+02	1.05E+08	3.01E+05			
Fe-55	1.60E-03	5.E+01	8.89E+02	3.25E-04	1.62E-07	6.35E-02	1.00E+00	9.00E+00	1.48E+00	1.00E+00	8.00E+00			
Fe-59	6.30E-04	8.E+02	5.19E+03	2.68E-04	8.49E-08	3.29E-02	1.04E+08	3.43E+05	7.69E+02	1.04E+08	8.06E+05			
Co-58	1.40E-02	1.E+03	7.00E+04	2.84E-02	1.42E-06	5.66E-01	1.06E+08	5.89E+07	1.30E+00	1.06E+08	3.37E+03			
Co-60	2.00E-03	5.E+02	2.00E+04	4.06E-04	2.08E-07	7.94E-02	1.94E+08	1.54E+07	1.85E+01	1.94E+08	3.59E+07			
Zn-65	2.69E-02	4.E+02	3.36E+05	5.49E-03	2.73E-06	1.07E+03	5.02E+07	5.38E+07	2.49E+00	5.02E+07	1.25E+08			
Np-239	1.00E-04	2.E+03	3.50E+02	2.84E-05	1.42E-08	5.54E-03	0.02E+00	0.02E+00	1.30E+02	0.02E+00	0.00E+00			
B-83	2.50E-05	7.E+01	1.79E+00	5.07E-06	2.54E-09	9.92E-04	1.48E+06	1.47E+03	2.12E+03	1.48E+06	3.45E+03			
B-84	2.50E-05	1.E+01	4.17E+00	5.07E-06	2.54E-09	9.92E-01	3.16E+03	3.14E+05	2.32E+03	3.16E+03	7.32E+05			
B-85	2.70E-06		0.00E+00	5.48E-07	2.74E-10	1.07E-04	6.71E+06	7.19E+02	2.50E+01	6.71E+06	1.66E+03			
Rb-86	7.50E-05	5.E+02	7.55E-02	1.52E-05	7.62E-09	2.98E-03	0.00E+00	0.00E+00	6.55E-03	0.00E+00	0.00E+00			
Sr-89	2.90E-04	5.E+02	2.90E+03	5.88E-05	2.95E-08	1.15E-02	8.84E+03	1.13E+02	2.69E-02	8.84E+03	2.64E+02			
Sr-90	1.10E-05	4.E+01	1.38E+03	2.23E-06	1.12E-09	4.73E-01	0.00E+00	0.00E+00	1.02E-03	0.00E+00	0.00E+00			
V-90	9.40E-06	5.E+02	9.40E+01	1.51E-06	9.55E-10	3.73E-04	0.00E+00	0.00E+00	8.71E-04	0.00E+00	0.00E+00			
V-91m	8.70E-06	1.E+05	4.35E-01	1.71E-06	8.84E-10	3.45E-04	1.07E+08	3.70E+01	8.06E-04	1.07E+08	8.52E+04			
V-91	5.70E-05	6.E+02	4.75E+02	1.16E-05	5.79E-09	2.26E-03	2.53E+05	5.72E+02	5.23E-03	2.53E+05	1.34E+03			
V-93	7.40E-07	1.E+03	3.70E+01	1.50E-07	7.52E-11	2.94E-05	0.00E+00	0.00E+00	6.85E-05	0.00E+00	0.00E+00			
Zr-95	5.10E-05	1.E+03	2.55E+02	1.04E-05	5.18E-09	2.02E-03	1.06E+08	2.15E+05	4.71E-03	1.06E+08	5.01E+05			
Nb-95	5.20E-05	2.E+03	1.30E+02	1.66E-05	5.28E-09	2.06E-03	1.06E+08	2.15E+05	4.80E-03	1.06E+08	5.11E+05			
Si-91	1.30E-05	2.E+03	3.25E+01	2.54E-06	1.37E-09	5.15E-04	8.13E+07	4.20E+04	1.20E-03	8.13E+07	9.75E+04			
Mo-99	1.10E-02	1.E+03	5.50E+04	2.23E-03	1.12E-06	4.37E-01	1.41E+08	6.15E+07	1.02E+00	1.41E+08	1.44E+08			
Tc-99m	1.10E-02	8.E+01	6.88E-02	2.23E-03	1.12E-06	4.37E-01	1.11E+08	4.85E+07	1.02E+00	1.11E+08	1.13E+08			
Ru-103	3.45E-05	2.E+03	8.50E-06	6.90E-06	3.45E-09	1.31E-03	1.13E+08	1.31E+05	1.13E+03	1.13E+08	3.56E+05			
Ru-105	1.00E-05	2.E+02	2.50E-02	2.03E-06	1.02E-09	3.97E-04	0.00E+00	0.00E+00	9.26E-04	0.00E+00	0.00E+00			
Rh-103m	3.40E-05	4.E+05	3.95E-01	6.90E-06	3.45E-09	1.35E-03	0.00E+00	0.00E+00	3.15E-03	0.00E+00	0.00E+00			
Te-125m	2.50E-05	1.E+03	1.25E-02	5.07E-06	1.25E-09	9.92E-04	9.92E-05	2.37E+03	2.37E+03	2.40E+05	5.56E+02	3.20E-06	3.20E+00	1.13E-05
Te-127m	2.60E-01	6.E+02	2.17E-03	5.28E-05	2.66E-08	1.05E-02	1.62E-07	1.67E+05	2.41E-02	1.62E-07	3.90E+05	6.51E-06	6.91E-04	2.55E-04
Te-127	2.70E-01	7.E+01	1.93E-02	5.48E-05	2.74E-08	1.07E-02	1.48E-06	1.59E+04	2.50E-02	1.48E-06	3.70E+04	3.75E-07	3.36E-01	1.26E-05
Te-129m	1.10E-03	5.E+02	1.10E-01	2.23E-04	1.12E-07	4.37E-02	1.11E-05	1.11E+08	1.11E+01	1.11E-05	1.11E+08	1.13E+04	1.57E-05	1.57E-03
Te-129	6.70E-03	1.E+04	1.27E-02	3.36E-04	6.80E-09	2.66E-02	1.69E-07	4.69E+05	6.21E-02	1.69E-07	9.56E+08	9.56E-02	9.08E-06	
I-130	1.20E-04	1.E+04	6.00E-02	2.44E-05	1.22E-08	4.76E-03	2.65E+08	1.26E+06	1.15E-02	2.65E+08	2.55E+06	6.50E-04	6.50E-02	1.11E-04
Te-131m	1.60E-04	6.E+02	1.33E-03	3.25E-05	1.62E-08	6.38E-03	1.15E-06	7.30E+03	1.48E-02	7.30E+03	5.56E+02	3.20E-06	3.20E+00	1.13E-05
Te-131	3.00E-05	6.E+03	2.50E-01	6.05E-06	3.05E-09	1.88E-03	1.11E-03	1.32E+05	2.78E-03	1.11E+03	3.08E+05	6.75E-02	6.75E-02	2.70E-07
I-131	1.60E-01	9.E+01	8.89E-06	1.25E-02	1.62E-05	6.35E-04	1.18E+08	7.66E+08	1.48E-01	1.18E+08	5.71E-03	5.71E-01	1.30E+02	
Te-132	4.10E-03	7.E+02	3.07E-04	8.73E-04	4.37E-07	1.71E-01	1.21E-08	2.07E+07	3.95E-01	1.21E-08	4.02E+07	6.51E-06	6.51E-01	3.97E-03
I-132	4.90E-03	9.E+02	2.72E-03	9.56E-04	4.98E-07	1.95E-01	3.16E-08	5.15E+07	4.54E-01	3.16E-08	1.48E+08	6.82E-05	6.82E-02	4.74E-02
I-133	4.00E-02	5.E+02	4.00E-05	8.12E-03	4.06E-06	1.59E-04	1.15E-08	1.64E+08	3.70E+00	1.15E-08	4.30E+08	1.36E-03	1.36E-01	7.11E-04
H-134	8.00E-05	3.E+04	1.33E-01	1.62E-05	8.12E-09	3.18E-03	1.17E-08	1.01E+06	7.41E-03	1.17E-08	2.35E+06	1.75E-05	1.75E-01	2.03E-04
Cs-134	4.60E-02	7.E+01	1.29E-06	9.34E-03	4.67E-06	1.89E-04	2.42E-08	4.42E+08	4.26E-02	2.42E-08	1.03E+09	2.42E-01	2.42E-01	
I-135	4.30E-03	3.E+03	7.17E-03	8.73E-04	4.37E-07	1.71E-01	1.47E-08	2.51E+07	3.98E-01	1.47E-08	5.83E+07	2.79E-04	2.79E-02	1.70E-01
Cs-136	8.90E-03	4.E+02	1.11E-05	1.81E-03	9.04E-07	3.53E-01	3.19E-08	1.12E+08	8.24E-01	3.19E-08	2.63E+08			
Cs-137	3.30E-03	1.E+02	1.65E-06	1.33E-03	3.35E-09	1.31E-03	9.30E-07	1.22E+08	3.05E-00	9.30E-07	2.84E+08			
Ba-137m	1.10E-02	1.E+02	6.29E-03	1.35E-06	1.22E-09	1.22E-02	9.85E-07	1.21E+08	2.87E+00	9.85E-07	2.83E+08			
Ba-140	1.10E-04	6.E+02	9.17E-02	2.23E-05	1.12E-08	4.37E-03	4.78E-07	2.09E+05	1.02E-02	4.78E-07	4.87E+05			
Ia-140	1.10E-06	6.E+02	9.17E-02	2.23E-05	1.12E-08	4.37E-03	2.22E+03	9.96E+05	1.02E-02	2.22E+03	2.26E+06			
Cs-141	5.10E-05	2.E+03	1.38E-02	1.04E-05	5.18E-09	2.02E-03	6.20E-07	1.26E+05	4.72E-03	6.20E-07	2.93E+05			
Cs-143	2.80E-05	1.E+03	1.49E-01	5.69E-07	2.84E-10	1.11E-04	7.67E-07	8.74E+08	2.59E-01	7.67E-07	2.04E+04			
Co-143	3.20E-05	3.E+02	5.39E-02	6.50E-06	3.25E-09	1.27E-03	1.36E-07	1.73E+04	2.95E-03	1.36E-07	4.05E+04			
Pr-143	2.70E-05	1.E+03	1.35E-02	5.84E-06	2.74E-09	1.07E-03	0.00E+00	0.00E+00	2.50E-03	0.00E+00	0.00E+00			
Pr-144	3.20E-05	4.E+01	4.00E-00	6.50E-06	3.25E-09	1.27E-03	2.32E-06	2.95E+03	2.95E-03	2.32E-06	6.68E+03			
H-3	5.50E-02	8.E+01	4.34E-07	1.25E-02	5.59E-02	2.18E-04	0.00E+00	5.05E-04	0.00E+00	5.05E-04	0.00E+00	2.09E-07	2.03E-01	1.58E-01
Total =	5.50E-02		4.98E-07											

Beaver Valley Power Station

Radiation Protection Technical Position/Evaluation/Calculation

REVISION: 1

Subject:

No.: ERS-LMR-14-001

Liquid Monitor Alert Emergency Action Level (EAL) Set Points

Page: 10

Attachment 3 - Unit 2 Liquid Monitors Alert EAL Set Points

Unit 2 Liquid Monitor Alert EAL Set Points									
NUCLIDE	[Ci]	ANNUAL RELEASE	10 CFR 20 stochastic ALR	TEDE	ICRP 23 total daily intake for ID		RG 1.109 Annual (ml)	(ml)	/365-25 days
					Midland intake (c <i>r</i>)	for hour intake			
					c <i>r</i> /ml	c <i>r</i> /ml			
Cr-51	1.00E-04	4.1E+04	1.25E-05	2.2E-05	1.12E-08	1.92E-03	2.01E-07	3.86E+04	
Mn-54	2.50E-05	2.1E+03	6.25E-05	5.61E-06	2.81E-08	4.80E-04	1.27E-08	6.10E+04	
Fe-55	1.30E-04	9.1E+03	7.22E-05	2.92E-05	1.46E-08	2.50E-03	0.00E+00	0.00E+00	
Fe-59	6.50E-05	8.1E+02	4.06E-04	1.48E-05	7.30E-09	1.25E-03	1.25E-08	1.57E+05	
Co-58	1.10E-03	1.1E+03	5.50E-03	2.47E-04	1.24E-07	2.11E-02	1.82E+08	3.84E+05	
Co-60	1.40E-04	5.1E+02	1.60E-03	3.59E-05	1.80E-08	3.07E-03	2.31E+08	7.31E+05	
Zn-65	5.10E-02	4.1E+02	6.38E-01	1.14E-02	5.73E-06	9.75E-01	6.50E+07	6.37E+07	
Np-239	3.20E-05	7.1E+03	8.10E-05	7.18E-06	3.96E-09	6.14E-01	1.65E+08	1.01E+05	
Br-83	2.90E-05	7.1E+01	2.07E-06	6.51E-06	1.26E-09	5.57E-04	2.42E+06	1.35E+03	
Bi-141	5.90E-09	3.1E+04	9.83E-10	1.32E-09	6.63E-13	1.13E-07	1.38E+00	1.56E+01	
Rb-86	3.70E-05	5.1E+02	3.70E-04	8.30E-05	4.16E-09	7.11E-04	1.04E+07	7.39E+03	
Sr-89	2.20E-05	5.1E+02	2.20E-04	4.34E-06	2.47E-09	4.21E-04	1.83E+04	7.73E+00	
Sr-90	8.50E-07	4.1E+01	1.06E-04	1.91E-07	9.55E-11	1.63E-05	0.00E+00	0.00E+00	
V-90	6.00E-07	5.1E+02	6.00E-06	1.35E-07	6.74E-11	1.15E-05	0.00E+00	0.00E+00	
V-91m	3.60E-06	1.1E+05	1.80E-07	8.18E-07	4.04E-10	6.91E-05	1.59E+03	1.10E+04	
V-91	4.40E-06	6.6E+02	3.67E-05	9.88E-07	4.94E-10	8.45E-05	3.55E+05	3.00E+01	
V-93	3.00E-07	1.6E+03	1.50E-06	5.71E-06	3.37E-11	5.76E-06	2.03E+07	1.17E+02	
Zr-95	4.00E-06	1.5E+03	2.00E-05	3.98E-07	4.45E-10	7.58E-05	1.35E+08	1.04E+04	
Nb-95	4.00E-06	2.1E+03	2.00E-05	8.98E-07	4.95E-10	7.58E-05	1.33E+08	1.02E+04	
Sr-91	5.30E-06	2.1E+03	1.31E-05	1.19E-06	5.95E-10	1.02E-04	1.04E+08	1.03E+04	
Mo-99	2.20E-03	1.1E+03	1.15E-02	5.16E-04	2.58E-07	4.42E-02	4.47E+07	1.97E+06	
Tc-99m	2.10E-03	8.5E+02	1.13E-04	4.71E-04	2.36E-07	4.03E-02	1.42E+08	5.85E+06	
Ru-102	2.70E-05	2.1E+03	6.75E-06	6.06E-07	3.03E-10	5.18E-05	1.71E+08	8.87E+05	
Ru-106	8.20E-07	2.1E+02	0.00E+00	1.84E-07	9.11E-11	1.57E-05	0.00E+00	0.00E+00	
Rh-103m	2.70E-06	4.1E+05	3.38E-08	6.05E-07	3.03E-10	5.18E-05	0.00E+00	0.00E+00	
Rh-103e	8.20E-07	8.1E+05	5.15E-07	1.84E-07	9.21E-11	1.57E-05	5.65E+07	8.90E+02	
Te-125m	1.90E-05	1.1E+03	9.50E-06	4.28E-07	2.13E-10	3.61E-05	3.94E+05	1.44E+01	
Te-127m	2.12E-05	6.1E+02	1.75E-06	4.71E-06	2.38E-09	4.08E-04	1.26E+05	5.93E+01	
Te-127	2.50E-05	7.1E+03	1.75E-05	5.61E-06	2.81E-09	4.80E-04	2.43E+05	1.17E+03	
Te-129m	5.10E-05	5.1E+02	8.20E-06	4.95E-05	9.21E-09	1.57E-03	6.53E+05	1.03E+04	
Te-129	5.30E-05	1.1E+01	8.88E-06	1.18E-05	5.95E-09	1.02E-03	1.86E+07	1.59E+04	
I-131	2.30E-04	1.1E+03	1.15E-03	5.11E-05	2.58E-08	4.27E-03	5.18E+08	2.39E+05	
Te-131m	5.20E-05	6.1E+02	4.19E-04	1.17E-05	5.84E-09	9.99E-04	2.85E+08	2.45E+05	
Te-131	9.40E-05	6.1E+03	7.83E-06	2.11E-06	1.06E-09	1.81E-04	1.88E+08	3.39E+04	
I-131	1.00E-01	9.5E+01	5.56E+00	2.74E-02	1.12E-05	1.92E+00	1.96E+08	1.75E+08	
Te-132	7.80E-04	7.1E+01	5.57E-03	1.75E-04	8.76E-08	1.50E-02	1.76E+08	2.64E+06	
I-132	2.30E-03	9.1E+03	1.28E-03	5.16E-04	2.58E-07	4.42E-02	4.22E+08	1.86E+07	
I-133	6.50E-02	5.1E+02	1.46E-01	7.30E-02	1.25E-06	1.75E+08	2.16E+08	6.31E+02	
I-134	4.60E-06	3.1E+01	7.67E-07	1.03E-06	5.17E-10	8.83E-05	4.03E+08	3.56E+04	
Cs-134	3.00E-02	7.1E+01	2.14E-00	6.73E-03	3.37E-06	5.76E-01	3.23E+08	1.57E+08	
I-135	4.20E-03	3.1E+03	1.53E-02	2.06E-03	1.03E-08	1.77E-01	1.71E+08	3.02E+07	
Cs-136	3.90E-03	4.1E+02	4.88E-02	8.75E-04	4.32E-07	7.49E-02	4.18E+08	3.21E+07	
Cs-137	2.20E-02	1.1E+02	4.94E-03	2.47E-06	4.21E-01	1.28E+08	5.41E+07		
Ba-137m	2.10E-02	1.1E+02	0.00E+00	4.71E-03	2.38E-06	4.01E-01	1.33E+08	5.36E+07	
Ba-140	9.30E-06	6.1E+02	7.75E-05	2.09E-06	1.04E-09	1.78E-04	7.50E+07	1.34E+04	
Ia-140	8.40E-06	6.1E+02	7.00E-05	1.85E-06	9.43E-10	1.61E-04	3.08E+08	4.97E+03	
Ca-141	4.00E-06	2.1E+01	1.00E-05	8.95E-07	4.49E-10	7.60E-05	7.75E-07	5.95E+02	
Cs-143	9.50E-07	1.1E+03	4.32E-06	1.93E-07	3.66E-11	1.65E-05	1.20E+08	1.58E+03	
Cs-144	2.70E-05	3.1E+02	4.38E-05	5.81E-07	2.92E-10	4.99E-05	1.37E+07	9.34E+02	
Pr-143	2.30E-05	1.1E+03	1.15E-05	5.14E-07	2.58E-10	4.42E-05	1.63E+00	7.20E-05	
Pr-144	2.60E-05	4.1E+04	3.25E-07	5.84E-07	2.92E-10	4.99E-05	3.40E+06	1.76E+02	
H-3	5.50E-02	8.1E+04	3.44E+01	1.23E+02	6.18E-02	1.06E-04	0.00E+00	0.00E+00	
Total					4.66E+01	1.06E+04			
							CR in cpm =	1.05E+03	
							CR in rpm =	4.32E+03	
							DV in uCi/ml =	5.89E+00	
							DV in uCi/ml =	2.42E+00	
									ccs based on 50 mrem Cth
									5.00E+01

Isotopes individually listed in the ODCM but not included in the dose calculation are Br-85 (17.2 half-life), Rb-106 (23.95 half-life). As short lived daughters of longer lived parents, production & intake limits are included with the parent values. Because of the short half life, the initial individual quantities are assumed to be insignificant.

Ba-137m and Cs-137 isotopes are also individually listed in the ODCM. However, Ba-137m (2.55 min half life) will contribute to the count rate at the monitor, but will be decayed by the time it reaches Midland Water Intake. All Ba-137m daughter isotopes that an individual is exposed to are included in the Cs-137 dose factor. Therefore, Ba-137m is included in total count rate, but not dose calculations.

Assumes daily drinking water intake occurs in 1 hour period at Midland water intake.

*Flow rates from 1/2-ODC-201

Source Term for (RM-1IW-104 and RM-1IW-110) from 1/2-ODC-201 (Stone and Webster Calculation Package UR(0)-16)

Detection Efficiency for (RM-1IW-104 and RM-1IW-110) from 1/2-ODC-201 (Calculation Package ERS-SFI-92-07)

ODCM source term CF11 conversion factor from ERS-ATL-93-021.

Assumptions -

Dose calculation is for one hour exposure. Reference Midland water intake in one hour.

Intake concentration is calculated using CT blowdown flowrate (default 1500-7800 gpm) prior to the river with ODCM rainfall and river dilution prior to intake.